

SHAW, PITTMAN, POTTS & TROWBRIDGE

1800 M STREET, N. W.
WASHINGTON, D. C. 20036

RAMSAY D. POTTS
STUART L. PITTMAN
GEORGE F. TROWBRIDGE
STEPHEN D. POTTS
GERALD CHARNOFF
PHILLIP D. BOSTWICK
R. TIMOTHY HANLON
GEORGE M. ROGERS, JR.
JOHN B. RHINELANDER
BRUCE W. CHURCHILL
LESLIE A. NICHOLSON, JR.
MARTIN D. KRALL
RICHARD J. KENDALL
JAY E. SILBERG
BARBARA M. ROSSOTTI
GEORGE V. ALLEN, JR.
WM. BRADFORD REYNOLDS
FRED A. LITTLE
FRED CRASNER
NATHANIEL P. BREED, JR.
MARY AUGENBLICK
ERNEST L. BLAKE, JR.
CARLETON S. JONES
THOMAS A. BAXTER
JAMES M. BURGER
SHELDON J. WEISEL
JOHN A. McCULLOUGH
J. PATRICK HICKEY
JAMES THOMAS LENHART

STEVEN L. MELTZER
DEAN D. AULICK
JOHN ENGEL
STEPHEN B. HUTTNER
WINTHROP N. BROWN
JAMES B. HAMLIN
ROBERT E. ZAHLER
RICHARD E. GALEN
ROBERT B. ROBBINS
LAURA K. FARRAND
MATIAS F. TRAVIESO-DIAZ
VICTORIA J. PERKINS
JOHN H. O'NEILL, JR.
JAY A. EPSTEIN
GEORGE D. CROWLEY, JR.
MICHAEL D. HAYS
THOMAS H. McCORMICK
SUSAN D. FALKSON
STEVEN M. LUCAS
RAND L. ALLEN
ALAN J. WEISBARD
WILLIAM P. BARR
ALAN R. YUSPEH
JOHN L. CARR, JR.
PHILIP J. HARVEY
KAY L. RICHMAN
TIMOTHY B. McBRIDE
CHARLES W. SURASKY*

*NOT ADMITTED IN D. C.

(202) 331-4100
TELECOPIER
(202) 296-0694 & 296-1760
TELEX
89-2653 (SHAWLAW WSH)
CABLE "SHAWLAW"
JOHN H. SHARUN
EDWARD B. CROSLAND
COUNSEL

August 7, 1979

George Frampton, Esquire
NRC/TMI Special Inquiry Group
Nuclear Regulatory Commission
Washington, D.C. 20555

Dear George:

Enclosed are the following documents in response to Item 3 of the NRC/TMI Special Inquiry Group's request of July 12, 1979:

Requested Documents
and/or Information

Identification Number
of Response

Information relating to the "hydrogen bubble" problem (Items 3.a through d, f)

G/712-3.a-f (Memorandum of J. P. Moore, Jr.)

Bubble book (Item 3.e)

G/712-3.e-1

Other documents reflecting hydrogen bubble data and analysis (Item 3.e)

G/712-3.e-2 to 65

Copy to Mr. Picklesheim Del. 9/13

Sincerely,

Mat

Matias F. Travieso-Diaz

MFTD:ry

Enclosures

~~8001200089~~

8001270013

P

Inter-Office Memorandum



Date August 7, 1979

Subject NRC/TMI Special Inquiry - Item 3 of
July 12, 1979, Request

To Mr. J. E. Guerin

Location Parsippany

This memorandum responds to Item 3 of the July 12, 1979, request by the Nuclear Regulatory Commission's TMI Special Inquiry Group. Item 3 asks for certain information concerning the "hydrogen bubble" problem from March 28, until April 2, 1979. The specific questions raised and the answers to these questions are as follows.

Item 3.a Who were the principal people within the company ... who considered and evaluated this problem?

Response: The principal people who considered and evaluated the "hydrogen bubble" problem were T. G. Broughton and I at the TMI site, as well as the GPUSC personnel stationed in the Control Room during the post-accident period. We received analytical support from John Daniel at GPUSC headquarters in Parsippany, New Jersey.

Item 3.b Who were the principal people from outside the company ... whose advice or assistance was sought?

Response: The main outside parties whose advice or assistance was sought with respect to this problem were William W. Lowe of Pickard, Lowe & Garrick, Inc. and D. A. Nitti of Babcock & Wilcox.

Item 3.c What plant data were acquired or gathered together in an effort to address the problem of the bubble, and how was it acquired?

Response: The primary coolant parameters collected between March 28, and April 2, 1979, were used to calculate the size and removal rate of the hydrogen bubble. These parameters were obtained from computer print-outs and control meter readings by GPUSC personnel stationed in the control room; the data thus collected have been gathered in what is referred to as the "bubble book".

Item 3.d What analyses were performed and what determinations were made concerning the bubble (including its size, dangerousness, etc.) and approximately when and by whom were they made?

Response: I derived the equation for calculating the bubble size at about 3:00 a.m. on March 30, 1979. The equation was immediately used to calculate the bubble size from plant data for 1:00 p.m. of March 29, 1979. Frequent bubble size computations were made thereafter through April 3, 1979, when it was concluded that the bubble had been removed. We also performed analyses to determine the hydrogen removal rate, including analysis of parameters (such as pressurizer spray flow rate and letdown flow rate to the makeup tank) which could affect the hydrogen removal rate.

In performing our analyses, our primary concern about the hydrogen bubble was that it could prevent natural circulation of the reactor coolant in the event we could not operate a reactor coolant pump, and it could impede depressurizing the reactor coolant system by depressing the water level. Therefore, our efforts were directed towards removing the bubble as soon as possible. We were not concerned about a hydrogen detonation in the reactor coolant system because we determined that there was no oxygen available to support it. We concluded that there was no oxygen to support an explosion for the following reasons:

- (1) There was an overpressure of hydrogen on the reactor coolant system prior to the incident. This ensured that any oxygen produced by radiolytic decomposition of water or added with the makeup water subsequent to the metal-coolant water reaction would be rapidly recombined with hydrogen to form water.
- (2) When the metal-water reaction took place in the core leading to the formation of large amounts of hydrogen, the associated oxygen was consumed in oxidizing the metal.


Our evaluation and analysis were confirmed by independent analysis by Babcock and Wilcox on April 1, 1979, and subsequently by others.

Item 3.e Provide any documents reflecting the data mentioned in (c) and (d), above, including the "bubble book".

Response: A copy of the "bubble book" is attached as document G/712-3.e-1. It contains the bubble size calculations and related data. Also attached are copies of correspondence concerning the removal of hydrogen and the problems associated with the hydrogen bubble. These are identified as document nos. G/712-3.e-2 to 65.

Item 3.f Provide any report that has been prepared or is acquired concerning the bubble and/or the company's evaluation of the bubble.

Response: The reactor coolant system data are being analyzed to gain a better understanding of the hydrogen removal process. A report will be issued as a result of this effort; the report will be forwarded to the NRC/TMI Special Inquiry Group upon its completion.



J. P. Moore

JPM:ry

MAY 16 1979

4-19-79

J. Moore

G/712-3.e-1

SHEET 1

DATE	TIME	CALC RUBBLE w/o TEMP COMP	CALC RUBBLE w/ TEMP COMP	Absolute Error
3-29-79	~1300	1624 FT ³	1839 FT ³	± 71%
3-30-79	0625	1055	828	± 600%
-	0730	1136	893	± 84%
-	1240	393	308	± 183%
-	1445	798	839	± 195%
-	1630	512	366	± 772%
-	1745	328	225	± 224%
-	1907	2298	1806	± 184%
3-31-79	0630	1098	850	
	1032	1093	860	
	1351	—	879	
	1619		621	
	1735		742	
	1925		901	
	2030		765	
	2139		999	
	2245		894	
	2355		717	
04-01-79	0107		848	NOT VALID DATA
	0200		818	
	0321		800	
	0403		833	
	0455		606	
	0620		710	
	0731		564	
	0825		535	

ABSOLUTE ERROR

CALC BUBBLE
 W/TAMP COMP

TIME

DATE

501

0946

04-01-79

627

1044

486

1211

343

1305

224

1456

347

1510

224

1645

635

1710

223

1758

438

1910

199

2059

215

0020

04-02-79

543

0128

211

0215

205

0315

253

0415

130

0500

203

0550

152

0650

47

0740

60

0850

208

1008

195

1225

174

1315

47.5

1600

149

1803

221.5

2025

EXTRAID - VENTING

DATE	TIME		CALC BUBBLE W/TEMP COMP
04-03-79	0453		-118
	0537		89
	0620		163
	1525		-14.0
	1604		81.5

DICK on
GARY BROUGHT

To: *MR. DH ROY*

From: *IN BISHOP*

BDS 662.5

Dist. File No. or Ref.

Subj. *COMPOSITION OF GAS BUBBLE* Date *APRIL 1, 1979*

This letter is cover one customer and one subject - 12.

After review of the postulated sequence of events on March 23, we conclude that there is no significant amount of oxygen in the bubble. At the time of reactor trip a hydrogen over pressure was present in the primary system. This hydrogen over pressure would have *remained* until boiling occurred about 3 hours after the trip. During the period of boiling some small generation of oxygen probably occurred. Shortly thereafter, a metal-water reaction began, generating large amounts of hydrogen. The metal-water reaction produced most of the gas in the bubble. After the metal-water was quenched, the hydrogen in the bubble inhibited oxygen generation. This only during the short time of boiling was oxygen generated.

If we make the conservative assumption of boiling for 15 hours we calculate a oxygen production of 1100 SCF by radiolysis. In addition, there is a small contribution from air dissolved in the BWST. This BWST contribution is 188 SCF. The total oxygen, 1288 SCF, is 27 cubic feet at RCS pressure and temperature. If this small amount of oxygen had been present on the 28th, it is likely that radiolytic recombination would have *removed* the oxygen.

MBB:jws

MBB
DL
JAL 4/1/79

TMI-2 RCS BUBBLE CALC SHEET

DATE 04/18/79

TIME 0120 AM PM

DATA TAKEN BY: ASL

34 RC PRESSURE ³⁷⁷ (~~393~~) RCS TEMP (394)
 30 P₁ = 629.1 PSIG = _____ PSIA T₁ = 281.0 °F
 27 P₂ = 693.9 PSIG = _____ PSIA T₂ = 280.8 °F
 25 ΔP = 64.8 PSI

29
 27 PRESSURIZER LEVEL (1682) PRESSURIZER TEMP ³⁵⁷ (~~455~~)
 24 L₁ = 216.1 INCHES T₁ = 504.0 °F
 27 L₂ = 213.3 INCHES T₂ = 514.9 °F
 32 ΔL = 2.8 INCHES
 26

31
 (35) MAKEUP TANK LEVEL (347) MAKEUP TANK TEMP ¹⁶¹ (CENTRAL BOARD METER)
 L₁ = 80.2 INCHES T₁ = 94.5 °F
 02 L₂ = 81.6 INCHES T₂ = 94.0 °F
 93 ΔL = -1.4 INCHES
 88
 98

05 ΔV_{PZR} = ΔL * 2.515 = 2.8 * 2.515 = 7.04 FT³
 3 ΔV_{MUT} = ΔL * 4.244 = -1.4 * 4.244 = -5.94 FT³
 0 ΔV_{TOTAL} = 1.1 FT³

94 V₁ = $\frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \left(\frac{\quad \times \quad}{\quad} \right) = \quad \text{FT}^3 @ P_1$
 94
 91

03 V_{1(875)}} = (V_{1 at P₁}) $\left(\frac{P_1}{875} \right) = \quad \text{FT}^3 @ 875 \text{ PSIA}$
 94 86
 90 74
 91 90
 92 65

TMI-2 RCS BUBBLE CALC SHEET

DATE 04 7/8/79

TIME 0120 ^{AM} _{PM}

DATA TAKEN BY: MSW

34 RC PRESSURE ³⁹⁹ (~~598~~) RCS TEMP (394)
 30 $P_1 = 629.1$ PSIG = _____ PSIA $T_1 = 291.0$ °F
 27 $P_2 = 693.9$ PSIG = _____ PSIA $T_2 = 280.8$ °F
 25 $\Delta P = 64.8$ PSI

29
 27 PRESSURIZER LEVEL (1682) PRESSURIZER TEMP (³⁵⁹~~405~~)
 24 $L_1 = 216.1$ INCHES $T_1 = 504.0$ °F
 27 $L_2 = 213.5$ INCHES $T_2 = 514.9$ °F
 32 $\Delta L = 2.8$ INCHES

31
 35 MAKEUP TANK LEVEL (347) MAKEUP TANK TEMP (¹⁶¹~~CONTROL BOARD METER~~)
 02 $L_1 = 90.2$ INCHES $T_1 = 94.5$ °F
 93 $L_2 = 91.6$ INCHES $T_2 = 94.0$ °F
 88 $\Delta L = -1.4$ INCHES

05 $\Delta V_{PZR} = \Delta L \times 2.515 = 2.8 \times 2.515 = 7.04$ FT³
 3 $\Delta V_{MUT} = \Delta L \times 4.244 = -1.4 \times 4.244 = -5.94$ FT³
 0 $\Delta V_{TOTAL} = 1.1$ FT³

96
 94 $V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(694 \times 1.1)}{(64.8)} = 11.78$ FT³ @ P_1
 94

91
 03 $V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = 8.5$ FT³ @ 875 PSIA.
 94 86
 90 94
 91 90
 85

RCS Bubble Calc.
0610

4/8/74
PSW

63	RCS	P_1	<u>556.5</u>	T_1	<u>240.2</u>
65		P_2	<u>605.5</u>	T_2	<u>240.0</u>
58		ΔP	<u>49.0</u>	ΔT	<u>-0.2</u>
54					
52	PER	L_1	<u>229.5</u>	T_1	<u>492.8</u>
47		L_2	<u>228.4</u>	T_2	<u>501.5</u>
43		ΔL	<u>1.1</u>		
54					
60	MUT	L_1	<u>81.6</u>	T_1	<u>95.5</u>
62		L_2	<u>80.2</u>	T_2	<u>95.3</u>
63		ΔL	<u>1.4</u>		

$$\Delta L' = \Delta L + \Delta T(2^2/40) = 1.1 + (-0.2)(2) = .7$$

$$\Delta V_{PER} = \Delta L' \times \frac{.0204}{.0173} \times 3.2 \text{ ft}^3/\text{in} = .7 \times 1.179 \times 3.2 = 2.18 \text{ ft}^3$$

$$\Delta V_{MUT} = \Delta L \times 4.244 = 1.4 \times 4.244 = \frac{5.94}{8.12}$$

$$V_i = \frac{(605.5)(8.12)}{49} = 100.4 \text{ ft}^3$$

- 57.

89.

- | | |
|----|----|
| 01 | 97 |
| 11 | 11 |
| 04 | 14 |
| 6 | 16 |
| 16 | 18 |
| 1 | 10 |
| 91 | 06 |
| 96 | 00 |
| 10 | 99 |
| 06 | 02 |
| 3 | 04 |

4/8/79 0345

Bubble calculation data *MSL*

<u>i</u>	<u>P_i</u>				
50	653	RES P	597.6	Temp	281.3
46	1		649.0 Δ 51.4		280.7
38	94	PER L	207.7	Temp	500.0
36	94		207.8		508.4
45	95		Δ 1.9		
56	90				
60	85	MUT L	94.6	Temp	93.8
56	83		95.4		94.0
53	90		Δ .8		
49	94				
44	04				
51	13				
2	65				
52	95				
45	03				
41	06				


$PER \Delta V = 1.9 \times 2.515 = 4.28$
 $MUT \Delta V = .8 \times 4.244 = 3.39$
 $\underline{\hspace{1.5cm}}$
 8.17

$$V_1 = \frac{649(8.17)}{51.4} = 103.2$$

$- 166.6 \text{ ft}^3$
 $+ .6 \text{ ft}^3$

volts

6ms Bubble Volume f13 @ 825 psia



24 18 12 6 0 6 12 18 24 1.0

4/13/75


4/14/75

5.2

2.0

1.5

1.0




○-BWS cmc's

H₂ CONCENTRATION IN CONTAINMENT % - ▽

Gas Rubble Volume FT³ @ 875 PSIA - ○

3-21-74 4-1-74 4-2-74

GAS VOLUME VOLUME PERCENTAGE @ 875 FPM — ○



H₂ CONCENTRATION IN CONTAINMENT % — △

4-1-79
4-2-79
4-3-79

Core check of 4/2/79 6:50 data

$$1. \quad \frac{1063}{98} \left[3.178 \left[\frac{.0172}{.02198} (202.9) - \frac{.0172}{.02159} (201.7) \right] + \right. \\ \left. -6.0541 \right]$$

$$4.128 \left(\frac{.0172}{.016052} \right) (46.1 - 49.4) - \cancel{6.116 \times 10^5} \left(\right) \\ -16.36$$

$$-6.166 \times 10^5 [9 \times 10^{-6} (278.5 - 278.8)] = \\ -1.665$$

$$-6.166 \times 10^5 (-10^{-7}) (1063 - 965) \\ -6.04$$

$$+6.166 \times 10^5 (5.839 \times 10^{-7}) (1063 - 965) = \\ 35.524$$

$$\frac{1063}{98} [-6.0541 - 16.36 + 1.665 + 6.04 + 35.524]$$

- 225.8 ? Bubble zone

4/3/79 0200

THE BABCOCK & WILCOX COMPANY
POWER GENERATION GROUP

Dick Wilson
NRC

To: DICK WILSON, MET ED OPERATIONS

FROM: D. W. BERGER, MANAGER, DEW OPERATIONS

BOS 653-5

Cust. File No. or Ref.

Subj. REACTOR BUBBLE SIZE CALCULATION PACKAGE


Date APRIL 1, 1979

0153

This letter is under NRC contract and use subject only.

ATTACHED ARE 12 PAGES OF THE CALCULATIONS FOR THE REACTOR BUBBLE.
OUR CALCULATIONS FROM DATA POINT 4 IS THAT THE BUBBLE HAS DISAPPEARED.
THIS IS SUBSTANTIATED BY NOISE MONITORING ON THE "B" LOOP PRESSURE TRANSMITTER.

*STATISTICAL
ANALYSIS
LATER*



D. W. BERGER

DWB/CW
ATTACHMENTS

NOTE: ALSO ATTACHED IS "REVIEW OF SODIUM SULFITE ADDITION ON RCS SYSTEM," DATED APRIL 1, 1979, 1 PAGE; AND 2) "COMPOSITION OF GAS BUBBLE," DATED APRIL 1, 1979, 1 PAGE.

LEE ROGERS - TRANSMIT THIS PACKAGE TO G. BROUGHTON

Calc of Volume of Bubble from Data @ 1510-1650 hr, 4/1/79

	Time t_1	Time t_2
RCS Pressure	955 psia ✓	1065 psia ✓
Temp	280.9°F ✓	281.3°F ✓
PZR Level	216.8" ✓	208.3" ✓
Temp	545.7°F ✓	553.2°F ✓
MWT Level	53.3" ✓	50.6" ✓
Temp	75°F ✓	74°F ✓

$$\textcircled{1} \frac{P_2}{P_1 - P_2} = \frac{1065}{955 - 1065} = - \frac{1065}{110} = -9.682 \checkmark$$

$$\textcircled{2} C_{\text{PZR}} \left(\frac{\gamma_{\text{PZR}}^{\text{RCS}}}{\gamma_{\text{PZR}}^{\text{PZR}}} L_2^{\text{PZR}} - \frac{\gamma_{\text{PZR}}^{\text{RCS}}}{\gamma_{\text{PZR}}^{\text{PZR}}} L_1^{\text{PZR}} \right) = 3.178 \left(\frac{.01720}{.02202} (208.3) - \frac{.01721}{.02163} (216.8) \right) = -31.122 \checkmark$$

$$\textcircled{3} C_{\text{MWT}} \left(\frac{\gamma_{\text{MWT}}^{\text{RCS}}}{\gamma_{\text{MWT}}^{\text{MWT}}} (L_2^{\text{MWT}} - L_1^{\text{MWT}}) \right) = 4.128 \left(\frac{.01721}{.01606} (50.6 - 53.3) \right) = -11.944 \checkmark$$

$$\textcircled{4} M_{\text{RCS}} \left(\frac{\partial \gamma^{\text{RCS}}}{\partial T^{\text{RCS}}} \right) (T_2^{\text{RCS}} - T_1^{\text{RCS}}) = (6.166 \times 10^5) (9 \times 10^{-6}) (281.3 - 280.9) = 2.220 \checkmark$$

$$\textcircled{5} M_{\text{RCS}} \left(\frac{\partial \gamma^{\text{RCS}}}{\partial P^{\text{RCS}}} \right) (P_2 - P_1) = (6.166 \times 10^5) (-10^{-7}) (1065 - 955) = -6.783 \checkmark$$

$$\textcircled{6} M_{\text{RCS}} \left(\frac{\partial S}{\partial P} \right) (P_2 - P_1) = (6.166 \times 10^5) (6339 \times 10^{-9}) (1065 - 955) = 39.604 \checkmark$$

$$V = \textcircled{1} [\textcircled{2} + \textcircled{3} - \textcircled{4} - \textcircled{5} + \textcircled{6}]$$

$$V = (-9.682) [(-31.122) + (-11.944) - (2.220) - (-6.783) + (39.604)]$$

$$V = (-9.682) [-31.122 - 11.944 - 2.220 + 6.783 + 39.604]$$

$$V = -10.660$$

Calc. of Volume of Bubble from Data @ 2200 hrs, 3/2/79:

	Time t_1	Time t_2
RES Pressure	955	1046
Temp	278.2°F	277.7°F
PER Level	196"	192.2"
Temp	595.6°F	556.6°F
MUT Level	49.5"	33"
Temp	81°F	81°F

$$1) \frac{P_2}{P_1 - P_2} = \frac{1046}{955 - 1046} = -\frac{1046}{91} = -11.495$$

$$2) C_{PER} \left(\frac{V_{RES}^{RES}}{V_{PER}^{PER}} L_2^{PER} - \frac{V_{RES}^{RES}}{V_{PER}^{PER}} L_1^{PER} \right) = 3.173 \left(\frac{.01719}{.02162} \left(\frac{196}{192.2} \right) - \frac{.01718}{.02176} \left(\frac{196}{192.2} \right) \right) = -1.65$$

$$3) C_{MUT} \left(\frac{V_1^{RES}}{V_2^{RES}} \right) (L_2^{MUT} - L_1^{MUT}) = 4.128 \left(\frac{.01718}{.01607} \right) \left(\frac{33 - 49.5}{17.2 - 75} \right) = -72.817$$

$$4) M_{RES} \left(\frac{\partial V^{RES}}{\partial T^{RES}} \right) (T_2^{RES} - T_1^{RES}) = (6.166 \times 10^5) (9 \times 10^{-4}) (277.7 - 278.2) = -2.775$$

$$5) M_{RES} \left(\frac{\partial V^{RES}}{\partial P^{RES}} \right) (P_2 - P_1) = (6.166 \times 10^5) (-10^{-7}) (955 - 1046) = -5.611$$

$$6) M_{RES} \left(\frac{\partial V}{\partial P} \right) (P_2 - P_1) = (6.166 \times 10^5) (5.839 \times 10^{-7}) (955 - 1046) = +32.763$$

$$V = 1 [2 + 3 - 4 - 5 + 6]$$

$$V = (-11.495) [(-1.65) + (-72.817) - (-2.775) - (-5.611) + (+32.763)]$$

$$V = (-11.495) [-12.279 - 72.817 + 2.775 + 5.611 + 32.763]$$

$$V = (-11.495) [-33.32] = 383. \quad \frac{383}{16} = 23.9375$$

		t_1	t_2
RES	P	957	1055
	Temp	280	279.4
PER	Level	195.1	192.7
	Temp	545.7	557.9
MUT	Level	53.3	39.6
	Temp	72	70

$$\textcircled{1} \frac{P_2}{P_1 - P_2} = \frac{1055}{957 - 1055} = -10.765 \checkmark \checkmark$$

$$\textcircled{2} C_{PER} \left(\frac{V_{f_2}^{RES}}{V_{f_1}^{PER}} L_2^{PER} - \frac{V_{f_1}^{RES}}{V_{f_2}^{PER}} L_1^{PER} \right) = 3.178 \left(\frac{.01719 (192.7)}{.02200} - \frac{.01710 (195.1)}{.02163} \right) = -14.53$$

$$\textcircled{3} C_{MUT} \left(\frac{V_f^{RES}}{V_f^{MUT}} \right) \left(L_2^{MUT} - L_1^{MUT} \right) = 4.128 \left(\frac{.01723}{.016952} \right) (39.6 - 53.3) = -60.578$$

$$\textcircled{4} M_{RES} \left(\frac{\partial V}{\partial T} \right)^{RES} \left(T_2^{RES} - T_1^{RES} \right) = 6.166 \times 10^5 (9 \text{ MD}^2) (279.4 - 280) = -3.33$$

$$\textcircled{5} M_{RES} \left(\frac{\partial V}{\partial P} \right)^{RES} (P_2 - P_1) = 6.166 \times 10^5 (-10^{-7}) (1055 - 957) = -6.073$$

$$\textcircled{6} M_{RES} \left(\frac{\partial S}{\partial P} \right) (P_2 - P_1) = 6.166 \times 10^5 (5.039 \times 10^{-7}) (1055 - 957) = 35.28$$

$$V = \textcircled{1} [\textcircled{2} + \textcircled{3} - \textcircled{4} - \textcircled{5} + \textcircled{6}] = (-10.765) \left[\begin{array}{l} -0.742 \\ -30.975 \end{array} \right] = \begin{array}{l} 7.977 \\ 328.0 \text{ ft}^3 \end{array}$$

0830 4/1

.01721 .01720

RES temp 280.5 $v_{12}^{res} = .01720 \text{ ft}^3/\text{lb}$ $P_2 = 1050$ $v_2^{res} = .01720$
 press 1050 $P_1 = 945$ $v_1^{res} = .01720$

premixer
 $T_1 = 544.6$ $v_{g1}^{pre} = .02159$ $L_1^{pre} = 201.2$
 $T_2 = 557.1$ $v_{g2}^{pre} = .02198$ $L_2^{pre} = 192.6$

making tank
 $T = 765$ $v_g^{mt} = .016064$ $L_2^{mt} = 50.7$
 $L_1^{mt} = 45.3$

① $\frac{P_2}{P_1 - P_2} = \frac{1050}{945 - 1050} = -10.0$

② $C_{pre} \left(\frac{v_{g1}^{pre}}{v_{g2}^{pre}} L_2^{pre} - \frac{v_{g2}^{pre}}{v_{g1}^{pre}} L_1^{pre} \right) = 3.173 \left(\frac{.01720}{.02198} (192.6) - \frac{.01720}{.02159} (201.2) \right) = -30.426$

③ $C_{mt} \left(\frac{v_g^{mt}}{v_g^{mt}} \right) (L_2^{mt} - L_1^{mt}) = 4.128 \left(\frac{.01720}{.016064} \right) (45.3 - 50.7) = -23.868$

④ $M_{res} \left(\frac{Y_V^{res}}{Y_P^{res}} \right) (T_2^{res} - T_1^{res}) = (6.166 \times 10^{-5}) (9 \times 10^{-6}) (280.5 - 280.5) = 0$

⑤ $M_{res} \left(\frac{Y_V^{res}}{Y_P^{res}} \right) (P_2 - P_1) = (6.166 \times 10^{-5}) (-10^{-7}) (1050 - 945) = -6.477$

⑥ $M_{res} \left(\frac{Y_S}{Y_P} \right) (P_2 - P_1) = (6.166 \times 10^{-5}) (5.839 \times 10^{-7}) (1050 - 945) = 37.497$

$V = ① [② + ③ - ④ - ⑤ + ⑥]$

$V = -10 [-30.426 + (-23.868) - 0 - (-6.477) + 37.497]$

$V = -10 [-9.369] = \frac{93.69}{54^3}$

RATE OF CHANGE OF SOLUBILITY IS A FUNCTION OF PRESSURE

$$T = 280^{\circ}\text{F} = 137.8^{\circ}\text{C}$$

Conc (cc/lb)	Conc (scf/lb)	Conc (cc/lb) [*]	Press Atm	Press (psi)
400	6.41×10^{-3}	1.54×10^{-4}	18.6	273
600	9.61×10^{-3}	2.39×10^{-4}	27.9	410
800	—	3.18×10^{-4}	37.2	547
1000	—	3.98×10^{-4}	46.5	684
1200	—	4.78×10^{-4}	55.8	820
1400	—	5.57×10^{-4}	65.1	957
1600	—	6.37×10^{-4}	74.4	1094
1800	—	7.16×10^{-4}	83.7	1230
2000	0.032	7.96×10^{-4}	93.0	1367

$$\text{Conc} \left(\frac{\text{scf}}{\text{lb}} \right) = \text{Conc} \left(\frac{\text{cc}}{\text{lb}} \right) \times \frac{0.4536 \text{ kg/lb}}{29.37 \text{ cc/cc}}$$

$$\text{Conc} \left(\frac{\text{cc}}{\text{lb}} \right) = \text{Conc} \left(\frac{\text{cc}}{\text{kg}} \right) \times \frac{0.4536 \text{ kg/lb}}{29.37 \text{ cc/cc}} \times \frac{14.7 \text{ psia}}{890 \text{ psia}} \times \frac{770 \text{ R}}{493 \text{ R}}$$

$$-\frac{dc}{dP} = -\left(\frac{C_2 - C_1}{P_2 - P_1} \right) = -\left(\frac{5.57 \times 10^{-4} - 4.78 \times 10^{-4}}{957 - 820} \right) = -5.76 \times 10^{-7} \left(\frac{\text{cc}}{\text{psi}} \right)$$

* REFERENCE CONDITIONS 875 PSIA & 280°F

Jim Moore

Date Taken By: JSM

RCS PRESSURE (343)

P₁ = 9.59 PSIA
P₂ = 10.57 PSIA
P₃ = 99 PSI

RCS TEMP (344)

T₁ = 278.4 °F
T₂ = 277.6 °F

Pressurizer Level (422)

L₁ = 197.0 inches
L₂ = 193.6 inches
ΔL = 3.4 inches

Pressurizer Temp (423)

T₁ = 546.5 °F
T₂ = 557.4 °F

MAKEUP TANK LEVEL (347)

L₁ = 32.1 inches
L₂ = 20.6 inches
ΔL = 11.5 inches

MAKEUP TANK TEMP (348)

T₁ = 81.0 °F
T₂ = 79 °F

ΔV_{WT} = ΔL × 2.515 = 30 × 2.515 = 75.45 FT³

ΔV_{WT} = ΔL × 4.245 = 11.5 × 4.245 = 48.8 FT³

ΔV_{WT} = 16.30 FT³

V₁ = $\frac{P_2 \Delta V}{P_1 - P_2} = \frac{(10.57 \times 16.30)}{(99 - 10.57)} = 1.5534 \text{ FT}^3 @ 99 \text{ PSI}$

V_{1 @ 875} = $(V_1 @ P_1) \left(\frac{P_1}{875} \right) = 1.5534 \times 11.15 \text{ FT}^3 @ 875 \text{ PSI}$

3353 Representations
0018 Time 2511
018 2353
018 2018

RC PRESSURE (502)

$P_1 =$ 957 PSIA
 $P_2 =$ 1055 PSIA
 $\Delta P =$ 98 PSI

RCS TEMP (704)

$T_1 =$ 285 °F
 $T_2 =$ 279.4 °F

DRYER LEVEL (1652)

$L_1 =$ 175.1 INCHES
 $L_2 =$ 192.7 INCHES
 $\Delta L =$ 17.6 INCHES

DRYER TEMP (205)

$T_1 =$ 545.7 °F
 $T_2 =$ 557.9 °F

MAKEUP TANK LEVEL (347)

$L_1 =$ 533 INCHES
 $L_2 =$ 571.6 INCHES
 $\Delta L =$ 38.6 INCHES

MAKEUP TANK TEMP (205)

$T_1 =$ 72 °F
 $T_2 =$ 70 °F

$\Delta V_{DRYER} = \Delta L \times 2.515 = 17.6 \times 2.515 = 44.26 \text{ FT}^3$

$\Delta V_{MT} = \Delta L \times 4.244 = 38.6 \times 4.244 = 163.8 \text{ FT}^3$

$\Delta V_{TOTAL} = 64.2 \text{ FT}^3$

$V_{RC} = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{1055 \times 64.2}{98} = 690.9 \text{ FT}^3 @ P_2$

$V_{RC} = (V_{RC} \text{ at } P_1) \left(\frac{P_1}{P_2} \right) = 933.1 \text{ FT}^3 @ 875 \text{ PSIA}$

S 0403
 S 0423

Representative Time
 Start 0403 Stop 0423
 Δt = 95

Date Time 07: 12:00

RC Pressure (393)
 $P_1 =$ _____ PSIG = 945 PSIG
 $P_2 =$ _____ PSIG = 1050 PSIG
 $\Delta P =$ 105 PSIG

RCS Temp (393)
 $T_1 =$ 280.5 °F
 $T_2 =$ 280.5 °F

Pressurizer Level (432)
 $L_1 =$ 201.3 INCHES
 $L_2 =$ 193.1 INCHES
 $\Delta L =$ 8.2 INCHES

Pressurizer Temp (432)
 $T_1 =$ 544.6 °F
 $T_2 =$ 557.1 °F

MAKUP TANK LEVEL (347)
 $L_1 =$ 50.7 INCHES
 $L_2 =$ 45.3 INCHES
 $\Delta L =$ 5.4 INCHES

MAKUP TANK Temp (347)
 $T_1 =$ 77.0 °F
 $T_2 =$ 75 °F

$\Delta V_{PR} = \Delta L \cdot 2.515 =$ 21.13 FT³
 $\Delta V_{MT} = \Delta L \cdot 4.244 =$ 22.92 FT³
 $\Delta V_{TOT} =$ 44.5 FT³

$V_1 = \frac{P_2 \cdot \Delta V_{TOT}}{P_2 - P_1} = \frac{1050 \cdot 44.5}{105} =$ 445.5 FT³ @ P_1

$V_{(393)} = (V_1 @ P_1) \left(\frac{P_1}{P_2} \right) = \frac{445.5}{1.112} =$ 399.7 FT³ @ 275 PSIG

DATA TAKEN BY: John

RCS PRESSURE (333)

$$P_1 = \underline{955} \text{ PSI}$$

$$P_2 = \underline{1065} \text{ PSI}$$

$$\Delta P = \underline{110} \text{ PSI}$$

RCS TEMP (344)

$$T_1 = \underline{280.9} \text{ }^\circ\text{F}$$

$$T_2 = \underline{284.3} \text{ }^\circ\text{F}$$

PRESSURIZER LEVEL (162)

$$L_1 = \underline{216.8} \text{ INCHES}$$

$$L_2 = \underline{208.3} \text{ INCHES}$$

$$\Delta L = \underline{-8.5} \text{ INCHES}$$

PRESSURIZER TEMP (355)

$$T_1 = \underline{545.9} \text{ }^\circ\text{F}$$

$$T_2 = \underline{558.2} \text{ }^\circ\text{F}$$

MAKEUP TANK LEVEL (347)

$$L_1 = \underline{53.3} \text{ INCHES}$$

$$L_2 = \underline{50.6} \text{ INCHES}$$

$$\Delta L = \underline{-2.7} \text{ INCHES}$$

MAKEUP TANK TEMP (355)

$$T_1 = \underline{72} \text{ }^\circ\text{F}$$

$$T_2 = \underline{74} \text{ }^\circ\text{F}$$

$$\Delta V_{PR} = \Delta L \cdot 2.515 = \underline{8.5} \cdot 2.515 = \underline{21.38} \text{ FT}^3$$

$$\Delta V_{MT} = \Delta L \cdot 4.244 = \underline{2.7} \cdot 4.244 = \underline{11.46} \text{ FT}^3$$

$$\Delta V_{TOT} = \underline{32.84} \text{ FT}^3$$

$$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{1065 \cdot (32.84)}{(110)} = \underline{317} \text{ FT}^3 @ P_2$$

$$V_1(\text{std}) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{347} \text{ FT}^3 @ 875 \text{ PSI}$$

Volume of Bubble Calculation

$$V_{\text{bubble}} = \frac{P_2}{P_1 - P_2} \left[C_{\text{PAR}} \left(\frac{V_{f1}^{\text{RES}}}{V_{f2}^{\text{RES}}} L_2^{\text{PAR}} - \frac{V_{f1}^{\text{RES}}}{V_{f1}^{\text{PAR}}} L_1^{\text{PAR}} \right) + C_{\text{MUT}} \left(\frac{V_f^{\text{RES}}}{V_f^{\text{MUT}}} \right) (L_2^{\text{MUT}} - L_1^{\text{MUT}}) - M_{\text{RES}} \left(\frac{\partial V^{\text{RES}}}{\partial T^{\text{RES}}} \right) (T_2^{\text{RES}} - T_1^{\text{RES}}) - M_{\text{RES}} \left(\frac{\partial V^{\text{RES}}}{\partial P^{\text{RES}}} \right) (P_2 - P_1) + M_{\text{RES}} \left(\frac{\partial S}{\partial P} \right) (P_2 - P_1) \right]$$

did not use
initial pressure
1875

$P_2 = RC$ $S_2 =$ Press After Change

$P_1 = RC$ $S_1 =$ Press Before Change

$C_{\text{PAR}} =$ Level to Volume Conversion for PAR. = 3.178 ft³/in

$C_{\text{MUT}} =$ " " " " " " MUT = 4.128 ft³/in

$V_f^{\text{RES}} =$ Specific Volume of water at RES temp, saturated steam tables

$V_{f2}^{\text{RES}} =$ " " " " " " PAR. " after change, saturated steam tables

$V_{f1}^{\text{RES}} =$ " " " " " " " before " " " " " "

$V_f^{\text{MUT}} =$ " " " " " " " MUT " saturated steam tables

$L_2^{\text{PAR}} =$ Level in pressurizer after change, inches

$L_1^{\text{PAR}} =$ " " " " before " " " "

$L_2^{\text{MUT}} =$ " " " " " " " " " " " " " "

$L_1^{\text{MUT}} =$ " " " " " " before " " " "

$\frac{\partial V^{\text{RES}}}{\partial T^{\text{RES}}} =$ change in RES specific vol per °F = 9.2×10^{-6} ft³/lbm-°F

$\frac{\partial V^{\text{RES}}}{\partial P^{\text{RES}}} =$ change in RES specific volume per pound pressure = -10^{-7} ft³/lbm-psi

$\frac{\partial S}{\partial P} =$ Change in solubility of H₂ per pound pressure = 5.839×10^{-7} ft³/lbm-psi

$M_{\text{RES}} =$ Mass of RCS = 6.166×10^{15} lbs

MEMO from:

G. P. MILLER


BUBBLE SIZE

4-2-79

211 FT.³ @ 2:15 AM


205 FT.³ @ 3:15 AM

130 FT.³ @ 5:00 AM



RCS BUBBLE

O = DATA POINTS WITH $\Delta P > 9.0$ PSI
 * = DATA TAKEN WITH DECREASING PRESSURE




5/2/75 | 5/2/75
 3/30/74 | 3/30/74
 4/6/74 | 4/6/74
 4/17/74 | 4/17/74
 4/21/74 | 4/21/74
 4/3 | 4/3
 4/4 | 4/4
 4/5 | 4/5
 4/18 | 4/18
 4/20 | 4/20
 4/21 | 4/21
 4/22 | 4/22
 4/23 | 4/23
 4/24 | 4/24
 4/25 | 4/25
 4/26 | 4/26
 4/27 | 4/27
 4/28 | 4/28
 4/29 | 4/29
 4/30 | 4/30
 5/1 | 5/1
 5/2 | 5/2
 5/3 | 5/3
 5/4 | 5/4
 5/5 | 5/5
 5/6 | 5/6
 5/7 | 5/7
 5/8 | 5/8
 5/9 | 5/9
 5/10 | 5/10
 5/11 | 5/11
 5/12 | 5/12
 5/13 | 5/13
 5/14 | 5/14
 5/15 | 5/15
 5/16 | 5/16
 5/17 | 5/17
 5/18 | 5/18
 5/19 | 5/19
 5/20 | 5/20
 5/21 | 5/21
 5/22 | 5/22
 5/23 | 5/23
 5/24 | 5/24
 5/25 | 5/25
 5/26 | 5/26
 5/27 | 5/27
 5/28 | 5/28
 5/29 | 5/29
 5/30 | 5/30
 5/31 | 5/31
 6/1 | 6/1
 6/2 | 6/2
 6/3 | 6/3
 6/4 | 6/4
 6/5 | 6/5
 6/6 | 6/6
 6/7 | 6/7
 6/8 | 6/8
 6/9 | 6/9
 6/10 | 6/10
 6/11 | 6/11
 6/12 | 6/12
 6/13 | 6/13
 6/14 | 6/14
 6/15 | 6/15
 6/16 | 6/16
 6/17 | 6/17
 6/18 | 6/18
 6/19 | 6/19
 6/20 | 6/20
 6/21 | 6/21
 6/22 | 6/22
 6/23 | 6/23
 6/24 | 6/24
 6/25 | 6/25
 6/26 | 6/26
 6/27 | 6/27
 6/28 | 6/28
 6/29 | 6/29
 6/30 | 6/30
 7/1 | 7/1
 7/2 | 7/2
 7/3 | 7/3
 7/4 | 7/4
 7/5 | 7/5
 7/6 | 7/6
 7/7 | 7/7
 7/8 | 7/8
 7/9 | 7/9
 7/10 | 7/10
 7/11 | 7/11
 7/12 | 7/12
 7/13 | 7/13
 7/14 | 7/14
 7/15 | 7/15
 7/16 | 7/16
 7/17 | 7/17
 7/18 | 7/18
 7/19 | 7/19
 7/20 | 7/20
 7/21 | 7/21
 7/22 | 7/22
 7/23 | 7/23
 7/24 | 7/24
 7/25 | 7/25
 7/26 | 7/26
 7/27 | 7/27
 7/28 | 7/28
 7/29 | 7/29
 7/30 | 7/30
 7/31 | 7/31
 8/1 | 8/1
 8/2 | 8/2
 8/3 | 8/3
 8/4 | 8/4
 8/5 | 8/5
 8/6 | 8/6
 8/7 | 8/7
 8/8 | 8/8
 8/9 | 8/9
 8/10 | 8/10
 8/11 | 8/11
 8/12 | 8/12
 8/13 | 8/13
 8/14 | 8/14
 8/15 | 8/15
 8/16 | 8/16
 8/17 | 8/17
 8/18 | 8/18
 8/19 | 8/19
 8/20 | 8/20
 8/21 | 8/21
 8/22 | 8/22
 8/23 | 8/23
 8/24 | 8/24
 8/25 | 8/25
 8/26 | 8/26
 8/27 | 8/27
 8/28 | 8/28
 8/29 | 8/29
 8/30 | 8/30
 8/31 | 8/31
 9/1 | 9/1
 9/2 | 9/2
 9/3 | 9/3
 9/4 | 9/4
 9/5 | 9/5
 9/6 | 9/6
 9/7 | 9/7
 9/8 | 9/8
 9/9 | 9/9
 9/10 | 9/10
 9/11 | 9/11
 9/12 | 9/12
 9/13 | 9/13
 9/14 | 9/14
 9/15 | 9/15
 9/16 | 9/16
 9/17 | 9/17
 9/18 | 9/18
 9/19 | 9/19
 9/20 | 9/20
 9/21 | 9/21
 9/22 | 9/22
 9/23 | 9/23
 9/24 | 9/24
 9/25 | 9/25
 9/26 | 9/26
 9/27 | 9/27
 9/28 | 9/28
 9/29 | 9/29
 9/30 | 9/30
 10/1 | 10/1
 10/2 | 10/2
 10/3 | 10/3
 10/4 | 10/4
 10/5 | 10/5
 10/6 | 10/6
 10/7 | 10/7
 10/8 | 10/8
 10/9 | 10/9
 10/10 | 10/10
 10/11 | 10/11
 10/12 | 10/12
 10/13 | 10/13
 10/14 | 10/14
 10/15 | 10/15
 10/16 | 10/16
 10/17 | 10/17
 10/18 | 10/18
 10/19 | 10/19
 10/20 | 10/20
 10/21 | 10/21
 10/22 | 10/22
 10/23 | 10/23
 10/24 | 10/24
 10/25 | 10/25
 10/26 | 10/26
 10/27 | 10/27
 10/28 | 10/28
 10/29 | 10/29
 10/30 | 10/30
 10/31 | 10/31
 11/1 | 11/1
 11/2 | 11/2
 11/3 | 11/3
 11/4 | 11/4
 11/5 | 11/5
 11/6 | 11/6
 11/7 | 11/7
 11/8 | 11/8
 11/9 | 11/9
 11/10 | 11/10
 11/11 | 11/11
 11/12 | 11/12
 11/13 | 11/13
 11/14 | 11/14
 11/15 | 11/15
 11/16 | 11/16
 11/17 | 11/17
 11/18 | 11/18
 11/19 | 11/19
 11/20 | 11/20
 11/21 | 11/21
 11/22 | 11/22
 11/23 | 11/23
 11/24 | 11/24
 11/25 | 11/25
 11/26 | 11/26
 11/27 | 11/27
 11/28 | 11/28
 11/29 | 11/29
 11/30 | 11/30
 12/1 | 12/1
 12/2 | 12/2
 12/3 | 12/3
 12/4 | 12/4
 12/5 | 12/5
 12/6 | 12/6
 12/7 | 12/7
 12/8 | 12/8
 12/9 | 12/9
 12/10 | 12/10
 12/11 | 12/11
 12/12 | 12/12
 12/13 | 12/13
 12/14 | 12/14
 12/15 | 12/15
 12/16 | 12/16
 12/17 | 12/17
 12/18 | 12/18
 12/19 | 12/19
 12/20 | 12/20
 12/21 | 12/21
 12/22 | 12/22
 12/23 | 12/23
 12/24 | 12/24
 12/25 | 12/25
 12/26 | 12/26
 12/27 | 12/27
 12/28 | 12/28
 12/29 | 12/29
 12/30 | 12/30
 12/31 | 12/31

AVG MAKEUP FLOW TO MAKEUP TANK.

4/1/79
JPM

Calculate Average rate of makeup to Makeup Tank for comparison with the calculated rate of decrease in bubble size. The first data is for makeup is from 0730 to 0825. This is floor the depressurization half of the cycle. The pressurization half of this cycle started at about 0700. Therefore the rate will be calculated on the basis of Time = 0 @ 0700.

Date	Time of Make-up to MUTC	GAL ADDED	FT ³ ADDED AT 70°F	FT ³ ADDED AT 280°F	TOTAL FT ³ ADDED	TOTAL Δ TIME (HR)	MAKEUP RATE FT ³ /HR @ 280°F
4/1/79	0730-0825	460	61.5	66	66	1.42	46
	0903-0945	400	53.47	57.5	123.5	2.75	44.9
	1020-1041	301	40.24	43.25	166.8	3.68	45.3
	1140-1200	446	59.62	64.1	230.9	5.00	46.2
	1238-1306	400	57.46	61.8	292.7	6:10	48.0
	-1506	456	60.95	65.52	358.2	8.10	44.2 35.47
	1650	505	67.5	72.567	430.8	9.83	43.83
	1805	456	60.95	65.52	496.3	11.01	45.08
	1900	455	60.82	65.38	561.68	12:00	46.8
	2015	454	60.69	65.24	626.92	13.25	47.31
	2120	455	60.82	65.38	692.3	14.33	
	2225	455	60.82	65.38	757.68	15.41	
	2347	455	60.82	65.38	823.06	16.77	
	0151	- See Next page					



4/1/79 4/2
2347 → 0853

Avg = 30.9

Ft 3 @ 875 - good

DP

3/29

1300

1839.3

95

DATA FROM J. FLOYD - SOURCES UNKNOWN

3/30

0625

* 828.6 16

MU TR_A LEVEL - BELIEVED TO BE ZERO IN.

0730

892.5 115

1240

* 308 32

1445

839 42

1630

* 365.6 17

1745

* 224.6 25

1907

* 1806.0 38

~~0630~~

850 55

3/31

1032

859.5 47

1351

879.4 92

1351

$$V_1 = \frac{P_2 \left[a (L_2 - L_1)_A + b (L_2 - L_1)_B \right]}{P_1 - P_2}$$

P_2 = RC System Pressure - Computer point ~~1482~~ 398

L_A = PRESSURIZER LEVEL - " " 1682

L_B = MAKEUP TANK LEVEL - " " 347

SUBSCRIPTS

1 - INITIAL DATA POINT

2 - FINAL DATA POINT

A - PRESSURIZER

B - MAKEUP TANK

$$a = \left(3.2 \frac{\text{FT}^3}{\text{IN}} \right) \left(\frac{0.0173}{0.022} \right) = 2.515$$

where v_f for RC TEMP = 0.0173 cc/gal
 v_f for PRESSURIZER TEMP = 0.0163 cc/gal

To Convert PZR ΔV to equivalent ΔV at RC Temp.

$$b = \left(4 \frac{\text{FT}^3}{\text{IN}} \right) \left(\frac{0.0173}{0.0163} \right) = 4.244$$

where v_f for RC Temp = 0.0173
 v_f for Makeup Tank Temp = 0.0163

To Convert MUTK ΔV to equivalent ΔV at RC Temp.

76
495-544

DATE 4/3/79

TMI-2 RCS BUBBLE CALC SHEET

TIME 1404-1434 AM PM

DATA TAKEN BY: JSC

45

49

54

57

56

51

55

45

40

44

51

52

51

44

48

53

44

41

40

53

46

49

51

52

53

54

53

52

41

42

44

51

56

55

50

RC PRESSURE (398)

P₁ = _____ PSIG = 949 PSIA

P₂ = _____ PSIG = 1050 PSIA

ΔP = 101 PSI

RCS TEMP (394)

T₁ = 280.2 °F

T₂ = 280.7 °F

PRESSURIZER LEVEL (1682)

L₁ = 193.5 INCHES

L₂ = 186.7 INCHES

ΔL = -3.2 INCHES

PRESSURIZER TEMP (311)

T₁ = 546.2 °F

T₂ = 557.4 °F

MAKEUP TANK LEVEL (347)

L₁ = 45.0 INCHES

L₂ = 41.4 INCHES

ΔL = 3.6 INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

T₁ = 74 °F

T₂ = 74 °F

ΔV_{PZR} = ΔL * 2.515 = -3.2 * 2.515 = -8.05 FT³

ΔV_{MUT} = ΔL * 4.244 = 3.6 * 4.244 = 15.29 FT³

ΔV_{TOTAL} = 7.23 FT³

V₁ = $\frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{1050 \times 7.23}{101} = 75.2 \text{ FT}^3 @ P_1$

V_{1(875)} = (V_{1 at P₁}) $\left(\frac{P_1}{875}\right) = 81.5 \text{ FT}^3 @ 875 \text{ PSIA}$}

49

43

46

50

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/3/79

TIME 1525 ^{AM} _{PM}

DATA TAKEN BY: PSL

44
54
64
64
64
61
50
48
52
54
64
65
64
59
50
44
50

RC PRESSURE (398)
 $P_1 = \underline{\hspace{2cm}}$ PSIG = 958 PSIA
 $P_2 = \underline{\hspace{2cm}}$ PSIG = 1056 PSIA
 $\Delta P = \underline{98}$ PSI

RCS TEMP (394)
 $T_1 = \underline{277.6}$ °F $v_g = .017228$
 $T_2 = \underline{280.0}$ °F $v_g = .017286$
 $v_{liq} = .017264$
 $\Delta v = 1.8 \times 10^{-5} \text{ ft}^3/\text{lb}$

PRESSURIZER LEVEL (1682)
 $L_1 = \underline{182.3}$ INCHES
 $L_2 = \underline{187.5}$ INCHES
 $\Delta L = \underline{-5.2}$ INCHES

PRESSURIZER TEMP (³⁸⁸ ~~403~~)
 $T_1 = \underline{547.7}$ °F
 $T_2 = \underline{554.6}$ °F

MAKEUP TANK LEVEL (347)
 $L_1 = \underline{50.2}$ INCHES
 $L_2 = \underline{47.4}$ INCHES
 $\Delta L = \underline{2.8}$ INCHES

MAKEUP TANK TEMP (CONTRACT BOARD METER)
 $T_1 = \underline{75}$ °F
 $T_2 = \underline{75}$ °F

57
58
46
41
47
55
58
60
61
60
59
57
60
58
60
56
49
55
61

$\Delta V_{PZR} = \Delta L \cdot 2.515 = \underline{-5.2} \times 2.515 = \underline{-13.07} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \cdot 4.244 = \underline{2.8} \times 4.244 = \underline{11.88} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{-1.19} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1056 \times -1.19)}{(98)} = \underline{-12.8} \text{ FT}^3 @ P_1$

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{-14.0} \text{ FT}^3 @ 875 \text{ PSIA}$

51
53
53
57

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/3/79

TIME 86:20 - 645 ^{AM} ~~PM~~

DATA TAKEN BY: JL

RC PRESSURE (398)

$P_1 = \underline{962} \text{ PSIG} = \underline{977} \text{ PSIA}$

$P_2 = \underline{1035} \text{ PSIG} = \underline{1050} \text{ PSIA}$

$\Delta P = \underline{73} \text{ PSI}$

RCS TEMP (394)

$T_1 = \underline{280.1} \text{ }^\circ\text{F}$

$T_2 = \underline{280.2} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.3} \text{ INCHES}$

$L_2 = \underline{205.2} \text{ INCHES}$

$\Delta L = \underline{-3.9} \text{ INCHES}$

PRESSURIZER TEMP (~~405~~ ³⁵⁵)

$T_1 = \underline{547.4} \text{ }^\circ\text{F}$

$T_2 = \underline{556.6} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{52.5} \text{ INCHES}$

$L_2 = \underline{47.8} \text{ INCHES}$

$\Delta L = \underline{4.7} \text{ INCHES}$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{70} \text{ }^\circ\text{F}$

$T_2 = \underline{70} \text{ }^\circ\text{F}$

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{3.9} \times 2.515 = \underline{-9.8} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{4.7} \times 4.244 = \underline{19.9} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{10.14} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1050 \times 10.14)}{(73)} = \underline{145.8} \text{ FT}^3 @ P_1$

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1^{1.971}}{875} \right) = \underline{162.8} \text{ FT}^3 @ 875 \text{ PSIA}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 11/3/79

TIME 5:37 - 6:02 ^{AM} ~~PM~~

DATA TAKEN BY: JLL

RC PRESSURE (398)

$P_1 = \underline{960} \text{ PSIG} = \underline{975} \text{ PSIA}$

$P_2 = \underline{1061} \text{ PSIG} = \underline{1076} \text{ PSIA}$

$\Delta P = \underline{101} \text{ PSI}$

RCS TEMP (394)

$T_1 = \underline{280.0} \text{ }^\circ\text{F}$

$T_2 = \underline{280.1} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.8} \text{ INCHES}$

$L_2 = \underline{205.9} \text{ INCHES}$

$\Delta L = \underline{-4.1} \text{ INCHES}$

PRESSURIZER TEMP (~~389~~)

$T_1 = \underline{548.0} \text{ }^\circ\text{F}$

$T_2 = \underline{558.8} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{45.4} \text{ INCHES}$

$L_2 = \underline{41.2} \text{ INCHES}$

$\Delta L = \underline{4.2} \text{ INCHES}$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{68} \text{ }^\circ\text{F}$

$T_2 = \underline{68} \text{ }^\circ\text{F}$

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{-4.1} \times 2.515 = \underline{-10.31} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{4.2} \times 4.244 = \underline{17.82} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{7.513} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1076 \times 7.513)}{(101)} = \underline{80.04} \text{ FT}^3 @ P_1$

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{89.19} \text{ FT}^3 @ 875 \text{ PSIA}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/3/79

TIME 4:53 - 5:23 ^{AM} _{PM}

DATA TAKEN BY: JF

RC PRESSURE (398)

$P_1 = \underline{941} \text{ PSIG} = \underline{956} \text{ PSIA}$

$P_2 = \underline{1055} \text{ PSIG} = \underline{1070} \text{ PSIA}$

$\Delta P = \underline{114} \text{ PSI}$

RCS TEMP (394)

$T_1 = \underline{279.7} \text{ }^\circ\text{F}$

$T_2 = \underline{240.0} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.5} \text{ INCHES}$

$L_2 = \underline{206.7} \text{ INCHES}$

$\Delta L = \underline{-5.2} \text{ INCHES}$

PRESSURIZER TEMP (³⁸⁹105)

$T_1 = \underline{546.2} \text{ }^\circ\text{F}$

$T_2 = \underline{558.8} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{53.8} \text{ INCHES}$

$L_2 = \underline{48.0} \text{ INCHES}$

$\Delta L = \underline{5.8} \text{ INCHES}$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{69} \text{ }^\circ\text{F}$

$T_2 = \underline{69} \text{ }^\circ\text{F}$

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{-5.2} \times 2.515 = \underline{-13.08} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{5.8} \times 4.244 = \underline{24.61} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{11.53} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1070 \times 11.53)}{(114)} = \underline{10828} \text{ FT}^3 @ P_1$

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{11813} \text{ FT}^3 @ 875 \text{ PSIA}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 2025 AM
PM

DATA TAKEN BY: PSL

RC PRESSURE (390)

RCS TEMP (390)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 964 PSIA

$T_1 = \underline{275.8}$ °F

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1062 PSIA

$T_2 = \underline{275.9}$ °F

$\Delta P = \underline{98}$ PSI

PRESSURIZER LEVEL (1682)

PRESSURIZER TEMP (405)

$L_1 = \underline{204.0}$ INCHES

$T_1 = \underline{546.8}$ °F

$L_2 = \underline{202.7}$ INCHES

$T_2 = \underline{559.1}$ °F

$\Delta L = \underline{1.3}$ INCHES

MAKEUP TANK LEVEL (347)

MAKEUP TANK TEMP (CONTROL BOARD METER)

$L_1 = \underline{52.8}$ INCHES

$T_1 = \underline{72}$ °F

$L_2 = \underline{49.2}$ INCHES

$T_2 = \underline{72}$ °F

$\Delta L = \underline{3.6}$ INCHES

$\Delta V_{PZR} = \Delta L \cdot 2.515 = \underline{1.3} \times 2.515 = \underline{3.30}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{3.6} \times 4.244 = \underline{15.28}$ FT³

$\Delta V_{TOTAL} = \underline{18.5}$ FT³

$$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1062 \times 18.5)}{(98)} = \underline{201.0}$$
 FT³ @ P_1

$$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{221.5}$$
 FT³ @ 875 PSIA.

66
61
65
67

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 1803 AM PM

DATA TAKEN BY: PSW

RC PRESSUR. (398)

P₁ = _____ PSIG = 976 PSIA

P₂ = _____ PSIG = 1063 PSIA

ΔP = 87 PSI

RCS TEMP (394)

T₁ = 275.9 °F

T₂ = 275.5 °F

PRESSURIZER LEVEL (1682)

L₁ = 201.9 INCHES

L₂ = 202.8 INCHES

ΔL = -0.9 INCHES

PRESSURIZER TEMP (³⁸⁹405)

T₁ = 553.1 °F

T₂ = 559.5 °F

MAKEUP TANK LEVEL (347)

L₁ = 41.5 INCHES

L₂ = 38.4 INCHES

ΔL = 3.1 INCHES

MAKEUP TANK TEMP (CONTROL ROOM METER)

T₁ = 72 °F

T₂ = 72 °F

ΔV_{RC} = ΔL × 2.515 = -0.9 × 2.515 = -2.26 FT³

ΔV_{MUT} = ΔL × 4.244 = 3.1 × 4.244 = 13.16 FT³

ΔV_{TOTAL} = 10.9 FT³

V₁ = $\frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{1063 \times 10.9}{(87)} = 133.1$ FT³ @ P₁

V_{1(875)} = (V₁ at P₁) $\left(\frac{P_1}{875}\right) = 148.5$ FT³ @ 875 PSIA}

48 54
53 57
65 55
61 55

75
77
79
80
78
74
73
74
74
79
77
73
70
64
76
74
73
74
76
78
70
73
71
22
73
22
71
65
63
62
67
71
58
46
51
65
20
89
51

TMI-2 RCS BUBBLE CALC SHEET

DATE 9/2

TIME 1600-1650 AM PM

DATA TAKEN BY: ASW

RC PRESSURE (398)

RCS TEMP (394)

$P_1 = \underline{\hspace{2cm}} \text{ PSIG} = \underline{960} \text{ PSIA}$

$T_1 = \underline{277.6} \text{ } ^\circ\text{F}$

$P_2 = \underline{\hspace{2cm}} \text{ PSIG} = \underline{1045} \text{ PSIA}$

$T_2 = \underline{278.0} \text{ } ^\circ\text{F}$

$\Delta P = \underline{85} \text{ PSI}$

PRESSURIZER LEVEL (1682)

PRESSURIZER TEMP (405)

$L_1 = \underline{209.5} \text{ INCHES}$

$T_1 = \underline{548.1} \text{ } ^\circ\text{F}$

$L_2 = \underline{213.5} \text{ INCHES}$

$T_2 = \underline{557.3} \text{ } ^\circ\text{F}$

$\Delta L = \underline{-4.0} \text{ INCHES}$

MAKEUP TANK LEVEL (347)

MAKEUP TANK TEMP (CENTRAL BOARD METER)

$L_1 = \underline{46.3} \text{ INCHES}$

$T_1 = \underline{76} \text{ } ^\circ\text{F}$

$L_2 = \underline{43.1} \text{ INCHES}$

$T_2 = \underline{74} \text{ } ^\circ\text{F}$

$\Delta L = \underline{3.2} \text{ INCHES}$

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{-4.0} \times 2.515 = \underline{10.06} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{3.2} \times 4.244 = \underline{13.58} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{3.52} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1045 \times 3.52)}{(85)} = \underline{43.3} \text{ FT}^3 @ P_1$

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{47.5} \text{ FT}^3 @ 875 \text{ PSIA}$

56
47
48
50

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79
 TIME 1:55 ^{PM} / 13/5 ^{AM} / PM

DATA TAKEN BY: TRF/ASL

1065	<u>RC PRESSURE (398)</u>	<u>RCS TEMP (394)</u>
72	$P_1 =$ _____ $PSIG =$ <u>942</u> $PSIA$	$T_1 =$ <u>228.4</u> °F
73		
72	$P_2 =$ _____ $PSIG =$ <u>1063</u> $PSIA$	$T_2 =$ <u>228.5</u> °F
71	$\Delta P =$ <u>121</u> PSI	
20		
65		
61	<u>PRESSURIZER LEVEL (1682)</u>	<u>PRESSURIZER TEMP (405)</u>
53	$L_1 =$ <u>206.4</u> $INCHES$	$T_1 =$ <u>545.1</u> °F
48		
44	$L_2 =$ <u>204.0</u> $INCHES$	$T_2 =$ <u>558</u> °F
48	$\Delta L =$ <u>2.4</u> $INCHES$	
60		
63	<u>MAKEUP TANK LEVEL (347)</u>	<u>MAKEUP TANK TEMP (CONTROL BOARD METER)</u>
64	$L_1 =$ <u>47.4</u> $INCHES$	$T_1 =$ <u>78</u> °F
61	$L_2 =$ <u>44.5</u> $INCHES$	$T_2 =$ <u>78</u> °F
58	$\Delta L =$ <u>2.9</u> $INCHES$	
60		
70	$\Delta V_{PZR} = \Delta L \times 2.515 =$ <u>2.4</u> $\times 2.515 =$ <u>6.04</u> FT^3	
74	$\Delta V_{MUT} = \Delta L \times 4.244 =$ <u>2.9</u> $\times 4.244 =$ <u>12.31</u> FT^3	
65		$\Delta V_{TOTAL} =$ <u>18.35</u> FT^3
57		
66	$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1063 \times 18.35)}{(121)} =$ <u>161.2</u> $FT^3 @ P_1$	
59		
70		
61	$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) =$ <u>173.5</u> $FT^3 @ 875 \text{ psia}$	

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79
 TIME 1305 ¹²²⁵ 135 ^{PM} 1225 ^{AM} PM

DATA TAKEN BY: MF

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 936 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1056 PSIA

$\Delta P = \underline{120}$ PSI

RCS TEMP (394)

$T_1 = \underline{280.1}$ °F

$T_2 = \underline{280.1}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{208.3}$ INCHES

$L_2 = \underline{207.6}$ INCHES

$\Delta L = \underline{105.7}$ INCHES

PRESSURIZER TEMP (389)
(405)

$T_1 = \underline{547.5}$ °F

$T_2 = \underline{557.9}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{45.5}$ INCHES

$L_2 = \underline{41.6}$ INCHES

$\Delta L = \underline{3.9}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{740}$ °F

$T_2 = \underline{75}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{1.7} \times 2.515 = \underline{1.76}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{3.9} \times 4.244 = \underline{16.55}$ FT³

$\Delta V_{TOTAL} = \underline{18.3}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1056 \times 18.3)}{(120)} = \underline{161.1}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{194.5}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79
 TIME ~~1144~~ 1208 AM PM
 DATA TAKEN BY: RAF

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 942 PSIA
 $P_2 = \underline{\hspace{2cm}}$ PSIG = 1036 PSIA
 $\Delta P = \underline{78}$ PSI

RCS TEMP (394)

$T_1 = \underline{280.1}$ °F
 $T_2 = \underline{280.1}$ °F

PRESSURIZER LEVEL (1682)

* $L_1 = \underline{206.4}$ INCHES
 $L_2 = \underline{211.3}$ INCHES
 $\Delta L = \underline{.8}$ INCHES

PRESSURIZER TEMP (435)

$T_1 = \underline{548.1}$ °F ³⁸⁹
 $T_2 = \underline{558.8}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{47.6}$ INCHES
 $L_2 = \underline{45.8}$ INCHES
 $\Delta L = \underline{4.6}$ INCHES

MAKEUP TANK TEMP (CONTACT BOARD METER)

$T_1 = \underline{78}$ °F
 $T_2 = \underline{76}$ °F

$\Delta V_{RR} = \Delta L \times 2.515 = \underline{.8} \times 2.515 = \underline{2.01}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{4.6} \times 4.244 = \underline{19.52}$ FT³ RAF

$\Delta V_{TOTAL} = \underline{21.53}$ FT³
 17.51

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{1036 \times \underline{21.53}}{(78)} = \underline{285.175}$ FT³ @ P_1
 1.7

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{235.6}$ FT³ @ 875 PSIA

RC Pressure 1030
~~277~~
 RC TEMP 277.1
 PZR TEMP 359 550.
 RCP RUNNING 1A
 RC make up Tank 49.8
~~Level~~
 letdown to 0
 make up TK
 S/GA level 35
 S/GA press 30
 S/G B level 94
 S/G B press 24
 Cond Vac. 25
 Cont Temp 84-90
 Cont press -19

Cont Hr 2.370
 PZR level 201.8
 Bubble size 198.5 (11:00p)

Plant status.
 very fine

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/77
 TIME 0850/0929 ^{AM} _{PM}

DATA TAKEN BY:

TF

RC PRESSURE (398)

$P_1 = \underline{950}$ PSIG = 965 PSIA

$P_2 = \underline{\quad}$ PSIG = 1056 PSIA

$\Delta P = \underline{106}$ PSI

RCS TEMP (394)

$T_1 = \underline{279.9}$ °F

$T_2 = \underline{278.5}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.7}$ INCHES

$L_2 = \underline{202.9}$ INCHES

$\Delta L = \underline{+ 1.2}$ INCHES

PRESSURIZER TEMP (³⁸⁹805)

$T_1 = \underline{546.4}$ °F

$T_2 = \underline{558.1}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{47.9}$ INCHES

$L_2 = \underline{48.5}$ INCHES

$\Delta L = \underline{+ 0.6}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{75}$ °F

$T_2 = \underline{78}$ °F

$\Delta V_{PR} = \Delta L \cdot 2.515 = \underline{+ 1.2} \times 2.515 = \underline{3.02}$ FT³

$\Delta V_{MUT} = \Delta L \cdot 4.244 = \underline{+ 0.6} \times 4.244 = \underline{2.55}$ FT³

$\Delta V_{TOTAL} = \underline{5.57}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1056 \times 5.57)}{(106)} = \underline{55.49}$ FT³ @ P_1

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{60}$ FT³ @ 875 PSIA.

Start 0850
 Stop 0929

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 7:40

AM
PM

DATA TAKEN BY:

JL

RC PRESSURE (398)

$P_1 = \underline{958}$ PSIG = 973 PSIA

$P_2 = \underline{1048}$ PSIG = 1063 PSIA

$\Delta P = \underline{90}$ PSI

RCS TEMP (394)

$T_1 = \underline{278.4}$ °F

$T_2 = \underline{279.1}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.9}$ INCHES

$L_2 = \underline{202.5}$ INCHES

$\Delta L = \underline{-0.6}$ INCHES

PRESSURIZER TEMP (389)

$T_1 = \underline{548.5}$ °F

$T_2 = \underline{558}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{40.3}$ INCHES

$L_2 = \underline{53.1}$ INCHES

$\Delta L = \underline{1.2}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{72}$ °F

$T_2 = \underline{72}$ °F

$\Delta V_{PR} = \Delta L \times 2.515 = \underline{-0.6} \times 2.515 = \underline{1.51}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{1.2} \times 4.244 = \underline{5.09}$ FT³

$\Delta V_{TOTAL} = \underline{3.583}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1063 \times 3.583)}{(90)} = \underline{42.3}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{47.07}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 6:50

ASB
PM

DATA TAKEN BY: JR

RC PRESSURE (398)

$$P_1 = \frac{950}{2.57} \text{ PSIG} = \underline{369} \text{ PSIA}$$

$$P_2 = \underline{1048} \text{ PSIG} = \underline{1063} \text{ PSIA}$$

$$\Delta P = \underline{98} \text{ PSI}$$

RCS TEMP (394)

$$T_1 = \underline{277.8} \text{ } ^\circ\text{F}$$

$$T_2 = \underline{278.5} \text{ } ^\circ\text{F}$$

PRESSURIZER LEVEL (1682)

$$L_1 = \frac{201.7}{202.1} \text{ INCHES}$$

$$L_2 = \underline{202.9} \text{ INCHES}$$

$$\Delta L = \underline{-1.2} \text{ INCHES}$$

PRESSURIZER TEMP (389)

$$T_1 = \underline{546} \text{ } ^\circ\text{F}$$

$$T_2 = \underline{558.5} \text{ } ^\circ\text{F}$$

MAKEUP TANK LEVEL (347)

$$L_1 = \frac{36.49.8}{36.49.8} \text{ INCHES}$$

$$L_2 = \underline{46.1} \text{ INCHES}$$

$$\Delta L = \underline{3.7} \text{ INCHES}$$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$$T_1 = \underline{71} \text{ } ^\circ\text{F}$$

$$T_2 = \underline{71} \text{ } ^\circ\text{F}$$

$$\Delta V_{PR} = \Delta L \times 2.515 = \underline{1.2} \times 2.515 = \underline{-3.02} \text{ FT}^3$$

$$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{3.7} \times 4.244 = \underline{15.703} \text{ FT}^3$$

$$\Delta V_{TOTAL} = \underline{12.685} \text{ FT}^3$$

$$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1063 \times 12.685)}{(98)} = \underline{137.6} \text{ FT}^3 @ P_1$$

$$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{151.7} \text{ FT}^3 @ 875 \text{ PSIA}$$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 5:50

AM
PM

DATA TAKEN BY:

RC PRESSURE (398)

$P_1 = \underline{977} \text{ PSIG} = \underline{992} \text{ PSIA}$

$P_2 = \underline{1059} \text{ PSIG} = \underline{1074} \text{ PSIA}$

$\Delta P = \underline{92} \text{ PSI}$

RCS TEMP (394)

$T_1 = \underline{278.5} \text{ }^\circ\text{F}$

$T_2 = \underline{278.2} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{203.3} \text{ INCHES}$

$L_2 = \underline{201.6} \text{ INCHES}$

$\Delta L = \underline{1.7} \text{ INCHES}$

PRESSURIZER TEMP (389)

$T_1 = \underline{549.8} \text{ }^\circ\text{F}$

$T_2 = \underline{558.6} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{48.9} \text{ INCHES}$

$L_2 = \underline{46.4} \text{ INCHES}$

$\Delta L = \underline{2.5} \text{ INCHES}$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{72} \text{ }^\circ\text{F}$

$T_2 = \underline{75} \text{ }^\circ\text{F}$

$\Delta V_{PR} = \Delta L \cdot 2.515 = \underline{1.7} \times 2.515 = \underline{4.275} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{2.5} \times 4.244 = \underline{10.61} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{15.36} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1074 \times 15.36)}{(92)} = \underline{179} \text{ FT}^3 @ P_1$

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1(875)}{875} \right) = \underline{203.3} \text{ FT}^3 @ 875 \text{ PSIA}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79
 TIME 5:00 ^(AM) _{PM}

DATA TAKEN BY: JL

RC PRESSURE (398)

$P_1 = \underline{960}$ PSIG = 975 PSIA
 $P_2 = \underline{1060}$ PSIG = 1075 PSIA
 $\Delta P = \underline{100}$ PSI

RCS TEMP (394)

$T_1 = \underline{277.7}$ °F
 $T_2 = \underline{279.4}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{217.6}$ INCHES
 $L_2 = \underline{215.8}$ INCHES
 $\Delta L = \underline{1.8}$ INCHES

PRESSURIZER TEMP (389)

$T_1 = \underline{548.6}$ °F
 $T_2 = \underline{559.6}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{39.3}$ INCHES
 $L_2 = \underline{52.8}$ INCHES
 $\Delta L = \underline{1.5}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{73}$ °F
 $T_2 = \underline{75}$ °F

$\Delta V_{RC} = \Delta L \times 2.515 = \underline{1.8} \times 2.515 = \underline{4.527}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{1.5} \times 4.244 = \underline{6.366}$ FT³

$\Delta V_{TOTAL} = \underline{10.89}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1075 \times 10.89)}{(100)} = \underline{117}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{130.7}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 4:15 AM
PM

DATA TAKEN BY: JK

RC PRESSURE (398)

$P_1 = \underline{869} \text{ PSIG} = \underline{884} \text{ PSIA}$

$P_2 = \underline{1055} \text{ PSIG} = \underline{1070} \text{ PSIA}$

$\Delta P = \underline{186} \text{ PSI}$

RCS TEMP (394)

$T_1 = \underline{276.4} \text{ }^\circ\text{F}$

$T_2 = \underline{277.7} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{231.7} \text{ INCHES}$

$L_2 = \underline{223.8} \text{ INCHES}$

$\Delta L = \underline{7.9} \text{ INCHES}$

PRESSURIZER TEMP (389)
~~(405)~~

$T_1 = \underline{534.6} \text{ }^\circ\text{F}$

$T_2 = \underline{558.1} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{48.0} \text{ INCHES}$

$L_2 = \underline{42.4} \text{ INCHES}$

$\Delta L = \underline{5.6} \text{ INCHES}$

MAKEUP TANK TEMP (CONTACT BOARD METER)

$T_1 = \underline{77} \text{ }^\circ\text{F}$

$T_2 = \underline{74} \text{ }^\circ\text{F}$

$\Delta V_{RC} = \Delta L \times 2.515 = \underline{7.9} \times 2.515 = \underline{19.8} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{5.6} \times 4.244 = \underline{23.76} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{43.56} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1070 \times 43.56)}{(186)} = \underline{250.6} \text{ FT}^3 @ P_1$

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{253.2} \text{ FT}^3 @ 875 \text{ PSIA}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 3:15

AM
PM

DATA TAKEN BY:

92

RC PRESSURE (398)

$P_1 = \underline{956}$ PSIG = 971 PSIA

$P_2 = \underline{1025}$ PSIG = 1040 PSIA

$\Delta P = \underline{69}$ PSI

RCS TEMP (394)

$T_1 = \underline{275.6}$ °F

$T_2 = \underline{275.5}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.5}$ INCHES

$L_2 = \underline{202.5}$ INCHES

$\Delta L = \underline{1}$ INCHES

PRESSURIZER TEMP ³⁸⁹ ~~(405)~~

$T_1 = \underline{547.2}$ °F

$T_2 = \underline{554.7}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{54.4}$ INCHES

$L_2 = \underline{52.1}$ INCHES

$\Delta L = \underline{2.3}$ INCHES

MAKEUP TANK TEMP (CENTRAL BOARD METER)

$T_1 = \underline{70}$ °F

$T_2 = \underline{75}$ °F

$\Delta V_{-R} = \Delta L \times 2.515 = \underline{1} \times 2.515 = \underline{2.515}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{2.3} \times 4.244 = \underline{9.76}$ FT³

$\Delta V_{TOTAL} = \underline{12.27}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1040 \times 12.27)}{(69)} = \underline{185}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{205.3}$ FT³ @ 875 psia.

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 2.15 ESP
PM

DATA TAKEN BY: J

RC PRESSURE (398)

$P_1 = \underline{945} \text{ PSIG} = \underline{960} \text{ PSIA}$

$P_2 = \underline{1056} \text{ PSIG} = \underline{1073} \text{ PSIA}$

$\Delta P = \underline{113} \text{ PSI}$

RCS TEMP (394)

$T_1 = \underline{276.1} \text{ }^\circ\text{F}$

$T_2 = \underline{276.4} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{210.8} \text{ INCHES}$

$L_2 = \underline{201.6} \text{ INCHES}$

$\Delta L = \underline{9.2} \text{ INCHES}$

PRESSURIZER TEMP (³⁸⁹~~405~~)

$T_1 = \underline{546.6} \text{ }^\circ\text{F}$

$T_2 = \underline{558.7} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{47.0} \text{ INCHES}$

$L_2 = \underline{49.3} \text{ INCHES}$

$\Delta L = \underline{10.3} \text{ INCHES}$

MAKEUP TANK TEMP (CONTACT BOARD METER)

$T_1 = \underline{69} \text{ }^\circ\text{F}$

$T_2 = \underline{72} \text{ }^\circ\text{F}$

$\Delta V_{PR} = \Delta L \times 2.515 = \underline{9.2} \times 2.515 = \underline{23.1} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{10.3} \times 4.244 = \underline{43.7} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{20.6} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1056 \times 20.6)}{(113)} = \underline{192.6} \text{ FT}^3 @ P_1$

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{211.3} \text{ FT}^3 @ 875 \text{ PSIA}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/2/79

TIME 1:28 ^{AM} ~~PM~~

DATA TAKEN BY: JG

Done while venting

RC PRESSURE (398)

$P_1 = \underline{1056}$ PSIG = $\underline{1071}$ PSIA

$P_2 = \underline{971}$ PSIG = $\underline{986}$ PSIA

$\Delta P = \underline{85}$ PSI

RCS TEMP (394)

$T_1 = \underline{276.4}$ °F

$T_2 = \underline{275.7}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.6}$ INCHES

$L_2 = \underline{201.7}$ INCHES

$\Delta L = \underline{-0.1}$ INCHES

PRESSURIZER TEMP (³⁸⁹~~405~~)

$T_1 = \underline{558.7}$ °F

$T_2 = \underline{549.0}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{49.3}$ INCHES

$L_2 = \underline{40.2}$ INCHES

$\Delta L = \underline{9.1}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{72}$ °F

$T_2 = \underline{70}$ °F

$\Delta V_{RC} = \Delta L \cdot 2.515 = \underline{-0.1} \times 2.515 = \underline{-0.2515}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{9.1} \times 4.244 = \underline{38.6}$ FT³

$\Delta V_{TOTAL} = \underline{38.3}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(986 \times 38.3)}{(85)} = \underline{444.3}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{543}$ FT³ @ 875 PSIA.

Done while venting

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/1/79 / 4/2/79

TIME 0020 ^{AM}/_{PM}

DATA TAKEN BY: JK

RC PRESSURE (398) 968
 $P_1 = \underline{953}$ PSIG = ~~970~~ PSIA
 $P_2 = \underline{1018}$ PSIG = 1073 PSIA
 $\Delta P = \underline{105}$ PSI

RCS TEMP (394)
 $T_1 = \underline{270.5}$ °F
 $T_2 = \underline{276.6}$ °F

PRESSURIZER LEVEL (1682)
 $L_1 = \underline{220.0}$ INCHES
 $L_2 = \underline{217.5}$ INCHES
 $\Delta L = \underline{2.5}$ INCHES

PRESSURIZER TEMP (405)
 $T_1 = \underline{545.9}$ °F
 $T_2 = \underline{559.3}$ °F

MAKEUP TANK LEVEL (347)
 $L_1 = \underline{51.753}$ INCHES
 $L_2 = \underline{50.0}$ INCHES
 $\Delta L = \underline{3.0}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)
 $T_1 = \underline{72}$ °F
 $T_2 = \underline{70}$ °F

$$\Delta V_{RC} = \Delta L \times 2.515 = \underline{2.5} \times 2.515 = \underline{6.2875} \text{ FT}^3$$

$$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{3} \times 4.244 = \underline{12.732} \text{ FT}^3$$

$$\Delta V_{TOTAL} = \underline{19.0195} \text{ FT}^3$$

$$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1073 \times 19.0195)}{(105)} = \underline{194.36} \text{ FT}^3 @ P_1$$

$$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{215.01} \text{ FT}^3 @ 875 \text{ PSIA}$$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/11

TIME 10:55 AM
PM

DATA TAKEN BY: JR

RC PRESSURE (398)

$P_1 = \underline{945} \text{ PSIG} = \underline{960} \text{ PSIA}$

$P_2 = \underline{1045} \text{ PSIG} = \underline{1060} \text{ PSIA}$

$\Delta P = \underline{1000} \text{ PSI}$

RCS TEMP (394)

$T_1 = \underline{277.8} \text{ }^\circ\text{F}$

$T_2 = \underline{278.0} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.4} \text{ INCHES}$

$L_2 = \underline{201.7} \text{ INCHES}$

$\Delta L = \underline{.3} \text{ INCHES}$

PRESSURIZER TEMP (389)

$T_1 = \underline{505} \text{ }^\circ\text{F}$

$T_2 = \underline{557.3} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{53.6} \text{ INCHES}$

$L_2 = \underline{49.4} \text{ INCHES}$

$\Delta L = \underline{-4.2} \text{ INCHES}$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{78} \text{ }^\circ\text{F}$

$T_2 = \underline{76} \text{ }^\circ\text{F}$

$\Delta V_{OR} = \Delta L \times 2.515 = \underline{.3} \times 2.515 = \underline{.755} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{4.2} \times 4.244 = \underline{17.825} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{17.07} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1060 \times 17.07)}{(1000)} = \underline{180.942} \text{ FT}^3 @ P_1$

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{198.15} \text{ FT}^3 @ 875 \text{ PSIA}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/6/79 TIME 1910-2000 ^{AM} _{PM}

DATA TAKEN BY: JPM

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 954 ^{Avg} ~~954~~ PSIA
 $P_2 = \underline{\hspace{2cm}}$ PSIG = 1058 ^{Avg} PSIA
 $\Delta P = \underline{104}$ PSI

RCS TEMP (394)

$T_1 = \underline{278.2}$ °F
 $T_2 = \underline{278.8}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.7}$ INCHES
 $L_2 = \underline{201.0}$ INCHES
 $\Delta L = \underline{-0.7}$ INCHES

PRESSURIZER TEMP (485) ³⁸⁹

$T_1 = \underline{547}$ °F
 $T_2 = \underline{559.1}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{51.2}$ INCHES
 $L_2 = \underline{42.3}$ INCHES
 $\Delta L = \underline{-8.9}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{78.}$ °F
 $T_2 = \underline{75}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{-0.7} \times 2.515 = \underline{1.76}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{-8.9} \times 4.244 = \underline{37.77}$ FT³

$\Delta V_{TOTAL} = \underline{39.53}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1058 \times 39.53)}{(104)} = \underline{402}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{438}$ FT³ @ 875 PSIA

TMI-2 RCS BUBBLE CALC SHEET

DATE _____ TIME 1758-1847 AM PM

DATA TAKEN BY: _____

RC PRESSURE (398)

P₁ = _____ PSIG = 955 ^{PSIA}
 P₂ = _____ PSIG = 1053.6 ^{PSIA}
 ΔP = 98.6 PSI

RCS TEMP (394)

T₁ = 279.4 °F
 T₂ = 278.6 °F

PRESSURIZER LEVEL (1682)

L₁ = 201.3 INCHES
 L₂ = 201.3 INCHES
 ΔL = 0 INCHES

PRESSURIZER TEMP (389)

T₁ = 557.8 °F
 T₂ = 558.9 °F

MAKEUP TANK LEVEL (347)

L₁ = 47.1 INCHES
 L₂ = 42.6 INCHES
 ΔL = 4.5 INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

T₁ = 78 °F
 T₂ = 78 °F

ΔV_{PZR} = ΔL × 2.515 = 0 × 2.515 = 0 FT³
 ΔV_{MUT} = ΔL × 4.244 = 4.5 × 4.244 = 19.1 FT³
 ΔV_{TOTAL} = 19.1 FT³

$$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1053.6 \times 19.1)}{(98.6)} = \underline{204} \text{ FT}^3 @ P_1$$

$$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{222.73} \text{ FT}^3 @ 875 \text{ PSIA}$$

TIME-2 RCS BUBBLE CALC SHEET

DATE _____ TIME 1710 - 1800 AM PM

DATA TAKEN BY: _____

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 972 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1050 PSIA

$\Delta P = \underline{78}$ PSI

RCS TEMP (394)

$T_1 = \underline{280.1}$ °F

$T_2 = \underline{279.7}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.4}$ INCHES

$L_2 = \underline{201.2}$ INCHES

$\Delta L = \underline{-0.2}$ INCHES

PRESSURIZER TEMP (389 / 405)

$T_1 = \underline{548.1}$ °F

$T_2 = \underline{557.8}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{50.0}$ INCHES

$L_2 = \underline{40.1}$ INCHES

$\Delta L = \underline{-9.9}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{78.1}$ °F

$T_2 = \underline{78}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{0.2} \times 2.515 = \underline{0.503}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{9.9} \times 4.244 = \underline{42.02}$ FT³

$\Delta V_{TOTAL} = \underline{42.52}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1050 \times 42.52)}{(78)} = \underline{572.4}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{635}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 4-07-79 TIME 1645 ^{AM}/_{PM}

DATA TAKEN BY: _____

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 962 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1064 PSIA

$\Delta P = \underline{102}$ PSI

RCS TEMP (394)

$T_1 = \underline{280.7}$ °F

$T_2 = \underline{280.5}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.1}$ INCHES

$L_2 = \underline{201.1}$ INCHES

$\Delta L = \underline{0}$ INCHES

PRESSURIZER TEMP (405) ³⁸⁹

$T_1 = \underline{548.4}$ °F

$T_2 = \underline{558.6}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{45.6}$ INCHES

$L_2 = \underline{41.0}$ INCHES

$\Delta L = \underline{4.6}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{75}$ °F

$T_2 = \underline{78}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{0} \times 2.515 = \underline{0}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{4.6} \times 4.244 = \underline{19.52}$ FT³

$\Delta V_{TOTAL} = \underline{19.52}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1064 \times 19.52)}{(102)} = \underline{203.6}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{223.8}$ FT³ @ 875 psia.

TMI-2 RCS BUBBLE CALC SHEET

DATE 04-07-77 TIME 1510-1550 ^{AM} _{PM}

DATA TAKEN BY: JPM

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 955 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1065 PSIA

$\Delta P = \underline{110}$ PSI

RCS TEMP (394)

$T_1 = \underline{280.9}$ °F

$T_2 = \underline{281.3}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{216.8}$ INCHES

$L_2 = \underline{208.3}$ INCHES

$\Delta L = \underline{-8.5}$ INCHES

PRESSURIZER TEMP (³⁸⁹~~405~~)

$T_1 = \underline{545.9}$ °F

$T_2 = \underline{558.2}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{53.3}$ INCHES

$L_2 = \underline{50.6}$ INCHES

$\Delta L = \underline{-2.7}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{75^{\circ}F}$ °F

$T_2 = \underline{74^{\circ}F}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{8.5} \times 2.515 = \underline{21.38}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{2.7} \times 4.244 = \underline{11.46}$ FT³

$\Delta V_{TOTAL} = \underline{32.84}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1065 \times 32.84)}{(110)} = \underline{317}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{347}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 07-01-77 TIME 1456-1505 AM PM

DATA TAKEN BY: JM

RC PRESSURE (398)

$P_1 = \underline{1055} \text{ PSIG} = \underline{1055} \text{ PSIA}$

$P_2 = \underline{\quad} \text{ PSIG} = \underline{962} \text{ PSIA}$

$\Delta P = \underline{93} \text{ PSI}$ 456

RCS TEMP (394)

$T_1 = \underline{280.5} \text{ }^\circ\text{F}$

$T_2 = \underline{280.7} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.8} \text{ INCHES}$

$L_2 = \underline{210.5} \text{ INCHES}$
 $\frac{214.5}{215.2}$

$\Delta L = \underline{+8.7} \text{ INCHES}$

PRESSURIZER TEMP (405) 389

$T_1 = \underline{557.9} \text{ }^\circ\text{F}$

$T_2 = \underline{547.0} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{42.8} \text{ INCHES}$

$L_2 = \underline{42.3} \text{ INCHES}$

$\Delta L = \underline{-0.5} \text{ INCHES}$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{75} \text{ }^\circ\text{F}$

$T_2 = \underline{75} \text{ }^\circ\text{F}$

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{+8.7} \times 2.515 = \underline{+21.88} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{-0.5} \times 4.244 = \underline{-2.122} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{19.758} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(962 \times 19.758)}{(93)} = \underline{204} \text{ FT}^3 @ P_1$

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{224} \text{ FT}^3 @ 875 \text{ PSIA}$

NOTE: THIS DATA WAS TAKEN DURING A FAIRLY RAPID DEPRESSURIZATION

TMI-2 RCS BUBBLE CALC SHEET

DATE 7/1/79
TIME 1305-1355 AM PMDATA TAKEN BY: J MooreRC PRESSURE (398)

$$P_1 = \underline{\quad\quad} \text{ PSIG} = \underline{967} \text{ PSIA}$$

$$P_2 = \underline{\quad\quad} \text{ PSIG} = \underline{1040} \text{ PSIA}$$

$$\Delta P = \underline{73} \text{ PSI}$$

RCS TEMP (394)

$$T_1 = \underline{279.8} \text{ }^\circ\text{F}$$

$$T_2 = \underline{279.6} \text{ }^\circ\text{F}$$

PRESSURIZER LEVEL (1682)

$$L_1 = \underline{194.3} \text{ INCHES}$$

$$L_2 = \underline{195.6} \text{ INCHES}$$

$$\Delta L = \underline{+1.3} \text{ INCHES}$$

PRESSURIZER TEMP (405)

$$T_1 = \underline{547.3} \text{ }^\circ\text{F}$$

$$T_2 = \underline{558.5} \text{ }^\circ\text{F}$$

MAKEUP TANK LEVEL (347)

$$L_1 = \underline{53.2} \text{ INCHES}$$

$$L_2 = \underline{47.3} \text{ INCHES}$$

$$\Delta L = \underline{-5.9} \text{ INCHES}$$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$$T_1 = \underline{78.1} \text{ }^\circ\text{F}$$

$$T_2 = \underline{78} \text{ }^\circ\text{F}$$

$$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{+1.3} \times 2.515 = \underline{+3.27} \text{ FT}^3$$

$$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{-5.9} \times 4.244 = \underline{-25.04} \text{ FT}^3$$

$$\Delta V_{TOTAL} = \underline{-21.77} \text{ FT}^3$$

$$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1040 \times 21.77)}{(73)} = \underline{310} \text{ FT}^3 @ P_1$$

$$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{343} \text{ FT}^3 @ 875 \text{ PSIA}$$

NOTE: ADDED 400 gal Makeup After The above data was taken.

TMI-2 RCS BUBBLE CALC SHEET

DATE 7/11 TIME 1211/1238 AM PM

DATA TAKEN BY: Whoo

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 952 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1049 PSIA

$\Delta P = \underline{97}$ PSI

RCS TEMP (394)

$T_1 = \underline{279.8}$ °F

$T_2 = \underline{279.7}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{196.0}$ INCHES

$L_2 = \underline{192.9}$ INCHES

$\Delta L = \underline{-3.1}$ INCHES

PRESSURIZER TEMP ³⁸⁷ ~~(405)~~

$T_1 = \underline{545.7}$ °F

$T_2 = \underline{557.2}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{51.6}$ INCHES

$L_2 = \underline{43.7}$ INCHES

$\Delta L = \underline{-7.9}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{75.1}$ °F

$T_2 = \underline{77}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{3.1} \times 2.515 = \underline{7.8}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{7.9} \times 4.244 = \underline{33.53}$ FT³

$\Delta V_{TOTAL} = \underline{41.33}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1049 \times 41.33)}{(97)} = \underline{447}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{486}$ FT³ @ 875 psia.

Confining Cells on
41179 1238 DATA

W

$$\textcircled{1} \frac{1049}{952-1049} = -10.814$$

$$\textcircled{2} 3.174 \left[\frac{.0172}{.02199} (192.9) - \frac{.0172}{.02159} (196.0) \right] = -16.73$$

$$\textcircled{3} 4.128 \left(\frac{.0172}{.01606} \right) (-51.6 + 43.7) = -34.91$$

$$\textcircled{4} (6.166 \times 10^5) (9 \times 10^{-6}) (\bar{279.8} + 279.7) = -1.55$$

$$\textcircled{5} (6.166 \times 10^5) (-10^{-7}) (97) = -5.98$$

$$\textcircled{6} 6.166 \times 10^5 (5.839 \times 10^{-7}) (87) = 34.92$$

$$\textcircled{1} [2 + 3 - 4 - 5 + 6] =$$

$$-10.814 [-16.73 - 34.91 + 1.55] + [-5.98] + 34.92$$

110.45

TMI-2 RCS BUBBLE CALC SHEET

DATE 5/17/77 TIME 1044/1140 AM PM

DATA TAKEN BY: J. M. ...

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 956 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1056 PSIA

$\Delta P = \underline{100}$ PSI

RCS TEMP (394)

$T_1 = \underline{280}$ °F

$T_2 = \underline{279.8}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{196.8}$ INCHES

$L_2 = \underline{192.4}$ INCHES

$\Delta L = \underline{-4.4}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{546.2}$ °F

$T_2 = \underline{557.9}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{52.6}$ INCHES

$L_2 = \underline{42.4}$ INCHES

$\Delta L = \underline{-10.2}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{79}$ °F

$T_2 = \underline{77}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{-4.4} \times 2.515 = \underline{11.07}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{-10.2} \times 4.244 = \underline{43.29}$ FT³

$\Delta V_{TOTAL} = \underline{54.36}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1056 \times 54.36)}{(100)} = \underline{574}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{627}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 04/01/77 TIME 0946/1020 AM PM

DATA TAKEN BY: J Moore

RCS PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 953 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1056 PSIA

$\Delta P = \underline{103}$ PSI

RCS TEMP (394)

$T_1 = \underline{280.2}$ °F

$T_2 = \underline{281.2}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{196.5}$ INCHES

$L_2 = \underline{193}$ INCHES

$\Delta L = \underline{-3.5}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \overset{389}{\underline{545.3}}$ °F ~~557.9~~

$T_2 = \underline{557.9}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{53.4}$ INCHES

$L_2 = \underline{44.9}$ INCHES

$\Delta L = \underline{-8.5}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{78.1}$ °F

$T_2 = \underline{79}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{3.5} \times 2.515 = \underline{8.80}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{8.5} \times 4.244 = \underline{36.07}$ FT³

$\Delta V_{TOTAL} = \underline{44.87}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1056 \times 44.87)}{(103)} = \underline{460}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{501}$ FT³ @ 875 PSIA

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/1/74
 TIME 0925/0903 AM PM

DATA TAKEN BY: JAF

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 945 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1050 PSIA

$\Delta P = \underline{105}$ PSI

RCS TEMP (394)

$T_1 = \underline{280.5}$ °F

$T_2 = \underline{280.5}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.2}$ INCHES

$L_2 = \underline{192.6}$ INCHES

$\Delta L = \underline{8.6}$ INCHES

PRESSURIZER TEMP (403)

$T_1 = \underline{544.6}$ °F

$T_2 = \underline{557.1}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{50.7}$ INCHES

$L_2 = \underline{45.3}$ INCHES

$\Delta L = \underline{5.4}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{78}$ °F

$T_2 = \underline{75}$ °F

LANCASTER

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{8.6} \times 2.515 = \underline{21.63}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{5.4} \times 4.244 = \underline{22.92}$ FT³

$\Delta V_{TOTAL} = \underline{44.5}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1050 \times 44.5)}{(105)} = \underline{445.5}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \frac{534.6}{445.5} \text{ FT}^3 @ 875 \text{ PSIA}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/1/79
 TIME 0731 ^{AM} _{PM}

DATA TAKEN BY: RAF

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 971 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1055 PSIA

$\Delta P = \underline{84}$ PSI

RCS TEMP (394)

$T_1 = \underline{280.1}$ °F

$T_2 = \underline{280.1}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{196.0}$ INCHES

$L_2 = \underline{193.0}$ INCHES

$\Delta L = \underline{3.0}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{545.9}$ °F

$T_2 = \underline{557.7}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{49.1}$ INCHES

$L_2 = \underline{42.1}$ INCHES

$\Delta L = \underline{7.0}$ INCHES

MAKEUP TANK TEMP (CENTRAL BOARD METER)

$T_1 = \underline{73}$ °F

$T_2 = \underline{73}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{3.0} \times 2.515 = \underline{7.54}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{7.0} \times 4.244 = \underline{29.71}$ FT³

$\Delta V_{TOTAL} = \underline{37.25}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1055 \times 37.25)}{(84)} = \underline{467}$ FT³ @ P_1

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{564}$ FT³ @ 875 psia.

Repressurize Time = 23 min
 Start 0731 Stop 0754
 3.6 $\frac{mi}{min}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/11/77 TIME 0620 AM
PM

DATA TAKEN BY: JAT

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 960 PSIA
 $P_2 = \underline{\hspace{2cm}}$ PSIG = 1053 PSIA
 $\Delta P = \underline{93}$ PSI

RCS TEMP (394) 1088

$T_1 = \underline{280.6}$ °F
 $T_2 = \underline{\hspace{2cm}}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{200.6}$ INCHES
 $L_2 = \underline{192.7}$ INCHES
 $\Delta L = \underline{7.9}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{557.9}$ °F = 545.9
 $T_2 = \underline{557.9}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{46.1}$ INCHES
 $L_2 = \underline{39.1}$ INCHES
 $\Delta L = \underline{7.0}$ INCHES

MAKEUP TANK TEMP (CENTRAL BOARD METER)

$T_1 = \underline{72.0}$ °F = 5
 $T_2 = \underline{70.0}$ °F = 53

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{7.9} \times 2.515 = \underline{19.9}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{7.0} \times 4.244 = \underline{32.4}$ FT³

$\Delta V_{TOTAL} = \underline{52.144}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \frac{(1053 \times 52.14)}{(93)} = \underline{590}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{710}$ FT³ @ 875 PSIA.

944-4411

Repressurization Time
 Start 0620 Stop 0655 ⁵⁵_{min}
 2.67 $\frac{psi}{min}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 4.17.79

TIME ~~0415~~ 0425 ^{AM} PM

DATA TAKEN BY: ORF

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 957 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1055 PSIA

$\Delta P = \underline{98}$ PSI

RCS TEMP (394)

$T_1 = \underline{280}$ °F

$T_2 = \underline{279.4}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{195.1}$ INCHES

$L_2 = \underline{192.7}$ INCHES

$\Delta L = \underline{2.4}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{545.7}$ °F

$T_2 = \underline{557.9}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{53.3}$ INCHES

$L_2 = \underline{39.6}$ INCHES

$\Delta L = \underline{13.7}$ INCHES

MAKEUP TANK TEMP (CENTRAL BOARD METER)

$T_1 = \underline{72}$ °F

$T_2 = \underline{70}$ °F

$\Delta V_{PZR} = \Delta L \cdot 2.515 = \underline{2.4} \times 2.515 = \underline{6.04}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{13.7} \times 4.244 = \underline{58}$ FT³

$\Delta V_{TOTAL} = \underline{64.2}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1055 \times 64.2)}{(98)} = \underline{690.9}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{833.1}$ FT³ @ 875 PSIA.

S 0403

S 0425

Repressurization Time 22 min

Start 0403 Stop 0425

$\frac{\Delta P}{\text{min}} = \frac{98}{22 \text{ min}}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 9/11/77
 TIME 0321 AM
PM

DATA TAKEN BY: RAF

RC PRESSURE (398)

$P_1 = \underline{910}$ PSIG = 910 PSIA

$P_2 = \underline{\quad}$ PSIG = 1058 PSIA

$\Delta P = \underline{98}$ PSI

RCS TEMP (394)

$T_1 = \underline{279.9}$ °F

$T_2 = \underline{280.1}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{199.3}$ INCHES

$L_2 = \underline{192.3}$ INCHES

$\Delta L = \underline{7.0}$ INCHES

PRESSURIZER TEMP (389)

$T_1 = \underline{546.3}$ °F

$T_2 = \underline{558.4}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{47.5}$ INCHES

$L_2 = \underline{37.2}$ INCHES

$\Delta L = \underline{10.3}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{72}$ °F

$T_2 = \underline{\quad}$ °F

$\Delta V_{PZR} = \Delta L \cdot 2.515 = \underline{7.0} \times 2.515 = \underline{17.6}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{10.3} \times 4.244 = \underline{43.7}$ FT³

$\Delta V_{TOTAL} = \underline{61.3}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \left(\frac{1058 \times 61.3}{98} \right) = \underline{661.9}$ FT³ @ P_1

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{806.3}$ FT³ @ 875 PSIA.

S 0253

S 0321

Repressurization Time To min
 Start 0253
 Stop 0321
 ΔP/min

TMI-2 RCS BUBBLE CALC SHEET

DATE 4/11/71
 TIME 0200/0230 ^{AM} _{PM}
 DATA TAKEN BY: RAF

RC PRESSURE (398)

$P_1 = \underline{956} \text{ PSIG} = \underline{956} \text{ PSIA}$
 $P_2 = \underline{1050} \text{ PSIG} = \underline{1050} \text{ PSIA}$
 $\Delta P = \underline{94} \text{ PSI}$

RCS TEMP (394)

$T_1 = \underline{279.5} \text{ }^\circ\text{F}$
 $T_2 = \underline{279.3} \text{ }^\circ\text{F}$

PRESSURIZER LEVEL (1682)

$L_1 = \underline{196.2} \text{ INCHES}$
 $L_2 = \underline{192.2} \text{ INCHES}$
 $\Delta L = \underline{4.0} \text{ INCHES}$

PRESSURIZER TEMP (405)

$T_1 = \underline{545.6} \text{ }^\circ\text{F}$
 $T_2 = \underline{557.0} \text{ }^\circ\text{F}$

MAKEUP TANK LEVEL (347)

$L_1 = \underline{59.9} \text{ INCHES}$
 $L_2 = \underline{47.9} \text{ INCHES}$
 $\Delta L = \underline{12.0} \text{ INCHES}$

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{730} \text{ }^\circ\text{F}$
 $T_2 = \underline{750} \text{ }^\circ\text{F}$

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{4} \times 2.515 = \underline{10.1} \text{ FT}^3$

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{12} \times 4.244 = \underline{50.9} \text{ FT}^3$

$\Delta V_{TOTAL} = \underline{61.0} \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1050 \times 61.0)}{(94)} = \underline{681.7} \text{ FT}^3 @ P_1$

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{818.03} \text{ FT}^3 @ 875 \text{ PSIA}$

s/0205
 0225
 Repressurization Time 20 min
 Start 0205 Stop 0225
 $\frac{\Delta P}{\text{min}}$

TMI-2 RCS BUBBLE CALC SHEET

DATE 2/9/77

TIME 0104 AM PM

DATA TAKEN BY: JAF

1.00

RC PRESSURE (398)

$P_1 =$ _____ PSIG = 958 PSIA
 $P_2 =$ _____ PSIG = 1008 PSIA
 $\Delta P =$ 50 PSI

RCS TEMP (394)

$T_1 =$ 279.4 °F (X)
 $T_2 =$ _____ °F

PRESSURIZER LEVEL (1682)

$L_1 =$ 193 INCHES
 $L_2 =$ 191.9 INCHES
 $\Delta L =$ 1.1 INCHES

PRESSURIZER TEMP (405)

$T_1 =$ 546.1 °F (X)
 $T_2 =$ _____ °F

MAKEUP TANK LEVEL (347)

$L_1 =$ 41.8 INCHES
 $L_2 =$ 33.4 INCHES
 $\Delta L =$ 8.4 INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 =$ 78 °F
 $T_2 =$ _____ °F (X)

$\Delta V_{PZR} = \Delta L \cdot 2.515 = 1.1 \times 2.515 = 2.77 \text{ FT}^3$
 $\Delta V_{MUT} = \Delta L \cdot 4.244 = 8.4 \times 4.244 = 35.65 \text{ FT}^3$
 $\Delta V_{TOTAL} = 38.42 \text{ FT}^3$

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{1008 \times 38.42}{50} = 774.6 \text{ FT}^3 @ P_1$

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = 848.1 \text{ FT}^3 @ 875 \text{ PSIA}$ (X)

(X) Note: MUT refilled 10 test period out short (data not informed)

@ 33.4 1008 191.9

Re-pressurization Time	1:23
Add	458.465
	41.4
	1058
	197.3
	178.1

(X) (X)

TMI-2 RCS BUBBLE CALC SHEET

DATE 10/01
 TIME 2355 AM
 PM

DATA TAKEN BY: MSW

RC PRESSURE (398)

$P_1 =$ _____ PSIG = 958 PSIA
 $P_2 =$ _____ PSIG = 1057 PSIA
 $\Delta P =$ 99 PSI

RCS TEMP (394)

$T_1 =$ 278.4 °F
 $T_2 =$ 279.6 °F

PRESSURIZER LEVEL (1682)

$L_1 =$ 197.0 INCHES
 $L_2 =$ 142.6 INCHES
 $\Delta L =$ 50 INCHES

PRESSURIZER TEMP (405)

$T_1 =$ 546.5 °F
 $T_2 =$ 557.8 °F

MAKEUP TANK LEVEL (347)

$L_1 =$ 52.1 INCHES
 $L_2 =$ 40.6 INCHES
 $\Delta L =$ 11.5 INCHES

MAKEUP TANK TEMP (CENTRAL BOARD METER)

$T_1 =$ 81.1 °F
 $T_2 =$ 79 °F

$\Delta V_{PZR} = \Delta L \times 2.515 =$ 50 $\times 2.515 =$ 12.6 FT³

$\Delta V_{MUT} = \Delta L \times 4.244 =$ 11.5 $\times 4.244 =$ 48.8 FT³

$\Delta V_{TOTAL} =$ 61.38 FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1057 \times 61.38)}{(99)} =$ 655.34 FT³ @ P_1

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) =$ 655.34 717.13 FT³ @ 875 PSIA.

2358
0018

2353 Re-pressurization
 0018 $T_{in} + 25 \Delta$
 54 + 2353
 564 0018
 1

TMI-2 RCS BUBBLE CALC SHEET

DATE 5/01 TIME 2245 ^{AM} _{PM}

DATA TAKEN BY: PSW

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 955 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1050 PSIA

$\Delta P = \underline{95}$ PSI

RCS TEMP (394)

$T_1 = \underline{277.6}$ °F

$T_2 = \underline{277.1}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{196.4}$ INCHES

$L_2 = \underline{192.4}$ INCHES

$\Delta L = \underline{4.0}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{545.6}$ °F

$T_2 = \underline{556.9}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{50.1}$ INCHES

$L_2 = \underline{35.0}$ INCHES

$\Delta L = \underline{15.1}$ INCHES

MAKEUP TANK TEMP (CONTACT BOARD METER)

$T_1 = \underline{81.1}$ °F

$T_2 = \underline{81}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{4.0} \times 2.515 = \underline{10.06}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{15.1} \times 4.244 = \underline{64.08}$ FT³

$\Delta V_{TOTAL} = \underline{74.14}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1050 \times 74.14)}{(95)} = \underline{819.4}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{894.4}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 07/01 TIME 2139 AM
PM

DATA TAKEN BY: BSL

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 955 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1046 PSIA

$\Delta P = \underline{91}$ PSI

RCS TEMP (394)

$T_1 = \underline{278.2}$ °F

$T_2 = \underline{277.7}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{196.0}$ INCHES

$L_2 = \underline{192.2}$ INCHES

$\Delta L = \underline{3.8}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{545.6}$ °F

$T_2 = \underline{556.6}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{49.5}$ INCHES

$L_2 = \underline{33.0}$ INCHES

$\Delta L = \underline{16.5}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{81.1}$ °F

$T_2 = \underline{81}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{3.8} \times 2.515 = \underline{9.56}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{16.5} \times 4.244 = \underline{70.03}$ FT³

$\Delta V_{TOTAL} = \underline{79.6}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1046 \times 79.6)}{(91)} = \underline{914.8}$ FT³ @ P_1

$V_1(875) = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{998.5}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 5/51 TIME 2030 AM PM

DATA TAKEN BY: PSL

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 953 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1053 PSIA

$\Delta P = \underline{100}$ PSI

RCS TEMP (394)

$T_1 = \underline{228.7}$ °F

$T_2 = \underline{228.3}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{193.9}$ INCHES

$L_2 = \underline{191.0}$ INCHES

$\Delta L = \underline{2.9}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{545.6}$ °F

$T_2 = \underline{557.4}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{48.4}$ INCHES

$L_2 = \underline{34.4}$ INCHES

$\Delta L = \underline{14.0}$ INCHES

MAKEUP TANK TEMP (CONTRACT 130420 METER)

$T_1 = \underline{81}$ °F

$T_2 = \underline{81}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{2.9} \times 2.515 = \underline{7.29}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{14.0} \times 4.244 = \underline{59.42}$ FT³

$\Delta V_{TOTAL} = \underline{66.7}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1053 \times 66.7)}{(100)} = \underline{702.5}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{765.1}$ FT³ @ 875 psia.

TMI-2 RCS BUBBLE CALC SHEET

DATE 5/31
 TIME 1925 AM
 PM

DATA TAKEN BY: PSW

RC PRESSURE (398)

$P_1 =$ _____ PSIG = 966 PSIA
 $P_2 =$ _____ PSIG = 1049 PSIA
 $\Delta P =$ 83 PSI

RCS TEMP (394)

$T_1 =$ 278.3 °F
 $T_2 =$ 278.3 °F

PRESSURIZER LEVEL (1682)

$L_1 =$ 205.2 INCHES
 $L_2 =$ 191.0 INCHES
 $\Delta L =$ 14.2 INCHES

PRESSURIZER TEMP (405)

$T_1 =$ 547.1 °F
 $T_2 =$ 556.8 °F

MAKEUP TANK LEVEL (347)

$L_1 =$ 41.8 INCHES
 $L_2 =$ 35.0 INCHES
 $\Delta L =$ 6.8 INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 =$ 82 °F
 $T_2 =$ 82 °F

$\Delta V_{PZR} = \Delta L \cdot 2.515 = 14.2 \times 2.515 = 35.713$
 ~~$= 29.85$ FT³~~

$\Delta V_{MUT} = \Delta L \times 4.244 = 6.8 \times 4.244 = 28.85$ FT³

$\Delta V_{TOTAL} = 64.57$
 ~~$= 57.71$ FT³~~

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{1049 \times 64.57}{83} = 816.1$
 ~~$= 729.5$ FT³ @ P_1~~

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = 805.3$ FT³ @ 875 PSIA

TMI-2 RCS BUBBLE CALC SHEET

DATE 5/31

TIME 1735 AM PM

DATA TAKEN BY: PSW

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 946 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1046 PSIA

$\Delta P = \underline{100}$ PSI

RCS TEMP (394)

$T_1 = \underline{279.4}$ °F

$T_2 = \underline{279.1}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{201.0}$ INCHES

$L_2 = \underline{191.6}$ INCHES

$\Delta L = \underline{9.4}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{545.0}$ °F

$T_2 = \underline{556.7}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{46.9}$ INCHES

$L_2 = \underline{37.0}$ INCHES

$\Delta L = \underline{9.9}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{81.0}$ °F

$T_2 = \underline{81}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{9.4} \times 2.515 = \underline{23.64}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{9.9} \times 4.244 = \underline{42.0}$ FT³

$\Delta V_{TOTAL} = \underline{65.64}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1046)(65.64)}{(100)} = \underline{686.6}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{742.3}$ FT³ @ 875 PSIA.

TMI-2 RCS BUBBLE CALC SHEET

DATE 5/31

TIME 1619 AM PM

DATA TAKEN BY: PSL

Checked JPM 3/31/79

RC PRESSURE (398)

$P_1 = \underline{\hspace{2cm}}$ PSIG = 949 PSIA

$P_2 = \underline{\hspace{2cm}}$ PSIG = 1046 PSIA

$\Delta P = \underline{97}$ PSI

RCS TEMP (394)

$T_1 = \underline{279.3}$ °F

$T_2 = \underline{279.2}$ °F

PRESSURIZER LEVEL (1682)

$L_1 = \underline{197.3}$ INCHES

$L_2 = \underline{191.7}$ INCHES

$\Delta L = \underline{5.6}$ INCHES

PRESSURIZER TEMP (405)

$T_1 = \underline{544.9}$ °F

$T_2 = \underline{556.7}$ °F

MAKEUP TANK LEVEL (347)

$L_1 = \underline{42.2}$ INCHES

$L_2 = \underline{33.0}$ INCHES

$\Delta L = \underline{9.2}$ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

$T_1 = \underline{\hspace{2cm}}$ °F

$T_2 = \underline{\hspace{2cm}}$ °F

$\Delta V_{PZR} = \Delta L \times 2.515 = \underline{5.6} \times 2.515 = \underline{14.08}$ FT³

$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{9.2} \times 4.244 = \underline{39.04}$ FT³

$\Delta V_{TOTAL} = \underline{53.13}$ FT³

$V_1 = \frac{P_2 \Delta V_{TOT}}{P_2 - P_1} = \frac{(1046 \times 53.13)}{(97)} = \underline{572.9}$ FT³ @ P_1

$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{621.4}$ FT³ @ 875 psia.

2000

1900

1800

1700

1600

1500

1400

1300

1200

1100

1000

900

800

700

600

500

400

300

200

100

GAS BUBBLE VOLUME - FT³ @ 875 PSIA



0600 0600 1200 1800

3/29/79

0600 1200 1800

3/30/79

0600 1200 1800

3/31/79


0600 1200 1800

4/1/79

6 12 18

RCS Gas Bubble

2390



Volume
ft³
converted
to
875 psia

16 Meisupic
conversion

3/31

point 347

Time	Pressure		Level		Temp		Flow	
	Pen Pen	Pen	Pen	MD Tank	ACS	Pen	Letdown	Seal
1907								
1907	1005	216.0	56		279.9	551.4	—	19
1909	1005	216.0	56		279.9	551.4	—	19
1911	1005	215.7	54		279.7	551.4	—	19
1913	1006	215.8	54		279.4	551.4	—	19
2017	1029	215.0	47"		279.5 279.4	554.5	—	17
2020	1031	215.4	46"		279.4	555.1	—	19
2029	1043	215.8	44"		279.4	556.5	—	19
2030	1043	214.0	43.5"		279.4	556.5	—	19
2031	1042	214.5	43.5		279.4	556.4	—	19
	1017			before				
	1070	215.6	44.5		281.2 279.4	553.7		

3/31/79

0630

JPM
3/31/79

	P_{gr}	MU
L1	215.8 Not Recorded!	41.8
L	233.1	41.0
L2	+ 17.3"	$\Delta = -0.8"$

$$\begin{aligned}
 P_1 &= 1038 \\
 P_2 &= 983 \\
 \Delta P &= 55 \text{ psi}
 \end{aligned}
 \left. \vphantom{\begin{aligned} P_1 \\ P_2 \\ \Delta P \end{aligned}} \right\} \text{assumed to be } P_{gr} \text{ } \textit{JPM}$$

$$\Delta V_{pgr} = +(17.3)(2.515) = 43.51 \text{ ft}^3$$

$$\Delta V_{mv} = -(0.8)(4.244) = 3.4 \text{ ft}^3$$

NOTE

Original Calc ~~was~~ used difference between these volumes, indicating that one ~~volume~~ volume increased and the other decreased - Can't be confirmed since data wasn't recorded.

OK - See Raw Data *JPM*

$$\Delta V_{total} = 43.51 - 3.4 = 40.11 \text{ ft}^3$$

$$V_1 = \frac{(983)(40.11)}{55} = 716.9 \text{ ft}^3 @ 1038 \text{ psi}$$

$$V_1 = (716.9) \left(\frac{1038}{875} \right) = 850 \text{ ft}^3 @ 875 \text{ psi}$$

$$P_1 =$$

$$\frac{1038 \text{ psia}}{983 \text{ psia}}$$

$$T_1 = 280.4$$

$$\frac{6630}{3/31}$$

$$P_2 =$$

$$P_1 V_1 = P_2 V_2$$



$$= P_2 (V_1 + \Delta V)$$

$$.8 \text{ in} \times 4 \text{ ft}^3$$

$$3.2 \text{ cuft}$$

MWT

$$17.3 \text{ in} \times 32 \text{ ft}$$

$$55.1 \text{ cuft}$$

$$55 - 3.2 = 51.9 \text{ ft}^3$$

$$\frac{1038}{(55)}$$

$$528 \text{ cuft}$$

$$= \Delta V \frac{1}{T} = 977 \text{ cuft}$$

$$526 \text{ cuft}$$

Comp

$$\frac{1038}{875}$$

$$977 = 1098.3 \text{ cuft} @ 875 \text{ psia}$$

Questions from Cronberger

1. The Recombiner when will it be ready
2. The Concentration & Activity in ^{20R} Gas Decay Tank
3. ^{Decay Tank} Gas line disch. filter ~~is~~ is plugged dirt or activity can someone get close to it?
4. Portable Rad. Monitors for Rad waste gas tanks

Tag Nos.
 HP-R-223 Spent Fuel Area Elev. 347'-6"
 -224 Aux. Bldg. 280'-6"

2303 03 0630
3/31

				1025	1032
394	RCS T	280.4	280.3	280.3	279.7 279.5
1612	Raz CC	215.8	233.1	232.5	190.7 187.0
0389	Press T	554.2	547.1	547.1	549.9 550.8
SA100	m/c level	41.8	41.0	41.2	m. 39.1 39.0
398	RCS R	1025	967.	968	988 975
	m/c TK +	78°	77°	77	77 79

3/31/79

1032/1039

JPM
3/31/79

<u>P_{gr}</u>	<u>MU</u>	<u>P_{res}</u>
L ₁ = 187.0	39.0	P ₁ = 995 psi
<u>L₂ = 201.9</u>	<u>39.0</u>	<u>P₂ = 948 psi</u> } assumed to be psi @ gm
ΔL = +14.9"	ΔL = 0	ΔP = 47 psi

$$\Delta V = +(14.9)(2.515) = 37.4 \times 735 \text{ ft}^3$$

$$V_1 = \frac{(948)(37.4 \times 735)}{(47)} = 755.85 \text{ ft}^3 @ 995 \text{ psi}$$

$$V_2 = (755.85) \left(\frac{995}{875} \right) = 859.5 \text{ ft}^3 @ 875 \text{ psi}$$

RCS Bubble Calculation 3/31/79

Time	Level		Pressure		Temp		
	Pen	MUT	Pen	RCS	Pen	MUT	
1032	187.0	39.0	995	279.8	550.8	79	
1039	201.9	39.0	948	280.2	544.5	80	
	ΔL 14.9'	0	47 psi				

$$\Delta V = 14.9' \times 3.2 \text{ ft}^{3/4} = 47.68 \text{ ft}^3$$

$$V_1 = \frac{P_2 \Delta V}{\Delta P} = \frac{948 (47.68)}{47} = 961.7 @ 995 \text{ psi}$$

$$V_1 = 961.7 \times \frac{995}{875} = 1093.6 \text{ psi} @ 875$$

See Revised Calcula
3/31/79 Jmm

3/31/79
1351

RCS Bubble Calc

3/31/79

1351

P. Walsh

	L_{per}	P_{acs}	T_{acs}	F_{per}	L_{mut}
1351	197.4	954	279.7	539.6	45.9
1352	196.2	961	279.8	534.6	45.9
1425	190.8	1046	280.0	539.6	33.1
	6.6	92			12.8

Correction to RCS time

$$\Delta V_{per} = 6.6 \times 3.2 \frac{ft^3}{in} = 21.1$$

$$\frac{.0175}{.022} = 16.6 \frac{ft^3}{in}$$

$$\Delta V_{mut} = 12.8 \times 4 \frac{ft^3}{in} = 51.2$$

$$\frac{.0175}{.0163} = 54.3 \frac{ft^3}{in}$$

$$\Delta V_{total} = 70.94 \text{ ft}^3$$

$$\Delta P = 92 \text{ psi}$$

$$V_1 = \frac{P_2 \Delta V}{\Delta P} = \frac{1046 (70.94)}{92} = 806.6 \text{ ft}^3 \text{ @ } 954$$

$$V_1 = 806.6 \left(\frac{954}{875} \right) = 879.4 \text{ ft}^3$$

$$\Delta V_{per} = -(6.6)(2.515) = -16.6$$

$$\Delta V_{mut} = -(12.8)(4.244) = -54.3$$

$$\Delta V_{Total} = -70.9$$

check on

$$V_1 = \frac{(1046)(70.9)}{92} = 806.6$$

About 1300 3/29/79 Per J. Floyd.

3/31/79
JFM

$$\begin{aligned} P_{gr} \\ L_1 &= 373 \\ L_2 &= 325 \\ \Delta L &= -48'' \end{aligned}$$

$$\begin{aligned} \text{MUTK} \\ L_1 &= 52'' \\ L_2 &= 38'' \\ \Delta L &= 14'' \end{aligned}$$

$$\begin{aligned} P_1 &= 875 \text{ psia} \\ P_2 &= 970 \text{ psia} \\ \Delta P &= 95 \text{ psi} \end{aligned}$$

$$\Delta L_{Pgr} = -48''$$

$$\Delta L_{MU} = -14''$$

$$\Delta V_{Pgr} = (-48) \left(\frac{2.515}{4.244} \right) = -28.072$$

$$\Delta V_{MU} = (-14) (4.244) = -59.414$$

$$\Delta V_{TOT} = \frac{-28.072 - 59.414}{180.136} = -71.488$$

$$V_i = \frac{P_2 \Delta V}{P_1 - P_2} = \frac{(970) \left(\frac{180.136}{-71.488} \right)}{95} = \frac{1839.3}{95} \text{ ft}^3$$

RC System
Size of Pressurizer Gas Bubble
Outside the Pressurizer

(T=0.311) 3/30/79
 J. Moore

Temp was about 280°F
 at this time per Jim Alford.

Data taken about
 14 hrs ago

$$L_1 = 373''$$

$$L_2 = 325''$$

$$\Delta L = 48''$$

$$P_1 = 860 \text{ psig} = 875 \text{ psia}$$

$$P_2 = 955 \text{ psig} = 970 \text{ psia}$$

$$\Delta P = 95 \text{ psi}$$

T_{crit} ~ 1300
 3/29/79

Pressurizer Capacitance = 3.2 ft³/in.

$$P_1 V_1 = P_2 V_2$$

$$V_2 = V_1 + \Delta V$$

$$\Delta V = 48 \times 3.2 = 153.6$$

$$P_1 V_1 = P_2 (V_1 + \Delta V)$$

$$P_1 V_1 = P_2 V_1 + P_2 \Delta V$$

$$V_1 (P_1 - P_2) = P_2 \Delta V$$

$$V_1 = \frac{P_2 \Delta V}{P_1 - P_2}$$

$$\Delta V_{\text{pen}} = 153.6 \text{ ft}^3$$

$$\Delta V_{\text{mutual}} = 56 \text{ ft}^3 \times 1.35$$

$$= 75.6 \text{ ft}^3$$

$$\text{Total } \Delta V = 229.2$$

See Revised Calc
 dated 3/30/79 J.M.

$$V_1 = \frac{229.2 \times 970}{95} = 2340.3 \text{ ft}^3$$

}

See Next

Volume of head = 800 ft³ per B&W

RV diameter = 14 ft.

The MU Tank level dropped during this time period

3/30/79
JPM

MU Tank Δ Volume

L_1 52"
 L_2 38"
 $\Delta L = 14"$

$$\frac{\Delta V}{\Delta L} = 30 \text{ gal/inch}$$

$$14 \times 30 = \frac{420 \text{ gal}}{7.481 \frac{\text{gal}}{\text{ft}^3}} = 56 \text{ ft}^3$$

$$V_1 = 1568 \text{ ft}^3 + 56 \text{ ft}^3 = 1624 \text{ ft}^3$$

Total Volume Above RV Nozzles = 5855 ft³

Rec'd from B&W
0325 3/30/79

RV outlet plenum	158
" upper "	411
" " Head	560
<hr/>	
	1129 ft ³

Doesn't include CROM volume

This includes total volume of RV head, RL loops, Pressurizer etc above the Rtr Coolant Loops.

RC Bubble Size Calcs

Data Taken: 0625/3-30-79
J. Moore

$$L_1 = 356.2''$$

$$P_1 = 1065 \text{ psig} = 1080 \text{ psia}$$

$$L_2 = 352.3''$$

$$P_2 = 1081 \text{ psig} = 1096 \text{ psia}$$

$$\Delta L = -3.9''$$

$$\Delta P = 16 \text{ psi}$$

$$V_1 = \frac{P_2 \Delta V}{P_1 - P_2}$$

$$\Delta V = 3.2 \frac{\text{ft}^3}{\text{in}} \times 3.9 \text{ in} = 12.48 \text{ ft}^3$$

$$V_1 = \frac{(1096)(12.48)}{16} = 854.88 \text{ ft}^3 @ 1080 \text{ psia}$$

$$= 854.88 \times \frac{1080}{875} = 1055 \text{ ft}^3 @ 875 \text{ psia}$$

Note: 3/31/79

3/31/79
J. Moore
I believe that there was little or no change in the MU Tank Level during these measurements. \therefore

The calc below is based on zero MU Tank Level Change.

$$\Delta V = (2.48) (2.515)$$

$$\Delta V = -\frac{3.9}{10} (2.515) = -9.8 \text{ ft}^3$$

$$V_1 = \frac{(1096)(9.8)}{16} = 671.3 \text{ ft}^3 @ 1080 \text{ psia}$$

$$V_1 = 671.3 \left(\frac{1080}{875} \right) = 828.576 \text{ ft}^3 @ 875 \text{ psia}$$

03/30/79

0730 AM

gdm
3/31/79

<u>P_{gr}</u>	<u>MUTU</u>
L ₁ = 360	?
<u>L₂ = 390</u>	_____
ΔL = +30"	

P ₁ = 1150	} assumed to the p _{gr} gdm
<u>P₂ = 1035</u>	
ΔP = 115	

$$\Delta V_{pgr} = \pi(30^2)(2.515) = 75.45 \text{ ft}^3$$

$$V_1 = \frac{(1035)(75.45)}{115} = 679.1 \text{ ft}^3 @ 1150 \text{ psia}$$

$$V_1 = \left(\frac{1150}{875}\right)(679.1) = 892.5 \text{ ft}^3 @ 875 \text{ psia}$$

0730 AM
3/30/79

RGS Bubble Calculation

From recordings on control panel

360

1050

7:30 am 3/30

390

1025

$$\Delta L = 30'' \quad \Delta P = 115$$

$$\Delta V = 30'' \times \frac{3.2}{3.9} \frac{96}{1.4} = 117 \text{ ft}^3$$

$$V_1 = \frac{P_2 \Delta V}{P_1 - P_2}$$

$$V = \frac{1035 \text{ (ft}^3\text{)} \times 96}{115}$$

$$V_1 = \frac{864}{1053} \text{ ft}^3 @ 1150 \text{ psia}$$

$$V_1 = \frac{864}{875} \times 1150 = 1156 \text{ ft}^3$$

@ 87.5 psia

8/30/79

1240/1340

$$\Delta L_{PZR} = -22.1''$$

$$\Delta V_{PZR} = \cancel{(-22.1)}(-22.1)(2.515) = -55.58 \text{ ft}^3$$

$$\Delta L_{MU} = +15''$$

$$\Delta V_{MU} = (+15)(4.244) = +63.66$$

$$\Delta V_{TOT} = 8.08 \text{ ft}^3$$

$$V_1 = \frac{(1018)(8.08)}{32} = 257. \text{ ft}^3 @ 1050$$

$$V_1 = (257) \left(\frac{1050}{875} \right) = 308 \text{ ft}^3 @ 875$$

RCS Bubble calculation

3/30/79

Time	Per LVL		WR Press Loop A		Temp Loop B Comp	M _w - 80°F Tank
	Co-10	Recount	Recorder	Computer		
1240	250.5	224	1100	1050	280.3	40"
1340	229.4	228	1065	1018	279.5	55
	22.1	88	35	32		15"

MV Tank Volume Change

$$15'' \times 30 \text{ gal/in} = 450 \text{ gal}$$

$$48'' \text{ dia} = 40 \text{ ft}^3 @ 80^\circ\text{F} \times \frac{.022}{.0163} = 80.98 \text{ ft}^3 \text{ at } 550^\circ\text{K}$$

Change in per volume =

$$\frac{22.1}{28''} \times 3.2$$

$$3.2 \text{ ft}^3/\text{in} = 107.2 \text{ ft}^3 @ 555^\circ\text{K}$$

Increase in vol due to bubble expansion =

$$-\Delta V_{\text{per}} + \Delta V_{\text{MV tank}} = 107.2 - 80.0 = 27.2 \text{ ft}^3$$

$$V_1 = \frac{P_2 \Delta V}{P_1 - P_2} = \frac{(1018) (27.2)}{32} = 828.9 \text{ ft}^3 @ 1050$$

$$V_1 = 828.9 \text{ ft}^3 \left(\frac{1050}{875} \right) = 1000 \text{ ft}^3 @ \text{time } 1240$$

See
flashed
calculator
3/31/79
JPM

Butstale Cales

~~3/31/79~~
3/31/79

3/30/74 1445/1510

$$\Delta L PZR = +2''$$

$$\Delta V_{pZR} = (2)(3.2 \frac{ft^3}{in}) \left(\frac{0.0173}{0.022} \right) = (6.4)(0.786) = +5.0 ft^3$$

$$\Delta L MUTK = -8''$$

$$\Delta V_{mu} = -(8)(4 \frac{ft^3}{in}) \left(\frac{0.0173}{0.0163} \right) = -(32)(1.061) = -33.96 ft^3$$
$$\Delta V = -28.96 ft^3$$

$$V_1 = \frac{P_2 \Delta V}{P_2 - P_1} = \frac{(1053)(28.96)}{42} = 726 ft^3 @ 1011 psia$$

$$V_1 = (726) \left(\frac{1011}{875} \right) = 839 ft^3 @ 875 psia$$

RCs Bubble Calc

3/30/79

	L _{RC}		P _{RC}		T	MU
	C	R	C	R	P _{RC} Loop B	Tank
1445	214.5	215	1011	1050	552.3	278.7 4.7" → 37
1510	216.5	215	1053	1100	557.9	221.2 50" ← 230"
	+ 2"		42 psi			ΔL = 8" 452 gal added ↓ 15"

ΔV_{RC} = 2 × 3.2 ft³/in × 3.2 = 7.8 ft³

* V_f @ 280°F = 0.0173 = RC Temp.

ΔV_{MU Tank} = 8" × 4 ft³/in = 32 ft³ × (0.0173 / 0.0163) = 33.96 ft³

ΔV_{Total} = 33.96 - 7.8 = 26.16 ft³

~~V₁ = (P₂ ΔV) / (P₂ - P₁) = (1053 (27.56)) / (42 psi) = 691.0 ft³ at 1053~~

See Revised Calc 3/31/79 gpm

V₁ = (9.275) (1011 / 875) = 1068 ft³ at 875 at time 1445

* ΔWater volume in MU Tank is interchanged with RC loop water rather than pressurizer level.

Therefore the ratio is (0.0188 / 0.0163) rather than (0.022 / 0.0163)

where V_f @ 285°F = 0.0173
V_f @ 1100 psi Sat = 0.022

gpm 3/31/79

3/30/79

1630/1735

3/31/79
JPM

$$\Delta L_{Pgr} = +0.2''$$

$$\Delta V_{Pgr} = + (0.2)(2.515) = +0.503 \text{ ft}^3$$

$$\Delta L_{mu} = -1.3''$$

$$\Delta V_{mu} = (-1.3)(4.244) = -5.517 \text{ ft}^3$$

$$\Delta V_{TOT} = 5.0142 \text{ ft}^3$$

$$V_1 = \frac{(1033)(5.0142)}{17} = 304.7 \text{ @ } 1050$$

$$V_1 = 304.7 \left(\frac{1050}{875} \right) = 365.6 \text{ ft}^3$$

RCS Bubble Calc

	L Pen		P Pen		T		MV Tank Level
	C	R	C	R	Pen	RCS Level	
1630	215.8	215	1050	1100	552.2	281.0	50"
1735	214.0	215	1058	1080	554.6	280.4	48.7"
	.2"		17 psi				57.5 -1.3"

$$P_{\text{one}} \Delta V = .2" \times 3.9 \text{ ft}^3/\text{in} = 28 \text{ ft}^3$$

$$MV \Delta V = 1.3" \times 48 \text{ ft}^3/\text{in} = 5.2 \text{ ft}^3 \times \left(\frac{1.025}{1.0167} \right)^{1.35} = 7.0 \text{ ft}^3$$

$$V_{\text{total}} \Delta V = 7.0 \text{ ft}^3 - 6.36$$

$$V_1 = \frac{P_2 \Delta V}{\Delta P} = \frac{1033 (7.0 \text{ ft}^3)}{17 \text{ psi}} = 426.5 @ 1050 \text{ ft}^3$$

$$V_2 = 426.5 \times \frac{1050}{875} = 511.8 \text{ ft}^3 @ 875$$

See Revised Calc 3/31/79 Jm

3/30/79

1745/1910

~~2017~~
3/31/79

$$\Delta L_{pr} = +0.2''$$

$$\Delta V_{pr} = +0.2)(3.2)(0.786) = +0.2(2.515) = 0.503 \text{ ft}^3$$

$$\Delta L_{mu} = +1''$$

$$\Delta V_{mu} = (+1)(4)(1.061) = (+1)(4.244) = 4.244 \text{ ft}^3$$

$$\Delta V = 4.747 \text{ ft}^3$$

$$V_1 = \frac{(1005)(4.747)}{25} = 190.82 \text{ ft}^3 @ 1030 \text{ psu}$$

$$V_1 = (190.82)\left(\frac{1030}{875}\right) = 224.63 \text{ ft}^3 @ 875$$

RCS Bubble Calc

3/30/79

	<u>L_{pen}</u>	<u>P_{pen}</u>	<u>T</u>	<u>L_{MU Tank}</u>
	<u>Comp</u>	<u>Comp</u>	<u>P_{en} RCS</u>	
1745	215.8	1030	554.3 280.3	55"
1910	216.0	1005	551.4 279.9	56"
	+ 12"	25 psi	.4°	+ 1"

~~$\Delta Vol_{pen} = .12" \times 3.2 \text{ ft}^3/in = .64 \text{ ft}^3$~~

~~$\Delta Vol_{MU} = 1" \times 4 \text{ ft}^3/in = 4 \text{ ft}^3 \times 1.35 = 5.4 \text{ ft}^3$~~

~~Total $\Delta Vol = 6.04 \text{ ft}^3$~~

~~$V_1 = \frac{P_2 \Delta V}{\Delta P} = \frac{1005 (6.04)}{25} = 242.8 \text{ ft}^3 @ 1030 \text{ psi}$~~

~~$V_1 = 242.8 \left(\frac{1030}{875} \right) = 327.8 \text{ ft}^3 @ 875$~~

See Revised
Calc
3/31/79
JPM

3/30/79

1907/2030

John
3/31/79

$$\Delta L P_{3r} = 0$$

$$\Delta V P_{3r} = 0$$

$$\Delta L M_{u1} = 13.5''$$

$$\Delta V_{M_{u1}} = (13.5)(\cancel{4.244}) = 57.294 \text{ ft}^3$$

$$\Delta V_{TOT} = 57.294$$

$$V_1 = \frac{(1043)(57.294)}{38} = 1572.5 @ 1005$$

$$V_1 = \frac{(1005)(1572.5)}{(875)} = 1804 @ 875$$

RCS Bubble Calc

3/30/79

	<u>L_{PZR}</u>	<u>L_{MU}</u>	<u>P_{PZR}</u>	<u>T</u>	
				<u>RCS</u>	<u>PZR</u>
1907	216.0	56"	100.5	279.9	551.4
2030	216.0	43.5"	104.3	279.4	556.5
	0	13.5"	38 psi		

$$\Delta Vol = 13.5'' \times 4 \text{ ft}^3/\text{in} = 54 \times 1.35 = 72.9 \text{ ft}^3$$

$$V_i = \frac{104.3 (72.9)}{38} = 2000.9 \text{ ft}^3 \text{ @ } 100.5 \text{ psi} = 2258 \text{ ft}^3 \text{ @ } 87.5 \text{ psi}$$

See Revised Calc
3/31/79 JPM

TMI-2 RCS BUBBLE CALC SHEET

DATE _____

TIME _____ AM
PM

DATA TAKEN BY: _____

RC PRESSURE (398)

P₁ = _____ PSIG = _____ PSIA

P₂ = _____ PSIG = _____ PSIA

ΔP = _____ PSI

RCS TEMP (394)

T₁ = _____ °F

T₂ = _____ °F

PRESSURIZER LEVEL (1682)

L₁ = _____ INCHES

L₂ = _____ INCHES

ΔL = _____ INCHES

PRESSURIZER TEMP (405)

T₁ = _____ °F

T₂ = _____ °F

MAKEUP TANK LEVEL (347)

L₁ = _____ INCHES

L₂ = _____ INCHES

ΔL = _____ INCHES

MAKEUP TANK TEMP (CONTROL BOARD METER)

T₁ = _____ °F

T₂ = _____ °F

$$\Delta V_{ER} = \Delta L \times 2.515 = \underline{\hspace{2cm}} \times 2.515 = \underline{\hspace{2cm}} \text{ FT}^3$$

$$\Delta V_{MUT} = \Delta L \times 4.244 = \underline{\hspace{2cm}} \times 4.244 = \underline{\hspace{2cm}} \text{ FT}^3$$

$$\Delta V_{TOTAL} = \underline{\hspace{2cm}} \text{ FT}^3$$

$$V_1 = \frac{P_2 \Delta V_{TOTAL}}{P_2 - P_1} = \left(\frac{\hspace{2cm}}{\hspace{2cm}} \right) = \underline{\hspace{2cm}} \text{ FT}^3 @ P_1$$

$$V_{1(875)} = (V_1 \text{ at } P_1) \left(\frac{P_1}{875} \right) = \underline{\hspace{2cm}} \text{ FT}^3 @ 875 \text{ psia.}$$

Ft3 @ 875 - ~~poia~~

DP

3/29 ^{E/R} 50.71 1300

1839.3 95 DATA FROM J. FLOYD - SOURCES UNKNOWN

3/30 6.06 0625

* 828.6 16 MU TK_A LEVEL - BELIEVED TO BE ZERO IN.

± 0.84 0730

892.5 115

± 1.8276 1240

* 308 32

± 1.948 1445

839 42

± 7.715 1630

* 365.6 17

1745

* 224.6 25

1907

* 1806.0 38

3/31

~~0630~~

850 55

1032

859.5 47

1351

879.4 92

1619

621.4 97

± 351

901

1925

2030

765

3/31/79

(1)

ERROR ANALYSIS FOR BUBBLE VOLUME CASES

$$P_1 V_1 = P_2 V_2$$

$$V_2 = V_1 + \Delta V$$

$$P_1 V_1 = P_2 (V_1 + \Delta V)$$

~~$$P_1 V_1 = P_2 V_1$$~~

$$P_1 V_1 = P_2 V_1 + P_2 \Delta V$$

$$V_1 (P_1 - P_2) = P_2 \Delta V$$

$$V_1 = \frac{P_2 \Delta V}{P_1 - P_2} = \frac{P_2 \Delta V}{\Delta P}$$

$V_1 = \frac{P_2 \left[\rho (h_A - h_B) \right]}{P_1 - P_2}$			
$V_A =$ PRESSURIZER LEVEL	Computer Point	1682	0-400"
$V_B =$ MAKEUP TANK LEVEL	"	347	0-100"
$P =$ RC PRESSURE	"	398	0-2500 psig

Per Jim Floyd
3/31/79

Range Accuracy
1% FS
~1% FS
1% FS

$$r = 2.515$$

$$\Delta = 4.244$$

JPM
3/31/79

ASSUME ERROR OF INST'S = 1% OF RANGE.

VARIABLE	RANGE	ESTIMATED UNCERTAINTY
P	3000 2500	$E_p = E_{R1} = 30 \quad 25$
L _A	600 IN 400	$E_{LA} = 4$
L _B	100 IN	$E_{LB} = 1$ ✓

$\alpha = 2.515$

$b = 4.244$

$R_1 = \frac{P_1}{R_1} (P_1 - P_2)$

~~$R_5 = \frac{R_2 + R_3}{R_1}$~~

$R_2 = \alpha(L_2 - L_1)_a$

$R_4 = P_2$

$R_3 = b(L_2 - L_1)_b$

$R_5 = [R_2 + R_3]$

$R_6 = \frac{R_4 R_5}{R_1}$

~~$(E_{R1})_1$~~

~~$$(E_{R1})_1 = \pm \left[(rR) \frac{E_p}{R} + (bR) \frac{E_p}{R} \right]$$

$$= \pm [rE_p + bE_p] = \pm [E_p (r+b)]$$

$$= \pm [2rE_p]$$~~

$(E_{R1})_2 = \pm \left[(P) \left(\frac{E_p}{P} \right) + P \left(\frac{E_p}{P} \right) \right] = \pm [2E_p]$

~~E_{R2}~~

$$E_{R2} = \pm \left[(\alpha L_A) \left(\frac{E_{LA}}{L_A} \right) + (\alpha L_A) \left(\frac{E_{LA}}{L_A} \right) \right]$$

$$= \pm [2\alpha E_{LA}]$$

$$E_{R3} = \pm [2b E_{L3}]$$

$$E_{R4} = P \left(\frac{F_p}{R} \right) = E_p$$

$$E_{R5} = \pm [E_{R2} + E_{R3}]$$

$$\frac{E_{R6}}{R_6} = \pm \left[\frac{E_{R4}}{R_4} + \frac{E_{R5}}{R_5} + \frac{E_{R1}}{R_1} \right]$$

$$ER_1 = \pm [2E_p] = \pm [2 \times \frac{25}{36}] = \pm [\frac{50}{36}]$$

$$ER_2 = \pm [2a E_{LA}] = \pm [(2 \times 2.515)(4)] = \pm [\frac{20.12}{36.18}]$$

$$ER_3 = \pm [2b E_{LB}] = \pm [(2)(4.244)(1)] = \pm [8.488]$$

$$ER_4 = \pm [E_p] = \pm [\frac{25}{36}]$$

$$ER_5 = \pm [ER_2 + ER_3] = \pm [\frac{20.12}{36.18} + 8.488] = \cancel{38.668} \quad 28.608$$

$$\frac{ER_6}{R_6} = \pm \left[\frac{ER_4}{R_4} + \frac{ER_5}{R_5} + \frac{ER_1}{R_1} \right]$$

$$R_4 = P_2$$

$$R_5 = [R_2 + R_3] = [a(L_2 - L_1)_A + b(L_2 - L_1)_B] \\ = [2.515(\Delta L)_A + (4.244)(\Delta L)_B]$$

$$R_1 = (P_1 - P_2)$$

$$\frac{ER_6}{R_6} = \pm \left[\frac{25}{36} \frac{1}{P_2} + \frac{28.608}{2.515(\Delta L)_A + 4.244(\Delta L)_B} + \frac{50}{36} \frac{1}{(P_1 - P_2)} \right]$$

3/31/79
ISSI Data

$$\frac{ER_6}{R_6} = \pm \left[\frac{25}{961} + \frac{28.608}{\underbrace{(2.515)(6.6) + (4.244)(12.8)}_{70.922}} + \frac{50}{92} \right]$$

$$\frac{ER_6}{R_6} = \pm \left[\left(\frac{2.60 \times 10^{-2}}{\cancel{2.12 \times 10^{-2}}} \right) + \left(\frac{0.4034}{\cancel{0.5452}} \right) + \left(\frac{0.543}{\cancel{0.652}} \right) \right]$$

$$\frac{ER_6}{R_6} = \pm \cancel{1.2286} \pm 0.973$$

ERROR ANALYSIS

$$\frac{ER_6}{R_6} = \pm \left[\frac{25}{P_2} + \frac{28.608}{\underbrace{2.515(\Delta I_A) + 4.244(\Delta I_B)}_{\Delta V_{TOT}}} + \frac{50}{(P_1 - P_2)} \right]$$

$$\underline{3/29/79 - 1300}$$

$$\begin{aligned} \frac{ER_6}{R_6} &= \pm \left[\frac{25}{970} + \frac{28.608}{(2.515)(48) + (4.244)(14)} + \frac{50}{95} \right] \\ &= \pm \left[(0.02577) + (0.1588) + (0.526) \right] \\ &= \pm [0.7105] \end{aligned}$$

$$\underline{3/30/79 - 0625}$$

$$\begin{aligned} \frac{ER_6}{R_6} &= \pm \left[\frac{25}{1096} + \frac{28.608}{(2.515)(3.9) + 0} + \frac{50}{16} \right] \\ &= \pm \left[0.0228 + \frac{2.9166}{\cancel{2.9166}} + 3.125 \right] \\ &= \pm 6.06 \end{aligned}$$

$$\underline{3/30/79 - 0730}$$

$$\begin{aligned} \frac{ER_6}{R_6} &= \pm \left[\frac{25}{1035} + \frac{28.608}{(2.515)(30) + 0} + \frac{50}{115} \right] \\ &= \pm \left[0.0242 + 0.379 + 0.435 \right] \\ &= \pm 0.84 \end{aligned}$$

3/30/79 - 1240

$$\begin{aligned}\frac{E_{R6}}{R_6} &= \pm \left[\frac{25}{1018} + \frac{28.608}{(2.515)(22.1) + (4.244)(15)} + \frac{50}{32} \right] \\ &= \pm [0.0246 + 0.240 + 1.563] \\ &= \pm 1.8276\end{aligned}$$

3/30/79 - 1445

$$\begin{aligned}\frac{E_{R6}}{R_6} &= \pm \left[\frac{25}{1053} + \frac{28.608}{(2.515)(2) + (4.244)(8)} + \frac{50}{42} \right] \\ &= \pm [0.0237 + 0.7338 + 1.1905] \\ &= \pm 1.948\end{aligned}$$

3/30/79 - 1630

$$\begin{aligned}\frac{E_{R6}}{R_6} &= \pm \left[\frac{25}{1080} + \frac{28.608}{(2.515)(0.2) + (4.244)(1.3)} + \frac{50}{17} \right] \\ &= \pm [0.0231 + 4.752 + 2.94] \\ &= \pm 7.715\end{aligned}$$

4/1/79 1211/238

$$\frac{E_R}{R} = \pm \left[\frac{25}{1049} + \frac{28.608}{41.33} + \frac{50}{97} \right] = \pm [0.0238 + 0.692 + 0.515]$$
$$= \pm [1.23]$$

4/1/79 1044/1140

$$\frac{E_R}{R} = \pm \left[\frac{25}{1056} + \frac{28.608}{54.36} + \frac{50}{100} \right] = \pm [0.0237 + 0.526 + 0.5]$$
$$= \pm [1.076]$$

4/1/79 0946/1020

$$\frac{E_R}{R} = \pm \left[\frac{25}{1056} + \frac{28.608}{44.87} + \frac{50}{103} \right] = \pm [0.0237 + 0.638 + 0.485]$$
$$= \pm [1.147]$$

4/1/79 0825/0903

$$\frac{E_R}{R} = \pm \left[\frac{25}{1050} + \frac{28.608}{44.5} + \frac{50}{105} \right] = \pm [0.0238 + 0.643 + 0.476]$$
$$= \pm 1.143$$

~~4/1/79 - 6731~~

~~(Stat)~~

$$\frac{E_R}{R} = \pm \left[\frac{25}{1055} + \frac{28.608}{37.25} + \frac{50}{84} \right] = \pm [0.0237 + 0.768 + 0.595]$$
$$= \pm 1.387$$

TO: Jack Devine.

4/4/79.

05:00

From: Jim Henrie,

(509-942-7811 x 509)

Home 509-976-2192

(number 967)

Subject: Work Summary.

Left Richland Wa., Sat., 3/31, 10:00

Arrived Harrisburg AP. Sun., 4/1, 11:00

1. Assigned by Dieckamp to recombinee problems

Advised in installation, checkout, safety & ^{review of start-up procedures} reliability considerations, start-up,

op. analysis, stability analysis, recommended corrections to improve stability. (Fig 1, 2, 3 & 4).

Hydrogen analysis, error correlation, (Fig 5).

Analysis of H₂ removal from containment, ^(Fig 6) without consideration of H₂ generation.

Recommended operation of single recombinee.



2. Made gross evaluation of apparent hydrogen burn on 3/28/79 at 13:50 (Fig 7)

This is crude. Includes many assumptions and lacks good corrections for initial (unknown to me) conditions.

3. Worked on procedures and safety of transferring hydrogen from WDGT-1B. See Fig 8, Fig 9 (checklist), and Procedure Z-2,

Sorry no more time, Good luck, J. Henrie

Recombined Control. D.Henry



~ 12:00


Minutes

4/13/79

Fig 1

Recombiner Control

J. Henin



02:45

4/4/79

Fig 2

Recombined Control
J. Henin

1355
1350
1345
1340

1130
1125
1120
1115
1110
1105
1100
1095
1090

03:41 42 43

45

47

49

51

53

55

57

59

Minutes.

03:44

4/14/79

$$\frac{240^\circ}{125} = \underline{\underline{1.92\% \text{ Hz}}}$$

↑ 4°
↓

Control
at 1350

15°
↑
↓

Fig 3

Recombined Control.
J. Herin

1355
1350
1345
1340

$$\frac{1348}{1105} = 245$$

$$\frac{243}{125} = \underline{\underline{1.944\% H_2}}$$

1130
1125
1120
1115
1110
1105
1100
1095
1090
1085


0635 37 39 41 43 45 47 49 51 53

06:35

4/4/79.

Minutes.

FIG 4.



J. Henry

Date	Time	H ₂	O ₂	N ₂	
Sat. 3/31	0700	1.7	16.5	81.8	100%
	1500	1.9	21.2	76.9	100%
	0600	2.4			*
Sun 4/1	0845	2.4	18.1	79.5	100%*
	1000	2.0			
Mon. 4/1	1200	2.2	19	78.8	100%
	1330	2.0			
	1500	2.0	19.0	78.8	99.8
	1830	2.0	19.0	78.8	99.8
	2330	2.3	18.9	78.9	100.1*
4/2	6:00	2.4	17.6	79.9	99.9*
	10:30	2.1	18.4	79.5	100.0
4/3	22:35	2.0	18.6	81.	101.0

* Sampling all from same spot.

- Same procedure, under water, 1500 to 1800.
- Prior procedure could have leaked in air.
- Results computed and just.

* Same operator.

~~Activity of contaminant atmosphere dropped by a factor of 3 at surface of 6.50 sample.~~

Fig 5.

944 4041

Unit 2 Control Room

Dick Dubiel
w/yr of chemists

J. Miller

Hydrogen concentration 2.1%.

Cont. Volume 2,000,000 FT³. X 2.1% = 42,000 FT³ H₂

Recombiner flow 9.0 SCFM.

90 X 60 X 24 = 130,000 FT³/day. X 2.1% = 2,722 FT³ H₂/day

Start	End	H ₂ (start)	Recom	H ₂ (end)	%
15:45, 4/2/79					
First day	4/5	42.0%	2.7	39.3	1.96
Second day	4/4	39.3	2.5	36.8	1.84
Third day	4/5	36.8	2.4	34.4	1.72
Fourth "	4/6	34.4	2.2	32.2	1.61
	4/7	32.2	2.1	30.1	1.50
	4/8	30.1	1.9	28.2	1.41
	4/9	28.2	1.8	26.4	1.32
	4/10	26.4	1.7	24.7	1.24
	4/11	24.7	1.6	22.1	1.10
	4/12	22.1	1.4	20.7	1.04
	4/13	20.7	1.3	19.4	0.97

Assume No Net H₂ input to containment

Fig 6.

Gary Miller
 Joe Logan, Plant Superintendent
 Jack Hesbire V.P. Generation
 Kreitz
 Dreckamp.

J. Allen

Analysis of hydrogen burn which appears to have occurred at about 13:50 on 3/28/79, Wednesday, about 9.8 hrs after start of incident.

Initial Conditions, Prior to burn, Pressure = 16 PSIA.

Humidity: Unknown. Temp: unknown.

Pressure spike increased to 426 PSIA in < 1 minute,
 reduced to 17.8 PSIA in ~ 10 minutes,
 13.8 PSIA in 4 1/2 hours.

Correlation of the 27 PSI spike with a 33.3 PSI spike observed in tests (A1-73-29, fig 12, attached).

The hydrogen concentration was about $16 \times \frac{27}{55.3} = 13\%$.

Subsequent oxygen analysis showing ~18% O₂

suggests that less than 13% H₂ burned. Assume 10% H₂.

Inventories were about as follows:

Reasonable correlation. 10% H₂ at time of burn appears to be reasonable.

	H ₂	O ₂	N ₂
O ₂ = .21 x 2 x 10 ⁶ x $\frac{530}{575}$ =		386,400	
N ₂ = .79 x 2 x 10 ⁶ x .92 =			1,454,000
H ₂ , metal/water reaction, 10% =	500,000		
Burn of H ₂ , 90% eff. =	-180,000	-90,000	
Radialysis, first week. =	+20,000	+10,000	
Air Inleakage*, first week =	40,000	1,800	2,900
Total Inventory	40,000	307,200	1,456,900
% of total. (1,804,000) =	2.2%	17.0%	80.8%

Analysis of gas, 4/3, 22:35 = 2.0% 18.0% 81%

Pressure: $\frac{1,809,000}{2,100,000} \times \frac{460+96}{460+70} \times 14.7 = 13.6 \text{ PSIA.}$ Measured 13.4 PSIA.

* based on .2%/day, 56 PSI ΔP, corrected to 1 PSI ΔP.

Q = .2% x 2 x 10⁶ x $\sqrt{\frac{1}{52} \times 55}$ x 7 days = 3,200 FT³ x .21 = 800; x .79 = 2,900.

Fig 7.

J. J. Henin
4/4/79

Gas in WDG T-1B.

Volume 1937 FT³
Pressure 86 PSIG.
Temperature 100°F.

$$\text{Volume} = 1937 \times \frac{86 + 14.7}{14.7} \times \frac{460 + 70}{460 + 100} = 12,605 \text{ SCF.}$$

Reducing to 15 PSIG, Subtract 3,874

Net transfer $\frac{8.7}{2,000} = \underline{.44\% \text{ Hz.}}$ = 8,731 SCF

Max rate of 3 PSI/HR, $\frac{3}{100} \times 12,605 / \text{HR} = 378 \text{ SCF/HR}$

$\frac{378}{60} = \underline{6.3 \text{ SCFM.}}$ $Q = \pi \frac{D^2}{4} V$
= .0497

Velocity = $\frac{Q}{A} = \frac{6 \text{ FT}^3/\text{min} \times 144 \text{ in}^2}{.0497 \text{ in}^2 \times 117} \times \frac{1 \text{ min}}{60 \text{ sec}} = 115 \text{ ft/sec}$

Flowrate $6 \frac{1}{2}$ #/min, 31 SCFM.

$31 \text{ SCFM} \times 60 \text{ min/HR} = \frac{1,860 \text{ SCFH} \times 100 \text{ PSIA} = 14.7 \text{ PSI/HR.}}$
 $\frac{1,860 \text{ SCFH}}{12,605 \text{ SCF}} = \underline{.147 \text{ PSI/HR.}}$
4.9 x rate max.

$\frac{31 \text{ CFM} \times .6 \text{ Hz}}{6,000 \text{ CFM total}} = \underline{.3\% \text{ increase.}}$

Location of exhaust line = 295'6"
227°38" Zero = South.

Needle Valve is 1/2 needle, Velan, 150#, 200#.

Need turns open to limit flow to 6.3 SCFM. Fig 8.

1. Temp of Tank, 100 to 200°F. too hot to vent,

2. Calc gas.

3. Flow rate, 50', 1/2" tubing,

4. Calculate Pressure drop rate 3 PSI/hr, can do it only by using the shutoff valve.

5. Exit detail. - No 1/2" nipple.

6. Assess failure modes.

- operator errors - Dumps H₂, alarms, Close Valve
- Equipment - Has been tested at 125% of max. measured, walk to see if OK.

7. Consider Recombined Running.

8. Check N₂ Source & Pressure.

9. Check for equipment near R571c Pen.

10. Valve position to limit flow to 4 to 8 SCFH.

11. Check Compressor logic. leave on 16 pump to low pressure

12. Consider Flame arrestor. - Talk to Chemists

13. Consider He charge total. .44% Fig 9

AP 1001
Figure 1001-8

Three Mile Island Nuclear Station
Special Operating Procedure

SIDE 1
SOP No. Z-2
(From SOP Log Index)

Unit No. 2
Date 4-4-79

NOTE: Instructions and guidelines in AP 1001 must be followed when completing this form.

1. Title DISCHARGE OF WDG-T-1B TO REACTOR BLDG.

2. Purpose (include purpose of SOP)
TO DISCHARGE WDG-T-1B TO REACTOR BLDG

3. Attach procedure to this form written according to the following format.

A. Limitations and Precautions

- 1. Nuclear Safety
- 2. Environmental Safety
- 3. Personnel Safety
- 4. Equipment Protection

SEE ATTACHED

B. Prerequisites

C. Procedure

4. Generated by Julien Abramowicz / Jim Heerie Date 4-4-79

5. Duration of SOP - Shall be no longer than 90 days from the effective date of the SOP or (a) or (b) below - whichever occurs first.

(a) SOP will be cancelled by incorporation into existing or new permanent procedure submitted by _____

(b) SOP is not valid after _____
(fill in circumstances which will result in SOP being cancelled)

6. (a) Is the procedure Nuclear Safety Related?

If "yes", complete Nuclear Safety Evaluation. (Side 2 of this Form) Yes No

(b) Does the procedure affect Environmental Protection?

If "yes", complete Environmental Evaluation. (Side 2 of this Form) Yes No

(c) Does the procedure affect radiation exposure to personnel? Yes No

NOTE: If all answers are "no", the change may be approved by the Shift Supervisor. If any questions are answered "yes", the change must be approved by the Unit Superintendent.

7. Review and Approval

Approved - Shift Supervisor _____ Date _____

Reviewed - List members of PORC contacted _____ Date _____

_____ Date _____

_____ Date _____

Approved - Unit Superintendent _____ Date _____

_____ Date _____

a. SOP is Cancelled

Shift Supervisor/Shift Foremen

Date

SPECIAL OPERATION PROCEDURE

TMI-2 NUCLEAR STATION

DISCHARGE OF WGD-T-1B TO REACTOR BUILDING

1.0 CONDITIONS

1.1 PRIMARY SYSTEM

- a) PRIMARY PRESSURE BETWEEN 1000 AND 1050 PSIG.
- b) PRESSURIZER LEVEL BETWEEN 175 AND 210 IN. H₂O
- c) PRIMARY PRESSURE/TEMPERATURE CONTROL USING PRESSURIZER HEATERS AND SPRAY.
- d) ONE R.C. PUMP OPERATING.

1.2 SECONDARY SYSTEM

- a) CONDENSER VACUUM BETWEEN 5 AND 29 IN. HG.
- b) ONE OTSG STEAMING TO CONDENSER.

1.3 REACTOR BUILDING (R.B.)

- a) R. B. TEMPERATURE BETWEEN 50 AND 125°F.
- b) R. B. HYDROGEN CONCENTRATIONS LESS THAN 4%.

2.0 PRECAUTIONS

2.1 DO NOT ALLOW THE WGD-T-1B PRESSURE TO DECREASE AT A RATE GREATER THAN 3 PSI | HR.

2.2 DO NOT ALLOW THE WGD-T-1B PRESSURE TO DECREASE BELOW 15 PSIG.

2.3 A FLAME ARRESTER HAS BEEN INSTALLED TO PREVENT FLAME PROPAGATION.

2.4 THE SYSTEM IS GROUNDED.

3.0 PROCEDURE

3.1 VERIFY TEMPORARY VALVES V1 AND V2 ARE CLOSED

3.2 HAVE CONTROL ROOM DEFEAT RMS INTERLOCKS ~~Wdg R-1485~~ USING KEYLOCK SWITCHES FOR WDG-R-1485, WDG-R-1486 AND HP-R-219. -

3.3 VERIFY WDG-V-32 IS CLOSED.

3.4 VERIFY WDG-V-33 IS CLOSED.

3.5 VERIFY WDG-V-170 IS CLOSED.

3.6 VERIFY WDG-V-24 IS CLOSED.

3.7 VERIFY WDG-V-142A AND V-143A ARE CLOSED.

3.8 VERIFY WDG-V-30A IS CLOSED.

3.9 VERIFY WDG-V-143B IS OPEN.

3.10 VERIFY WDG-V-54B IS OPEN.

3.11 VERIFY WDG-V-188B IS CLOSED.

3.12 VERIFY T-V20 ~~AND T-V19~~ ^{IS} CLOSED.

3.13 VERIFY ~~Wdg V-7~~ ~~AND V-6~~ OPEN AND V-6 CLOSED

3.14 VERIFY WDG-V-30B IS CLOSED AT RADWASTE PANEL.

3.15 CLOSE SHUT WDG-V-26B AT RADWASTE PANEL ^{TO ISOLATE COMPRESSOR}

3.16 VERIFY WDG-V-142B IS CLOSED

3.17 OPEN BS-V-149.

3.18 OPEN WDG-V-30B FROM RADWASTE PANEL


3.19 OPEN WDG-V-188B BY TURNING 1/2 TURN OR AS NECESSARY TO ACHIEVE LESS THAN 3PSI PER HOUR DECREASE IN WASTE GAS DECAY TANK PRESSURE AT THE RADWASTE PANEL.

- 3.20 WHEN THE WASTE GAS DECAY TANK (WTG-T-1B) REACHES 15PSIG SECURE DISCHARGING BY CLOSING WDG-V-30B AT RADWASTE PANEL.
- 3.21 CLOSE WDG-V-188B.
- 3.22 CLOSE WDG-V-54B.
- 3.23 CLOSE BS-V-149.
- 3.34 CLOSE WDG-V-143B
- 3.35 ~~WDG-V-143B~~ OPEN WDG-V-20B.

NOTES 1) ALL VALVES UNLESS OTHERWISE NOTED ARE WDG.

2) ALL VALVES OTHER THAN VALVES THAT ARE CYCLED SHOULD BE "DANGER" TAGGED.

3) VALVES THAT ARE INSTALLED AS PART OF THE TEMPORARY RIG SHOULD BE BRASS TAGGED.



Ed Fubrock
Est.

← Jim Floyd → C.R.

Stations Daily Log Sheet.

	1050	- 85	4/3/79 Jim WG Decay Tank Pressure
	0700	- 87	
↑	0525	- 86	
	0100	- 87	
	0000	- 87	

In think tank

24
60
1440


MEMO from:
G. P. MILLER

WASTE GAS DECAY TANK

<u>1A</u>			<u>1B</u>		
<u>DATE</u>	<u>TIME</u>	<u>P. T.</u>	<u>DATE</u>	<u>TIME</u>	<u>P. T.</u>
3/30	2400		3/30	2400	
3/31	2400 2320	84	3/31	2400 2320	84
4/1	2400 0100	86	4/1	2400 0100	86
4/2	1200	87	4/2	1200	86

FIRST
READING
AF R
ACCIDENT

944-0415, 0423, 367-0318, 6868

MEMO from: 

G. P. MILLER,

~~Franklyn~~

~~Franklyn~~

Waste gas decay tank.

²⁰³ call Dennis Brown at

1250 ~~0415~~

MEMO from:

CECILIA KORCHNAK

~~Franklyn~~

Waste Gas Decay Tank

- ① First Reading after accident
(PRESS)
- ② 3/30/79 2400 hr
- ③ 3/31/79 2400 hr
- ④ 4/1/79 2400 hr
- ⑤ 4/2/79 1200 hr

~~For~~ FOR BOTH TANKS

PLUS TEMP.

Marshall
Bills →

AUX. OPERATOR
LOGS.

WDG

T

1A

85PSIG

1B

85PSIG

MEMO from:
G. P. MILLER

file # 2000 ins center

WASTE GAS DECAT TANK: WHICH IN SERVICE?
CALL DENNIS ~~MOORE~~ OLSON AT 1250. 4

1050 ES in both

			4/2	0700	A B 86-86
2400	85A, 86B		4/2	1100	85-85
0400	87A 85B		4/1	1400	86-86
				2200	86-86

	A	B
4/3 0200	87	86
0500	87	86
0700	87	87



MEMO from:

G. P. MILLER

WASTE GAS DECAY TANK PRESSURE

	TIME	PRESS.
4/2	2400	A-87 B-85
	2200	
	2200	A-86 B-86
	1400	A-86 B-86
	1100	A-85 B-85
	0700	A-86 B-86

4/1	0400	A-87 B-85
-----	------	--------------

4/3	0200	A-87 B-86
	0500	A-87 B-86
	0700	A-87 B-87

RCV 137 - on 21:11

periodic fogs

22:17 closed

23:10 OPENED

2:24 dep PZR - open spray blum
3:15 closed

18:00 open RC-V-137
18:28 455 TO MU-T-1

18:25 shut RC-1-137

18:06 open RC-V-137

19:18 shut = 11 =

19:48 added 456 TO MU-T-1

20:07 open RC-V-137

20:27 closed

20:52 open

21:13 closed

21:56 open

21:32 closed ??

22:17 open

22:33 closed

22:45 added 455 to MU-T-1

22:57 open

23:10 closed

RC 571C

4/3/79
open

Makeup Addition in g
RC-V-137 (Pyr vent)

0712 450

0720 open

0737 closed

0805 open

0849 closed

0914 open

0822 closed

829 450

840 open

913 open

927 closed

934 450

939 open

1005 closed

1021 open

1041 closed

1070 450

1107 open

1123 closed

1155 open

1173 closed

? closed

0570 open
0536 close
0600 open
0605 added 450 to nu-T-1
0615 closed
0642 open
0652 closed
0712 added 450 to nu-T-1
0720 open
0737 closed
0805 open
0849 closed
0930 open

23:35 open
23:49 closed

0006 added 450 to nu-T-1
0024 open
0038 closed
0111 open
0127 closed
0130 added 450 to nu-T-1
0152 open
0206 close
0227 open
0243 close
0326 added 450 for 4 nu-T-1
0306 open
0325 closed
0346 open
0404 close
0409 open
0449 added 450 to nu-T-1
0450 closed

(4)

11-4-82 252

Make Up Tank Makeup Data From Operators Log

3/24	3/29	3/30	3/31	4/1	4/2
1720 BWSF @ 26 1/2'	BWSF 20.5' @ 0615	0800 371	0033 300	0825 460	01.0 -455
1500 BWSF @ 24'		0815 300	0315 Started degas proc	0945 460	0360 455
1320 23'		1502 462		1041 301	0445 455
1147 22'		1719 200	0445 150	120 446	0630 455
1950 -2'		1853 Start filling BWSF Level @ 15.5'	0547 150	1306 460	0723 455
		2036 300	0705 150	1508 456	0853 455
		2307 170	0737 Start degas	1656 505	1310 456
		2547 300	0830 546	1805 456	1458 671
		2310 Start per Vent	1042 130	1900 455	1658 455
		2353 Start per Spray	1120 900	2015 454	1828 455
		<u>Total Makeup</u> 2123	1530 413	2118 454	
			1543 900	2225 455	
			1705 370	0112 470	
			1920 370	0127 470	
			2000 470	0325 470	
			2120 480	0435 470	
			2228 470	0645 470	
			2330 470		
			<u>Total 5262</u>	<u>Total 8553</u>	

16438

From Alarm
Data on
day of accident

One RB Sump Pump on for 31 min
Other " " " " for 28 min

4/3/79
gpm

Makeup Tank - Addition of water.

3/29/79

<u>Time</u>	<u>GAL. ADDED</u>	<u>ΔTime (min)</u>	<u>gpm</u>
2240	—		
2315	300 gal	35	8.57 gpm
0020	300	65	4.62
0105	300	45	6.67
0145	303	40	7.58
0250	303	65	4.66
0332	303	42	7.21
	<u>ΣGal = 1809</u>	<u>ΣTime = 292</u>	

$$\frac{1809}{292} = 6.19 @ 2155 \text{ psig}$$

This may have been due to Pressurizer Safety Valve leakage.
Since this is critical flow, the leak rate at present plant
conditions would be:

$$6.19 \times \left(\frac{1000 + 15}{2155 + 15} \right) = 2.9 \text{ gpm}$$

MEMO from:
G. P. MILLER

Makeup Results

<u>Date</u>	<u>Avg MU (gpm)</u>	<u>a</u>	<u>a / DTavg</u>
3/30/79	2.39		
3/31/79	5.52	680.9	$\frac{680.9}{80.44} = 8.71$
4/1/79	5.52	408.7	$\frac{408.7}{80.94} = 5.05$
4/2/79	4.77	540	5.05
4/3/79	5.325	450	$\frac{450}{84.5} = 5.325$ THRU 0712

Makeup - 4/3/79 0006 → 672

$$y = a + bx$$

$$I. \sum(y) = Na + b \sum(x)$$

$$II. \sum(xy) = a \sum(x) + b \sum(x^2)$$

$$I. 2700 = 6a + b(507)$$

$$\frac{507}{6} = 84.5$$

$$II. 228,150 = 507a + b(44,227)$$

$$-228,150 = -507a + 42841.5b$$

$$228,150 = 507a + 44,227b$$

$$I. 2700 = 6a + 507b$$

$$II. 228,150 = 507a + 44,227b$$

$$~~235528.4 = 44227b~~$$

$$I. \frac{235,528}{20,565,788} = 523.49 + 44227$$

$$II. -228,150 = -507a + 44227$$

$$~~20,317,638 = 16.4a~~$$

$$7,378$$

$$a = ~~12,388.80~~$$

$$a = 450$$

$$6a = 2700$$

OK
 $\frac{2700}{6} = 450$

$$2700 = (6)(450) + 507b$$

$$507b = 0$$

$$Avg = \frac{2700}{507} = 5.325 \text{ gpm}$$

MEMO from:

G. P. MILLER

Makeup 4/2/79 0150 → 2245

I $5654 = 12a + 1433b$

II $469,512 = 1433a + 337,455$

$$\frac{337,455}{1433} = 235.49$$

I $133,145.9 = 2825.9(a) + 337,455(b)$

II $669,512 = 1433(a) + 337,455(b)$

$$-536,366 = 1392.9a$$

$$a = -385 ?$$

Ignore data point for 1310 - There must be one or more
~~data~~ data points missing between 0853 and 1310.

$$N = 11$$

$$\Sigma(y) = 5654 - 432 = 5612$$

$$\Sigma(x) = 1433 - 257 = 1176$$

$$\Sigma(xy) = 669,512 - 111,024 = 558,488$$

$$\Sigma(x^2) = 337,455 - 66,049 = 271,406$$

I. $5612 = 11a + 1176b$

$$\frac{271,406}{1176} = 230.77$$

II. $558,488 = 1176a + 271,406$

I. $1,295,179 = 2539(a) + 271,406(b)$

II. $558,488 = 1176(a) + 271,406(b)$

$$736,691 = 1363a$$

$$a = 540$$

$$11a = 5940$$

$$\Delta T_{\text{avg}} = \frac{1156}{11} = 107$$

$$\text{Avg MU} = \frac{5612}{1176} = 4.77$$

~~Avg MU~~ Without 1310 data

$$\frac{5612}{11} = 510$$

~~1176 =~~

MEMO from:

G. P. MILLER

4/3/79
JPM

Makeup 4/1/79 0112 → 2347

I. $8047 = 18a + 1457b$

II. $657,754 = 1457a + 131,231b$

I. $724,788 = 1621a + 131,231b$

II. $-657,754 = -1457a + 131,231b$

$67034 = 1649$

$a = 408.7$

$\Delta T_{avg} = 80.94 \text{ mi}$

$Avg \text{ MU} = \frac{8047}{1457} = 5.52 \text{ gpm}$

OK
 $\frac{8047}{18} = 447$

MEMO from:

G. P. MILLER

Makeup - 3/31/79 0035 → 2339

omit 0445 data point

I. $6212 = 15a + 1173b$

$$\frac{141,345}{1173} = 120.5$$

II. $432,040 = 1173a + 141,345b$

I. $748538 = 1807.5(a) + 141345(b)$

$$\frac{6212}{15} = 414$$

II. $432,040 = 1173(a) + 141,345(b)$

$$316,498 = 634.5a$$

$$a = 680.9$$

Poor Correlation

$$\Delta T_{avg} = \frac{1457}{18} = 80.94$$

$$\Delta T_{avg} = \frac{1173}{15} = 78.2$$

$$\text{Avg MW} = \frac{8047}{1457} = 5.52$$

RCS Makeup - (Cont'd)

4/2/79

Time

(y)
M-U
G/G

(x)
Δ Time (MIN)

(xy)

(x²)

Previous
activation
2347
4/1/79

0150	455	123 123	55965	15129
0300	455	115	52325	13225
0445	455	115	52325	13225
0630	455	105	47775	11025
0723	455	53	24115	2809
0853	455	90	40950	8100
1310	432	257	111024	66049
1458	671	108	72468	11664
1658	455	120	54600	14400
1828	455	90	40950	8100
1948	456	80	36480	6400
2245	455	177	80535	31329
	5654	1433	669512	337455

$$\text{Avg} = \frac{2730}{601} = 4.54 \text{ gpm}$$

$$\text{Avg} = \frac{5654}{1433} = 3.95 \text{ gpm}$$

$$\text{Avg} = \frac{2492}{575} = 4.33 \text{ gpm}$$

Missing
data
point?

4/3/79

(y)

(x)

(xy)

(x²)

0006	450	81	36450	6561
0130	450	84	37800	7056
0326	450	116	52200	13456
0449	450	83	37350	6889
0605	450	76	34200	5776
0712	450	67	30150	4489
	Σ(y) = 2700	507	228150	44227



$$\text{Avg} = \frac{900}{165} = 5.45$$

$$\text{Avg} = \frac{1350}{226} = 5.97$$



$$\text{Avg} = 5.325 \text{ gpm}$$

$$\text{Avg} = \frac{2700}{507} = 5.325 \text{ gpm}$$




$$T_{\text{avg}} = \frac{507}{6} = 84.5$$



**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



3/31/79 (Contd.)

TIME	(y) M-u gal	(x) Δ Time	(xy)	(x ²)
2000	470	100	47,000	10,000
2120	450	80	39,200	6,400
2228	470	68	31,960	4,624
2330	470	62	29,140	3,844

$\Sigma(y) = 6212$
 $\Sigma(x) = 1173$
 $\Sigma(xy) = 433,040$
 $\Sigma(x^2) = 141,345$
 $N = 15$

4/1/79

	Y	X	XY	X ²
0825	460	100	46000	10,000
0945	400	80	32000	6400
1041	301	56	16856	3136
1200	446	79	35234	6241
1306	400	66	26400	4356
1508	456	122	55632	14884
1650	505	102	51510	10404
1805	456	75	34200	5625
1900	455	55	25025	3025
2015	454	75	34050	5625
2118	454	63	28602	3969
2225	455	67	30485	4489
2347	455	82	37310	6724
0112	470	102	47940	10404
0127	470	15	7050	225
0325	470	118	55460	13924
0435	470	70	32900	4900
0645	470	130	61100	16900
<u>8047</u>	<u>1457</u>		<u>657,754</u>	<u>131,231</u>

$Avg = \frac{8047}{1457}$
 $= 5.528 \text{ gpm}$

$\Delta Tavg = \frac{1457}{18} = 80.94$

MAKEUP TO RCS

DATA FROM CONTROL ROOM LOG.

4/3/79
JDM

Time	M-U (Y) (GAL)	(X) Δ Time	(XY)	(X ²)
3/30/79 0800	371	?		
0815	300	15		
Missing Date? 1502	462	407?		
1719	200	137		
2036	300	197		
2387	190	151		
2347	300	40		
2310	1752	947		

$$\frac{1752 \text{ gal}}{947 \text{ min}} = 1.85$$

Omit 1502 data.
 $\frac{1752 - 462}{947 - 407} = \frac{1290}{540} = 2.39$

3/31/79	Y	X	XY	X ²	
0035	300	48	14400	2304	
Missing Date? 0445	150	250 250	37500	62500	omit
0547	150	62	9300	22500	
0705	150	78	11700	6084	
0830	566	85	48110	7225	
1042	130	132	17160	17424	
1120	900	38	34200	1444	
1427	303	187	56661	34969	
1530	413	63	26019	3969	
1543	700	135	9100	169	
1805	370	142	52540 52540	20164	
1820	370	15	5550	225	

- CONTD -

SIM, MORIE,

I couldn't find the error in your calculations, so I changed the time to minutes and did my own. I also dropped the first data entry because I couldn't verify it. I incl formula is same out to be ==

$$Y = 339 + 1.266(x)$$

	$\frac{x}{\Delta T - \text{MIN}}$	$\frac{x^2}{\text{SEC.}}$	$\frac{y}{Y}$	$\frac{xy}{X Y}$
0825				
0945	80	6400	400	32000
1041	56	3136	301	116856
1200	79	6241	446	35234
1306	66	4356	400	26400
1506	120	14400	456	54720
1650	104	10816	505	52520
1805	75	5625	456	34200
1900	55	3025	455	25025
2015	75	5625	454	34050
2120	65	4225	455	29575
2225	65	4225	455	29575
2347	82	6724	455	37310
	<u>922</u>	<u>74798</u>	<u>5238</u>	<u>407465</u>

$$\Sigma Y = 5238$$

$$\Sigma x = 922$$

$$\Sigma x^2 = \cancel{4126024} 74798$$

$$n = 12$$

$$\Sigma xy = \cancel{1551426} 407465$$

~~Σ~~

$$Y = a + bx$$

$$Y = 339 + 1.266(x)$$

$$9238 = (12)(a) + (b)(922)$$

$$407465 = 922(a) + (b)(74798)$$

$$-402453 = 922(a) + (b) 70840.$$

$$407465 = 922(a) + (b) 74798$$

$$5012 = 3958(b)$$

$$1.266 = b$$

$$407465 = 922(a) + (1.266)(74798)$$

$$407465 = 922(a) + 94694$$

$$312771 = 922(a)$$

$$339 = a$$

$$y = a + bx$$

$$y = \text{Makeup in Time } X \text{ (gal)}$$

$$x = \text{Time}$$

$$b = \text{Makeup Rate (gal/hr)}$$

$$N = \text{No of Data Points}$$

$$\lambda = 0.700 \text{ to } 2.347$$

From
B&W
Volume of CROM
motor Housing
is 58 #3 total

$$\Sigma(y) = 5698 \quad N = 13$$

$$\Sigma(x) = 16.78$$

$$\Sigma(xy) = 7442$$

$$\Sigma(x^2) = 22.78$$

$$y = a + bx$$

$$I. \quad \Sigma(y) = Na + b\Sigma(x)$$

$$II. \quad \Sigma(xy) = a\Sigma(x) + b\Sigma(x^2)$$

$$5698 = 13a + b(16.78)$$

$$\frac{13}{16.78} = 0.7747$$

$$7442 = a(16.78) + b(22.78)$$

$$5698 = 13a + 16.78b$$

$$5766 = 13a + 17.65b$$

$$68 = 0.87b$$

$$b = 78$$

$$5766 = 13a + (17.65)(78)$$

$$5766 = 13a + 1379.5$$

$$13a = 5766 - 1379.5$$

$$y = 337 + 78x$$

$$a = 337$$

$$\text{Integrated Makeup} = 337 + 78(\text{Time})$$

(MAKE-UP DATA)

	Y		X			
	Gal Added	FT ³ @ 70°F	FT ³ @ 280°F	CHRS	xy	x ²
4/1/79				Δ TIME	5.31 hr	
					653	
0825	460			1.42	653.2	2.02
0945	400			1.33	532	1.77
1041	301			0.93	280	0.86
1200	446			1.32	589	1.74
1306	400			1.10	440	1.21
1506	456			2.00	912	4.00
1650	505			1.73	874	2.99
1805	456			1.25	570	1.56
1900	455		65.38	0.92	419	0.85
2015	454			1.25	568	1.56
2120	455		65.38	1.08	491	1.17
2225	455		65.38	1.08	491	1.17
2347	455		65.38	1.37	623	1.88
	<u>5698</u>			<u>16.78</u>	<u>7442</u>	<u>22.78</u>
4/2/79					FT ³ /HR	
0150	455		65.38	2.05	31.84	4.20
0300	455		65.38	1.16	56.36	1.35
0445	455		65.38	1.75	37.36	3.06
0630	455		65.38	1.75	37.36	3.06
0723	455		65.38	0.84	74.30	0.77
0853	455	60.82	65.38	1.5	43.59	2.25
	<u>2730</u>			<u>9.09</u>	<u>4136</u>	<u>14.64</u>

(over)

DTmic gal/hr

1316 - 430

~~6.32~~ 148.5

1458 - 671

1.8 372

1658 - 455

2.0 227.5

1848 - 455

2.0 227.5

2347 - 0853

$$\Sigma(y) = 2730$$

$$N = 6$$

$$\Sigma(x) = 9.09$$

$$\Sigma(xy) = 4136$$

$$\Sigma(x^2) = 14.69$$

$$2730 = 6a + 9.09b$$

$$\underline{4136 = 9.09a + 14.69b}$$

$$2730 = 6a + 9.09b$$

$$\underline{2730 = 6a + 9.7b}$$

$$a = 0$$

$$b = \frac{306 \text{ gal/hr}}{60} = 5 \text{ gpm}$$

MAKE-UP RATE

Sheet 1
JPM

<u>4/1/79</u>	<u>GAL ADDED</u>	<u>Δ TIME</u>	<u>MAKEUP RATE</u>
0825	460	1.42	324
0945	400	1.33	301
1041	301	0.93	324
1200	446	1.32	338
1306	400	1.10	364
1506	456	2.00	228
1650	505	1.73	292
1805	456	1.25	365
1900	455	0.92	495
2015	454	1.25	363
2120	455	1.08	421
2225	455	1.08	421
2347	<u>455</u>	<u>1.37</u>	332
	5698	16.78	

LEAST SQUARES
FIT FLOW
RATE = 337 gal/hr

<u>4/2/79</u>	<u>GAL ADDED</u>	<u>Δ TIME</u>	<u>MAKEUP RATE</u>
0150	455	2.05	222
0300	455	1.16	392
0445	455	1.75	260
0630	455	1.75	260
0723	455	0.88	568
0853	<u>455</u>	<u>1.5</u>	303
	2730	9.09	

LEAST SQUARES
FIT FLOW RATE
= 300 gal/hr

Makeup Rate

Sheet 2
JMM

<u>4/2/79</u>	<u>GAL ADDED</u>	<u>Δ TIME</u>	<u>MAKEUP RATE</u>
1310	430		
1458	671	1.8	372
1658	455	2.0	227.5
1848	455	2.0	227.5

Cont. Hydrogen VS. Time

-	1.7%
-	1.9%
-	2.0%
-	1.9%
0600	2.6% ?
0845	2.4% ?
4/11 1030	2.0%
1200	2.2%
1330	2.1%
1550	2.2%

Data Points H₂ Concentration In Confinement

Recombination flow = 90 ft³/hr

at -1.2 psig: 32 → 94 °F

0.02 x 90 = 1.8 cfm of H₂
burned & started recombines
at 1547 on 4/2/79

Date	Time	Concentration	
3-28-79	1400	0 %	(Assumed Defonation Event)
3-31-79	0400	1.7 %	
3-31-79	1200	1.9 %	
?	?	2.0 %	
?	?	1.9 %	
4-1-79	0700	2.6 %	
4-1-79	0900	2.4 %	
4-1-79	1030	2.0 %	} Calculated Removal Rate and Gen. Rate Generation Rate slowed - 2.6 & 2.4 readings appear to be erroneous.
4-1-79	1200	2.2 %	
4-1-79	1330	2.1 %	
4-1-79	1500	2.2 %	
4-1-79	1600	2.1 %	
4-1-79	2200	2.3 %	
4-2-79	0215	2.3 %	
4-2-79	2100	1.9 %	
4.3-79	0001	2.1 %	IN LINE MONITOR
4.3-	2100	1.9 %	

* H₂ in Confinement is @ 22 = .02 x 2 x 10⁶ = 40000 ft³

Removal rate = $\frac{24 \times 16 \times 18 \times 100\%}{2 \times 10^6} = 1.034\%/\text{day}$

MICROFILM

DOCUMENT INDEX TARGET

DESCRIPTION

MAR ANALYSIS RESULTS
HG-0002

(55 spaces maximum)

DATE

05-03-79

(18 spaces maximum)

DESCRIPTION CONTINUATION

FILE NUMBER

(20 spaces maximum)

NOTE: Maximum spaces include all punctuation marks, dashes and spaces between words.

Description continuation should only be used when abbreviations are not appropriate.

REEL NO. _____ BLIP NO. _____

GAS ANALYSIS RESULTS

RIP

DATE: 3/31/79
VOLUME: HYDROGEN= 0.0
VOLUME: OXYGEN= 20.5
VOLUME: NITROGEN= 79.5

Gas Partitioner
to check
analyser

Chart UNITS

H₂ - 0
O₂ - 16
N₂ - 46 1/2

3/31/79
0600 Hrs

GAS ANALYSIS RESULTS

UNIT: P. BLDG

DATE: 3/31/79
VOLUME: HYDROGEN= 1.7
VOLUME: OXYGEN= 15.7
VOLUME: NITROGEN= 82.6

Chart UNITS

H₂ - 14.5
O₂ - 12
N₂ - 47 1/2

GAS ANALYSIS RESULTS

UNIT: P. BLDG

DATE: 3/31/78
VOLUME: HYDROGEN= 1.7
VOLUME: OXYGEN= 16.5
VOLUME: NITROGEN= 81.8

Chart UNITS

H₂ - 16
O₂ - 14
N₂ - 52

J. J. J. Men

7000-0-0-A

Analytic Hydrocal Continued

D.A. Nitti

22:00 hrs 3/29

20 lbs on 3/29

EV = 1.7×10^{29}

22 lbs on 3/29

(12) hrs @ 22:00 hrs

Assumes Too High
at Energy Release
Boundary

$$\frac{0.45 \times 10^{29} \times 1.7 \times 10^{29} \text{ (CV)}}{6.03 \times 10^{23} \times 100 \text{ (REV)}} \times \frac{22,400 \text{ cc}}{28,317 \text{ g}} = 10,036 \text{ FT}^3 \text{ H}_2$$

EV IN CORE FOR PMA	4.14×10^{29}	REF: 7M-2 FS
10% EV IN SOLID FOR PMA	0.85×10^{29}	APPENDIX-15
TOTAL EV FOR PMA	4.95×10^{29}	

$$\frac{0.45 \times 4.95 \times 10^{29} \times 22,400}{6.03 \times 10^{23} \times 100 \times 28,317} = 5284 \text{ FT}^3 \text{ H}_2$$

FOR S_{H_2} OF 0.5 VOL OF H_2 WOULD BE 5871 $\text{FT}^3 \text{ H}_2$
 FOR G_{O_2} OF 0.25 " " O_2 " " 2936 $\text{FT}^3 \text{ O}_2$
 8807 FT^3

Compressional Ratio = $\frac{935 \text{ PSIA}}{14.7 \text{ PSIA}} \times \frac{502^\circ \text{R}}{517^\circ \text{R}} = 32$

(275 FT^3 COMPRESS)

$$\frac{275 \text{ FT}^3}{42 \text{ hr}} = 6.5 \text{ FT}^3/\text{hr}$$

9.6. to release to Met Ed, then you will draw

BRIDGMAN & WILCOX

AIR ADDED TO RCS WITH WATER FROM DWST

PERRY'S CHEM HANDBOOK P. 675 IN 3RD ED

VOLUME of HEAD ROOM
 Head 800 FT³
 Room 1000 FT³
 OPERATING 500 FT³
 2300 FT³

AIR: $H = 5.1 \times 10^{-10}$ @ 6°C (42°F)
 $H = 6.6 \times 10^{-9}$ @ 20°C (68°F)

TEMP @ 53°F

$$p = H \cdot z$$

- H = Henry Law CONST
- p = Partial Press. of Atmosphere
- z = MOLE FRACTION

$$z = \frac{p}{H} = \frac{1 \text{ atm}}{5.1 \times 10^9} = 2.7 \times 10^{-5} = \frac{\frac{1 \text{ lb}}{29 \text{ (air)}}}{\frac{1000 \text{ lb}}{15 \text{ (O}_2\text{)}}}$$

$M_2(\text{O}_2) = 0.0322 \text{ gm air}$
 $M_2(\text{O}_2) = 1.1 \times 10^{-3}$
 $V_2(\text{O}_2) = 24.9 \text{ cc/kg}$

$$\frac{473,000 \text{ gal in DWST}}{55 \text{ ft (dia)}} \times 33 \text{ ft LONG COLUMN} = 284,000 \text{ gal}$$

$$284,000 \text{ gal} \times 8.33 \frac{\text{lb}}{\text{gal}} \times 0.4536 \frac{\text{kg}}{\text{lb}} = 1.072 \times 10^6 \text{ kg DWST L}$$


$$\text{Volume of Air Added} = \frac{1.072 \times 10^6 \text{ kg} \times 24.9 \frac{\text{cc}}{\text{kg}}}{23,317 \frac{\text{cc}}{\text{ft}^3}} \times \frac{14.7 \text{ psia}}{93.5 \text{ psia}} \times \frac{517^\circ \text{R}}{502^\circ \text{R}} = 29 \text{ FT}^3$$

$$\frac{1.072 \times 10^6 \text{ kg} \times 24.9 \frac{\text{cc}}{\text{kg}}}{23,317} = 1133 \text{ FT}^3 \text{ AT } T_{\text{DWST}} = 0^\circ \text{F}$$

Volume Calculations

CWP 3/29/79

Reactor Vessel Head Volume



$$V_1 = \pi r^2 h = \pi (22')^2 (20')$$

$$V_1 = 422,881 \text{ in}^3$$

$$V_1 = 244 \text{ ft}^3$$

$$V_2 \approx \frac{2}{3} \pi R^3 - V_1$$

$$V_2 = \frac{2}{3} \pi \left(\frac{37}{12}\right)^3 - 244$$


$$V_2 = 554 \text{ ft}^3$$

$$V_{\text{head}} = V_1 + V_2 = \underline{\underline{798 \text{ ft}^3}}$$

Remaining Volume

$$V = \pi r^2 h = \pi (44) 13$$

$$V_{\text{room}} = \underline{\underline{2000 \text{ ft}^3}}$$



PARTIAL PRESSURE OF H₂ NORMALLY IN UTILITY WIND IS SUFFICIENT TO SUPPRESS RADIOACTIVE DECOMPOSITION

$H_2 = 7.65 \times 10^9 \text{ @ } 60^\circ\text{C (140}^\circ\text{F)}$ CRC. INC. P. 65

$V_0 = 20 \text{ cu ft}$

$\gamma_0 = \frac{20 \text{ cu ft}}{K_g \text{ H}_2} \times \frac{18 \text{ g/mole}}{1000 \text{ g/gal}} \times \frac{1}{22,400 \frac{\text{cc}}{\text{mole}}} = 1.607 \times 10^{-6}$

$p = H \gamma_0 = 7.65 \times 10^9 \times 1.607 \times 10^{-6} = 1.23 \text{ ATM} \rightarrow 18 \text{ PSI H}_2$

PARTIAL PRESSURE OF H₂ IN RCS REQUIRED TO SUPPRESS RADIOACTIVE DECOMPOSITION

$H = 11 \times 10^5 \frac{\text{psi}}{\text{gram}} = \frac{\text{mm}}{11.7 \text{ PSI}} = 7.5 \times 10^9 \text{ @ } 75^\circ\text{F}$
 $H = 2.53 \times 10^5 \frac{\text{psi}}{\text{gram}} \text{ @ } 537^\circ\text{F}$ } DHI-7-25
TABLE 2

250
250
100

$\gamma = \gamma P$ $p = H \gamma$
 $\gamma = \frac{p}{H}$
 $\gamma = \frac{2.53 \times 10^5}{130} \times 1.607 \times 10^{-6}$

MIN PART. W. WIND = $\gamma = 9.32 \times 10^{-3}$ ✓

$p = H \gamma = 2.53 \times 10^5 \frac{\text{psi}}{\text{gram}} \times \frac{20 \text{ cu ft}}{K_g \text{ H}_2} \times \frac{18 \text{ g/mole}}{1000 \text{ g/gal}} \times \frac{1}{22,400 \text{ cc}} = 9.05$

ASSUME AN 800 FT³ DUDALE

V _{air} @ 537°F @ 935 PSI	= 29 FT ³	= 1192 gram
V _{air} @ " " "	= 179 FT ³	= 7418 gram
V _{air} @ " " "	= 92 FT ³	= 3709 gram
V _{air} Steam @ " " "	= 505 FT ³	= 20,045 gram
	<u>800 FT³</u>	<u>29,364 gram</u>

0.478

$\gamma_0 = 0.193$

800 FT³ DUDALE IS 45 TIMES UNDER THIN 2 OF 9.32110

D
Pirani Sample

11. COLLECTION OF GASES FROM WATER

1.0 Introduction

Dissolved gases are obtained from water samples by pumping a vacuum over the sample and stripping the water vapor from the gas stream in a cold trap. The apparatus used to separate the gases from the water and to measure the gas volume is shown in Figure 1. The maximum volume of gas that can be collected is limited by the mercury depth in the base of the Toepler pump. This maximum volume is approximately 100 standard cc; however, optimum gas collection is 25 standard cc or less. Avoid overpressuring the system because the glass apparatus may shatter.

2.0 Apparatus

The components as described in Figure 4 include a 500-cc ballast volume, a cold trap, a Toepler pump, and a gas burette with leveling bulb. Mercury is the working fluid in both the gas burette and the Toepler pump. One mechanical pump is used to evacuate the gas system and to operate the Toepler pump; another pump is used to evacuate the sampling bulb. A Pirani tube is sealed into the apparatus to determine the quality of the vacuum and to test for leaks in the system. The small sampling bulb (approximately 5 to 10-cc) is used to separate a portion of the gas collected from the sample for analysis by mass spectrometry.

Water samples to be degassed usually are supplied in stainless steel bombs of about 500-cc, and these bombs are connected to the ballast volume by a length of flexible tubing. Other size samples can be accommodated but require that the quantity of gas obtained be compatible with the volumetric limitations of the apparatus.

2.1 Normal Operation

The sample bomb is connected to the empty ballast volume with flexible tubing. The mercury in the Toepler pump is lowered by carefully opening and adjusting stopcock D, which is connected to the mechanical pump. Stopcock B is then turned to connect the Toepler pump and cold trap, and the system is evacuated by opening stopcock A to the mechanical pump.

While the gas system with the cold trap is degassing, the gas burette, sampling bulb, and small section of tubing between stopcocks B and C are evacuated with another mechanical pump. The mercury is outgassed by raising and lowering the leveling bulb while pumping. Stopcock C is turned so that the gas burette and tubing between B and C can be filled with mercury by raising the leveling bulb. The mechanical pump is left pumping on the sampling bulb.

When the Pirani gauge indicates that the pressure in the gas system is less than 50 μ , stopcock A is closed to check the system for leaks. Leaks are evidenced by a rapid rise in pressure on the Pirani gauge. Stopcock D should be closed during the leak test because mercury can be forced out of the Toepler pump system into the mechanical pump if a large leak should appear in the gas system. The most common source of leakage is the connection to the sample bomb; the valve on the sample bomb may not be tightly closed; or water might still be evaporating from the bomb fitting under the partial vacuum.

When all leaks have been eliminated, the system is pumped down to less than 50 μ , and liquid nitrogen is added to the cold trap. (Note: if carbon dioxide is a component of interest in the sample, dry ice and acetone must be substituted as a coolant). The pressure shown by the Pirani gauge should now be less than 10 μ . Stopcock A is closed next; no significant rise in system pressure should occur. At this stage, the mercury in the Toepler pump can be in either the raised or lowered position.

The valve on the sample bomb is opened to allow water to run into the ballast volume. As soon as the ballast volume is partially filled, the sample bomb is lowered so that no more water flows into the ballast volume (do not allow the flexible tubing to become kinked). The ballast volume is filled only partially so as to leave considerable water surface area exposed to the vacuum system; this assures maximum release of the gases from the sample. A rise in pressure usually is observed as the gases are released and generally is followed on the "Leak Test" scale of the Pirani gauge since the pressures are normally higher than can be read on the two pressure scales. When no further increase in pressure is observed, the release of dissolved gases is considered complete.

If the mercury has been in the raised position in the Toepler pump, the mercury now is lowered by carefully opening stopcock D to the vacuum pump. Stopcock B is examined to make sure it is open to the cold trap. Approximately 1 min is allowed for the gases to come to equilibrium in the system. The gas is transferred from the Toepler pump to the gas burette by opening stopcock B to the gas burette and by raising the mercury in the Toepler pump by carefully opening stopcock D to the atmosphere. When the gas in the Toepler pump has emptied into the burette, stopcock C is turned to close off the gas in the burette. The leveling bulb is used to equalize the pressure in the gas burette with atmospheric pressure, and the gas volume is read.

A second Toepler pump stroke is taken by dropping the mercury in the Toepler pump after opening stopcock B to the cold trap and repeating the operation as described. Toepler pump strokes are repeated until no increase in gas volume is observed. As many as 10 Toepler pump strokes may be required. The measured volume of gas is corrected to standard conditions with the following equation:

$$V_{stp} = \frac{P_i T_{stp}}{P_{stp} T_i} V_i \quad (1)$$

where

V_{stp} = volume of gas at standard conditions, cc

T_{stp} = 273.16 °K

P_{stp} = 760 mm Hg

P_i = barometric pressure mm Hg

T_i = room temperature °K

V_i = volume as gas measured, cc.

Another method for calculating the volume of gas recovered arises from the fact that each Toepler pump stroke is a fixed percent of the total volume of the system. If the first Toepler pump stroke delivers 40% of the total gas in the system, then the second will deliver 40% of the residual 60% or 24% of the total. Using this relationship, a value for the total gas in the system can be calculated from each Toepler pump stroke although it is better to take several pump strokes to minimize any forcible fractionation of the gas during release from the water or from the cold trap. The percent of each Toepler pump stroke to the total volume must be determined for each size sample container but can be calculated from the normal data taken from the accumulated gas volume and numbers of Toepler pump strokes as follows:

<u>Toepler Pump Stroke</u>	<u>Gas Accumulated (cc)</u>	<u>Gas each Stroke(cc)</u>
1	5.7	5.7
2	9.4	3.7
3	11.5	2.1
4	12.8	1.3

The percent of gas remaining in system after each pump stroke is:

$$\frac{3.7}{5.7} = 64.8\% \quad \frac{1.3}{2.1} = 62\%$$

$$\frac{2.1}{3.7} = 57\% \quad \text{average} = 60\%$$

Therefore, a pump stroke in this example is 40% of the total volume. Table 11 shows a typical gas volume calculation using this relationship. This calculated total volume also must be corrected to standard conditions. After the gas has been collected and measured, a portion is expanded into the sampling bulb for analysis by mass spectrometry.

TABLE 13
GAS VOLUME CALCULATION

Toepler Pump Strokes	Gas Accumulated (cc)	Total Gas (%)	Calculated Total Vol. (cc)
1	5.7	40	14.3
2	9.4	64	14.7
3	11.5	78	14.7
4	12.8	87	14.7
5	13.5	92	14.7

3.0 Type of Samples

3.1 Reactor Primary Coolant Water Samples

The gases normally observed in these samples are H₂, H₂, N₂, O₂, Ar, and CO₂. If carbon dioxide is requested in the analysis, dry ice and acetone must be used as the coolant in the cold trap to remove water vapor. This type of sample usually is received in a 500-cc stainless steel Hoke bomb. A 50-ml gas burette is used to collect the released gases. Results are reported as standard cc/liter of water

for total gas recovered, and from the mass analysis of the gas, standard cc/liter for each of the observed components. The volume of water for each sample is measured after recovering it from the gas collection apparatus and the sample bomb.

3.2 Miscellaneous

When samples are received with no estimation of the quantity of gases per sample, the 50-ml gas burette is used during gas collection because this burette is suitable for volumes from approximately 1 to 50 ml. A 5-ml gas burette is available for use with samples known to contain less gas than can be accurately measured with the 50-ml burette.

When opening any sample container to the gas collection apparatus, care must be taken because a sample containing a large volume of gas under pressure could break the glass system. Watching the Pirani gauge while opening the sample container is good practice; although, some acceptable samples will have sufficient gas to be off scale on the gauge. An abnormally large volume of gas will cause pressure sufficient to force gas and mercury through the tube in the Toepler pump into its reservoir. Approximately 80-mm Hg pressure in the system is required or about 50 standard cc of gas if the Toepler pump reservoir is evacuated as it is during normal operation. If this occurs, the valve on the sample container should be closed immediately.

The sample arrived in Idaho Falls at 0640 hrs. MST on 4/14/79 via air transportation. Figure 1 illustrates how the sample was packed, with activity readings. Smears of the air craft and shipping drum indicated no external contamination.

At 0715 the sample left the Idaho Falls Airport, it arrived at INEL (CPP-502) at 0845 hrs. Upon arrival at CPP the sample (shipping drum) was off-loaded with an overhead hoist onto a four-wheeled dolly and transferred to lab 103C. At no time was the shipping drum allowed in a nonvertical position.


In lab 103C, the shipping drum was opened and the 8" diameter pipe lifted into a chemical fume hood. In the fume hood a sample of the argon atmosphere within the 8" pipe was taken. The method used for taking this sample involved the following. When valve 8 was opened on the TMI sample (~1105 hrs. MST) only a small rise in pressure was observed on the Pirani gauge (Figure 2) which indicated a small amount of gas compared to the ATR sample. Consequently, the TMI sample gas was collected for approximately 1 hr. or 10 Teopler pump strokes. The volume of gas collected was $0.8 \pm .2$ cc and had the following composition:

H ₂	$1.5 \pm .1^*$	
He	< 0.01	(vol. percent)
N ₂	$89.4 \pm .1$	
O ₂	$8.1 \pm .1$	
Ar	1.00 ± 0.02	

*Uncertainties are based on mass spectrometry measurements only. The mass spectrometry analysis is detailed in reference ICP-1031.

A gamma-ray pulse height analysis of the TMI gas sample indicated no observable activities above background.

Fig I




31.5 ml sample total
 ~ 2 ml gas

Transferable Contamination: none detectable

(From ~~the~~ shipper)
 4/1/59

1610



DUC-0-15

Replaced by
revised apparatus
for TMI East

Fig 2 Apparatus for Collection of Gases From Water

gas bomb
70cc bulb
Toepler Pump

APPENDIX A

Volume Measurement

Due to the sensitive nature of the analysis, we initially attempted to be extremely conservative and include all possible sources of error (no matter how remote they may be). The measurements indicated a total gas volume of 0.8 cc, but to be conservative a range of 0.8-1.7 cc was reported.

The initial measurement of the total gas volume performed at the gas collector is supported by the pressure measurement performed when the gas from the 10 cc sample bulb was expanded into the mass spectrometer inlet.

Based upon detailed analysis of the data, we conclude that the best estimate of the total gas in the 31.5 ml bomb is 0.8 std. cc and that this value is good to + 30%.

Air Inleakage

We estimate that the air inleakage to the TMI sample was less than 0.07 std. cc. This estimate is based on the results using the ATR sample. To obtain an upper limit for air inleakage, it was assumed that all the oxygen detected in the ATR sample was due to air inleakage. Pumping time for the ATR sample was about 15 minutes.

APPENDIX B

Leakage to Cover Gas

Based on evaluation of the cover gas analysis, the maximum detectable hydrogen leakage from the 31.5 ml bomb to the cover gas is estimated to be 0.2 std. cc. This is based on the detection limit for hydrogen (i.e., 0.004%) and the assumption that the gas volume in the 8 inch pipe was 5000 cc.

$$\text{Max. H}_2 \approx \frac{0.00004 (150)}{150/5000} = 0.2 \text{ cc}$$

MICROFILM

DOCUMENT INDEX TARGET

DESCRIPTION

H G - 0001 _____

_____ (55 spaces maximum)

DATE

05 - 03 - 79 _____ (18 spaces maximum)

DESCRIPTION CONTINUATION

FILE NUMBER

(20 spaces maximum)

NOTE: Maximum spaces include all punctuation marks, dashes and spaces between words.

Description continuation should only be used when abbreviations are not appropriate.

REEL NO. _____ BLIP NO. _____

4-1-79 @ 1000

1. Calculations of Hydrogen Generation Rate

1. Sample Data

3-31-79	0700	1.7% H ₂
5-31-79	1000	1.9% H ₂
4-1-79	0700	2.6% H ₂
4-1-79	0900	2.4% H ₂

2. From 0700 on 3-31-79 to 0700 on 4-1-79

$$\Delta \% \text{ H}_2 = .9\%$$

$$\Delta t = 27 \text{ Hours}$$

3. Hydrogen Generated:

$$\text{Cont. Free Air Vol} = 2.1 \times 10^6 \text{ ft}^3$$

$$\text{Change in H}_2 \text{ Conc.} = .9\%$$

$$2.1 \times 10^6 \text{ ft}^3 \times .009 = 1.89 \times 10^4 \text{ ft}^3$$

4. Generation Rate:

$$\Delta t = 27 \text{ hrs}$$

$$\text{H}_2 \text{ Gen. Vol.} = 1.89 \times 10^4 \text{ ft}^3$$

$$\text{GR} = 1.89 \times 10^4 / 27 \text{ hrs} \times 1 \text{ hr} / 3600 \text{ sec}$$

$$\text{GR} = .194 \text{ ft}^3/\text{sec}$$

Assumptions:

1. Data points are correct and worst case.
2. Information in problem is correct

B Calculations of Chamber Removal Rate (ft^3/sec)

1. Data on Chamber:

- Removal Rate = 4.4×10^{-3} miles/sec @ 57 SCFM flow + 3% He
- Removal eff = 99%

2. Conversion:

a. Feet:

- 1 mile = 22.4 l @ STP
- 1 ft^3 = 28.32 l @ STP

b. Calculations:

$$\begin{aligned} 1. \quad 4.4 \times 10^{-3} \text{ miles/sec} &= .00348 \text{ ft}^3/\text{sec} \\ 4.4 \times 10^{-3} \times 22.4 (\text{l/mile}) (\text{miles/sec}) &= 9.86 \times 10^{-2} \text{ l/sec} \\ 9.86 \times 10^{-2} \text{ l} \div 28.32 (\text{l/ft}^3) (1 \text{ l} / \text{ft}^3) &= .348 \text{ ft}^3/\text{sec} \times 10^{-2} \end{aligned}$$

3. Removal Rate:


$$\ast .00348 \text{ ft}^3 \text{ He/sec}$$

4. Based on Flow Rate of 57 SCFM 3% He

- $3\% \times 57 \text{ SCFM} = 1.71 \text{ ft}^3 \text{ He/min}$
- $1.71 \times \frac{1}{60} (\text{ft}^3/\text{min}) (\text{min}/\text{sec}) = .0285 \text{ ft}^3/\text{sec}$

$$\ast \text{ Removal Rate} = .0285 \text{ ft}^3 \text{ He/sec}$$

G1712-3.e-5



6/12-3e-6

OTIME	SUB	OTIME	SUB	OTIME	SUB	OTIME	SUB	OTIME	SUB	OTIME	SUB
2.54	1839	4.58	809	5.13	809	5.51	824	6.09	211	6.51	195
3.26	803	4.67	821	5.18	827	5.59	347	6.13	205	6.55	174
3.3	803	4.72	742	5.19	806	5.59	224	6.17	254	6.67	48
3.58	303	4.8	981	5.26	718	5.71	635	6.21	138	6.75	148
3.6	833	4.25	765	5.3	554	5.73	203	6.23	203	6.84	222
3.68	303	4.89	899	5.34	535	5.8	438	6.27	152	7.19	118
3.73	225	4.94	394	5.39	501	5.94	199	6.31	47	7.22	183
3.79	1837	4.92	717	5.44	627	5.91	215	6.35	68	7.24	8
4.28	837	5.04	848	5.5	488	5.95	543	6.5	288	7.67	82
4.43	839	5.08	812	5.54	343						

1.

TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401

6/7/72-3.e-7

April 2, 1979

Metropolitan Edison Company

Attention: Mr. Gibb Staudt

LOAN OF HYDROGEN RECOMBINERS

Attached for execution by an authorized representative of your company is an agreement regarding liability for nuclear energy hazards and incidents applicable to two hydrogen recombiner systems.

The recombiners are being loaned with the understanding that they will be returned to TVA in the same condition as they were received, otherwise TVA will be equitably compensated for the equipment.

The equipment consists of 2 FWR hydrogen recombiner systems P/N H12000001-3 Serial Numbers 111A and 111B; 2 control consoles P/N H12000005-01 Serial Numbers 111A and 111B; one thermocouple test panel P/N H12000004-01 Serial Number 77027-4; and two operating and maintenance manuals DT-95-NPB.

TENNESSEE VALLEY AUTHORITY

J. Marcel Anderson
J. Marcel Anderson
Purchasing Agent

Attachment

Metropolitan Edison Co., in consideration of TVA's loaning two hydrogen recombiner systems to it, agrees that if said property is used in a nuclear facility owned or operated by Metropolitan Edison Co., or by its subcontractor, Metropolitan Edison Co. will furnish nuclear liability protection in accordance with section 170 of the Atomic Energy Act (42 U.S.C. § 2210) and applicable regulations of the Atomic Energy Commission. Should this system of protection be repealed or changed, Metropolitan Edison Co. will undertake to maintain in effect during the period of operation of the plant, to the extent available on reasonable terms, liability protection which would not result in a material impairment of the protection afforded to TVA, Atomic International Division of Rockwell International Corp., or their subcontractors under the existing system.

Metropolitan Edison Co. waives any claim it might have against TVA, Atomic International Division of Rockwell International Corp., or their subcontractors because of damage to, loss of, or loss of use of Metropolitan Edison Co.'s property at the site of the nuclear facility resulting from nuclear energy hazards or nuclear incidents. Metropolitan Edison Co. will indemnify TVA its agents and employees and save each of them harmless from any and all liability to Metropolitan Edison Co.'s employees or any other third parties for personal injuries, property damage, or loss of life or property resulting from or in any way connected with the loaning of the hydrogen recombiners.

The foregoing provisions will apply to the full extent permitted by law and regardless of fault. The subcontractors referred to above include any of TVA's or Atomic International Division of Rockwell International Corp.'s suppliers of material, equipment, or services for the work, regardless of tier.

"Nuclear Energy Hazards" shall mean the hazardous properties of nuclear material. "Hazardous Properties" shall include radioactive, toxic, or explosive properties of nuclear material. "Nuclear Material" shall include source material, special nuclear material, or byproduct material as those are defined in the Atomic Energy Act (42 U.S.C. § 2014).

"Nuclear Incident" shall have the meaning given that term in the Atomic Energy Act (42 U.S.C. § 2014(q)).

Metropolitan Edison Co. shall not transfer any interest in the said property without first providing TVA and Atomic International Division of Rockwell International Corp. with written assurances of limitation of and protection against liability following the proposed removal or transfer in an amount at least equivalent to that afforded under this agreement. In the event of a transfer, such assurances shall be obtained by Metropolitan Edison Co. from the transferee. Transfer contrary to the provision of this agreement shall, in addition to any other legal or equitable rights of TVA or Atomic International Division of Rockwell International Corp., make Metropolitan Edison Co. the indemnitor of TVA and Atomic International Division of Rockwell International Corp., and their subcontractors, to the same extent that TVA and Atomic International Division of Rockwell International Corp., and their subcontractors, would have been protected had no such transfer taken place.

ATTEST:

METROPOLITAN EDISON CO.

TASK TRACKING SHEET

6/712-3e-8

3107

INITIATED BY JACK DEVINE

TASK DESCRIPTION:

1. How Much Gas (PARTICULARLY $H_2 + N_2$) COULD BE IN THE R.C. SYSTEM NOW?
2. UNDER Max. DEGAS. @ 100 gpm LETDOWN How Much Gas Will Come Out of SOLUTION INTO M.U. TANK?

ASSIGNED TO: DANIELS "URGENT"

DATE/TIME ASSIGNED: 4-4-79 1645

RESPONSE REQUIRED BY: ASAP
(Time)

TYPE RESPONSE EXPECTED:

R

- WRITTEN PROCEDURE
- GENERAL DESCRIPTION
- QUICK ANSWER
- OTHER

RESOLUTION:

R.C. PRESSURE = 168 psia pressurizer - 210"
 R.C. TEMP = 545 °F 11,300 ft³ = primary coolant.

- *1. Gas solubility calculations based on H_2 and N_2 , assuming saturation conditions, show that there is approximately 15,000 cu ft (based on standard conditions, i.e. 14.7 psia) of gas in the Reactor Coolant System.
2. Assuming complete degasification in the make-up tank, the degasification rate will be 13 cu ft per minute.

*Note: Per information from J.P. Moore at TIME SITE on 4/5/79, R.C. System conditions used for these calculations are 1000 psia and 280 °F. The temperature of 545 °F above seems to be the local high temp. in the pressurizer to the operation of the pressurizer heaters.

PREPARED BY: Stanley S. Chan / Tim Dempsey

DATE/TIME RESPONSE GIVEN: 4/5/79, 12:10

TRANSMITTED TO: J. Moore by phone VIA: TELECON

- TELECOPY
- MAIL
- HAND CARRIED BY: R. A. GAWLER

J. A. Daniels

4/6/77

①

Maximum H_2 Concentration in Reactor Coolant

Reactor Coolant Inventory: (ft^3)

Reactor	4010
2x Steam gen	4214
4x RC pumps	392
RC inlet	950
RC outlet	932
Pressurizer Surge	20
	<u>10,524</u>

Pressurizer Water	800	(Steam = 700/63)	(Total volume = 1500 ft^3)
	<u>11,324</u>		

Total reactor coolant inventory = $11,324 \text{ ft}^3 = 320,660 \text{ liters}$
 $1 \text{ ft}^3 = 30.48^3 \text{ cm}^3 = 28,316.8 \text{ cm}^3 = 28.3168 \text{ liters}$

From Figure 3: (a) 1000 psia and 258°F

Max H_2 Concentration = 525 cc H_2 / liter @ STP

Maximum Inventory of H_2 in Reactor Coolant:




$$= 525 \left(\frac{\text{cc}}{\text{liter}} \right) \times 320,660 \text{ (liters)} = 168.35 \times 10^6 \text{ cc } H_2 \text{ @ STP}$$

$$= 168,350 \text{ liters (STP)} = \underline{5,945 \text{ scf}}$$

Density of dry H_2 @ STP, 16.5 moles/lb = 1.293 g/liter

What is the Conversion factor between 1 cc (STP) and 16-moles of

Zirconium-Water Reactions:



Assuming $\gamma = 1.4$ in gas law:

$$V = \frac{nRT}{P} = \frac{(0.021978)(10.71)(530)}{14.7} = 8.4866 \text{ scf/lb Zr} \quad (2)$$

1 lb-mole H_2 \rightarrow $\frac{8.4866}{0.021978} \text{ scf } H_2 = 10,934.3 \text{ liter } H_2$
 $1 \text{ liter} = 28.3168 \text{ grams} @ \text{STP}$

Because:

$$\frac{0.021978 \text{ lb-mole } H_2}{1 \text{ lb Zr}} = \frac{0.043956 \text{ lb } H_2}{1 \text{ lb Zr}} = \frac{8.4866 \text{ scf } H_2}{1 \text{ lb Zr}}$$

\therefore 1 liter $H_2 @ \text{STP} = 91.4553 \times 10^{-6}$ lb-mole H_2

Finally, (Appendix A to SRP 6.2.5:
 "Combustible Gas Inside Containment")

Maximum H_2 Inventory in Reactor Coolant @ 283°F, 1000 psia

$$= 168,350 \text{ [liters } H_2 @ \text{STP}] \times 91.4553 \times 10^{-6} \text{ [lb-mole } H_2 \text{ / liter } H_2 @ \text{STP}]$$

$$= 15.3965 \text{ lb-moles } H_2$$

$$= 30.8 \text{ lb } H_2$$




FIGURE 1


Source: T.R. Cronson (NUS)'s Training Manual for an Army DT-1 Salt Resol. (Water Chemistry)

1000
1000

4

FIGURE 2.

(Derived from Data in Figure 1)



(5)





FIGURE 3.1

PERCENT CONSTANT TEMPERATURE (C.P.)

Discussion



Case 1: Assume that H_2 -concentration is equal to maximum value (525 cc/liter) in reactor coolant at 1000 psia and 288°F.

If: (a) RC pressure decreases from 1000 psia to 710 psia while RC temperature is maintained constant at 288°F, then $(525 - 360) = 165$ cc of H_2 /liter will be released from RC to form H_2 bubbles.

(b) RC temperature increases from 288°F to 355°F while RC pressure is maintained constant at 1000 psia, then $(525 - 360) = 165$ cc of H_2 /liter will be released from RC to form H_2 bubbles.

Case II:

Assume that H_2 -concentration is 360 cc/lit^r
in reactor cabinet at 1000 psia and 285°F



If: (a) PC pressure decreases from 1000 psia to 710 psia while PC temperature is maintained constant at 285°F, then no H_2 will be released from PC, but only the maximum H_2 -concentration (at new conditions) will be achieved.

(b) PC temperature increases from 285°F to 355°F while PC pressure is maintained constant at 1000 psia, then no H_2 will be released from PC, but only the maximum H_2 -concentration (at new conditions) will be reached.

Transient Plot views:

(2)

H₂ Removal from Reactor Coolant



DEGASSING FLOW

GAS Diffusion:

ALSO
SEE BACK
OF PAGE

Don't
think
the
table

② Dr R. L. Pigford
300 Wilson Rd
NEWARK DE
302 366-1237

NO ANS-CT

① Dr Aaron Teller
293 Turnpike Rd
Apt 504E
WEST BORO MASS.
617-366-8044

DR. SHELBY MILLER.
ARGONNE NAT LAB - CHICAGO
1-312

Jim Duvall
recommends
not to
recommend
Vivian

① Artisan Industries
WALTHAM MASS 617-593-6800

CHEM SEPS: OAKRIDGE TOWN
615-403-7424.

① Please not
an answer

David Rose (617) 494-8266
Hoyt Hotel (617) 727-3873

Pat...
good...
on...
system

Manny Saylor, Lloyd Nesbitt
Bill DeHollander
Chem Technology E

Shelby Miller
MIT

8:00 PM
billball

① Dr J. Edward Vivian, MIT, (617) 646-3129 (home)
(617) 253-4592
auxiliary stresses on helium system

good to have
on site
system

Mary Saylor, Lloyd Nesbitt
Bill DeHollander
Chem Technology E

copy of ...

8:00 am
will call
back

Dr. J. Edward Vivian, MIT, (617) 646-3129 (home)
(617) 253-4592

Results to be auxiliary nitrogen on helium system

written to 600 . reduce making tank press

per 7/18/79 discussion
-7 DAB
max atom flow in process

let down probably more effective

C.J. King Univ Calif Berkeley Chem Eng

P.L.T. Brun VP Eng Air Products Allentown Pa
325 Lehigh Ave

Kenneth A. Smith, MIT, Manchester, Mass (617) 526-1743

How to Maximize O₂ gas starting from
1000 psic - 285 °F

Revised Available

- 2/1/79

How to Maximize O₂ gas. Starting from
1000 psi - 285 °F

Revises Available

Messengers - Spray rate & height

- Bubble conditions

MIT

Diffusion (Hex gas test) & S/G TUBES)

Other?

Method - draw what size RV bubble

- Strain bubble

- Mix bubble

- Control traps

Fundamental Principles →

MIT,

253-4561
Professor Vivian

→ MIT, Chem Eng.
Exec Dir

Lower Temp.?

FIND OTHER EXPERTS TOO

Tom -

Per vision consultation (telephone) w/ D.A. Rockwell

For improved letdown degassing we want

- 1) higher vessel pressure
- 2) higher temp gives lower H_2 concentration of H_2 left in soln but much higher void fraction on prob better to go to low temp to maximize H_2 removal.

Nucleation press = 535 psi (300°F)

800 psi	.018	vol gas vol liquid
100 psi	.116	
20 psi	.75	

Cooled to (200°F)

gives → 515 psi nucleation press

500 psia	.0008	vol gas vol liq	.61	$\frac{ml H_2}{gm H_2O}$ S.T.P.
300	.013		.36	
100	.116		.11	
20	.75		.011	

← strip H_2 better but larger volume to handle
 ← $\frac{ml H_2}{gm H_2O}$ (left in soln)
 ← $\frac{ml H_2}{gm H_2O}$ (left in soln)
 ← $\frac{ml H_2}{gm H_2O}$ (left in soln)

$P_v = 11.5 \text{ psi steam}$
 $P_v = 8.5 \text{ psi } H_2$

Cooled to (140°F)

gives 506 psi nucleation press

500 psi	.003		.62
300	.016		.37
100	.094		.12
20	.64		.021

is 3% of starting concentration

Higher press good

- 1) higher driving head
- 2) more subcooling so less σ of flow.

Tom Crummins 4/8/79 15:15 5 ~~Flax~~ Deeps

request: Provide addl guidance on use of
verbal potassium permanganate - potential problems,
with interaction, any precipitate, how
is it removed if it needs to be removed, what
is end product?

Requested from Pat 4/8/79 15:40

Response

Murray Siegler, Lloyd Nesbitt 4/9/79 14:40 Telecon

500 psi 285 °F sal of H₂

Would require the addition 1.2×10^4 kg of saturated KMnO₄

This is 5% of total loop volume.

Will make 600 kg of sludge & could increase
pH to a value > 10

Conclusion: sludge could plug bottom filters

H₂O₂ forms soluble product (H₂O)

Will form free O₂ (not good)

If necessary, add very slowly

Verbal response DAR to Dick Wilson, T. Crummins 4/9/79 15:00

Copy to → " " 4/9/79 15:05

Don't Use
KMnO₄

H₂O₂
possible
is req'd

(P) DEBAS

Tom Crammins (GPU)

8/9/79 0840

Request: Get second opinion, perhaps GE, to confirm Vivian's opinion that temperature should be reduced.

Requested from San Jose (Pat Marriott) 4/2/79 0915

Response per telecon of Manny Siegler, Lloyd Nesbitt on 4/9/79 1455

- 1) increased press OK
- 2) temp effect not important on stripping
- 3) 200°F would be better to maximize flow

Confirming telex to be sent.

Verbal response to T. Crammins, Dick Wilson 4/9/79 1500 from EAC

Copy to " " 4/9/79 1505

400, 414179

G/712-3e-9

RCA
RFW

Subj: Containment Bldg Pressure

E.C. Brodin called re. negative pressure design of Containment Building.

Tech Spec limit -2.5 psi (FSR APPENDIX 3B)

Negative design pressure based on tornado (page 14)
not long term negative pressure - the concern is that buckling of the liner may occur. i.e. pop-in

B&L does not recommend exceeding the -2.5 limit. They are going to provide the safety factor built into the codes. They have discussed this with the NRC.

RCA
RFW

Subj: Containment Bldg Pressure

E.C. Berlin Called: Safety factor
for building design = 2. But he does
not recommend using it, in fact,
he recommends getting pressure down to
1/2 ps. He has a concern for buckling of the
liner since the design basis was for
a tornado.



Reactor Coolant System Pressure

To R. F. Wilson

R. F. Wilson

Location: Three Mile Island

The attached discussion and data is forwarded for your consideration as plans are made for where to go from here. There is general consensus among engineers on back shift at Mt. Lakes that starting to slowly reduce primary pressure (about 50 psi every six hours) is the most prudent course of action. Would propose reducing pressure to 350 (+50 -0) psi.

D. G. Slear
D. G. Slear

DCS/al
ATT

*Ash
Keaton
Crimmins*

... pressure -

Problems:

1. Drive dissolved gases back out of solution due to reduced solubility at lower pressures so they can leak out (if we have leak path in head). If we have no spray flow, this gas in solution is not being removed very efficiently and could present a real hazard if we lose pressure rapidly. Could cause 1) NCP gas binding, 2) gas bind natural circulation flow, 3) gas blanket the core.

NOTE: @ 1000 psia can hold 1.3 ml H₂ @ STP/gm H₂O in solution (Figure 4). This equates to 18,314 cuft of H₂ @ STP possibly dissolved in primary coolant.
 $(311,643,660 \text{ gm H}_2\text{O} \times 1.3 \frac{\text{ml}}{\text{gm}} \times 3.53 \times 10^{-5} \frac{\text{ft}^3}{\text{ml}} = 18,314 \text{ ft}^3)$

If we do not drive dissolved gasses out while we have flow, any pressure reduction while on natural circulation may result in gas binding of candy cane. If lost flow at 1000 psi, we may have to stay at 1000 psi indefinitely with only pressurizer or HPI pumps available to maintain pressure.

2. Get to point where we have a backup pressure control mechanism that is relatively passive. Below 600 psi could float on core flood tanks to preclude further pressure reduction.
3. Less cycling of pressurizer heaters so may extend their life.
4. Below 300 psi decay heat system is usable.
5. Below 125 psi, spent fuel cooling and cleanup system is usable if interconnected thru decay heat.

Liabilities of Reduced Pressure:

1. Closer to pump NPSH limits. However, at 1000 psi and 280 F, we are approximately 600 psi higher than NPSH requirements. At 600 psi, we would still have approximately 250 psi cushion before reach pump NPSH curve.
2. Lower pressures require higher natural recirculation flows to keep temperature of primary below T_{sat}. Data available to us is as follows:

Primary Flow (GPM)	Reactor Pressure
327	1000
327	400
327	300
327	250
327	200
327	150
327	100

Compare Natural Circulation Flow Test

<u>Decay Heat</u>	<u>Required Natural Circulation Flow</u> <i>Example</i>	<u>Measured Natural Circulation Flow</u>
$1.66 \times 10^8 \frac{\text{BTU}}{\text{HR}}$	$.99 \times 10^6 \text{ lbm/HR} = 25260 \text{ M}$	$7.6 \times 10^6 \text{ lbm/HR}$

NOTE: We are working with EI to run RETRAN for natural circulation mode and predict flow analytically.

to see if one loop by itself will establish natural circulation. Also using model

3. If need higher pressures later on, reducing pressure now may complicate raising pressure later if pressurizer heaters or level is lost.

Another Benefit of Reduced Pressure:

DHV-1, DHV-2 and DHV-171 are all inside containment and operators may become inoperable due to high radiation. There is a school of thought that they should be opened as soon as practical and left open to give us assurance that Decay Heat is a viable option. They are interlocked to not open above 320 psi.


Containment Integrity

There is a precharge pressure of 400 psi in F&R P&S. Pressure below this may result in further damage to distressed P&S. Should monitor core closely as go down 400 psi.

Dole

450700

UNITED STATES GOVERNMENT
WASHINGTON, D. C.



12. 100 (100)

Message to B. 1/10/77
4/15/77

Dick Wilson/Ton Crimmins

From: Larry Heckriber
WE

As for our phone
conversation last night,
seeing calculations indicate
that the reactor vessel
looks okay from thermal
shock point of view.

Information on the
degasser calculations
and other thermal shock
calculations given to
Dick Wilson

DICK WILSON

1010
4-4-79


PIPING TIE-IN FOR VACUUM DEGASSIFIER
EXHAUST FILTRATION UNIT

The piping tie-in for the vacuum degassifier filtration unit is composed of standard Victrolite couplings.

No welding in the shop or in the field is required. The fittings, which will be located near column lines

TJ-TH and T58-T39, will require that a 72" section of straight pipe be cut. Equipment location, ductwork layout, and exact piping tie in will be provided later. It will be located on elevation 280'-6" in the turbine bldg.

See Drawg. M011



- ① Victaulic, 12" NIPPLE, grooved by plain end. (2)
- ② Victaulic, Tee = 20, 12" X 12" X 12" (2)
- ③ Victaulic Tee, Tee = 701, 12" standard (3)
- ④ Victaulic Vic-Elange 741, 12" (2)
- ⑤ Victaulic Standard Coupling, Style 77, 12" (6)
- ⑥ Victaulic Plain End Pipe Coupling, 12" (2)

Dick Wilson

LOCATION 1111-1

4-4-79

VACUUM DEGASSIFIER DISCHARGE INTO
AUXILIARY BUILDING HEPA

1. HERSHMAN DWG 77-600-20 SHOWS
2. REF: FILE NO 63-01-0076

THE ABOVE AS-BUILT DWG BY HERSHMAN WAS SUBMITTED 9/21/78. IT SHOWS THE CONNECTION OF THE DUCT WHERE G.P.U. DECIDES IT. PCN 5892 REVISED IT TO THE NEW LOCATION. IT IS POSSIBLE THAT HERSHMAN PIECE # (136) STILL EXISTS AT THE SITE AND CAN BE INSTALLED BY REMOVING THE BLIND FLANGE ON PIECE # (133) AND REMOVING THE NEW DUCTWORK WHERE IT ATTACHES TO (137). THE BLIND FLANGE CAN BE MOVED FROM THE EXISTING LOCATION TO THE NEWLY EXPOSED DUCT.

6/712-3.e-11

RF Wilson

TO RF Wilson
4/6/79
2244

DICK WILSON / L Rogers

R. U. [unclear]

(Handwritten signature/initials)

013 010-2

701-10

of [unclear]

VOLUME OF CONTROL ROD DRIVES AND HEAD NOZZLES

Date

6-6-79 - 5:23 p.m.

THE VOLUME OF THE CONTROL ROD DRIVES AND HEAD NOZZLES IS 64 CUBIC FEET. A TABULATION OF THE CALCULATED NOZZLE VOLUMES IS ATTACHED. THE CONTROL ROD DRIVE VOLUME CALCULATIONS WERE PERFORMED AT DIAMOND POWER.

Date

cc: F. A. Burke *for Miller for FR Clarke*
B. A. Ullin
E. E. Schrie *E. E. Schrie*

	No. of Rockets	Individual Volume in Rocket (in. ³)	Total Rocket Volume (in. ³)
	1	106.71	106.71
	4	103.95	415.80
	4	111.50	446.00
33.2013	4	117.60	470.40
36.2013	8	120.76	966.08
37.6075	4	139.91	559.64
38.6075	4	133.05	532.20
39.2100	8	135.31	1082.48
42.0125	8	146.06	1168.48
45.0313	4	155.20	620.80
47.1250	8	159.65	1277.20
48.2500	4	163.20	652.80
50.5313	<u>8</u>	170.38	<u>1363.04</u>
	69	-	9649.30

No. of Drives	Individual Drive Volume (in. ³)	Total Drive Volume (in. ³)
69	1466.6	101,195.6

Total Volume = 110,645 in.³
= 64 ft.³

*Rocket Volume less loadcrew and support tube displacement

Reference: GPO ID 32-1100577-00

1. ... We told him of the results of our degassing calculations and that they generally agreed with the Combustion Engineering results. We also mentioned that the W W calculations were also consistent.
2. As per John Houchman (20000), we told Wilson to have B&W examine the stresses in the tubes if you would cool down the SG quickly with minimum temperature feedwater flow. We told him to consult the Crystal River PBR which indicated that a differential temperature between the tube and the shell of 200F would give a compressive stress of 12000 psia. A 1500F AT would give ~28000 psi. Therefore must bring both shell and tubes down at nearly same temperature to prevent buckling of the tubes.

There doesn't seem to be a thermal shock problem with the shell wall. We also told them to have B&W dig out their transient accident analysis for loss of feedwater heater (we did not have it in an FSAR copy). John Crimm's people (Ted Loyer and Warren Bamford) examined thermal shock and crack growth in a SG tube sheet and reactor vessel if they would have to go to natural circulation.

Their calculations indicated no crack initiation in the vessel and the SG could take 1/4" flow (i.e., it would not fail).

This completes the action items W agreed to on 4/4/79.

L. E. Hochreiter

Telcom with Dick Wilson

Xc: TMC

RFW

RK

TGB (2)

IRCA

Joffe/Bein

D Montgomery

G. Stault / File

10M REMAINS OF CHM LUNNINGTON

Question: what pressure can 1/2 stainless steel pipe
(ASME - CLASS II Section II pipe) and 1/2
fuel pool coolers really take?

Answer:

1. From Shelly Morrison of B&R. (201-262-
the piping into and out of the coolers

is

10" ϕ 8" - Seamless

ASME-A-376

17-512 Type 3

Based on this info

Code	Allowable	Applied at
8"	850 psi	2.5 x 10 ⁶
10"	750 psi	2.5 x 10 ⁶

2. Coolers

Based on Taylor - B&R

coll Hydro gas - shell 200 psi

- Tube 217

Vendca (Ametek) - Fuel tank 1/2

to use coll Hydro gas - upper bowl

given 1/2 filling - 1/2 dia

1. Normal - 102 psi

2. AT - shell 445 psi

3. AT - shell < 30

ASME - A-376

If any of the coolers will be of
GPR must confirm conditions are acceptable

W. BABCOCK & WILCOX COMPANY
 NUCLEAR GENERATION GROUP

6/712-3.e-12

DICK WILSON, CPU OP. CENTER (TELECOPY TO 717-944-5070)

B. S. DUREY, CPU OP. CENTER

FORM 603-9

File No.
or Ref.

Date
APRIL 6, 1979 0703

4b). ESTIMATE OF HYDROGEN CONCENTRATION
 IN THE REACTOR COOLANT

This form to cover one estimate and one output only.

ATTACHED IS A PLOT WHICH SHOWS THE DISSOLVED HYDROGEN CONCENTRATION IN THE REACTOR COOLANT AS A FUNCTION OF TIME AND DEGASSIFICATION RATE. THE CURVES ARE BASED ON THE ASSUMPTION THAT THE SUDDEN APPEARANCE OR DISAPPEARANCE OF A HIGH AC NOISE IN THE PRESSURE SIGNAL FROM THE B-LOOP PRESSURE TRANSDUCER ARE INDICATIVE OF THE APPEARANCE AND DISAPPEARANCE OF BUBBLES, AND THIS ARE INDICATIVE OF WHEN THE COOLANT JUST REACHES ITS SATURATION POINT. WE HAVE THE FOLLOWING TWO DATA SETS:

	DC PRESS. (PSIG)	SAT. H ₂ PRESS. (PSIA)	SOLUBILITY AT SATURATION (PPM. H ₂)
APRIL 1 @ 15:10	900	805	1000
APRIL 2 @ 3:33	805	802	1200

ALSO BASED ON THESE TWO DATA POINTS, WE ESTIMATE AN EFFECTIVE REMOVAL RATE OF $k = 3.7 \text{ DPH}$.

MASS OF RCS WATER @ 280°F 1000 PSIG INCLUDING 1000 FT³ IN PRESSURIZER IS 300,200 KG.

WE HAVE CONTACTED BETTIS (DAPL) TO OBTAIN THEIR ESTIMATE OF THE HYDROGEN REMOVAL RATE, BUT THEY COULD NOT PROVIDE US WITH ANY INFORMATION SINCE THEY ARE RCS'S CONSULTANTS.

NOTE: ALSO TRANSMIT TO LEE ROGERS.
 LEE ROGERS TRANSMIT TO GARY BROUGHTON

RSE:GD
 ATTACHMENT

Effective Degassing Flow Rate: Q_{eff}


$$Q_{eff} = E_1 F_1 + E_2 F_2 + F_3$$

where:

E_1, F_1 = efficiency and flow rate for pressurized film

E_2, F_2 = efficiency and flow rate for mixing tank


F_3 = reactor constant tank rate



STYRON 600000 000

Case Summary

(1980)
(1980)



- ① DEGAS AT A; LOWER PRESSURE (A → A') WHILE DEPRESSING, THEN RETURN TO A.
- ② CONTINUE DESIGN/INSTALLATION OF STATIC AND ACTIVE SYSTEMS FOR PRIMARY MAKEUP/PRESSURE CONTROL AND SECONDARY COOLING SYSTEM FOR 'B' S/G
- ③ REDUCE TEMPERATURE (A → B) BY STEERING ON 'A' S/G
- ④ TAKE 'A' S/G SOLID-DRIP PRIMARY TEMP. TO MINIMUM (100)
- ⑤ TOP RC PUMP 'A' - ESTABLISH NATURAL CONVECTION -
- ⑥ ... COOLING TO 'B' S/G IF AVAILABLE
- ⑦ ... PRIMARY PRESSURE TO CONTROL (C → D)
- ⑧ ... SYSTEM ... ?
- ⑨ ... ?

PRIMARY - HOT WATER, SOLID LIQUID, LONG TERM W/ CHILL
 SECONDARY - SOLID WATER, LONG TERM HEAT EXCH SYSTEM

THE BAWCOCK & WILCOX COMPANY
POWER GENERATION GROUP

telecopier #

G/712-3.e-13
717-744-5070
million #63

To
BOB KEATON, GFU

From
N. S. EMBREY

File copy
1-JGH-L3
1-RLA
1-RFW
1-Reddon
J.G. Brighton
803 643.9

Dist. File No. or Ref.

Subj. RESPONSE TO QUESTIONS RELATIVE TO FREE GAS TESTING Date
PLANNED FOR 1200, FRIDAY, APRIL 6, 1979 APRIL 6, 1979 0725

This letter to cover one document and one related only

THE FOLLOWING ARE RESPONSES TO YOUR QUESTIONS RELATIVE TO THE PLANNED TESTING TO DETERMINE THE PRESSURE LEVEL AT WHICH FREE GAS PRESENT IN THE REACTOR COOLANT SYSTEM WILL COME OUT OF SOLUTION:

1. WHAT IS THE VOLUME OF THE PRIMARY SIDE OF THE CONTROL ROD DRIVE?

ANSWER: THE PRIMARY SIDE VOLUME OF THE CONTROL ROD DRIVES IS 58 CUBIC FEET.

2. WHAT IS B&W'S POSITION ON LOWERING PRESSURE AND CHECKING FOR GAS. THAT IS, WHAT IS THE LOWEST PRESSURE WE WOULD RECOMMEND GOING TO IN DETERMINATION OF THE COMING OUT OF SOLUTION OF DISSOLVED GAS?

ANSWER: THE LIMITS ON PRESSURE FOR THIS TEST SHOULD BE THE SAME AS THOSE PROVIDED IN THE MEMO FROM R. E. KOSIBA TO LEE ROGERS DATED 4/04/79 TRANSMITTED AT 11:10 P.M. TRANSMITTAL LOG #275. THESE LIMITS ARE THOSE RELATIVE TO THE NPSH CURVE FOR THE PUMPS.

3. BE SURE THE REACTOR DIAGNOSTIC GROUP IS READY FOR MONITORING DURING THE SUBJECT TEST.

THE REACTOR DIAGNOSTICS GROUP HAS BEEN INFORMED OF THE PENDING TEST AT NOON ON APRIL 6, 1979 AND WILL BE READY FOR TAKING OF DATA DURING THIS TEST.

4. DOES BSW'S TEST PROCEDURE WHICH REQUIRES LOWERING PRESSURE TO DETERMINE THE PRESSURE AT WHICH GAS COMES OUT OF SOLUTION WORK AT LOWER PRESSURES THAN THOSE PREVIOUSLY USED. THAT IS WILL GAS BE DETECTED IF THE PRESSURE IS REQUIRED TO BE LOWERED IN THE 400-500 PSI RANGE?

ANSWER: THE PROCEDURES SHOULD BE JUST AS EFFECTIVE IN THE LOWER PRESSURE RANGES AS AT THE UPPER PRESSURE RANGES AND AT THE TEMPERATURE OF 200°F BECAUSE THE SAME RELATIVE VOLUME OF GAS COMING OUT OF SOLUTION APPLIES AND HENRY'S LAW IS A LINEAR FUNCTION WITH PRESSURE.

5. CAN BSW SUGGEST AN ALTERNATIVE METHOD FOR DETERMINING THE PRESSURE AT WHICH GAS COMES OUT OF SOLUTION THAN THE USE OF PRESSURE SIGNAL NOISE CONDITIONS?

ANSWER: ANOTHER POTENTIAL METHOD IS TO MEASURE THE PRESSURE BUILDUP IN THE MAKEUP TANK WITH THE VENT VALVE CLOSED. BY KNOWING THE MAKEUP TANK PRESSURE, WATER LEVEL AND PRESSURE AT THE BEGINNING AND END OF THE TEST, AND THE LETDOWN FLOW, THE DISSOLVED GAS IN THE REACTOR COOLANT SYSTEM CAN BE ESTIMATED WITH AN ASSUMED GAS REMOVAL EFFICIENCY IN THE MAKEUP TANK. BASED ON WHAT WE THINK THE DISSOLVED GAS LEVELS IN THE RCS ARE NOW, THE REMOVAL EFFICIENCY SHOULD BE VERY CLOSE TO 100%.

IF YOU HAVE ANY FURTHER QUESTIONS WITH RESPECT TO THE GAS BUBBLE TEST PLANNED FOR THIS NOON, PLEASE LET US KNOW.

NSE:dh

J. W. Berger
0841 4/6/79

6/7/72-3.e-14

6040-004

5040-Jm

L. Wilson

-DKC

PASS TO:

JIM KUNKEL

HIRST TRAILER, TMI

GPJ POPY

WJ INFOMASTER 4-373355F796 04/16/72
ICS IPKRN3Z CSP
ZCZC 2352375660 TDRN HUNTSVILLE AL 275 04-05 0743P EST
TLX 136482 GPJ POPY
KEV PASTOR, THE G.P. UTILITY, TLX IKMY, BUSH
263 CHERRY HILL RD
PARSIPPANY NJ 07054

BT

REFERENCE THREE MILE ISLAND HYDROGEN HIGH PRESSURE STORAGE TANKS AND HYDROGEN CORBLIN COMPRESSORS. THESE ITEMS AVAILABLE FOR IMMEDIATE DELIVERY NOTE USUAL LEAD TIME FOR OBTAINING THESE ITEMS IS 6 TO 9 MONTHS. SIX EACH HYDROGEN STORAGE TANKS, MAXIMUM CODE DESIGN MULTILAYER TANKS FOR SAFEST SERVICE IN CRITICAL APPLICATIONS, AS FOLLOWS: 3 EACH HIGH PRESSURE TANKS WITH HORIZONTAL STANDS 4 FEET DIAMETER BY 9 FEET OAL, WJ 45 CF MAXIMUM DESIGN WP 6600 PSIA, CAPACITY EACH TANK 20,300 SCF ORIGINALLY DESIGNED FOR HELIUM OR HYDROGEN FLOOR SPACE REQUIRED ONLY 4 FEET BY 9 FEET. TANKS WILL STACK FOR MINIMUM SPACE STORAGE. ONE EACH HIGH PRESSURE TANK WITH HORIZONTAL STAND 28 INCHES DIA. BY 16 FEET OAL, WJ 44CF MAX WP 4400 PSIA. TANK STORES 13000 SCF. FLOOR SPACE REQUIRED 28 INCHES BY 16 FEET. ORIGINALLY DESIGNED FOR HELIUM OR HYDROGEN SERVICE.

TWO EACH HIGH PRESSURE TANKS WITH VERTICAL STANDS 4 FEET DIA BY 6 FEET 6 INCHES OAL, WJ APPROX 25CF MAX WP 6000 PSIA, EACH TANK STORES APPROX 10200 SCF, FLOOR SPACE REQUIRED FOR EACH TANK IS SQUARE 4 FEET BY 4 FEET. ORIGINALLY DESIGNED FOR HELIUM OR HYDROGEN. OTHER SUITABLE ASME AND NATIONAL BOARD TANKS AVAILABLE.

TWO EACH HYDROGEN COMPRESSORS MER CORBLIN DIAPHRAGM TYPE. SECTION 250 PSIA UP TO 4000 PSIA. DISCHARGE PRESSURE 3000 PSIA TO 9000 PSIA. SKIDDED UNITS WITH ALL ACCESSORIES INTEGRATED INTO SKID. MAX THRUPUT UP TO 385 SCFM. SKID SPACE 50 INCHES BY 110 INCHES. TOTAL HOURS ONLY ABOUT 30. LIKE NEW.

ALL TANKS AND COMPRESSORS ORIGINALLY VASA SPECIFICATIONS. DRAWINGS AND SPECS AVAILABLE. ALL AVAILABLE FOR INSPECTION. FOB HUNTSVILLE ALABAMA. INSPECTION AND ACCEPTANCE HUNTSVILLE ALABAMA. IMMEDIATE SHIPMENT AVAILABLE

L L MCCLURE, CONSUMER FUELS INC, FONE 235-8375660

NNVV
1946 EST
GPJ POPY

→ R.F. Wilson

→ W.H. Hirst

4/7/79 19.30

Tom -

H.E. mentioned again that you may
want to consider injecting potassium permanganate
to assist in getting H_2 out of solution. Could
it be added to makeup water?

Don Rockwell

6/7/2-3e-1/b

THE BABCOCK & WILCOX COMPANY
POWER GENERATION GROUP

FILE

RCVD 0110 4/7/79

Time: 0110

To: Dick Wilson, CPU
L. C. Powers, T-1-2

TELECOPY #77

From: R. E. Koster *R. E. Koster*

005 002.0

Cost: File No. or Ref.

Subj: Pressure Reduction Procedure During Degasification (Z-57) Date: April 7, 1979

Via letter to sender and customer and also subject only

ATTACHED PLEASE FIND, THE DWM COMMENTS ON THE SUBJECT PROCEDURE.

Handwritten initials

- CC: A. F. HARRIDE
- H. B. [unclear]
- C. F. [unclear]
- J. S. TALESCO

Limits and Precautions:

- 65.C - Minimum pressure for RC pump operation is limited to pump pressure curve in Figure 1 provided that 100 psi is added for instrument error.
- 65.D - RC pump vibration should not exceed limits of 30 mils peak-to-peak shaft vibration and 5 mils frame vibration.
- 65.E - The highest core outlet thermocouple reading shall be maintained at least 10°F below the saturation temperature for the RCS pressure existing at the given point in time. (NOTE: This information replaces the previous criterion.)
- 65.I - (To be added) Terminate further pressure reduction steps in RCS pressure at the end of the 50 psi step sequence if during the sequence the EDM Noise Monitoring personnel indicate that the solubility limit has been reached based on signal noise.
- 65.J - (To be added) The maximum rate of pressure reduction during any sequence should be 5 psi per minute.

Permissives:

- 65.A - Should align RCP 1A as the backup RC pump.
- 65.B - Pressurizer heater control should be in manual. (Note: If heater control is automatic, EDM is concerned about status of heater control during depressurization steps).
- 65.C - Spray flow adjusted to maximize degasification rate and balance the existing heater input.
- 65.G - (To be added) EDM Noise Monitoring Personnel increase strip chart speed to 2 in/min.

Procedure:

- 07.C - Lower primary system pressure by controlling spray flow (and heater operation) and intermittent venting of pressurizer via the 1 inch vent valve (RC-V137).
- 07.E - See limit and precautions 05.J (to be added). If during the pressure reduction sequence either 05.D or 05.E are exceeded, return to the pressure level at the end of the previous sequence.
- 07.F - Upon completion of each of the 50 psi pressure reduction sequences calculate the pressurizer bubble size based on the RCS parameter changes over the 50 psi pressure reduction sequence.

All core outlet thermocouple readings should be submitted to BSI for continuing evaluation.

If BSI Noise Monitoring Personnel report that noise signals indicate that the solubility limit has been reached during the sequence, maintain the plateau pressure of this sequence until noise analysis indicates bubbles are no longer present.

- 07.G - Do not proceed to next pressure reduction sequence until all perturbations of incore thermocouple readings have been stabilized.
- 07.H - BSI recommends that after test is completed, the RCS pressure be slowly raised to ~1000 psi.

Data Required for Bubble Calculation

1. RCS Pressure (Loop A & B)
2. RCS (T_H & T_C)
3. Ra Tank Level and Temperature
4. Pressurizer Level and Temperature
5. Pressurizer Heater Heat Input

Prepared By 1000 Date 1/10/78
 Reviewed By 1000 Date 1/10/78
 Approved By 1000 Date 1/10/78

File Degea

4/7

1030

B & W

Degea half-life!

pld. number \rightarrow 4 days

now - fraction

lost info \rightarrow 50 days

based on the dull
point data

Present estimate: Gas content

2327 and out 4/6/79

~~2327~~

1130 ce/kg \rightarrow

on 4/1/79

1300 ce/kg

4 of STP

4/7/79

1000

Feb → Deques - Band

→ Procedure 50 $\frac{1}{10}$

Doing these would be a reward
→ must be in controlled
fashion → The deques

RFV

G/712-3.e-16

... ..

... ..

... ..
of

... ..

APRIL 7, 1950

... ..

This will confirm that limitation of 600 psig minimum RCS pressure has been removed. This deletion was made in Revision C1 of DRI Procedure 603 which was not sent because we are now working from DRI 62-57.

Limitation is RC Pump section pressure. Use curve of RC Pressure vs. RC Temperature which is Attachment A of Z-57, adding 100 psi for instrument error.

RSC/...

Teletype to R. Boston
Teletype to L. Rogers.

To: Milt Levenson
Subject: Hydrogen in RCS
Copies: J. Hurley

Date: April 6, 1979
From: F. E. Haskin
J. W. Thiesing
Of: Industrial Advisory Group
At: TNI

Degassing History

Rapid degassing of reactor coolant occurred in the make-up tank, with the letdown system in normal alignment (except for bypassing the block orifice), until about 0716 on 3/29/79 at which time the waste gas decay tank pressures approached the shutoff head of the waste gas compressors. At this time, letdown was diverted to the B reactor coolant bleed tank. Letdown continued using the A, B, and C RCB tanks until 1920 on 3/30/79 when the A tank went full. During this time, makeup to the makeup tanks was demineralized water and boric acid which reduced makeup tank pressure from a 65 psig level by redissolving makeup tank gases and injecting them into the PRCS. By 1440 on 3/30/79, both waste gas decay tanks were essentially at the waste gas compressor shutoff head. At 2036 on 3/30/79, makeup to the makeup tanks was shifted to the bleed tanks, letdown from the PRCS was still to the bleed tanks, which also vent to the waste gas compressor. Operation in this mode continued until at least 4/2/79 at 1835 (the end of available operator log data). Sometime after this time, letdown was shifted back to the makeup tank and apparently continues in this mode at this time. RCS makeup to balance RCS leakage and pressurizer leakage is being taken from the reactor coolant bleed tanks.

Clearly, the waste gas decay tanks have been unable to accommodate additional hydrogen gas since about 1440 on 3/30/79 at which time the tank pressures were about 84 psig, estimated to be the compressor shutoff head. During the ensuing period, regardless of whether the makeup tank or the bleed tanks are receiving letdown, offgas must have followed one or more of the following paths:

1. Released to the auxiliary building via the reactor coolant bleed tank relief valves.
2. Leaked to the auxiliary building through leakage paths, probably downstream of the compressor.
3. Leaked to the auxiliary building from waste gas collection header upstream of compressors.

M. E. Haskin
J. W. Thiesing

April 6, 1979

We estimate that this mode of degassing is probably quite efficient and it is possible, if not probable, that hydrogen concentrations in the PRCs are quite low.

F. E. Haskia

J. W. Thiesing

FEH/JWT/dms

It is also of importance that, prior to 2036 on 3-30-79, letdown to the makeup tank resulted in rapid pressurization of the tank, surmised to be a result of rapid degassing of RCS water coupled with inability to vent the tank to the waste gas decay tanks, which were approaching the compressor shutoff head. This inability to vent still exists, but letdown to the makeup tanks no longer results in ^{rapid (as permes only)} tank pressurization. The implication is a low degas rate at present, and thus a low PRCs hydrogen concentration.

FEH
JWT

PROCEDURE FOR MEASURING REACTOR COOLANT HYDROGEN CONCENTRATION

4-0-17
Friday, February
1955.

1. Bring MU tank level to approximately 55" pumping by transferring, if necessary, liquid from RC Bleed Tank. Maintain letdown flow at maximum available rate, hold constant. (*Flow < 25 gpm*)

Align MU-V8 to take reactor coolant letdown directly to makeup tank.

2. Open either MU-V13 or MU-V134 and pull the makeup tank pressure down as far as possible with the waste gas compressor.

3. Promptly close MU-V13 and MU-V134 to isolate gas space in makeup tank. (*H₂, N₂, and sampling lines should be isolated*).

5-15 psi range

4. Record:

- a. Time
- b. WDG vent header pressure
- c. Makeup tank pressure
- d. Makeup tank level
- e. Makeup tank temperature
- f. Letdown flow, seal return flow.

Record these parameters at the initiation of Step 3 and every time the make-up tank pressure increases 1 to 5 psig, depending on rate of pressure increase.

5. Continue procedure for as long as possible, consistent with makeup tank pressure limits and plant operating necessities.

> 15 psi

6. Secure from procedure, return to normal operating mode.

←
Ramp in fresh water to quench pressure before venting

THE ATTACHED INFORMATION IS IN RESPONSE TO YOUR QUESTION REGARDING THE
CERTAIN CASES LISTED IN THE FINANCIAL INFORMATION GUIDE

APRIL 6, 1979- 2127

REZ/leh

cc: JIM TAYLOR




ATTENTION: E.D. WALLACE

Vogel 100 2/112-3.e-17

Inter-Office Memorandum

Task 3107



Date April 7, 1979

Subject

(F) DEGAS

To J. C. DeVine

Location TMI Site

Xc; TMC
RFW
TGB
R Kautm

On 4/5/79 you received a reply to TTS #3107 concerning the amount of gas in the RC system and how much will come out of solution into the makeup tank.

Later calculations indicate that the original estimate of 15,000 ft.³ was high by at least a factor of two. A calculation showing that the equilibrium concentration of hydrogen in the primary loop at 235°F and 1000 psig is approximately 6000 ft.³ (STP) is enclosed (Note: Hydrogen is the predominant gas by far so 6000 ft.³ is probably a good estimate for total gas).

Also enclosed is a proposed method for degassing without releasing any gas bubble.

If you have any questions, contact John Daniel or Jack Thorpe at Mt. Lakes.

Jack/c
J. R. Thorpe

JRT:ejm
att.

PRIMARY PLANT CONDITIONS

Pressure - 1000 psig
Temperature - 290°F

1. Maintain temperature and pressure while degassing via a "bleed and feed" process.
 - a) Degas letdown being returned as much as possible.
 - b) Makeup with degassed water only.
2. Continue process until hydrogen concentration in the primary coolant is approximately 40 cc/liter. This is the equilibrium conditions for 290°F and 100 psig.
3. Slowly depressurize primary loop to 100 psig, holding primary temperature at 290°F. Monitor primary system inventory to assure that no gas bubbles are being evolved (Note: There should be none).
4. Maintain the primary pressure at 100 psig and cool the primary. This will increase the solubility of gas in the liquid, increasing our safety margin in this area.
5. Continue to makeup with degassed water.

NOTE: Since hydrogen is the predominant gas dissolved in the primary loop, control of it will assure control of other gases in the loop.

Tom - *Q. J. 2015*

STOR UNIT 4/8/79 18:35

Per Vision consultation (telephone) w/ D.A. Rockwell
 For improved letdown degassing we want

- 1) higher vessel pressure
- 2) higher temp gives lower H₂ concentration of H₂ left in soln but much higher vol fraction so vol better to go to low temp to maximize H₂ removal.

Nucleation press = 535 psi (300°F)

500 psi	.018	vol gas vol liquid
100 psi	.116	
20 psi	.75	

Cooled to (200°F)

gives → 515 psi nucleation press

500 psia	.0008	vol gas vol liq
:00	.018	
100	.116	
20	.644	

slightly H₂ better but larger volume to handle

.63 $\frac{ml H_2}{gm H_2O}$ (left in soln)
 .61 $\frac{ml H_2}{gm H_2O}$ S.T.P.
 .36
 .11
 .011

P_v 11.5 psi STM
 P_v 8.5 psi H₂

Cooled to (140°F)

gives 506 psi nucleation press

500 psi	.003	
300	.016	
100	.094	
20	.64	

.021 is 3% of starting concentration

Higher press good 1) higher driving head

curr. | ^{Person}
April 3, 1977

J. Bechtel

Subj Primary Sample. Degas

The highest priority from Tech Support for the Re Collect Sample Anal is total gas content. This requires a pressurized sample for which additional precautions (shielding, more people etc) may be required. Nevertheless it is very important for our eventual depressurization & other analyses are needed ~~ie activity~~ Barium concentration is of high priority for pressure subcriticality. Other analyses ie activity total and isotopic would

• • • • •

If H_2 content of the cell gas
could be determined easily this would
be important —

W. M. C. C. C.

INITIATED BY BS

5/712-3e-20

3061
K: PFW

TASK TRACKING SHEET

TASK DESCRIPTION:

WHAT IS SOLUTION TO LONG TERM DISPOSAL OF CONTAINMENT ATMOSPHERE.

ASSIGNED TO: John Danise

DATE/TIME ASSIGNED: 4/2 22.50

DETAILS/STATUS:

CONTAINMENT

RESOLUTION:

Containment atmosphere will level off approximately April 30, 1979 at 500,000 Ci, most of which is Sr-89 & 90. Significant quantities of K-85 are also present. Long term disposal may be accomplished by cryogenic storage (may take 4-5 years) or by filtered release to the environment, at variable purge rates as atmospheric conditions permit. Dose calculations are being performed by Richard Lowe & Derrick.

DATE/TIME RESOLVED:

J. Danise / 4/8/79

Wilson — Ma. I
J. Devine

14.01
64-69-79

D. A. Rockwell

- 2 -

April 9, 1979

Case 4. Experience data from GE BWRs on shut down at 5 MPa (as in 2 above) 9 scfh

Case 5. The most likely value is case 3 with the ANL6565 non boiling corrective factor of 0.03: $73 \text{ (scfh)} \times 0.03 \left(\frac{\text{non boiling}}{\text{boiling}} \right)$ 2.2 scfh

H₂ removal rate by solubility based on 515 psia and 200°F. we can remove 100 scfh.

Conclusion: Even in the worst case at 515 psi the radiolysis H₂ can be removed even at 10 gpm with a factor of safety greater than 10 (based on non boiling).

As per 1300 PST this date we have data from plant that shows possibility of slow boiling in core - if we use BWR boiling data our rates would be 10-20 scfh.

III. Potassium Permanganate as a Hydrogen Getter

We have considered what problems might be encountered. In using K MnO₄ to remove H₂. Assumingly saturated loop at 500 psi 200°F: this would require the addition of 1.6×10^4 kg of saturated KMnO₄ water solution - about 6% of the total primary loop volume or about 1400 minutes at 3 gpm.

This would add about 1000 kg of K MnO₄ and yield about 600 kg MnO₂ sludge if all the H₂ were reacted. This much sludge could interfere with the freedom flow. KOH is an end product of the reaction, so the coolant could become quite basic (pH is 12). Materials properties are still being studied. A better alternative might be H₂O₂ because the reaction product is H₂O. The major question is the decomposition of H₂O₂ to form O₂ (free) which could lead to H₂O₂ and the possibility of rapid reaction. The decomposition would be less troublesome with slow injection so that the H₂O₂ could immediately react with ample H₂ in the vicinity of the injection point.

P. W. Merritt

P. W. Merritt, Chairman
Three Mile Island Task Force

/esp

Hydrogen Concentration 2.1%

Cont. Volume 2,000,000 FT³. X 2.1% = 42,000 FT³ H₂.
 Recombined flow 9.0 SCFM.

90 X 60 X 24 = 130,000 FT³/day. X 2.1% = 2,722 FT³/day.

Start	Date	H ₂ (start)	Recom	Total	%
15:05	4/2/79	42.0K	2.7	39.3	1.96
First day	4/3	39.3	2.5	36.8	1.84
Second day	4/4	36.8	2.4	34.4	1.72
Third day	4/5	34.4	2.2	32.2	1.61
Fourth "	4/6	32.2	2.1	30.1	1.50
	4/7	30.1	1.9	28.2	1.41
	4/8	28.2	1.8	26.4	1.32
	4/9	26.4	1.7	24.7	1.24
	4/10	24.7	1.6	23.1	1.10
	4/11	23.1	1.4	20.7	1.04
	4/12	20.7	1.3	19.4	0.97
	4/13				

Assume No Net H₂ input to Containment

Gray Miller
 Joe Logan, Plant Superintendent.
 Jack Heebner VP. Generation
 Kreitz
 Dieckman.

6/7/12-3.e-22

OPERATING PRESSURE CONSIDERATIONS

Operation in a boiling mode at atmospheric pressure has the advantage of maintaining the system at the final desired end conditions. However, there are several concerns that suggest this may not be the best operating condition:

1. Low vapor density will make system less stable, particularly due to large changes in vapor volume with changes in condensation rate (S.G. level oscillation concern).
2. Relatively lower H₂ concentrations in water would require higher bleed flows to compensate for any continuous H₂ source.
3. Eliminates driving potential to operate letdown system or other degas techniques.
4. Maximizes volumes of non-condensable gas.

These same considerations suggest that "higher is better" for the boiling mode operating pressure. The maximum pressure may be determined by other considerations (e.g. back-up RHR limits).

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

Pat Marriott 4/8/79 1605

Task VII

Request: Copy of IASG (Milt Livingston) procedure
for setting up boiling mode.
(BW Memo 63)

Requested from Tom Crummins @ 1620 4/8/79 verbally
" " " " 0955 4/9/79 written

Done

Pat Marriott 4/9/79 0925

Request: Copy of fig showing planned maneuvers
on Press/Temp plot

Telecopied 4/10/79 1020 to Marriott

To: Milt Levenson

Date: April 9, 1979

Subject: RCS Behavior

From: J. W. Thiesing

Copies: J. C. Judd

Of: TMI - IAG

The following is an assessment of RCS behavior in the "percolating" mode before large amounts of noncondensibles build up:

Initial Conditions

1. Secondary side solid -- cold water
2. Pressurizer vented to containment atmosphere, either by relief valve open or through 3/8" sample line re-plumbed to containment. ~ 2"
3. Primary system solid
4. Core flood tanks floating -- either under N₂ head or on head tank
5. Little or no non-condensibles
6. RC pumps off
7. Assume little or no natural circulation

Behavior

1. Heat generation in core will form steam
2. Steam will form bubble in top of vessel
3. Steam bubble will displace water and raise pressurizer level (~~and head tank level if in place.~~)
4. When bubble uncovers top of hot legs, steam will (eventually) slide out hot leg, forming bubble at top of candy cane quite rapidly (roughly 5000 - 10000 cfm).
5. The increasing bubble volume continues to drive water into pressurizer (~~and core flood, if on head tank.~~)
6. The increasing bubble volume in candy cane uncovers cold tubes in steam generator until such time as the condensing rate in steam generator equals or exceeds the steaming rate in the core.
7. Then,
 - a. If the system is heavily damped, a steady state steaming in core/condensing in steam generator condition will result.

Or

- b. If the system is undamped which is more likely the bubble in the steam generator and candy cane will collapse rapidly, and the process will begin at Step 3 above again and repeat itself, ad infinitum.

In this mode before significant non-condensibles build up, I do not believe there will be any percolating through the pressurizer, only a rising and falling of water level in the pressurizer.

Non-condensibles formed during this time will be swept to the top of the candy cane where they will form a bubble at the top of the bend.

Percolation may occur every 0.5 to 0.5 sec⁻¹

Step I Go to Natural Circulation-with Pressurizer Solid

- A. Float core flood tanks at B&W set pressure, but with tanks solid and pressure coming from N_2 tanks outside containment. This is to expedite conversion to Step II if and when deemed desirable.
- B. All valves from primary system to Auxiliary Building closed except for occasional use of core flood tank fill line to make up losses.

Step II Conversion to Benign Building

- A. Remove high pressure N_2 supply from core flood tanks.
- B. Open Pressurizer Vent valve. Leave open. Pressurizer Sample Line should have been rigged in reentrant mode back to containment so that if the vent block valve cannot be opened, the sample line is a fall back.
- C. Eventual steady state may result in occasional bubbles rising through flooded pressurizer.
 - 1. Water (plus additives such as H_2O_2 if desired) can be added via core flood tank fill line.
- D. Eventual state may permit isolation of steam generator secondaries and use of hot drain coolers as heat sinks--needs to be looked at.

TRN-2 OPERATIONS

6/112-3e-23

TRANSMITTAL TO:

DE-ROGERS TRANSMITTAL # _____

ALSO TELECOPY TO:

R. WILSON TRANSMITTAL # _____

B&W TRAILER 26 TRANSMITTAL # _____

TIME 1400

DATE 4/9/79

SUBJECT RCS HYDROGEN CONCENTRATION

APPROVED BY [Signature]
OPERATION MANAGER

B&W ACTION # 237 (ICAT)

This letter to cover one customer and one subject only

ATTACHED IS AN EVALUATION OF THE PAST AND PRESENT HYDROGEN GAS SITUATION
IN THE REACTOR COOLANT SYSTEM.

DAN:dsf

- cc: W. N. BISHOP
- R. B. COAD
- M. J. BELL
- J. H. HICKS
- W. R. STAGG

OVERVIEW OF HYDROGEN GAS PROBLEM IN THE REACTOR COOLANT SYSTEM

THE FOLLOWING SUMMARY ATTEMPTS TO CONNECT THE KNOWN TECHNICAL FACTS ASSOCIATED WITH THE QUANTITY OF HYDROGEN CONTAINED IN THE REACTOR COOLANT SYSTEM. THE METAL WATER REACTION WHICH APPARENTLY OCCURRED DURING INITIAL PHASES OF THE ACCIDENTS GENERATED LARGE QUANTITIES OF HYDROGEN GAS. THE TECHNIQUES FOR MEASURING THE AMOUNT OF GAS IN THE REACTOR COOLANT SYSTEM WERE NOT IMMEDIATELY AVAILABLE AND REQUIRED SEVERAL DAYS TO DEVELOP. AFTER THE TECHNIQUES WERE DEVELOPED, MEASUREMENTS OF BUBBLE SIZE SEEMED TO CORRELATE VERY WELL AS EVIDENCED BY FIGURE 1. FIGURE 1 INDICATES THAT THE BUBBLE VOLUME TENDED TO DECREASE AT A LINEAR RATE WHICH IS REASONABLE CONSIDERING THAT THE REACTOR COOLANT SYSTEM WAS HELD AT CONSTANT PRESSURE. FIGURE 1 ALSO INDICATES THAT WHEN GAS SOLUBILITY IS CONSIDERED, THE BUBBLE VOLUME SHOULD HAVE DECREASED TO 0 AT ABOUT 1500 HOURS ON APRIL 1. AT 1510 ON APRIL 1 WE OBSERVED A MARKED INCREASE IN THE AMOUNT OF NOISE ON THE PRESSURE SIGNAL FROM THE TRANSMITTER MONITORING THE REACTOR COOLANT SYSTEM PRESSURE ON A LOOP. THIS CAN BE SEEN BY REFERRING TO FIGURE 2. FIGURE 2 IS INTERPRETTED AS FOLLOWS: THE RIGHT HAND TRACE IS A TRACE OF THE REACTOR COOLANT SYSTEM PRESSURE MONITORED ON LOOP A. THIS IS THE DC PRESSURE SIGNAL. THE LEFT HAND TRACE IS THE AC NOISE COMPONENT OF THE DC SIGNAL FROM THE A LOOP PRESSURE TRANSMITTER. KEEPING IN MIND THAT TIME PROGRESSES FROM THE BOTTOM TO THE TOP OF THE CHART, THE NOISE SIGNAL IS INTERPRETTED AS FOLLOWS: THE LOWER PORTION OF THE SIGNAL IS AT A VERY HIGH GAIN SETTING AND THEREFORE EXHIBITS HIGH AMPLITUDE. THAT GAIN SETTING WAS REDUCED AT ABOUT 1555 HOURS; THE NEXT PORTION OF THE CHART IS THE 15 MINUTE PERIOD AT LOW GAIN SETTING

FROM 1555 TO 1610 HOURS; THE UPPER PORTION OF THE CHART WHICH STARTS AT 1510 HOURS IS THE PORTION THAT REFLECTS THE HIGH NOISE COMPONENT WHEN BUBBLES ARE NOT PRESENT IN THE REACTOR COOLANT. WE BELIEVE THAT A BUBBLE WILL DAMP THE VIBRATION. INITIALLY THIS WAS INTERPRETTED TO MEAN THAT ALL OF THE HYDROGEN GAS VOID VOLUME HAD BEEN REMOVED FROM THE REACTOR COOLANT SYSTEM. SUBSEQUENT THINKING HAS LED US TO BELIEVE THAT IT IS ONLY INDICATIVE OF THE ABSENCE OF BUBBLES WHICH ARE CIRCULATING AROUND THE LOOP IN THE REACTOR COOLANT. IT CAN BE SEEN BY AGAIN REFERRING TO FIGURE 1 THAT IF SOLUBILITY OF THE GAS IS NOT INCLUDED IN THE BUBBLE SIZE CALCULATION ONE WOULD ESTIMATE THAT THERE IS STILL A SMALL VOLUME OF HYDROGEN REMAINING IN THE REACTOR COOLANT SYSTEM. OUR PRESENT THINKING IS THAT THIS GAS IS CONTAINED IN THE CONTROL ROD DRIVE HOUSING AND AS SUCH IS NOT READILY AVAILABLE FOR REMOVAL BY ABSORPTION INTO THE REACTOR COOLANT. ONE WOULD EXPECT THAT UPON PRESSURE REDUCTION THIS GAS CAUGHT IN THE CONTROL ROD DRIVE WOULD EXPAND AND BE SWEEP INTO THE REACTOR COOLANT FLOW STREAM. SUCH AN EVENT IS DOCUMENTED IN FIGURE 3 WHICH SHOWS THE EFFECTS OF A PRESSURE REDUCTION WHICH OCCURRED AT 0333 HOURS ON APRIL 2. NOTE THAT THE HIGH NOISE LEVEL CONTINUED UNTIL 0330 HOURS ON APRIL 2 AND THEN SHOWED A MARKED DECREASE IN AMPLITUDE FOR THE TEN MINUTE PERIOD THAT THE PRESSURE WAS BELOW 900 PSIG. THE MINIMUM PRESSURE REACHED DURING THIS PRESSURE TRANSIENT WAS ABOUT 865 POUNDS AS SHOWN IN FIGURE 4. DURING THE PERIOD FROM APRIL 2 TO APRIL 6 EXTENSIVE EFFORTS WERE MADE TO DEGAS THE REACTOR COOLANT SYSTEM VIA THE PRESSURIZER AND THE MAKEUP TANK. BASED ON THESE EFFORTS ONE WOULD EXPECT THAT THE DISSOLVED HYDROGEN CONCENTRATION IN THE REACTOR COOLANT SYSTEM SHOULD HAVE DECREASED FROM ABOUT 1300 STANDARD CC'S PER KILOGRAM TO ABOUT 300 STANDARD CC'S PER KILOGRAM. HOWEVER, AT 0041 HOURS ON APRIL 7, WHEN ANOTHER REACTOR COOLANT SYSTEM PRESSURE DECREASE OCCURRED SOME ADDITIONAL GAS WAS EXPELLED FROM THE CONTROL ROD DRIVE AREA. FIGURE 5 SHOWS THAT WHEN THE PRESSURE WAS DECREASED TO 825 POUNDS, WHICH IS 35 POUNDS LOWER THAN THE PREVIOUS PRESSURE REDUCTION, A CORRESPONDING REDUCTION WAS INDICATED IN THE NOISE SIGNAL ASSOCIATED WITH THAT SAME

PRESSURE TRACE. IN CONCLUSION, WE FEEL THAT THERE IS STILL SOME GAS TRAPPED IN THE CONTROL ROD DRIVE AREA, THAT THAT GAS IN THE CONTROL ROD DRIVE WILL EXPAND UPON EACH SUCCESSIVE PRESSURE REDUCTION AND WILL BE SWEEPED INTO THE REACTOR COOLANT FLOW, THAT THE AC NOISE TRACE WILL OBSERVE THE APPEARANCE OF THESE BUBBLES UPON RELEASE INTO THE FLUID STREAM, AND THAT IF THE PRESSURE IS HELD CONSTANT AT THE LOW VALUE THE BUBBLES CIRCULATING IN THE COOLANT WILL SLOWLY DISSOLVE AND THE HIGH AMPLITUDE AC NOISE SIGNAL SHOULD RETURN. THE TIME REQUIRED TO DISSOLVE THE BUBBLE IS AN INDICATION OF THE COOLANT'S PROXIMITY TO SATURATION. THAT IS, IF THE COOLANT IS SATURATED THE BUBBLES WILL REMAIN SUSPENDED INDEFINITELY PROVIDED THAT THE COOLANT SYSTEM PRESSURE REMAINS CONSTANT, BUT IF THE SOLUTION IS FAR FROM ITS SATURATION CONDITION, THE BUBBLES SHOULD DISSOLVE RATHER RAPIDLY. IT IS THEREFORE IMPERATIVE THAT WE CONDUCT THE TESTING PER PROCEDURE GPUS57 WHILE THE RC PUMPS ARE AVAILABLE AND BEFORE ATTEMPTS ARE MADE TO GO TO NATURAL CIRCULATION.

SIGNED,

Donald A. Nitti by My Beil

DONALD A. NITTI

Gen. Bill. Volume (1853)

Year	Month	Day	Particulars	Debit	Credit	Balance
1853	Jan	1	To Balance			100.00
1853	Jan	15	By Cash		50.00	150.00
1853	Jan	31	To Cash	50.00		200.00
1853	Feb	1	To Cash	25.00		225.00
1853	Feb	15	By Cash		75.00	300.00
1853	Feb	28	To Cash	75.00		375.00
1853	Mar	1	To Cash	100.00		475.00
1853	Mar	15	By Cash		150.00	625.00
1853	Mar	31	To Cash	150.00		775.00
1853	Apr	1	To Cash	200.00		975.00
1853	Apr	15	By Cash		250.00	1225.00
1853	Apr	30	To Cash	250.00		1475.00
1853	May	1	To Cash	300.00		1775.00
1853	May	15	By Cash		350.00	2125.00
1853	May	31	To Cash	350.00		2475.00
1853	Jun	1	To Cash	400.00		2875.00
1853	Jun	15	By Cash		450.00	3325.00
1853	Jun	30	To Cash	450.00		3775.00
1853	Jul	1	To Cash	500.00		4275.00
1853	Jul	15	By Cash		550.00	4825.00
1853	Jul	31	To Cash	550.00		5375.00
1853	Aug	1	To Cash	600.00		5975.00
1853	Aug	15	By Cash		650.00	6625.00
1853	Aug	31	To Cash	650.00		7275.00
1853	Sep	1	To Cash	700.00		7975.00
1853	Sep	15	By Cash		750.00	8725.00
1853	Sep	30	To Cash	750.00		9475.00
1853	Oct	1	To Cash	800.00		10275.00
1853	Oct	15	By Cash		850.00	11125.00
1853	Oct	31	To Cash	850.00		11975.00
1853	Nov	1	To Cash	900.00		12875.00
1853	Nov	15	By Cash		950.00	13825.00
1853	Nov	30	To Cash	950.00		14775.00
1853	Dec	1	To Cash	1000.00		15775.00
1853	Dec	15	By Cash		1050.00	16825.00
1853	Dec	31	To Cash	1050.00		17875.00
1854	Jan	1	To Cash	1100.00		18975.00
1854	Jan	15	By Cash		1150.00	20125.00
1854	Jan	31	To Cash	1150.00		21275.00
1854	Feb	1	To Cash	1200.00		22475.00
1854	Feb	15	By Cash		1250.00	23725.00
1854	Feb	28	To Cash	1250.00		25000.00
1854	Mar	1	To Cash	1300.00		26300.00
1854	Mar	15	By Cash		1350.00	27650.00
1854	Mar	31	To Cash	1350.00		29000.00
1854	Apr	1	To Cash	1400.00		30400.00
1854	Apr	15	By Cash		1450.00	31850.00
1854	Apr	30	To Cash	1450.00		33300.00
1854	May	1	To Cash	1500.00		34800.00
1854	May	15	By Cash		1550.00	36350.00
1854	May	31	To Cash	1550.00		37900.00
1854	Jun	1	To Cash	1600.00		39500.00
1854	Jun	15	By Cash		1650.00	41150.00
1854	Jun	30	To Cash	1650.00		42800.00
1854	Jul	1	To Cash	1700.00		44500.00
1854	Jul	15	By Cash		1750.00	46250.00
1854	Jul	31	To Cash	1750.00		48000.00
1854	Aug	1	To Cash	1800.00		49800.00
1854	Aug	15	By Cash		1850.00	51650.00
1854	Aug	31	To Cash	1850.00		53500.00
1854	Sep	1	To Cash	1900.00		55400.00
1854	Sep	15	By Cash		1950.00	57350.00
1854	Sep	30	To Cash	1950.00		59300.00
1854	Oct	1	To Cash	2000.00		61300.00
1854	Oct	15	By Cash		2050.00	63350.00
1854	Oct	31	To Cash	2050.00		65400.00
1854	Nov	1	To Cash	2100.00		67500.00
1854	Nov	15	By Cash		2150.00	69650.00
1854	Nov	30	To Cash	2150.00		71800.00
1854	Dec	1	To Cash	2200.00		74000.00
1854	Dec	15	By Cash		2250.00	76250.00
1854	Dec	31	To Cash	2250.00		78500.00

1854




Figure 2





Figure 3

Report of
some work

Figure 1

Dec 20 1979
10:00
10:15
10:30
10:45
11:00
11:15
11:30
11:45
12:00



10:05 10:30 10:55 11:20 11:45

TIME on 4/2/79




Figure 5

Smith # 12
 Page 1 of 3
 APRIL 4, 1977

FOR: ERIC HOSKIN OF BEENTEL
 717-944-1012
 717-944-4756

FROM: D.A. NITTI - BIL

TABLE 2. SOLUBILITY OF MERCURY IN WATER

F2 Partial Pressure, P.s.i.a.	Source	ml. H ₂ (S.T.P.)/g. of Water	Average	Probable Error	Maximum Deviation
300	W. and O. (2)	75°F. ---	0.32	--	-- $m = \frac{y}{x} = \frac{0.32}{0.10} = 3.2$
367		125°F. ---	0.46	--	-- $m = \frac{y}{x} = \frac{0.46}{0.10} = 4.6$
200	P.H.I.	0.33	0.33	0.01	+0.05
300		0.42	0.41	0.00	+0.01
350		0.47	0.44	0.01	+0.02
100	I. and T. (3)	300°F. ---	0.13	---	---
200		---	0.23	---	---
300		---	0.40	---	---
375		---	0.52	---	---
500		---	0.70	---	---
100	I. and T. (3)	245°F. ---	0.15	---	---
200		---	0.30	---	---
300		---	0.43	---	---
375		---	0.55	---	---
500		---	0.75	---	---
100	I. and T. (3)	390°F. ---	0.18	---	---

REFERENCE: BAIL-T-25




FIGURE 7. SOLUBILITY OF HYDROGEN IN WATER

0-10200




FIGURE 5. SOLUBILITY OF HYDROGEN IN WATER

STAUD

Hydrogen Concentration 2.1%

Cont. Volume 2,000,000 FT³. X 2.1% = 42,000 FT³ H₂.

Recombined flow 9.0 SCFM.

90 X 60 X 24 = 130,000 FT³/day. X 2.1% = 2,722 FT³/day.

Start	4/2/79	H ₂ (start)	Recom	Heads	%
First day.	4/3	42.0K	2.7	39.3	1.96.
Second day.	4/4	39.5	2.5	36.8	1.84
Third day	4/5	36.8	2.4	34.4	1.72
Fourth "	4/6	34.4	2.2	32.2	1.61
	4/7	32.2	2.1	30.1	1.50
	4/8	30.1	1.9	28.2	1.41
	4/9	28.2	1.8	26.4	1.32
	4/10	26.4	1.7	24.7	1.24
	4/11	24.7	1.6	22.1	1.10
	4/12	22.1	1.4	20.7	1.04
	4/13	20.7	1.3	19.4	.97

Because No Net H₂ input to Containment

Gary Miller.
 Joe Logan, Plant Superintendent.
 Jack Heebma V.P. Generation
 Cretz
 Dieckamp.

Hydrogen Concentration 2.1%

Cont. Volume 2,000,000 FT³. X 2.1% = 42,000 FT³ H₂.

Recombiner flow 9.0 SCFH.

90 X 60 X 24 = 130,000 FT³/day. X 2.1% = 2,722 FT³/day.

	Date	H ₂ (start)	Recom	H ₂ (end)	%
Start	4/2/79	42.0K	2.7	39.3	1.96
First day	4/3	39.3	2.5	36.8	1.84
Second day	4/4	36.8	2.4	34.4	1.72
Third day	4/5	34.4	2.2	32.2	1.61
Fourth "	4/6	32.2	2.1	30.1	1.50
	4/7	30.1	1.9	28.2	1.41
	4/8	28.2	1.8	26.4	1.32
	4/9	26.4	1.7	24.7	1.24
	4/10	24.7	1.6	22.1	1.10
	4/11	22.1	1.4	20.7	1.04
	4/12	20.7	1.3	19.4	0.97
	4/13				

Assume No Net H₂ input to Containment

Gary Miller.
 Joe Logan, Plant Superintendent.
 Jack Heebma V.P. Generation-
 Credit
 Disclaim.

Hydrogen Concentration 2.1%

Cont. Volume 2,000,000 FT³. $\times 2.1\% = \underline{\underline{42,000}}$ FT³ H₂.

Recombined flow 9.0 SCFH.

90 X 60 X 24 = 130,000 FT³/day. $\times 2.1\% = 2,722$ FT³/day.

	Date	H ₂ (Start)	Remove	Head	%
Start	15:05	4/2/79			
First day	4/3	42.0K	2.7	39.3	1.96
Second day	4/4	39.5	2.5	38	1.84
Third day	4/5	36.8	2.4	34.4	1.72
Fourth "	4/6	34.4	2.2	32.2	1.61
	4/7	32.2	2.1	30.1	1.50
	4/8	30.1	1.9	28.2	1.41
	4/9	28.2	1.8	26.4	1.32
	4/10	26.4	1.7	24.7	1.24
	4/11	24.7	1.6	22.1	1.10
	4/12	22.1	1.4	20.7	1.04
	4/13	20.7	1.3	19.4	.97

Assume No Net H₂ input to Containment

Gray Miller
 Joe Logan, Plant Superintendent.
 Jack Heebme VP. Generation -
 Coetz
 Dieckhoff.

Hydrogen Concentration

2.1%

Cont. Volume 2,000,000 FT³. X 2.1% = 42,000 FT³ H₂.
 Recombined flow 9.0 SCFM.
 90 X 60 X 24 = 130,000 FT³/day. X 2.1% = 2,722 FT³/day.

	Date	H ₂ (start)	Remove	Heard	%
Start	4/2/79	42.0K	2.7	39.3	1.96
First day	4/3	39.3	2.5	36.8	1.84
Second day	4/4	36.8	2.4	34.4	1.72
Third day	4/5	34.4	2.2	32.2	1.61
Fourth "	4/6	32.2	2.1	30.1	1.50
	4/7	30.1	1.9	28.2	1.41
	4/8	28.2	1.8	26.4	1.32
	4/9	26.4	1.7	24.7	1.24
	4/10	24.7	1.6	23.1	1.16
	4/11	23.1	1.4	21.7	1.04
	4/12	21.7	1.3	19.4	0.97
	4/13				

Assume No Net H₂ input to Containment

Gary Miller
 Joe Logan, Plant Superintendent
 Jack Heebma VP. Generation
 Greitz
 Director

Action Item Response.

I. B. 5 Refine end point for degas mode

I think the reactor coolant system should be degassed until the total gas concentration is less than 5 STD cc/kg. This should preclude the possibility of any gas coming out of solution if the reactor coolant system was depressurized to atmospheric conditions.

B+W document 57-00 dated 4-7-78 (original issue) states that the generation of radiolytic gas should be small. They recommend that 15 STD cc/kg of H_2 be maintained on the coolant to suppress gas formation.

I question whether this is necessary as the H_2 will only minimize O_2 .

If minimizing O_2 is important during long term cooling, would it be better to do it with N_2/H_2 addition?

Can we continue some degas with the lid-down system while in the 100 PSI range?

How much gas would be produced by the radiation present in the coolant?

The total gas should be kept low so that gas is coming out of solution when depressurizing would not hinder natural air that will contain

ACTION ITEM RESPONSE

Degas

6/112-3,e-25

I.B.5 define end point for degas mode.

Requirements:

Do depressurization test to determine gas content of coolant.

Do MU tank measurement procedure to measure gas content/degas rate, if possible.

Get results of gas content from primary pressurized sample, if available.

Plan:

Using results from above tests & samples, as start point, project the gas content by calculating the degas rate and rate of coolant gas concentration. Plct against time.

Continue to degas at high pressure, approximately 1000 psi while cooling down to point B on the "Base Case Summary". (about 220 - 230°F primary temperature). At that point determine value of proceeding further considering;

- 1 Ultimate condition pressure; time needed for further degas;
2. compatability of degas operations with next cooldown (solid SG) mode.
- 4 Radiolysis generation rate.
- 5 Need to keep radiolytic gas in solution.

① L.M.

REC'D FROM COX-119
COMBUSTION FACILITY
1800 HRS 4/16/79
PAGE 1 OF 5

INITIALLY

Procedure

estimate the volume of gas released, if any, as a result of cooling and depressurizing the reactor coolant system, taking into account continuous gas removal by feed and bleed at approximately 20 GPM.

Initial Conditions

- Pressure = 1,200 PSIA/985 PSIG
- Temperature = 230°F

Assumptions

- Bubble disappeared at 1200, April 2, 1979
- RC saturated with H₂ at that time (2,560 cc H₂ @ STP/lb)
- Shutdown flow 20 GPM @ 120°F (9,900 #/HR) not recycled
- Mixup flow same, air-saturated water (18 cc/lb air, assume 100% H₂ for most limiting case)
- Ideal Gas Law assumed for all gases and water vapor
- Perfect mixing in RCS

Results

1. Calculation of limiting dissolved H₂ gas concentrations

The approach was to calculate limiting dissolved gas concentrations relative to:

- bubble nucleation
- formation of 100 cc³ of bubble

Results are presented on Table I.

These figures should be taken as targets for denitrogenation.

Conclusions

- (1) H₂ must be reduced to < 1,100 cc/lb to avoid bubble formation due to cooling while maintaining 1,000 PSIA. The maximum bubble, assuming no denitrogenation, would be approximately 75 cc³ at 1,000 PSIA/150°F.
- (2) H₂ must be reduced to < 10 cc/lb to avoid bubble formation due to cooling and depressurizing to 10 PSIG.
- (3) Total gas (H₂ plus air) must be reduced to < 50 cc/lb to avoid bubble formation due to cooling and depressurizing to 10 PSIG.

Calculation of Rate of Gas Removal

Based on a RCS mass of 4×10^5 to 9.0×10^5 lb/yr bleed, gas concentrations will be reduced with a half-life of approximately 17 hours (1-3/4 day). Coolant air concentration will increase to saturation (15 cc/lb) with the same half-life. Results are plotted on Figure 1.

Also plotted are the minimum pressures to prevent bubble formation at 200°F and 150°F as a function of time. These curves include the partial pressures of air (assumed N_2), H_2 , and water vapor.

Conclusions

(1) In order to reach a target concentration of 50 cc H_2 /cc, degasification should continue until approximately noon on April 12.

(2) In order to depressurize to 50 psig at 200°F without forming gas bubbles, degasification should continue until early on April 11.

Note: As final temperature increases, the vapor pressure of water becomes more significant and reduces the allowed gas concentration (extends degasification times).

Slightly increasing system pressure will compensate for the additional water vapor pressure.

Note: The above calculations assume no input of gases from radiolysis.

Summary Conclusion

Based on coolant bleed/feed and the associated assumptions, a gas bubble will not form at 150°F primary temperature and 50 psig primary pressure after 4/12/79.

Rate of Decrease
of Dissolved

3015

RESUME: H-SATURATED

1000 PSI @ 25°F

1200 4 1/2 179

1013 cc/kg AIR 10

H₂O




TABLE I

1. UNITED STATES - 1890-1900
2. UNITED STATES - 1900-1910
3. UNITED STATES - 1910-1920
4. UNITED STATES - 1920-1930
5. UNITED STATES - 1930-1940
6. UNITED STATES - 1940-1950
7. UNITED STATES - 1950-1960
8. UNITED STATES - 1960-1970
9. UNITED STATES - 1970-1980
10. UNITED STATES - 1980-1990
11. UNITED STATES - 1990-2000
12. UNITED STATES - 2000-2010
13. UNITED STATES - 2010-2020
14. UNITED STATES - 2020-2030
15. UNITED STATES - 2030-2040
16. UNITED STATES - 2040-2050
17. UNITED STATES - 2050-2060
18. UNITED STATES - 2060-2070
19. UNITED STATES - 2070-2080
20. UNITED STATES - 2080-2090
21. UNITED STATES - 2090-2100

1. UNITED STATES - 1890-1900
2. UNITED STATES - 1900-1910
3. UNITED STATES - 1910-1920
4. UNITED STATES - 1920-1930
5. UNITED STATES - 1930-1940
6. UNITED STATES - 1940-1950
7. UNITED STATES - 1950-1960
8. UNITED STATES - 1960-1970
9. UNITED STATES - 1970-1980
10. UNITED STATES - 1980-1990
11. UNITED STATES - 1990-2000
12. UNITED STATES - 2000-2010
13. UNITED STATES - 2010-2020
14. UNITED STATES - 2020-2030
15. UNITED STATES - 2030-2040
16. UNITED STATES - 2040-2050
17. UNITED STATES - 2050-2060
18. UNITED STATES - 2060-2070
19. UNITED STATES - 2070-2080
20. UNITED STATES - 2080-2090
21. UNITED STATES - 2090-2100

1. UNITED STATES - 1890-1900
2. UNITED STATES - 1900-1910
3. UNITED STATES - 1910-1920
4. UNITED STATES - 1920-1930
5. UNITED STATES - 1930-1940
6. UNITED STATES - 1940-1950
7. UNITED STATES - 1950-1960
8. UNITED STATES - 1960-1970
9. UNITED STATES - 1970-1980
10. UNITED STATES - 1980-1990
11. UNITED STATES - 1990-2000
12. UNITED STATES - 2000-2010
13. UNITED STATES - 2010-2020
14. UNITED STATES - 2020-2030
15. UNITED STATES - 2030-2040
16. UNITED STATES - 2040-2050
17. UNITED STATES - 2050-2060
18. UNITED STATES - 2060-2070
19. UNITED STATES - 2070-2080
20. UNITED STATES - 2080-2090
21. UNITED STATES - 2090-2100

PRELIMINARY

Based on discussions with Dr. Paul Cohen (consulting chemical engineering from Westinghouse, retired), review of data in his book, and discussions with Dr. Jacks of ORNL, it is their opinion that net recombination, VIZ no coolant radiolysis persists in the TMI-II core.

From my experience with a pressurized heavy water cooled and moderated reactor, net radiolysis occurred only under power operation, with a thermal neutron flux of 10^{14} n/cm², a dissolved hydrogen content of <1.5 cc/kg coolant, and sub-cooled boiling in the core. Even there, oxygen concentrations were <2 ppm in the coolant.

Thus, with current and anticipated primary system conditions at TMI-II, we do not expect any hydrogen generation from radiolysis.

References

1. Cohen, P. Water Coolant Technology of Power Reactors, Gordon and Breach, 1969, page 100,101.
2. Jacks, ORNL 3441, 1965
3. Jacks and Greiss - ORNL 4173, 1967

JH/mac

~~Degas~~

Theory for

Uchida - 02

6.11.79

JWT

③ We can estimate degassing time w/ recycle.

Please note 5 pages that follow discussed by P. Bryant / Archibald H. H.

Please review with a sense of urgency to Schenker in the AM.

Look
at this

① Calculations are correct given the assumption of no recycle.

② There has been, for the most part, total recycle. Therefore, all times and dates are incorrect (times too short, dates when total degassing could be accomplished are too early. JWT Thesing 8-11-79

REC'D FROM
COMBUSTION ENGINEERING
1800 HRS 4/10/79
PAGE 1 OF 5

PRELIMINARY

Problem

Estimate the volume of gas released, if any, as a result of cooling and depressurizing the reactor coolant system, taking into account continuous gas removal by feed and bleed at approximately 20 GPM.

Initial Conditions

- Pressure = 1,000 PSIA/985 PSIG
- Temperature = 230°F

Assumptions

- Bubble disappeared at 1200, April 2, 1979
- RC saturated with H₂ at that time (1,300 cc H₂ @ 50 PSI/230°F)
- Loaddown flow 20 GPM @ 230°F (9,000 g/Hr) not recycled
- Maximum flow same, air-saturated water (10 cc/kg air, assume 100% H₂ for most limiting case)
- Ideal Gas Law assumed for all gases and water vapor
- Perfect mixing in RCS

Results

1. Calculation of limiting dissolved H₂ gas concentrations.

The approach was to calculate limiting dissolved gas concentrations relative to:

- bubble nucleation
- formation of 100 ft³ of bubble

Results are presented on Table I.

These figures should be taken as targets for design.

Conclusions

- (1) H₂ must be reduced to < 1,100 cc/kg to avoid bubble formation due to cooling while maintaining 1,000 PSI. The maximum bubble, assuming no depressurization, would be approximately 75 ft³ at 1,000 PSIA/150°F.
- (2) H₂ must be reduced to < 50 cc/kg to avoid bubble formation due to cooling and depressurizing to 50 PSIG.
- (3) Total gases (H₂ plus air) must be reduced to < 50 cc/kg to avoid bubble formation due to cooling and depressurizing to 50 PSIG.

Results in all
initial conditions

given the no-recycle

2. Calculation of Rate of Gas Removal

Based on a RCT rate of 6×10^5 lb of H_2 per day, H_2 concentrations will be reduced with a half-life of approximately 42 hours (1-3/4 day). Coolant air concentration will increase to saturation (13 cc/l) with the same half-life. Results are plotted on Figure 1.

Also plotted are the minimum pressures to prevent bubble formation at 200°F and 150°F as a function of size. Curves include the partial pressures of air (assumed H_2 , and water vapor.

Conclusions:

- (1) In order to meet a target concentration of 30 cc H_2 /degasification should continue until approximately noon on April 12. *→ Too soon - there has been*
- (2) In order to depressurize to 50 PSIG at 200°F without forming gas bubbles, degasification should continue until early on April 12. *→ Same comment*

Note: As final temperature increases, the vapor pressure of water becomes more significant and reduces the allowed gas concentration (extends degasification times).

Slightly increasing system pressure will compensate for the additional water vapor pressure.

Note: The above calculations assume no input of gases from radiolysis.

✓ OK per attached notes (i.e. zero net radiolysis)

Summary Conclusion:

Based on coolant bleed/feed and the associated assumptions, a gas bubble will not form at 150°F primary temperature and 50 psig primary pressure after 4/12/79.

*→ too soon!
the operating mode is recycle!*

TABLE

2. CONCENTRATIONS
 3. INITIAL CONDITIONS

CONDITIONS: INITIAL TEMPERATURE 200 OF
 INITIAL TEMP - 200 OF

1. Coolant

2. To

3. To

4. To

5. To

6. To

7. To

8. To

9. To

10. To

11. To

12. To

FINAL

PRESSURE / TEMPERATURE
 (MM HG) / (DEG C)

1150 1220 11500

IN EXCESS OF SAT

0 1500 1500

75 150 150

50 50

111 38

110 33

75 62

157 128

ADD 1800

10 800

RATE OF DECREASE OF RESOLVED

SUMMER 4 - 5 1/2 1/2 1/2

3-1000 PSI @ 200°

1000 PSI @ 179°

2000 PSI @ 170°

No. cells

No. cells

No. cells

40

10

10

50 PSI

SUMMER 4 - 5 1/2 1/2 1/2
3-1000 PSI @ 200°
1000 PSI @ 179°
2000 PSI @ 170°

1/2 1/3 1/4 1/5 1/6 1/7 1/8 1/9 1/10 1/11 1/12 1/13 1/14

PRELIMINARY

Based on discussions with Mr. Paul Cohen (consulting chemical engineering from Westinghouse, retired), review of data in his book, and discussions with Dr. Jenks of OORL, it is their opinions that net recombination, VIZ no coolant radiolysis persists in the TMI-II core.

From my experience with a pressurized heavy water cooled and moderated reactor, net radiolysis occurred only under power operation, with a thermal neutron flux of 10^{13} n/cm², a dissolved hydrogen content of ≤ 1.5 cc/kg coolant, and sub-cooled boiling in the core. Even there, oxygen concentrations were ≤ 2 ppb in the coolant.

Thus, with current and anticipated primary system conditions at TMI-II, we do not expect any hydrogen generation from radiolysis.

References

1. Cohen, P. Water-Coolant Technology of Power Reactors, Gordon and Breach, 1969, page 100,101.
2. Jenks, OORL 3043, 1965
3. Jenks and Graiss - OORL 4173, 1967

PB/mac

6/7/72-3.e-29

WILSON & WILSON CO.
FARMERS SUPPLY
MOTOR OPERATORS

REPORTING TO: TOM CROSBY/DICK SKELTON

L. HIGGINS TRANSMITTAL # _____

SEND TELECOPY TO: R. WILSON TRANSMITTAL # W-162
 GAS TRAILER 25 TRANSMITTAL # _____

TIME 12:00 DATE 4/11/79

SUBJECT EMERGENCY/CRISIS MANAGEMENT STUDY

APPROVED BY [Signature] 0805
[Signature]

END ACTION # 300

RDV 0555
4-11-79

- R. ARNOLD
- G. BROUGHTON
- J. HENNING
- B. MONTGOMERY
- R. KORTCH
- R. WILSON
- R. CRIMMINS
- ~~SPRUELL~~

THE BARNER & WILSON COMPANY
STEEL GENERATION GROUP

INSTRUCTIONS #120

1. IN 1979

CONCRETE & REINFORCEMENT GROUP

ONE COPY

Dist.

File No.
of Ref.

Subj.

Date

CONCRETE & REINFORCEMENT GROUP

APRIL 12, 1979

ATTACHED ARE COPIES FOR THE DESIGN TEAM MEMBERS REGARDING THE VARIOUS DESIGN
ELEMENTS AND THE GAS CONCENTRATIONS. SEVERAL COMMENTS WAS MADE IN THE
COMMENTS OF THE COPIES:

DESIGN TEAM LEVEL - 71 INCHES

DESIGN TEAM IS SAME AS DESIGN PLAN

DESIGN TEAM TEMPERATURE 90F

TEMPERATURE LEVEL IS CONSTANT

DESIGN TEAM CONCENTRATION DESIGN TEAM IS AN INDICATOR ABOUT THE DESIGN TEAM

DESIGN TEAM TEMPERATURE - 15 FEET AT SIDE OF THE

1/20

ATTACHED

Building in Filtration Tank Pressure
 For Various Levels of Dissolved
 Hydrogen in Reactor Outlet (100 cc/hr)

20 GPM Lubrication Flow

Filtration Tank Pressure (psia)

30
 28
 26
 24
 22
 20
 18
 16
 14

2 4 6 8 10

Time (hours)



Buildup in Makeup Tank Pressure
 For Various Levels of Dissolved
 Hydrogen in Reactor Cabinet (at 100°C)

20 GPM Water Flow

Makeup Tank Pressure (psia)

30
28
26
24
22
20
18
16
14

2 4 6 8 10

TIME (Hours)



DEBS

4/11/79 G/712-3.e-30
11 CO

April 11, 1979
1030 AM

Teletype to:

Branch Elam / Jack Davine

from W.A. Crandall

cc RFW
TMC
R. Kuntz
E. Montague

DATA SHEET

No. _____
 DATE _____
 LOCATION CG-100
Mountain Lake, Pa.

Prepared by W. A. Crawford
 Consulting Engineer

Quantity _____

SOLUBILITY OF ETHYLENE GAS IN ETHYLENE OXIDE

(System Temperature and Pressure vs. Concentration in cc/kg)

Temp. °F	Sat. Press. P ₁₀	M ₁₀ × 10 ⁻⁴	System Pressure, P ₁₀								
			10	20	30	40	50	60	80	100	
50	0.13	6.35									
60	0.24	6.60	12.5	25.3	37.1	50.9	67.7	76.5	102.1	127.7	
70	0.36	6.85									
80	0.51	7.10	11.8	23.2	35.1	48.0	58.9	72.8	93.6	118.4	
90	0.70	7.50									
100	0.93	7.50	16.2	21.5	32.7	44.0	55.3	66.5	85.1	111.6	
110	1.20	7.60	9.7	20.9	31.9	45.1	54.2	65.3	87.5	109.8	
120	1.70	7.60									
130	2.32	7.55									
140	2.89	7.50									
150	3.72	7.45	7.1	18.5	29.0	41.2	52.5	63.8	86.5	109.2	
200	11.53	6.81		10.5	22.9	35.3	47.7	60.2	85.0	109.8	
250	29.83	5.93			0.2	14.6	23.9	35.3	72.0	102.7	
300	67.01	4.91							22.0	56.8	
350	151.6	4.01									
400	287.3	3.30									
450	422.4	2.51									
500	612.8	1.94									
550	1015.2	1.47									
600	1542.9	1.08									

Note: System Temperature = T₁₀ = T₁₀, P₁₀ = Sat. Press. in P₁₀.

DATA SHEET

(System Temperature and Pressure vs. Concentration in g/l)

System Number: 10113

	100	200	300	400	500	600	700	800	900	1000
100	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
200	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
300	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
400	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
500	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
600	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
700	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
800	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
900	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30
1000	6.07	11.52	17.00	22.60	28.30	34.10	40.00	46.00	52.10	58.30

6/7/72-3e-31

REC'D. 6550
4/12/79

TEST NO. _____
TESTER _____
TEST DATE _____
TEST LOCATION _____

TEST TYPE _____
TEST METHOD _____

TEST RESULT _____
TESTER'S SIGNATURE _____
DATE _____

2. ANALYSIS OF THE GAS CONCENTRATION IN THE GAS STREAM SHOWS THE FOLLOWING RESULTS:

AT 1000 HRS ON 4/12/79, FUEL GAS WAS ANALYZED TO BE _____ PERCENT NITROGEN. THIS IS COMPARED TO THE GAS CONCENTRATION LIMIT AT 1000 HRS AND 1000 HRS. _____

AT 1000 HRS ON 4/12/79, FUEL GAS WAS ANALYZED TO BE _____ PERCENT NITROGEN. AT 1000 HRS ON 4/12/79, FUEL GAS WAS ANALYZED TO BE _____ PERCENT NITROGEN. THIS IS COMPARED TO THE GAS CONCENTRATION LIMIT AT 1000 HRS AND 1000 HRS. _____

THE BARCOCK & MILCOX COMPANY
ENGINEERING GROUP

To: BOB KEATOR - CPU TECHNICAL SUPPORT

From: MILCOX ENGINEERING *4-20-79*

Subj.

RESPONSE TO QUESTIONS RELATIVE TO FREE GAS TESTING
DURING THE REACTOR TEST ON WEDNESDAY, APRIL 6, 1979

XG: PCA
PFW
SMITH No.
123(2) 4/27
TMC
JCH
D. Montgomery
APRIL 8, 1979 CND

THE FOLLOWING ARE RESPONSES TO YOUR QUESTIONS RELATIVE TO THE PLANNED TESTING TO DETERMINE THE PRESSURE LEVEL AT WHICH FREE GAS PRESENT IN THE REACTOR COOLANT SYSTEM WILL COME OUT OF SOLUTION.

1. WHAT IS THE VOLUME OF THE PRIMARY SIDE OF THE CONTROL ROD DRIVES?
ANSWER: THE PRIMARY SIDE VOLUME OF THE CONTROL ROD DRIVES IS 55 CUBIC FEET.

2. WHAT IS OAM'S POSITION ON LOWERING PRESSURE IN CHECKING FOR GAS, THAT IS, WHAT IS THE LOWEST PRESSURE WE WOULD RECOMMEND GOING TO IN DETERMINATION OF THE COMING OUT OF SOLUTION OF DISSOLVED GAS?
ANSWER: THE LIMITS ON PRESSURE FOR THIS TEST SHOULD BE THE SAME AS THOSE PROVIDED IN THE MEMO FROM R. E. NOSIDA TO LEE ROGERS DATED 4/4/79, TRANSMITTED 11:10 P.M. TRANSMITTAL LOG NO. 275. THESE LIMITS ARE THOSE RELATIVE TO THE NPSH CURVE FOR THE PUMPS.

3. BE SURE THE REACTOR DIAGNOSTICS GROUP IS READY FOR MONITORING DURING THE SUBJECT TEST. THE REACTOR DIAGNOSTICS GROUP HAS BEEN INFORMED OF THE PENDING TEST AT NOON ON APRIL 6, 1979 AND WILL BE READY FOR TAKING OF DATA DURING THIS TEST.

4. DOES OAM'S TEST PROCEDURE WHICH REQUIRES LOWERING PRESSURE TO DETERMINE THE PRESSURE AT WHICH GAS COMES OUT OF SOLUTION WORK AT LOWER PRESSURES THAN THOSE PREVIOUSLY USED; THAT IS, WILL GAS BE DETECTED IF THE PROCEDURE

PAGE 2

MEMO H. ENGLEY TO B. KEATON

APRIL 9, 1973 0110

IS REQUIRED TO BE LOWERED IN THE 400 TO 500 PSI RANGE?

ANSWER: THE PROCEDURE SHOULD BE JUST AS EFFECTIVE IN THE LOWER PRESSURE RANGES AS AT THE UPPER PRESSURE RANGES AND AT THE TEMPERATURE OF 200°F BECAUSE THE SAME RELATIVE VOLUMES OF GASES COMING OUT OF SOLUTION APPLY IN HENRY'S LAW AS A LINEAR FUNCTION WITH PRESSURE.

5. CAN YOU SUGGEST AN ALTERNATIVE METHOD FOR DETERMINING THE PRESSURE AT WHICH GAS COMES OUT OF SOLUTION THAN THE USE OF PRESSURE SIGNAL LOGGE CONDITIONS?

ANSWER: ANOTHER POTENTIAL METHOD IS TO MEASURE THE PRESSURE BUILD-UP IN THE MAKE-UP TANK WITH THE VENT VALVE CLOSED. BY RECORDING THE MAKE-UP TANK PRESSURE WATER LEVEL AND PRESSURE AT THE BEGINNING AND END OF THE TEST AND THE LETDOWN FLOW, THE DISSOLVED GAS IN THE REACTOR COOLANT SYSTEM CAN BE ESTIMATED WITH AN ASSUMED GAS REMOVAL EFFICIENCY IN THE MAKE-UP TANK. BASED ON WHAT WE THINK THE DISSOLVED LEVELS IN THE GAS ARE NOW, THE REMOVAL EFFICIENCY SHOULD BE VERY CLOSE TO 100%.


IF YOU HAVE ANY FURTHER QUESTIONS WITH RESPECT TO THE GAS BUBBLE TEST PLANNED PLEASE LET US KNOW.

WSE/can

Felt, J.T.

PROBLEM F2 STEADY-STATE ANALYSIS
OF PRC'S H₂ CONCENTRATION

RC Makeup tank in steady-state gas stripping mode, no discharge to waste gas tank.



Let: n_2 = moles H₂ in liquid phase
 n = total moles H₂ in tank
 n_g = moles H₂ in gas phase

F = Total feed rate to and discharge rate from tank

C_2 = H₂ concentration in liquid phase

C_F = H₂ concentration in feed stream

P_{H_2} = H₂ partial pressure in gas phase

T = Tank fluid temperature (assume isothermal operation)

$$\frac{dn(t)}{dt} = FC_F - FC_2(t)$$

$$m_a(t) = \frac{P_{H_2}(t) V_g}{RT}$$

V_g = gas space volume

FEM 5.7
4-4-79

⊙

$$C_2(t) = K P_{H_2}(t)$$

where $K =$ equilibrium constant for H_2 (gas/liquid)

$$m_c = V_e C_e = V_e K P_{H_2}(t)$$

$$m(t) = V_e K P_{H_2}(t) + \frac{P_{H_2}(t) V_g}{RT}$$

$$m(t) = P_{H_2}(t) \left(K V_e + \frac{V_g}{RT} \right)$$

$$\frac{dm(t)}{dt} = \left(K V_e + \frac{V_g}{RT} \right) \frac{dP_{H_2}(t)}{dt}$$

$$\left(K V_e + \frac{V_g}{RT} \right) \frac{dP_{H_2}(t)}{dt} = F C_F - F K P_{H_2}(t)$$

$$\frac{dP_{H_2}(t)}{dt} = \frac{F C_F R T}{V_g + R T K V_e} - \frac{R T F K}{V_g + R T K V_e} P_{H_2}(t)$$

define

$$K_1 = \frac{F C_F R T}{V_g + R T K V_e}$$

$$K_2 = + \frac{R T F K}{V_g + R T K V_e}$$

Thus

$$\frac{dP_{H_2}(t)}{dt} = K_1 - K_2 P_{H_2}(t)$$

$$\frac{dP_{H_2}(t)}{dt} + K_2 P_{H_2}(t) = K_1$$

$$e^{K_2 t} \frac{dP_{H_2}(t)}{dt} + K_2 e^{K_2 t} P_{H_2}(t) = K_1 e^{K_2 t}$$

$$d \left\{ \frac{P_{H_2}(t) e^{K_2 t}}{dt} \right\} = K_1 e^{K_2 t}$$

$$P_{H_2}(t) e^{K_2 t} = \frac{K_1}{K_2} e^{K_2 t} + C_1$$

$$P_{H_2}(t) = \frac{K_1}{K_2} + C_1 e^{-K_2 t} \quad \leftarrow \rightarrow$$

$$P_{H_2}(t) = \frac{C_F}{K} + C_1 e^{-K_2 t}$$

At start of operation, purge tank with nitrogen, this $P_{H_2}(0) = 0$


to measurement

$$0 = \frac{C_F}{K} + C_1$$

$$C_1 = -\frac{C_F}{K}$$


7/11/21
4-79 (3)

$$P_{H_2}(t) = \frac{C_F}{K} (1 - e^{-K_2 t})$$



OR

$$C_F = \frac{K P_{H_2}(t)}{(1 - e^{-K_2 t})}$$




Operate letdown system at steady state
liquid flow through makeup tank;
after pressure builds up, say to 15 psig,
note time and tank pressure, temperature.
Check tank for isothermal approximation.

$$P_{total} = P_{N_2} + P_{H_2}$$

$$P_{N_2} = \frac{n_{N_2} R T}{V_g} \quad \therefore \quad P_{H_2}(t) = P_{total}(t) - P_{N_2}(t)$$

1145
file
degen-9



$\frac{910}{136}$

THREE MILE ISLAND BOILING MODE EVALUATION

- NON-CONDENSIBLE GAS EFFECTS ON BOILING MODE
- OTHER POTENTIAL PROBLEMS
- METHODS TO VERIFY EXISTENCE OF BOILING
- METHODS TO DETERMINE STATE OF SYSTEM
- CONTROL NEEDS AND METHODS WHILE IN BOILING MODE
- TRANSITION FROM FORCED CIRCULATION TO SINGLE PHASE
NATURAL CIRCULATION
- REVIEW OF IAG DOCUMENT
- OPERATING PRESSURE CONSIDERATIONS

NON-CONDENSIBLE GAS EFFECTS ON BOILING MODE

The presence of significant quantities of non-condensable gas (presumably hydrogen) can significantly affect the boiling mode operation. The affects result primarily from a degradation of the condensation heat transfer coefficient in the primary side of the steam generator. The boiling in the core will strip some hydrogen out of solution and into the steam. The hydrogen will be transported with the steam to the steam generator (note that no separation of the hydrogen from the steam is expected until the steam condenses on the cooled tubes of the steam generator). As the steam is condensed, the hydrogen concentration will increase in the steam generator. The hydrogen causes a diffusion controlled limitation in the condensation process. The resulting lower heat transfer rate will cause more of the heat transfer surface to be exposed. For a given rate of hydrogen flow into the steam generator, a final condition can be achieved where the liquid level is low enough (i.e. sufficient condensing surface) to condense the total steam flow, and the hydrogen concentration is sufficient to drive the total hydrogen flow back into solution.

If the total hydrogen flow into the steam generator is steady, then the above condition would represent a stable operating mode for the system. However, if the hydrogen content of the system continuously increases, then the steam generator liquid level would continuously recede. A limit to this process would occur if a change in liquid level caused the system hydrogen content to stabilize. Such a change could result by uncovering the surge line, with subsequent venting of steam and hydrogen out of the pressurizer.

There are two possible sources of hydrogen generation in the system. The first, Zr-H₂O reaction, would imply localized high temperatures in the core. Such a source could be relatively continuous, and independent of the hydrogen concentration that exists. The second, radiolysis of H₂O, can be suppressed when the hydrogen concentration reaches a sufficient value. From this, there appear to be three possible operating modes that should be considered. One mode is with a continuous source of H₂. Another mode is with a continuous source of H₂ and a system bleed rate that will remove hydrogen to compensate for the source. The third mode is assuming no continuous source (i.e. radiolysis only). Expected operating characteristics for these three modes are indicated in the attached table and figures 1 and 2. Analyses requirements to define these modes are also attached.

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

WHAT MAY HAPPEN ASSOCIATED WITH NON-CONDENSIBLES

CONTINUOUS SOURCE OF H ₂	CONTINUOUS SOURCE OF H ₂ WITH SYSTEM BLEED	RADIOLYSIS ONLY
Continuous H ₂ buildup	H ₂ buildup to equilibrium level (dependent on bleed rate)	H ₂ buildup to equilibrium level (sufficient to balance radiolysis)
Continuous degradation of heat transfer	Heat Transfer degradation to associated equilibrium level	Heat transfer degradation to associated equilibrium level
Reduction of level in S.G. and hot leg, with venting through pressurizer when surge line uncovers	Reduction of S.G. and hot leg levels, determined by heat transfer coefficient (expect above surge line)	Reduction of S.G. and hot leg levels determined by heat transfer coefficient (expect above surge line)
Equilibrium H ₂ level achieved due to pressurizer venting. Part of heat load out S.G. and remainder through vented steam.	Heat load out S.G.	Heat load out S.G.

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

WHAT SHOULD BE DONE TO EVALUATE PERFORMANCE WITH NON-CONDENSIBLES

I. Assume Continuous Source of H₂

- Calculate level in S.G. when surge line uncovers
- Estimate equilibrium H₂ concentration after pressurizer venting starts
- Estimate the associated H₂ concentration in the condensing loop of the S.G.
- Determine value of heat transfer coefficient associated with S.G. H₂ concentration
- Calculate heat load out of S.G.
- Calculate steam venting rate from pressurizer
- Calculate system pressure to achieve vent rate
- Re-estimate equilibrium H₂ concentration (iterate above)

II. Assume Continuous Source of H₂ with System Bleed

- Specify bleed flow rate
- Calculate H₂ concentration in bleed flow to compensate for H₂ source
- Estimate the associated H₂ concentration in the condensing loop of the S.G.
- Determine value of heat transfer coefficient associated with S.G. H₂ concentration
- Calculate expected mixture levels in S.G. and hot leg (for entire heat load out steam generator)
- Determine operating pressure required to achieve bleed rates

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN


III. Assume Radiolysis is Only Source of H₂

- Determine equilibrium H₂ concentration to prevent radiolysis
- Estimate the associated H₂ concentration in the condensing loop of the S.G.
- Determine value of heat transfer coefficient associated with the S.G. H₂ concentration
- Calculate expected mixture levels in S.G. and hot leg (for entire heat load out steam generator).

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN


Figure 1. Final Mode. With Stable* Quantity
Non-condensible Gas

* Radiolysis only
or
Continuous source with Compensating Bleed



PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

Figure 2. Final Mode - Noncondensable Gas Source
(Both Secondaries Assumed Solid)



PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

OTHER POTENTIAL PROBLEMS

- LOSS OF STEAM GENERATOR FEEDWATER PUMP
- LOSS OF HEAT EXCHANGER
- LOSS OF PRIMARY FEEDWATER PUMP
- STUCK OPEN RELIEF VALVE
- FURTHER CORE DAMAGE - DUE TO PRESSURE OSCILLATION
- CAN VENTING KEEP UP WITH STEAMING?
- CONDENSATION SHOCKS/WATERHAMMER
- CONDENSATION (INSTABILITIES)
- VENT VALVE INTERACTION
- INADVERTENT CHANGE IN S.G. COOLANT FLOW TO SECONDARY SIDE
- CORE HEAT TRANSFER - LOCAL LARGE BUBBLES BELOW BLOCKAGE

* MUST BE RE-EVALUATED AFTER SYSTEM ANALYSES COMPLETED.

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

METHODS TO VERIFY EXISTANCE OF BOILING

- T.C.'S TOP OF CORE $\rightarrow T_{\text{sat}} (P)$
- DECREASED NATURAL CIRCULATION FLOW DETECTED IN HOT LEGS FLOW INSTRUMENTS (DEPENDS ON FLOWMETER RANGE)
- SYSTEM PRESSURE INCREASES OR PRESSURIZER LEVEL CHANGES
- DECREASE IN TEMPERATURE RISE ACROSS S.G. (SECONDARY SIDE)

METHOD TO DETERMINE STATE OF SYSTEM

- ULTRASONIC DETECTOR
- INTEGRATE BLEED OUT FLOW
- FEED FLOW
- DECREASE IN TEMPERATURE RISE ACROSS S.G. (SECONDARY SIDE)
- DECREASE IN NATURAL CIRCULATION FLOW DETECTED IN HOT LEGS FLOW INSTRUMENTATION

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

CONTROL NEEDS & METHODS WHILE IN BOILING MODE

- BLEED AND FEED SYSTEMS
- FEEDWATER HEAT EXCHANGE AND FLOW CONTROL
- PRESSURIZER (MAINTAIN VAPOR BUBBLE)

TRANSITION FROM FORCED CIRCULATION TO SINGLE PHASE NATURAL CIRCULATION

EXPECTED PERFORMANCE

- HOT LEG TEMPERATURE SHOULD HEATUP TO NEAR STEADY TEMPERATURE IN A FEW HOURS

DEVIATION LIMITS

- CORE TEMPERATURE RISE AT HOT LEG,

$$\Delta T / \Delta t > 0.1 \text{ } ^\circ\text{F}/\text{sec}$$

- PRESSURIZER WATER LEVEL SHOULD NOT CHANGE--AN INCREASE IMPLIES BULK BOILING IN CORE
- NOT STEADY SYSTEM PRESSURE
- IN-CORE T.C.'s $> T_{\text{sat}} (P_{\text{sys}})$

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

REVIEW OF IAG DOCUMENT

"Behavior of RCS with Steam Generators in Condensing Mode", 4/10/79.

Document recommends system to operate in boiling mode at atmospheric pressure. Several problems exist with such low pressure operation, as identified on attached, "Operating Pressure Considerations". The scenario suggested to occur with non-condensable gas identifies separation of the hydrogen and formation of a bubble at the top of the hot leg. Such separation of hydrogen and steam is unlikely (the expected phenomena are discussed elsewhere). The suggestion that hydrogen concentration in S.G. would approach 100% is unlikely due to it going into solution in the water on the condensing tubes. Postulated level reduction and venting through the pressurizer is possible if a continuous hydrogen source exists in the system. However, even for that case, the steam generator should have some effectiveness to handle part of the heat load.

PRELIMINARY AND UNVERIFIED
NOT TO BE USED IN DESIGN

Task VII

6/7/2-3.e-34

CC DRW/PDJ
GE DIX
MSiegler

TO: EP Stroupe

FROM: PWMarritt

SUBJECT: Review of IAG Task 12a Close Out Document,
"Evaluate the Effect of Non-Condensibles in the
REFLUX Boiling Mode".

REFERENCE: Three Mile Island Boiling Mode Evaluation:
Non-Condensable Gas Effects on Boiling Mode,
General Electric Review 4/13/79

The subject document departs somewhat from the previous IAG boiling mode description, but still centers upon the possibility of a non-condensable gas bubble forming in the "candycane" of the TMI plant under boiling mode operation. It is felt that such a bubble is extremely unlikely. The most likely operation mode has previously been defined (cf. Reference).

The formation of a gas bubble could occur in the single phase natural circulation mode due to gas coming out of solution as the pressure is reduced. Such a bubble could fill the candycane and stop the circulation. However, the significantly increased driving potential that would result from subsequent boiling should carry such a bubble into the steam generator and provide thorough mixing with the steam. Thereafter, the non-condensable gas would move with steam flow and by diffusion while remaining well mixed with steam. Hence, the conclusion that a gas bubble with boiling mode is unlikely. If a gas bubble is assumed to occur in the candycane during the boiling mode, it would subsequently be eliminated. Steam generated by the boiling would rise through the candycane and increase the gas bubble size by mixing with the non-condensibles, and thus lowering the liquid level in the steam generator. The liquid level would continue to drop. Eventually, a portion of the tube surface would become exposed and steam condensation would occur. With the on-set of condensation, non-condensable gas would be absorbed in the liquid film. As more tube surface became exposed, more condensation and absorption would occur. With time, the non-condensable gas bubble would diminish in size and be eliminated.

The recommended actions of the subject document are appropriate in any case, except for the recommended scaled test on breaking the "gas seal", which may not be necessary as discussed above. However, a representative test of condensation effectiveness in a B&W steam generator geometry with non-condensable gas would be beneficial to define the expected liquid levels that would result in the TMI system.

Another possible concern is the system response in the boiling mode if the pressurizer relief valve control is lost with the valve closed. This could result in high pressures to relieve the vaporization volume changes. This raises associated ductility concerns.

FIELD OPERATIONS

310 4-14-77
1302

19/07/6

G/112-3.e-35

TRANSMITTAL TO: ATTN: Tom Crimmins

L. ROGERS TRANSMITTAL # 766

ALSO TELECOPY TO: R. WILSON TRANSMITTAL # W237

B&W TRAILER 26 TRANSMITTAL # _____

TIME 12:30 DATE 4/14/77

SUBJECT Gas Solubility Curves

APPROVED BY [Signature]
OPERATIONS MANAGER

B&W ACTION # 264

THE BABCOCK & WILCOX COMPANY
POWER GENERATION GROUP

Pg 2076

RESPONSE TO INSTRUCTION
#264

To |
• ENGINEERING OPERATIONS MANAGER

From
J. D. CARLTON *JDC*

805 683

Cust. | File No.
or Ref.

Subj. | Date
GAS SOLUBILITY CURVES (RESPONSE TO INSTRUCTION #264) | APRIL 14, 1979 - 12:07 P

THIS LETTER IS PRINTED ON RECYCLED PAPER AND IS RECYCLED PAPER.

ATTACHED ARE SOLUBILITY CURVES FOR O₂, H₂, He, AND N₂ IN WATER.

THIS INFORMATION SHOULD BE FORWARDED TO THE SITE AND TO THE ATTENTION OF TOM GREENS.

JDC/fch
ATTACHMENTS
CC: E. A. WYACK
B. A. KARRASCH
J. H. HICKS
C. C. ENGLAND





FIGURE 4. SOLUBILITY OF OXYGEN IN WATER

794066

SOLUBILITY, ml. H₂/g. H₂O






FIGURE 10. SOLUBILITY OF HELIUM IN WATER




FIGURE 13. SOLUBILITY OF NITROGEN IN WATER

GE Converter 9/14/79

Relay IV - can handle noncondensables

1. Ref. to Fig 24 on GE transmittal

(a) Calculate Relays/RTM for confirm Figure on page 24 - steady state

(b) start out in 1 phase natural circulation - run thru the transient into boiling

major concern - sensitivity to large amount of surface area in the S.G. water - collapse of bubble, oscillation leading

to reduce sensitivity - heat up secondary side and become much less sensitive. May be hard since 1 phase requires cold secondary

(c) Surging/oscillations can be done by steam generator alone set up steady state - partial S.G. vent bleed primary - raise secondary temperature, non condensable may help to stabilize surges

Run Primary system at 1000 psi - look good must still important on boiler - change volume SV
change in enthalpy Sh

65

non condensable gas -

may help to stabilize oscillation - solution of H_2 into
water - diffusion to surface, etc complicated

can we bound min/max heat or heat transfer coefficient

Source of H_2 - $Zr \cdot H_2O \rightarrow H_2 +$ - starts to be significant
at $2000^\circ F$, will be some at very low temperatures

is source of H_2 - stay at high temperatures, if so use H_2
of $65 \text{ m}^3/\text{kg } H_2O \approx 2 \text{ atmospheres}$ - $400-500 \text{ ft}^3/\text{kg } H_2$ total
at STP

biggest problem is inventory control - as level is S.C.

Experiment of ullage - set up whole boiling experiment

Probably don't have to worry about bubble collapse as it
affects piping loads

PROBLEMS

logao

WHAT IS COMPOSITION OF WASTE FROM TANK VAPOR SPACE
(see Venting to Condensate or Waste per day tank) (1)

$V = 4.5 \text{ cu ft}$ Total pressure = 137.09 = 99 psia
 $V_H = 3.5 \text{ cu ft}$ Total pressure = 60.6 = 137.1 psia
 $H = 250 \text{ ft} = 10.13 \text{ ft}^3$ Total V_H = 950 - 1371 = 2629 gal

[Final tank H₂O + H₂O] Temp = 01 °F

Assume vapor water column in tank is 100 ft. And amount in Vapor space is inversely proportional to relative solubility

PRIMARY GAS MIXTURE

RELATIVE SOLUBILITIES PER 100

$\frac{0.0001}{31.5 \text{ ft}^3} = 0.00000317$				
H_2	.015	20.4	70.6/20.4	.047
H_2O	.874	16.	70.6/16	.394
O_2	.081	31.2	70.6/31.2	.013
H_2 Ar	.01	-	-	4.16
Σ	1.00	70.6		100.1

$2629 \text{ gal} \times \frac{1 \text{ ft}^3}{7.48 \text{ gal}} \times 0.0113 \times \frac{1 \text{ ft}^3}{17.5} \times \frac{29.1 \text{ lb}}{15 \text{ ft}^3} = 7.7 \text{ 'SCF' of } H_2$

$\frac{17.5 \text{ ft}^3}{15 \text{ ft}^3} \times \frac{31.2 \text{ lb}}{15 \text{ ft}^3} (\text{air}) = 39.89 \text{ SCF of } O_2$

Waste gas = $7.7 \times \frac{15}{21} = 9.0 \text{ 'SCF' of } O_2$

$\frac{9.0 \text{ 'SCF' of } O_2 \times 100\%}{39.89 \text{ SCF of } O_2} = 0.17 \text{ } O_2$

Limiting Case: All waste gas Vapor is O_2
 $2629 \text{ gal} \times \frac{1 \text{ ft}^3}{7.48 \text{ gal}} \times \frac{29.1 \text{ lb}}{15 \text{ ft}^3} = 680 \text{ SCF } O_2$

$680 \text{ SCF } O_2 \times 15\% = 102 \text{ 'SCF' } O_2 = 7.6 \% O_2$

If the atmosphere is all, it will be

$$78 \times .217 = 14 \%$$

(2)

ΔP if tank level drops to 52" of 10 psig

$$\text{liq space} = 50.6' \times 30.97 = 1970$$

$$52 \times 30.97 = \underline{1625}$$

$$265 \text{ gal}$$

$$\text{Gas Space } 4500 - 1970 = 2630$$

$$4500 - 1625 = \underline{2895}$$

$$265 \text{ gal}$$

$$\frac{2620}{2895} \times 25 \text{ psia} = 25.4 \text{ psia} = 10.7 \text{ psig}$$

Microanalytical Data on Microanalytical Sample

Cover Gas analyzed as follows:

(3)

- Argon - 71.8%
- He - 20.8%
- O₂ - 7.3%
- CO₂ - 0.07%

Gas Sample - 0.8 cc (STP); Liquid volume 31.5 ml

- H₂ - 1.5%
 - He - < 0.01%
 - N₂ - 89.4%
 - O₂ - 8.1%
 - Argon - 1%
- Wt. (25 Torr) 25 cc/kg

What were the extraction conditions?

NRC 9/15/79
R. Mattson
J. Murgin

$$\frac{0.8 \text{ cc}}{31.5 \text{ g}} \times \frac{1 \text{ g}}{1 \text{ g}} = 25.4 \text{ cc/g} = 0.0254 \text{ cc STP/gm (1 cc)}$$

Depos. 350 micron dia
20 micron coat

$$\frac{0.025 \text{ cc STP}}{31.5 \text{ g}} \times \frac{1 \text{ g}}{1 \text{ g}} \times \frac{22.4 \text{ L}}{273 \text{ K}} \times \frac{1 \text{ mol}}{1 \text{ mol}} \times \frac{12.01 \text{ g}}{1 \text{ mol}} = 300 \text{ g}^3$$

$C = 1.0 \times 10^{-4}$
 $m^2 = 10^{-4} \text{ cm}^2$


(4)

$$1 \text{ ppm H}_2 = \frac{1 \text{ gm H}_2}{1000 \text{ kg H}_2} \times \frac{22,400 \text{ cc H}_2 \text{ STP}}{28 \text{ gm H}_2} = \frac{11.2 \text{ cc H}_2}{\text{kg H}_2}$$

$$1 \text{ ppm O}_2 = \frac{1 \text{ gm O}_2}{1000 \text{ kg H}_2} \times \frac{22,400 \text{ cc O}_2 \text{ STP}}{32 \text{ gm O}_2} = \frac{0.7 \text{ cc O}_2}{\text{kg H}_2}$$

From Dave Pollen
 4/16/79

$$1 \text{ ppm H}_2 = \frac{1 \text{ gm H}_2}{1000 \text{ kg H}_2} \times \frac{22,400 \text{ cc H}_2 \text{ STP}}{28 \text{ gm H}_2} = \frac{.5 \text{ cc O}_2}{\text{kg H}_2}$$



6/7/72-3e-38

MICROFILM

DOCUMENT INDEX TARGET

DESCRIPTION

604 SITE TECH SUPPORT
T COMPLETED TASKS

(55 spaces maximum)

DATE

DESCRIPTION CONTINUATION

FILE NUMBER

(20: _____)

NOTE: References include all punctuation marks, dashes and spaces between words.

Continuation should only be used when abbreviations are not appropriate.

REEL NO. _____ BLIP NO. _____

REF ID: A66429 1-72

Smith, Eric

APR 17 1973

Micro No.

7A-R-1000-1

10/10

Handwritten

APR 17 1973

Meeting No. *J. P. ...*

10:00

R. Wilson

TASK CLOSE OUT DOCUMENT

Task Scope *Review of Santa Monica*
Emergency Containment Unit
Design Package

To: M. Levenson
S. Levy
E. Zebroski

Task No. _____

Date Complete *4-16-77*

Reason felt task is complete:

Review complete, to the extent consistent
with lack of design detail. Comments
attached.

Members of Committee

James W. Thuring

James W. Thuring
Committee Leader

To: Milt Levenson
Subject: Emergency Containment
Venting Package

Date: April 16, 1979
From: J. W. Thiesing

Comments on emergency containment venting package received from Sandia/NRC follow:

- (1) Page 1 - 10^6 Ci I release represents about 10% of current total activity of I-131 (core & RCS) seems reasonable - given core melt (no containment or vessel cooling) and containment failure above grade.
- (2) Page 2 - "Steam-condense" and "steam-no condense" labels appear to be interchanged.
- (3) Page 3 - Containment pressure - Spike up to 70 psig at 374 hours is too fast. Would expect only about a 12 psig per hour (superheat from core heat) at today's decay heat level. I do not understand rapid drop in containment pressure after vessel failure (no cooling of containment was assumed). Pressure would remain constant at 70 psig until debris heated water pool in containment and began steaming. End result is the same, however, failure above grade.
- (4) Page 4 - Appears to postulate 2.4 Core I-131 becomes airborne.
- (5) Page 5 - System Design
 1. All air handling systems should be designed for 150 psig if maximum utility is to be gained (150 is probable containment failure pressure).
 2. What is purpose of H_2 system - I presume it is inerting for H_2 , but the utility of this is questionable. (Prevent H_2 burn in exhaust line, I suppose).
 3. 3×10^6 Btu/hr cooling on diffuser tanks will not keep up with decay heat until about July 1, 1979.
 4. Why install return line to containment. The presumption of containment overpressure mitigates against its use except as a routine cleanup tool. If there is urgency to install this system, it can probably not be well-enough thought out to serve as the ultimate clean up mechanism.
 5. Diffuser tanks should be buried in yard outside sux building. Line from containment to diffuser tanks should also be buried. Cooling system must also be shielded.
 6. Need valves in filter bypass.
- (6) Page 6 - Options
 1. Backup filters (Option 2) will require demisters, and could defeat system by becoming clogged - Recommend HEPA only, with bypass capability. *and perhaps coolers*
 2. Option #3 - There is not a recombiner in the world that will handle the flow rates that will be required.

Milt Levenson
Page 2
April 16, 1979

3. Option #4 - Should not put tanks in fuel pool - it's being used for tank farm. Also, violates last constraint on page 7.
4. Option #6 - What is a "Hydrogen combustion mechanism."

COMMUNICATIONS SECTION
COMMUNICATIONS CENTER
COMMUNICATIONS SECTION

*2400
Handwritten*

FOR JN MacMillan

TRANSMITTAL TO:

E. HARRIS TRANSMITTAL # _____

ALSO TELETYPE TO:

R. WILSON TRANSMITTAL # 2-12-63

DON TRAMER 25 TRANSMITTAL # 2-12-63

TIME 14:00

DATE 11/1/63

SUBJECT Gas Production from Hydrozine Addition to PCS

APPROVED BY

[Signature]

REMARKS # _____

1558 11/1/63

- CC: R. C. ARNOLD
- K. F. WILSON
- R. W. KEATEN
- T. M. CRIMMINS
- J. DANIELS
- J. G. HENZLIN
- D. MONTGOMERY
- ADM. ASST. GPU ON SITE
- TECH SUPPORT
- DATA REDUCTION & MNT
- STAUDT/FILE (ORIGINAL)

THE BABCOCK & WILCOX COMPANY
POWER GENERATION GROUP

TO: PERSONNEL
JIM VEINOTTA, THE SITE

D. M. BERGER

P. L. EGGS

808 600-8

DATE
OF LET.

GAS PRODUCTION FROM HYDRAZINE ADDITION TO RCS

DATE
APRIL 10, 1970-2:00 PM

This letter is sent for information and only enclosed copy.

A CALCULATION WAS PERFORMED TO DETERMINE THE TOTAL AMOUNT OF GAS (H_2 & H_2) PRODUCED FROM A POSTULATED ADDITION OF 25 LITERS OF 30 WT % HYDRAZINE TO THE REACTOR COOLANT SYSTEM. ASSUMING COMPLETE DECOMPOSITION OF THE HYDRAZINE AND NO OXYGEN SCAVENGING, THE MAXIMUM GAS PRODUCTION WAS CALCULATED TO BE 56 cc/kg. CONSIDERING THE SCAVENGING OF 1.8 cc/kg O_2 (LDC SAMPLE AT 2100 HOURS ON 4/10/70), THE TOTAL GAS CONCENTRATION WOULD INCREASE BY 57 cc/kg.

AT APPROXIMATELY 1300 HOURS TODAY, THE PERSONNEL MADE A HYDRAZINE ADDITION TO THE REACTOR COOLANT SYSTEM OF 7.5 LITERS OF 35 WT % HYDRAZINE SOLUTION. THIS CHEMICAL ADDITION WAS VERIFIED DURING A TELEPHONE CONVERSATION WITH JIM VEINOTTA IN THE CONTROL ROOM TO ENSURE THAT THE TOTAL GAS PRODUCED IN THE RCS WOULD BE LESS THAN 30 cc/kg. THE CALCULATED TOTAL GAS PRODUCED WOULD INCREASE BY 14 cc/kg BASED ON SCAVENGING THE 1.8 cc/kg OXYGEN. THE MAXIMUM TOTAL GAS CONCENTRATION WOULD HAVE INCREASED BY ONLY 19.6 cc/kg ASSUMING NO SCAVENGING AND COMPLETE DECOMPOSITION.

FUTURE ADDITIONS OF HYDRAZINE WILL BE BASED UPON THE OXYGEN GAS ANALYSIS OF FRESHNESS REACTOR COOLANT SAMPLES TO BE TAKEN PERIODICALLY. LATER HYDRAZINE ADDITIONS OF 25 LITERS OR LESS ARE ACCEPTABLE.

PLD/jac

P. L. EGGS

PLD

6/712-3e-40

B400 Sample results (Sample of 4/15/79)

ME(L)

4/12/79

ML

$$\frac{31.2 \text{ cc H}_2}{\text{kg}}$$

$$\frac{4.4 \text{ cc O}_2}{\text{kg}}$$

$$\frac{32.8 \text{ cc N}_2}{\text{kg}}$$

$$\underline{68.4 \text{ cc/kg}} = .0684 \text{ cc/lm}$$

$$\text{H}_2 (\text{Vol}) = \frac{31.2 \text{ cc}}{68.4 \text{ cc}} = 45.6\%$$

$$\text{O}_2 = \frac{4.4 \text{ cc}}{68.4 \text{ cc}} = 6.4\%$$

$$\text{N}_2 = \frac{32.8 \text{ cc}}{68.4 \text{ cc}} = 47.8\%$$

99.8%

Correct Gas in MV TK could be as follows if in Equilibrium at 100°F & 12 psig, with primary valve for

	Relative lg line	Relative lg	Relative lg	Relative lg	Relative lg
H ₂	.456	22.4	70.6/22.4	1.47	39.0
N ₂	.478	16	70.6/16	2.11	57.2
O ₂	.064	32.2	70.6/32.2	.14	3.8
		70.6		3.69	100.0

So mixture in MV TK vapor space is not explosive

ME(2)

11/17/22: 1315 hrs

~~Smith The Lockin~~

~~503 - 1011~~

~~7/11/21~~

How much of which gas will be left at steady state
Conditions

Condition 1

Condition 2

Primary liquid $T = 21.5^\circ F$

$P = 545 \text{ psia}$

Misc liquid $T = 90^\circ F$

$P = 0 \text{ psia}$

Gas = Air saturated

Impurity free make up H₂O

$T = 100^\circ F$

$P = 0 \text{ psia}$

Dissolved gas in primary is

31.2 cc H₂ STP

4.4 cc O₂ "

32.8 cc H₂ "

per kg

Condition 2

Primary

Condition 2
is not
returnable
your call

See next Pg

Raw Material 2073
 Annie McCracken
 203-688-1911

Vin
 Mr. Hoff
 X 4134

ME(2)
 4/17/75 1350 hrs
 ur

What dissolved gas will be in Primary liquid
 at Steady State for following Conditions. Asked

	Condition 1	Condition 2	Condition 3
<u>Primary liquid</u>			
T (°F)	235	160°F	160°F
P (psig)	850	850	0
Dissolved gas	4/15/79 (100% water)		
H ₂ (cc STP/gal)	31.2	-	-
O ₂ "	4.4	-	-
N ₂ "	32.8	-	-
Other "	-	-	-
Revolysis (H ₂ O + H ₂ + O ₂)	?	?	?
Oxidation (2r + r ₂ + r ₂ + 2r ₂)	?	?	?
Volume (gal)	85,000	85,000	95,000
Activity (Ci/cc)	1.0	1.0	
<u>Recycle liquid (from Waste of TK Spray)</u>			
Made up TK cover gas	N ₂	H ₂	
T _i (°F)	91	91	91
P _i (psig)	0	0	0
Flow in (gpm)	20	20	20
Vol (gal)	3500	3500	3500
ΔVol (gal/hr)	30.87	30.87	30.87
Mixer	T (°F)	70	70
P (psig)	0	0	0
Dissolved gas	de-aerated	de-aerated	de-aerated
Made up water (gpm)	2.5	2.5	2.5
Water volume (at 100% water)	2.5	2.5	2.5

CAN PRIMARY BE DEPRESSURIZED NOW
(ie 850 psig; 250°F → 0 psig; 100°F)

4/17/99 1230 hrs
WR

Calculation of Candy cones


VOL = 4' length of 56" I.D. pipe

$$V = \frac{\pi D^2 H}{4}$$

$$H = 4'$$

$$D = 3'$$

$$V = \frac{\pi (3')^2 \times 4'}{4} = 63 \text{ ft}^3$$



Dissolved gas in primary loop @ 250°F + 850 psig.

as measured, = 63.4 cc STP

$$\frac{0.014 \times 1000 \times 1000}{(10^3)(250)} = 0.0056$$

$$\frac{8 \times 10^4}{850 \text{ psig}} \times \frac{3755.4 \text{ cc}}{\text{gal}} \times \frac{63.4 \text{ cc STP}}{1000 \text{ gal}} \times \frac{1 \text{ ft}^3}{28.316 \text{ cc}} = 778 \text{ ft}^3$$

Equilib dissolved gas at NUTK conditions of 15 psia + 100°F

is 22.4 cc H₂/kg H₂O or 16 cc N₂/kg of H₂O. Assume 7.5% H₂

$$\frac{85000 \text{ gal}}{1000 \text{ gal}} \times \frac{3755.4 \text{ cc}}{\text{gal}} \times \frac{22.4 \text{ cc}}{1000 \text{ gal}} \times \frac{1 \text{ ft}^3}{28.316 \text{ cc}} = 255 \text{ ft}^3$$

$\Delta = 778 - 255 = 523 \text{ ft}^3$ would be evolved going from

measured conditions @ 850 psig + 250°F → 0 psig + 100°F

1) CONCLUSION: DONT DEPRESSURIZE or will
bind candy cones and defeat circulation
especially Natural Circ.

CAUTION: based on only one sample mass of gas
in primary.

2) CONCLUSION: Must strip down to ~ 20 cc STP
of dissolved gas in primary before depressurizing.
Note: CE (Carmie McClachlan) has been asked to
reach conclusions + estimate rate of degassing.

Miss Hannah ²⁰¹¹
Annie McGeehan ^{Via} Mr. Hill
 203-688-1911 X 4134

11-5-51
 4/17/59 1350 hrs
 us

What dissolved gas will be in Primary liquid
 at Steady State for following conditions

	<u>Condition 1</u>	<u>Condition 2</u>	<u>Condition 3</u>
<u>Primary liquid</u>			
T (°F)	225	160°F	130°F
P (psi)	850	850	0
Dissolved gas	^{4/17/59} (1350 hrs)		
H ₂ (cc STP/gal)	31.2	-	-
O ₂ "	2.1	-	-
N ₂ "	32.3	-	-
CO ₂ "	-	-	-
Reduction (2H ₂ + O ₂ → 2H ₂ O)	?	?	?
Oxidation (2C + O ₂ → 2CO)	?	?	?
Volume (gal)	85,000	85,000	95,000
Activity (Ci/cc)	1.0	1.0	
<u>Recycle liquid (flow rate of TC pump)</u>			
Rate of the cover gas			
	H ₂	H ₂	
T (°F)	91	91	91
P (psi)	0	0	0
Flow m (gpm)	20	20	20
Vol (gal)	3500	3500	3500
ΔVol (gpm)	30.81	30.81	30.77
<u>Makeup</u>			
T (°F)	70	70	70
P (psi)	0	0	0
Dissolved gas	Associated	deassociated	Associated
Makeup rate (gpm)	2.5	2.5	2.5
Vent to atm (at 100 ft. rise)	2.5	2.5	2.5

Can't find the ...
 (10 000 ...)

1122
 1123062
 102

...
 ...



...
 ...

$$\frac{1000 \times 1000 \times 1000 \times 1000}{1000000000000} = 1000$$

Explic ...
 10 220 ...
 $\frac{1000 \times 1000 \times 1000 \times 1000}{1000000000000} = 255$

$\Delta = 775 = 245 = 523 \text{ ft}^3$...

1) CONCLUSION: DONT ...
 ...

2) CONCLUSION: MUST ...
 ...

Inter-Office Memorandum

Date April 18, 1979
TSG-057
Subject Primary System Dissolved Gases
(Degas File)
To R. F. Wilson



Location Three Mile Island

I asked Conrad McCracken to estimate the equilibrium dissolved gases in primary liquid for the three conditions shown on the attached. The request was made the afternoon of April 17, 1979.

I also asked him to think about how long it might take to go from Condition 1 to equilibrium in Condition 2 and in Condition 3 assuming a step change from Condition 1 to Condition 2 and from Condition 2 to Condition 3.



W. W. Lowe

WWL/al
ATT

cc: T. M. Crimmins
Staudt/File

C-E Power Systems
Combustion Engineering, Inc
1000 Prospect Hill Road
Windsor, Connecticut 06095

Tel 203/688 1911
Telex 9-9297

6/7/2.3.e-42
DEFITS

POWER
SYSTEMS

CC W. Lowe
G. Broughton
Law

April 17, 1979

Mr. Tom Crimmins
Three Mile Island
Visitors Center and Trailer Camp
Trailer #11
Route 441
Middletown, Pennsylvania

Subject: Estimate of Volume of Non-Condensable Gas vs. Time

Dear Mr. Crimmins:

Confirming our telecopy of 4/10/79, attached is the C-E writeup regarding the subject gas release. One comment received back was that the letdown flow was "recycled", not as assumed by C-E to be "not recycled". We do not see this assumption as changing our conclusions as long as the makeup water tank is of sufficient volume and at a pressure where degassing will occur in the letdown stream. This appears to be the case.

The only potentially significant source of error would be the estimated 20 GPM flow rate (given to C-E for pump seal leakoff). Based on 20 GPM it would have taken 10 days to reach a safe condition (i.e., April 2 to April 12, 1979, 10 days, as shown on the curves). In the event actual seal leakoff was less, the necessary degas time would increase proportionally (i.e., at 10 GPM degassing would have to continue for 20 days, until April 22, and at 5 GPM degassing would have to continue for 40 days, until May 12, 1979).

Very truly yours,

V C Hall
V. C. Hall

VCH/es
Attachment

PRELIMINARY

Problem

Estimate the volume of gas released, if any, as a result of cooling and depressurizing the reactor coolant system, taking into account continuous gas removal by feed and bleed at approximately 20 GPM.

Initial Conditions

- Pressure = 1,000 PSIA/985 PSIG
- Temperature = 280°F

Assumptions

- Bubble disappeared at 1200, April 2, 1979
- RC saturated with H₂ at that time (1,560 cc H₂ @ STP/Kg)
- Letdown flow 20 GPM @ 120°F (9,900 #/HR) not recycled
- Makeup flow same, air-saturated water (18 cc/Kg air, assume 100% N₂ for most limiting case)
- Ideal Gas Law assumed for all gases and water vapor
- Perfect mixing in RCS

Results

1. Calculation of limiting dissolved H₂ gas concentrations.

The approach was to calculate limiting dissolved gas concentrations relative to:

- bubble nucleation
- formation of 100 ft³ of bubble

Results are presented on Table I.

These figures should be taken as targets for degasification.

Conclusions

- (1) H₂ must be reduced to < 1,100 cc/Kg to avoid bubble formation due to cooling while maintaining 1,000 PSIA. The maximum bubble, assuming no degasification, would be approximately 75 ft³ at 1,000 PSIA/150°F.
- (2) H₂ must be reduced to < 30 cc/Kg to avoid bubble formation due to cooling and depressurizing to 50 PSIG.
- (3) Total gases (H₂ plus air) must be reduced to < 50 cc/Kg to avoid bubble formation due to cooling and depressurizing to 50 PSIG.

4/10/79

2. Calculation of Rate of Gas Removal

Based on a RCS mass of 6×10^5 lb @ 9.9×10^3 lb/hr bleed, H₂ concentrations will be reduced with a half-life of approximately 42 hours (1-3/4 day). Coolant air concentration will increase to saturation (13 cc/Kg) with the same half-life. Results are plotted on Figure 1.

Also plotted are the minimum pressures to prevent bubble formation at 200°F and 150°F as a function of time. These curves include the partial pressures of air (assumed N₂), H₂, and water vapor.

Conclusions

- 1) In order to meet a target concentration of 30 cc H₂/Kg, degasification should continue until approximately noon on April 12.
- 2) In order to depressurize to 50 PSIG at 200°F without forming gas bubbles, degasification should continue until early on April 12.

Note: As final temperature increases, the vapor pressure of water becomes more significant and reduces the allowed gas concentration (extends degasification times).

Slightly increasing system pressure will compensate for the additional water vapor pressure.

Note: The above calculations assume no input of gases from radiolysis.

Summary Conclusion

Based on coolant bleed/feed and the associated assumptions, no gas bubble will form at 150°F primary temperature and 50 psig primary pressure after 4/12/79.

4/10/79

TABLE I

DISSOLVED H₂ CONCENTRATIONS
FOR VARIOUS CONDITIONS
CONDITION: INITIAL PRESSURE - 1000 PSIA
INITIAL TEMP - 200°F

PRELIMINARY

FINAL PRESSURE (PSIA)	TEMPERATURE (°F)	UNITS - CC (STD) / KG WATER
985 (1000)	150	1130
	200	1220
	220	1300

1. COOL WHILE MAINTAINING PRESSURE
a. TO PREVENT BUBBLE FORMATION
b. TO PREVENT BUBBLE > 100 ft³ IN HOT LEG

TOTAL BUBBLE FORMED BY COOLING H₂ SAT WATER
50 (65)

a. TO PREVENT BUBBLE FORMATION

(assuming air-saturated makeup, 70°F atm)	44	38	34
** (assuming N ₂ -saturated makeup, 70°F atm)	40	33	36

b. TO PREVENT BUBBLE > 100 ft³ IN HOT LEG

→ (assuming all bubble to one HL)	75	62	55
→ (assuming 30% of bubble to HL)	157	128	115

3. TOTAL GNS (H₂ + AIR) TO PREVENT ABOVE

ADD 18 cc/kg
to above

RATE OF DECREASE OF DISSOLVED H₂

ASSUME: H₂-SATURATED

① 1000 PSIA @ 280°F,

12-00, 4/2/79,

18.3 cc/kg AIR IN
H₂O

H₂ cells

10² PSIG

10⁰

AIR cells

10⁰



PRELIMINARY

Based on discussions with Mr. Paul Cohen (consulting chemical engineering from Westinghouse, retired), review of data in his book, and discussions with Dr. Jenks of ORNL, it is their opinions that net recombination, VIZ no coolant radiolysis persists in the TMI-II core.

From my experience with a pressurized heavy water cooled and moderated reactor, net radiolysis occurred only under power operation, with a thermal neutron flux of 10^{13} n/cm², a dissolved hydrogen content of ≤ 1.5 cc/kgm coolant, and sub-cooled boiling in the core. Even there, oxygen concentrations were ≤ 2 ppb in the coolant.

Thus, with current and anticipated primary system conditions at TMI-II, we do not expect any hydrogen generation from radiolysis.

References

1. Cohen, P. Water Coolant Technology of Power Reactors, Gordon and Breach, 1969, page 100,101.
2. Jenks, ORNL 3843, 1965
3. Jenks and Greiss - ORNL 4173, 1967

PB/mac

4/10/79

MICROFILM

DOCUMENT INDEX TARGET

DESCRIPTION

H Y D R O G E N B U B B L E D A T A
H C - 0 0 0 2

(55 spaces maximum)

DATE

0 5 - 0 3 - 7 9

(18 spaces maximum)

DESCRIPTION CONTINUATION

FILE NUMBER

(20 spaces maximum)


NOTE: Maximum spaces include all punctuation marks, dashes and spaces between words.

Description continuation should only be used when abbreviations are not appropriate.

REEL NO _____ BLIP NO _____

HYDROGEN BUBBLE DATA
TMI UNIT 2
(4/18/79 DRMG)

TIME (MRS)	HYDROGEN BUBBLE SIZE
78	118.3
79	69.2
81	82
86.3	900
86.9	717
87.3	804
88	848
101.4	833
101.9	685
103.3	710
104.75	564
105	535
107.3	501
110.3	486
113.7	224
115.7	223
117	428
120.0	101
122.25	655
124.25	198
125.1	285
127.0	108
127.8	203
128.5	162
130.5	47
132.25	289
133.25	194
135.25	175
137.5	48
142.5	221
150.25	118
151	82
151	82
202.7	0



TIME - HOURS 0-3/28/7900400:36

41 20 117

31 235 117

41 20 899

41 20 823.1

41 20 505.2

41 20 919

41 20 514

41 20 519.1

41 20 501

41 20 476

41 20 293

41 20 6640

41 20 437

41 20 1105

41 20 675

41 20 188

41 20 205.2

41 20 125.1

41 20 200

D

D

D

D

D

D

D

1942
1943

1944
1945
1946

1947
1948
1949

MICROFILMED

HYDROGEN
BUBBLE LIFE

TIME (HRS)
C = 3/27 (2040)

-y6BVB T

TIME (HRS)

Hydrogen

THE
RCS Total
Gas Concentration

He received two questions on April 16, 1979, via you, from Bill Lons on total gas, as follows.

2. Can they add hydrazine (N₂H₄) to scavenge the oxygen in the RCS?

If hydrazine is added to scavenge oxygen, the RCS total gas concentration will be increased. This occurs because hydrazine reacts not only with the O₂ being scavenged (N₂H₄ + O₂ + 2H₂O + N₂) but also with metal oxides. In both cases N₂ is released. Extensive experience indicates that in a RCS you will produce approximately 2 cc/kg of N₂ for every cc of O₂ which is scavenged. Thus, in this case, 4.4 cc/kg of O₂ would be replaced with approximately 8.8 cc/kg of N₂.

If their concern is total gas, then adding N₂H₄ would not be a good choice.

If their concern is chloride stress corrosion cracking due to chlorides (Cl) and O₂ in the RCS, then it is obviously a weighted decision (i.e., add N₂H₄ to reduce chloride stress corrosion worry at the expense of total gas).

2. Based on their April 16, 1979, gas analysis (N₂-31.2 cc/kg, O₂-4.4 cc/kg, total-35.6 cc/kg); is it possible to add a bubble of air at temperature were reduced to 100°F (100°F were reduced to 100°F) (100°F)?

Based on the April 14, 1979, gas analysis, a bubble of approximately 1,020 ft³ would be formed. This includes 707 ft³ of non-condensables and 257 ft³ water vapor, with a percentage distribution as follows:

- N₂ -- 37.6
- H₂ -- 33.0
- O₂ -- 4.5
- H₂O * 24.9

At the above stated condition, 10.1 cc/kg of gas would be in solution at the following concentrations.

- N₂ -- 3.0 cc/kg
- H₂ -- 5.5 cc/kg
- O₂ -- 0.8 cc/kg


...the above sentence, the solubility of gases in water at 14.7 PSIA and 150°F is approximately 10.1 cc/kg. ... that is the concentration necessary prior to ... if no bubble is to be formed. ... the ... to 10.1 cc/kg can only be accomplished (in a ... this ... if fully deaerated makeup is used. This can be accomplished in two ways:

- A. Fall a vacuum on the RCS makeup tank (if it is so constructed as not to collapse);
- B. Discard letdown flow and only use deaerated makeup (or somehow put the letdown flow through the deaerator).

Other data which may be of interest in understanding the problem:

- At this point the major problem prior to depressurization is total gas, not its individual constituents.
- To prevent a bubble of less than 100 ft³ (assuming it forms at one location) at 14.7 PSIA, 150°F, the LMS total gas must be less than approximately 16 cc/kg.
- The major difference in bubble size between full depressurization and 50 PSIG (64.7 PSIA) is that at 50 PSIG total gas solubility in coolant is approximately 43 cc/kg while it is only approximately 10.1 cc/kg at 1 ATM.
- The conservative thing to do would be depress to approximately 10 cc/kg prior to securing the reactor coolant pump. Care the pump is secured and natural circulation initiated, perfect mixing of the RCS which is assumed and probably correct with a pump running, would no longer be the case.

In the natural circulation mode depressing rate or success will be virtually impossible to predict or measure because of imperfect mixing.


G. H. McCracken

173 10 173

1341

April 19, 1973

11 Lowe
CE 7
S
W
2009

W
W
W
W

Very faint typed text, possibly a letter or report, mostly illegible due to fading.

Very truly yours,

XXXXXXXXXXXXXXXXXXXX, INC.

J. C. [Signature]
J. C. [Name]
Project Manager

cc: [Faint text]

THE
1978
Gas Analysis

We received two questions on April 23, 1979, via you, regarding the gas, as follows.

1. Can the following (H₂) be removed by the current

... to surface oxygen. The H₂ ... will be ...
... but also ...
... of 3 ...
... of O₂ would be replaced with
... cc/lb of H₂.

If ... is total gas, then adding H₂, would not
be a ...

... chloride stress corrosion cracking
... in the ...
... (i.e., ... to ...
... at the expense of ...

2. Can the following (H₂) be removed by the current

... 23, 1979, gas analysis, a ...
...
... and 257 ...
... as follows:

- H₂ -- 37.6
- H₂ -- 53.0
- O₂ -- 4.5
- H₂O -- 23.9

If the ... 10.1 cc/lb of gas would
be ... following concentrations.

- H₂ -- 3.8 cc/lb
- H₂ -- 5.5 cc/lb
- O₂ -- 0.8 cc/lb

Preserving the above sentence, the calculation of excess for
... is a... necessary prior to
... is to...
... can only be...
... is used. This can be
...:

- A. ... (if it is so
... to collapse);
- B. ... and only use decorated ...
... through the ...

Other data which may be of interest in understanding the

- ... prior to ...
... individual ...
- ... less than ...
... at 10.7 ...
... approximately 10 ...
- ... in ...
... 10.7 ...
... only approximately 10 ...
- ... to do would be ...
... the reactor ...
... of the ...
... would be ...

In the ... of ... rate of
... to ... or
... of imperfect ...


C. H. Anderson


6/7/2. 3.e-46.

APR 22 1979

Sam

C-E Power Systems
1000 Prospect Street
Middletown, Pennsylvania 17057

Tel 207/585-1911
Telex 93057



April 19, 1979

Mr. Tom Crimmins
Three Mile Island
Visitors Center and Trailer Camp
Trailer #11
Route 441
Middletown, Pennsylvania 17057

Subject: TMI RCS Total Gas Concentration

Dear Mr. Crimmins:

Please note the attached of same subject that was prepared per your request. Copies are telecopied herewith and will be sent to you on April 19, 1979.

Very truly yours,

COMBUSTION ENGINEERING, INC.

J. C. Moulton
Project Manager

bk

Attachment

cc RFLW
RWK
JAD
APU on site Tech. Su
DRMB
G. Stouet/file

TMI
RCS Total
Gas Concentration

We received two questions on April 18, 1979, via you, from Bill Lowe on total gas, as follows.

1. Can they add hydrazine (N₂H₄) to scavenge the oxygen in the RCS?

If hydrazine is added to scavenge oxygen, the RCS total gas concentration will be increased. This occurs because hydrazine reacts not only with the O₂ being scavenged (N₂H₄ + O₂ + 2H₂O + N₂) but also with metal oxides. In both cases N₂ is released. Extensive experience indicates that in a RCS you will produce approximately 2 cc/kg of N₂ for every cc of O₂ which is scavenged. Thus, in this case, 4.4 cc/kg of O₂ would be replaced with approximately 8.8 cc/kg of N₂.

If their concern is total gas, then adding N₂H₄ would not be a good choice.

If their concern is chloride stress corrosion cracking due to chlorides (?) and O₂ in the RCS, then it is obviously a weighted decision (i.e., add N₂H₄ to reduce chloride stress corrosion worry at the expense of total gas).

2. Based on their April 14, 1979, gas analysis (H₂-31.2 cc/kg, N₂-32.8 cc/kg, O₂-4.4 cc/kg, total-68.4 cc/kg); how big would a bubble be if temperature were reduced to 150°F and pressure were reduced to one atmosphere (14.7 PSIA)?

Based on the April 14, 1979, gas analysis, a bubble of approximately 1,020 ft³ would be formed. This includes 767 ft³ of non-condensables and 257 ft³ water vapor, with a percentage distribution as follows:

N₂ -- 37.6
H₂ -- 33.0
O₂ -- 4.5
H₂O ~ 24.9

At the above stated condition, 10.1 cc/kg of gas would remain in solution at the following concentrations.

N₂ -- 3.8 cc/kg
H₂ -- 5.5 cc/kg
O₂ -- 0.8 cc/kg


Restating the above sentence, the solubility of gasses in the RCS at 14.7 PSIA and 150°F is approximately 10.1 cc/kg, therefore, that is the concentration necessary prior to depressurization if no bubble is to be formed. Degassing the RCS to 10.1 cc/kg can only be accomplished (in a reasonable time span) if fully deaerated makeup is used. This can be accomplished in two ways:

- A. Pull a vacuum on the RCS makeup tank (if it is so constructed as not to collapse);
- B. Discard letdown flow and only use deaerated makeup (or somehow put the letdown flow through the deaerator).

Other data which may be of interest in understanding the problem:

- At this point the major problem prior to depressurization is total gas, not its individual constituents.
- To prevent a bubble of less than 100 ft³ (assuming it forms at one location) at 14.7 PSIA, 150°F, the RCS total gas must be less than approximately 16 cc/kg.
- The major difference in bubble size between full depressurization and 50 PSIG (64.7 PSIA) is that at 50 PSIG total gas solubility in coolant is approximately 40 cc/kg while it is only approximately 10.1 cc/kg at 1 ATM.
- The conservative thing to do would be degass to approximately 10 cc/kg prior to securing the reactor coolant pump. Once the pump is secured and natural circulation initiated, perfect mixing of the RCS which is assumed and probably correct with a pump running, would no longer be the case.

In the natural circulation mode degassing rate or success will be virtually impossible to predict or measure because of imperfect mixing.


C. E. McCracken

6/712-3.e-47

CONSTRUCTION ENGINEERING, INC.
100 WEST 42ND STREET
NEW YORK, N.Y. 10018

100 WEST 42ND STREET
NEW YORK, N.Y. 10018

APR 19 1979

E. DeGos

April 19, 1979

1341

*W. Wilson
at 7:00 am
of 4/19/79
by Wilson
D. J.
ADP 100-100-100
with 100-100-100
D.*

Mr. Tom Collins
Visitors Center and Trailer Camp
State College, PA
State College, Pennsylvania 17057

Subject: THE NEW Total Gas Concentration

Dear Mr. Collins:

Please note the attached of same subject that was prepared for your request. Copies are being copied herewith and will be sent to you on April 19, 1979.

Very truly yours,

CONSTRUCTION ENGINEERING, INC.

J. C. Houlton

J. C. Houlton
Project Manager

cc
Attachment

GENERAL & MILITARY CO.
COMM. SEC. GROUP
TU-2 OPERATIONS

6/712.3.e-48

APR 20 1979

11:45 am

TRANSMITTAL TO:

E. ROGERS TRANSMITTAL # _____

ALSO TELECOPY TO: R. WILSON TRANSMITTAL # W311

B&W TRAILER 26 TRANSMITTAL # W311

TIME _____ DATE APRIL 20, 1979

SUBJECT REACTOR COOLANT CHEMISTRY RECOMMENDATION

APPROVED BY *[Signature]*
OPERATIONS MANAGER

B&W ACTION # 543

F Regan

- CC: R. C. ARNOLD
- R. F. WILSON
- R. W. KEATEN
- T. H. CRIPMINS*
- J. DANIELS
- J. G. HERBEIN
- D. MONTGOMERY
- ADM. ASST. GPU ON SITE
- TECH SUPPORT
- DATA REDUCTION & MGMT
- STAUBT/FILE (ORIGINAL)

BADCOCK & WILCOX COMPANY
2ND GENERATION GROUP

INSTRUCTION NO. 543

D. W. BERRY

H. J. BELL

808 643-3

File No.
or Ref.

REACTOR COOLANT CHEMISTRY RECOMMENDATION

Date
APRIL 19, 1979 0945

This letter is confidential and contains sensitive information.

ADDITIONAL INFORMATION OBTAINED FROM THE LATEST PRESSURIZED REACTOR COOLANT SAMPLE INDICATES DEVIATION TO THE PREVIOUS TRANSMITTAL (18-300) IS IN ORDER. A SUMMARY OF RCS GAS DATA (H_2 , N_2 , O_2) FROM PRESSURIZED SAMPLES IS GIVEN IN THE ATTACHED DRAWING. A MAJOR DISCREPANCY IS NOTED BETWEEN THE IGMND (4/19) AND THE DSM HYDROGEN RESULTS (4/16, 19). BASED ON TELEPHONE INFORMATION, IGMND WAS TESTED 75 SECONDS "DOWN" AND FOUND SIGNIFICANT HYDROGEN LEAKAGE AFTER ABOUT A THREE HOUR TIME INTERVAL. THIS MAY ACCOUNT FOR THE LOW HYDROGEN VALUE REPORTED BY IGMND SINCE THE DSM SAMPLES WERE ANALYZED AFTER A SHORTER TIME INTERVAL. THE HYDROGEN AND THE LAST TWO OXYGEN DATA POINTS WOULD INDICATE SOME DEGRASSING IS OCCURRING WITH ABOUT A 4 DAY HALF TIME. SINCE THE DATA BASE IS ONLY TWO SAMPLES (DSM), WE RECOMMEND THAT SAMPLING BE CONTINUED UNTIL A CONFIRMED TREND IS ESTABLISHED.

ALL OF THE SAMPLES INDICATE THE PRESENCE OF OXYGEN (1.8-4.4 cc/kg). AS DISCUSSED IN TRANSMITTAL 18-300, ABOUT 67,000 cc OF OXYGEN MAY BE ADDED TO THE RCS AT A 2 GPM MAKEUP RATE. THIS OXYGEN WOULD BE EXPECTED TO RECOMBINE WITH THE 22-31 cc/kg OF HYDROGEN INDICATED TO BE PRESENT FROM THE SAMPLE ANALYSES. HOWEVER, WE RECOMMEND THAT IT WOULD BE PRUDENT TO ADD HYDRAZINE TO THE RCS TO INSURE A REDUCING ENVIRONMENT AND MINIMIZE THE POTENTIAL FOR MATERIAL DAMAGE. BASED ON 1.8 cc O_2 /kg, ABOUT 7.5 LITERS OF 30% HYDRAZINE SOLUTION BE ADDED TO THE RCS. THIS IS EQUIVALENT TO ABOUT 300% OF THE STOICHIOMETRIC OXYGEN CONCENTRATION.

THE ADDITION OF HYDRAZINE MAY RESULT IN THE FORMATION OF SOME INERT GAS IN THE RCS. IF IT IS ASSUMED THAT ALL OF THE HYDRAZINE DECOMPOSES TO NITROGEN AND HYDROGEN, EACH POUND OF HYDRAZINE COULD GENERATE ABOUT 3.5 cc/kg OF GAS IF NO OXYGEN REACTION OCCURS. FOR 7.5 LITERS OF HYDRAZINE SOLUTION (DSM) ADDED TO THE RCS, ABOUT 20 cc/kg OF INERT GAS (N_2 AND H_2) WOULD BE GENERATED. IF THE 1.8 cc O_2 /kg

Page 2

From H. J. Bell to D. M. Berger

April 19, 1973 0045

REACTS WITH THE HYDRAZINE, 16.4 cc/kg OF INERT GAS RESULTS. THIS REACTION IS UNLIKELY SINCE HYDRAZINE WOULD BE EXPECTED TO DECOMPOSE IN THE RADIATION FIELDS TO NITROGEN, HYDROGEN, AND AMMONIA. IN THIS CASE, ONLY 6.4 cc/kg OF INERT GAS WOULD BE GENERATED (FOR THE 7.5 LITERS OF SOLUTION ADDED). THIS IS THE REACTION BY WHICH WE BELIEVE THE MAJORITY OF THE DECOMPOSITION WILL OCCUR.

IN SUMMARY, THE INDICATIONS ARE THAT THE IDEAL GROSS ANALYSES MAY BE LOW DUE TO LEAKAGE. HOWEVER, SOME DEGRASSING MAY BE INDICATED FROM THE NITROGEN DATA. WE RECOMMEND ADDITIONAL SAMPLING UNTIL A CONFIRMED TREND IS OBSERVED. ~~IT IS OUR RECOMMENDATION THAT IT IS PRUDENT TO ADD HYDRAZINE (7.5 LITERS OF 35% SOLUTION) TO THE RCS TO REACT WITH THE HYDROGEN INTRODUCED WITH THE AERATED MAKEUP.~~ IT IS OUR RECOMMENDATION THAT IT IS PRUDENT TO ADD HYDRAZINE (7.5 LITERS OF 35% SOLUTION) TO THE RCS TO REACT WITH THE HYDROGEN INTRODUCED WITH THE AERATED MAKEUP.


MJB/cm

cc: RAD CHEM. GROUP

6/12-3.8-49

RC Gas Concentration (cc/lb)

4/15
4/15
4/19
4/15
4/1
4/15
4/15
4/19
4/19



Summary of
 Analyzed RC Gas
 Temperature
 2
 RC Gas

Hydrogen
 Hydrogen

Analysis Performed at:

4/13

4/16

4/18

*Hypoxia
Committee*

APR 20 1979

R. C. ARVED
L. VILLO
R. W. PLATT
T. H. ...
J. ...
D. ...
S. ...
STAUDT/FILE (ORIGINAL)

20 April 1979

To: D. A. Pullen
From: P. W. Marriott
Subject: FLAMMABILITY OF H₂ AT HIGH PRESSURE

On April 3, Dr. Richl of NASA, who was consulting for GM, telephoned us directly to request our comments on his proposed flammability and detonability limits for H₂ at 100 psia. Since the request did not come through Rockwell from GM, we have treated the request as second priority. I realize the need has passed, but for the record our comments follow. Please give them to GM: I do not know how to contact Dr. Richl.

For the conditions of 1000 psia, 300°F water, H₂ and O₂ mixtures, the referenced sources give the following for the limits of flammability.

	H ₂	O ₂	
Lower limit of flammability	6	6	(1)
Flammability limit for 100% combustion	9	7-1/2	(2)
Lower limit for detonability	15	10	(3)

Reference (1): Bureau of Mines Bulletin #503

Reference (2): NACA Report #1333

Reference (3): GE SAR Advanced Design Memo #25

- a) The conditions listed give about 7% (mole fraction) of H₂O in the gas, really a very small influence.
- b) The lower limit of detonability is an extrapolation of KAPL experimental data.

In summary, our sources show Dr. Richl's proposed limits to be conservative with the exception of the O₂ concentration required for detonation.

P. W. Marriott
P. W. Marriott, Chairman
Three Mile Island Task Force
IVC 199 Ext. 56948

/afm

cc: LB Nesbitt
ER Wilkins/FD Judge

A. G. ...
W. H. ...
P. W. ...
T. M. ...
J. E. ...
J. G. ...
D. W. ...
ADM. ASST. CPU ON SITE
FROM DIRECTOR
DATA DIVISION - CPU
SINGAPORE (ORIGINAL)

5000
APR 20 1979

20 April 1979

To: E. P. Stroupe
D. A. Pullen

From: P. W. Marriott

Subject: REABSORPTION OF NONCONDENSIBLE GASES IN BOILING MODE

This memorandum summarizes the information in the eleven pages of calculations and notes telecopied to Ditsore at IAG on April 17. EPS - it is for your use as you see fit. DAP - it is for you to give to CPU, who asked the same question on April 3.

The TID 14044/RG 1.7 radiolysis source term, i.e., for 1% of the core diffused into water, 100% of the H₂ released, 50% of the halogen in the water, will be about 60 scfh for H₂ and approximately 30 scfh for O₂.

If the H₂ concentration in the water near the ionizing source is 2 ppm or above, it is expected that radiolysis will be essentially completely suppressed, i.e., H₂ generation rate below 3 scfh.

The case for boiling in the reactor, condensing in the steam generator was analyzed for mass transfer of H₂ into the condensed film on the inside of the tubes and for the maximum possible amount of H₂ (or O₂) that could be transferred to the condensed steam.

- Assumptions:
- 1) About 27 feet of tube was available for condensing and mass transfer from the gas to the liquid.
 - 2) 15,500 tubes with 0.030" wall, 0.625 OD.
 - 3) Cooling water approximately 120°F.
 - 4) Heating rate 3 MWt = boiling mass transfer of approximately 10⁴ lb/hr.

Conclusions: 1) Under these conditions it is calculated that at 2 ata of H₂ and 1 ata of O₂ in the noncondensable gas portion of the steam generator tubes, the maximum rate of removal of H₂ is, conservatively 5.6 scfh; for O₂ the rate is approximately 3 scfh (water saturated with H₂ and O₂).

E. P. Stroupe
D. A. Pullen
20 April 1979
Page 2

- 2) If the H_2 pressure was 15 ata, the removal rate would be about 49 scfh and O_2 of 7.5 ata about 22 scfh (water saturated with H_2 and O_2).
- 3) In both cases the concentration of H_2 in the liquid would be in excess of 2.9 ppm.
- 4) Under these conditions, with $P_{H_2} = 2$ ata, and assuming that all the steam is condensed in the first 12 feet of the tube and mass transfer in the remaining 15 feet, more than 255 scfh of H_2 could be transferred to the film versus a maximum of 5.6 needed, (i.e., the process is limited by the solubility of H_2 in H_2O , not by film transfer).

Almanis

P. W. Harriott, Chairman
Three Mile Island Task Force
W/C 194 Ext. 56948

/aim

cc: DC Ditmore
LB Heshitt
W Siegler
LR Wilkins/FD Judge

5:15 pm
APR 20 1979

Task 1A
6/7/12-3052
C: R. C. ARNOLD
A. F. WILSON
K. W. KEATON
T. H. GRIMMINS
J. DANIELS
J. G. HANGLIN
D. MONTGOMERY
ADM. ASST. CPU ON SITE
TECH SUPPORT
DATA RECEPTION & MGMT
STAUFF/FILE (ORIGINAL)

20 April 1979

To: D. A. Pullen
From: P. W. Harriott
Subject: FLAMMABILITY OF H₂ AT HIGH PRESSURE

On April 3, Dr. Richl of NASA, who was consulting for GPU, telephoned us directly to request our comments on his proposed flammability and detonability limits for H₂ at 1000 psia. Since the request did not come through Rockwell from GPU, we have treated the request as second priority. I realize the need has passed, but for the record our comments follow. Please give them to GPU. I do not know how to contact Dr. Richl.

For the conditions of 1000 psia, 200°F water, H₂ and O₂ mixtures, the referenced sources give the following for the limits of flammability.

	H ₂	O ₂	
Lower limit of flammability	4	6	(1)
Flammability limit for 100% combustion	8	7-1/2	(2)
Lower limit for detonability	15	10	(3)

Reference (1): Bureau of Mines Bulletin #503

Reference (2): NACA Report #1383

Reference (3): GE SAR Advanced Design Memo #56

- a) The conditions listed give about 7% (mole fraction) of H₂O in the gas, really a very small influence.
- b) The lower limit of detonability is an extrapolation of KAPL experimental data.

In summary, our sources show Dr. Richl's proposed limits to be conservative with the exception of the O₂ concentration required for detonation.

P. W. Harriott, Chairman
Three Mile Island Task Force
M/C 194 Ext. 55948

/aim

cc: LB Nesbitt
DR Wilkins/FD Judge

6/7/2-3.e-53

Inter-Office Memorandum



Page 2

Date April 21, 1979
TSG-081

Subject Recommendation for End Point of
Degas Mode

To T. M. Crimmins

Location Three Mile Island

Recommendations from CE (Conrad McCracken, Herb Cato, V.C. Hall) and B&W (J. H. McMillan) all focus on total gas content of the primary coolant rather than individual partial contributors such as hydrogen.

The objective of the degas mode is to lower primary coolant gas content sufficiently to assure that gas evolution will not occur as primary coolant pressure and temperature are lowered to ultimate cold depressurized conditions (<100°F atmospheric pressure).

For the ultimate cold depressurized conditions, CE and B&W recommendations for degas end point are 20 cc/kg (STP) total gas and 15 cc/kg (STP) total gas respectively.

Recommendation: Establish the end point for degassing as ≤ 15 cc/kg (STP) total gas content of primary coolant.

K. Ellison
K. Ellison

KE/al

cc: R. W. Keaten
R. F. Wilson
Staudt/File

6/712-3.e-54

Inter-Office Memorandum

4/21/79
Date: April 21, 1979
TSG-081
Subject: Recommendation for End Point of
Degas Mode
To: T. M. Crimmins



Three Mile Island

Recommendations from CE (Conrad McCracken, Herb Cato, V.C. Hall) and B&W (J. H. McMillan) all focus on total gas content of the primary coolant rather than individual partial contributors such as hydrogen.

The objective of the degas mode is to lower primary coolant gas content sufficiently to assure that gas evolution will not occur as primary coolant pressure and temperature are lowered to ultimate cold depressurized conditions (<100°F atmospheric pressure).

For the ultimate cold depressurized conditions, CE and B&W recommendations for degas end point are 20 cc/kg (STP) total gas and 15 cc/kg (STP) total gas respectively.

Recommendation: Establish the end point for degassing as ≤ 15 cc/kg (STP) total gas content of primary coolant.

K. Ellison

K. Ellison

KE/al

cc: R. W. Keaten
R. F. Wilson
Staudt/Pile

April 22, 1979
TSG-082



Alternate Recommendation for End
Point of Degas Mode (Including Long
Term Radiolysis Control) (Task AA9 and AA22)
T. M. Crimmins

Three Mile Island

Reference: Memo R. Ellison to T. M. Crimmins, Recommendation for
End Point of Degas Mode, April 21, 1979

The referenced memo identified a recommended end point for the degas mode of ≤ 15 cc/kg (STP) total gas content of primary coolant. This recommendation was based on the ultimate cold depressurization of the primary system ($< 100^{\circ}\text{F}$, atmospheric pressure).

Since ultimate depressurization to atmospheric pressure will not occur in the near future, the end point for the current degas mode may be redefined to address long term cooling with the primary system in natural circulation ($< 100^{\circ}\text{F}$, ≥ 50 psig). To prevent gas evolution from the primary coolant which could jeopardize successful natural circulation, CE and B&W have recommended < 50 cc/kg and < 40 cc/kg (STP) total gas content of the primary coolant.

In addition to limiting total gas content, B&W has recommended that 5-15 cc/kg (STP) of hydrogen be maintained in the primary coolant to suppress the possibility of long term radiolysis. In addition, Paul Cohen has indicated that no radiolysis is expected even with < 1.5 cc/kg H_2 in the primary coolant. P. W. Marriott has indicated that with 1 atm. of H_2 overpressure in the makeup tank (approximately 15 cc/kg H_2) no radiolysis would occur.

Recommendation:

1. Establish the end point for degassing (to support long term natural circulation) as ≤ 40 cc/kg (STP) total gas content of primary coolant.
2. To suppress the possibility of long term radiolysis, maintain 5-15 cc/kg (STP) of hydrogen in the primary coolant.

K. R. Ellison
K. Ellison

RE/al

cc: R. F. Wilson
R. W. Keaten

6/712-3.e-56

MICROFILM

DOCUMENT INDEX TARGET

DESCRIPTION

*Temp. in blue reading
in start up of Hylley
on 05-03-79* (55 spaces maximum)

05-03-79

DATE

~~05-03-79~~

(18 spaces maximum)

DESCRIPTION CONTINUATION

LLP-0001

FILE NUMBER

(20 spaces maximum)

NOTE: Maximum spaces include all punctuation marks, dashes and spaces between words.


Description continuation should only be used when abbreviations are not appropriate.

REEL NO. _____ BLIP NO. _____

Per Temp - 11-11-4-24-79

230
229
226
224
222
220
218
216
214
212
210
208
206
204
202

1900
1915
1930
1945
2000
2015
2030
2045
2100
2115
2130
2145
2200
2215
2230
2245
2300
2315
2330
2345
2400



11-11-4-24-79

Cancelled - Put on inner head OPCA.
Cop B.

A. CTSC pressure

25
21
23
24
21
20
19
18
17
16
15
14
13
12
11
10
9
8
7
6

1900
1915
1930
1945
2000
2015
2030
2045
2100
2115
2130
2145
2200
2215
2230
2245
2300
2315
2330
2345
2400



Other part on lower level CPSC

B. C156 JOURNAL

25 24 23 22 21 20 19 18 17 16 15 14 13 12 11 10 9 8 7

1920
 1915
 1930
 1945
 2000
 2015
 2030
 2045
 2100
 2115
 2130
 2145
 2200
 2215
 2230
 2245
 2300
 2315
 2330
 2345
 2400

Cancelled part on main book C156 of B

MASSACHUSETTS
INSTITUTE OF TECHNOLOGY

DEPARTMENT OF
CHEMICAL ENGINEERING



6/712-3.e-57
MAY 2 1979

Room number: 66-350

Cambridge, Massachusetts
02139

Telephone: (617) 253-4561

April 25, 1979

MAY 8 1979

1500

cc: JFW
R Long
J Daniel
DPMG
Adm. Assist. - G.P.
File

Mr. Tom Crimmins
Three Mile Island
General Public Utilities
Trailer 11
Middletown, Pennsylvania 17057

Dear Mr. Crimmins:

I must apologize for the omission of the copy of the article by Pray et al, "Solubility of Hydrogen, Oxygen, Nitrogen and Helium", Ind. and Eng. Chem. 44, 1146 (1952) which was supposed to be attached to my recent memorandum on Hydrogen Degassing.

Please find a copy enclosed.

Sincerely,

J. Edward Vivian
Professor of Chemical Engineering
Executive Officer

JEV:sje

Attach.

TABLE VIII. COMPARISON OF CYCLOPARAFFIN CONTENT OF C_7 AND HEAVIER FRACTIONS

(By mass spectrometer analysis and refractivity intercept method)

Boiling Range of Fraction, ° F.	Volume % of Naphtha					
	Mono-cyclo-paraffins		Dicyclo-paraffins ^a		Corrected ^b	
	Paraffins		Paraffins	Cyclo-paraffins	Paraffins	Cyclo-paraffins
	MASS SPECTROMETER ANALYSIS			REFRACTIVITY INTERCEPT METHOD		
270-306	56	44	0	57	43	43
306-338	55	40	5	44	56	46
338-391	51	40	6	33	67	54
391 and higher	53	38	9	25	75	55

^a May also include small amounts of tricycloparaffins.
^b Refractivity intercept of the cycloparaffins corrected for the presence of dicycloparaffins indicated in mass spectrometer analysis.

fractions. A serious discrepancy is shown in Table VIII between the paraffin-cycloparaffin splits in the C_7 and heavier distillate fractions boiling above 306° F. as calculated by the mass spectrometer and refractivity intercept methods. It is believed that much of this difference is due to the presence of dicycloparaffins and possibly tricycloparaffins which are shown in Table VIII to as high as 9% in one fraction. The data of Ward and Kurtz (12) show that the difference in refractivity intercept between paraffins and dicycloparaffins is several times greater than that between paraffins and monocycloparaffins. By correcting the value of the refractivity intercept of cycloparaffins for the presence of dicycloparaffins, a fair agreement was reached between the two methods of analysis for paraffin content. Exact agreement can hardly be expected since a small deviation in the mass spectrometer analysis

for dicycloparaffins produced a change in the refractivity intercept termination for paraffins.

LITERATURE CITED

- (1) Bell, M. F., *Anal. Chem.*, **22**, (1950).
- (2) Brown, R. A., *Ibid.*, **23**, 430 (1951).
- (3) Brown, R. A., Taylor, R., Polder, F. W., and Young, W., *Ibid.*, **20**, 5 (1948).
- (4) Cady, W. E., Marschner, R. F., Cropper, W. P., paper presented at 119th Meeting, Am. Chem. Soc., Cleveland, Ohio, April 1951.
- (5) Glasgow, A. R., Willingham, C., and Rossini, F. D., *IND. ENG. CHEM.*, **41**, 2292 (1949).
- (6) Mair, B. J., *J. Research Natl. Bur. Standards*, **34**, 435 (1942).
- (7) Noller, C. R., and Barusch, M. R., *IND. ENG. CHEM., ANAL. ED.*, **14**, 907 (1942).
- (8) Podbielniak, W. J., *Ibid.*, **13**, 639 (1941).
- (9) Rampton, H. C., *J. Inst. Petroleum*, **35**, 42 (1949).
- (10) Starr, C. E., Tilton, J. A., and Hockberger, W. G., *IND. ENG. CHEM.*, **39**, 195 (1947).
- (11) Taylor, W. J., Wagman, D. D., Williams, M. G., Pitzer, K. S., and Rossini, F. D., *J. Research Natl. Bur. Standards*, **37**, 1 (1946).
- (12) Ward, A. L., and Kurtz, S. S., *IND. ENG. CHEM., ANAL. ED.*, **11**, 559 (1938).

RECEIVED for review May 2, 1951.

ACCEPTED December 31, 1951.

Presented as part of the Symposium on Composition of Petroleum and Hydrocarbon Derivatives presented before the Division of Petroleum Chemistry at the 119th Meeting of the AMERICAN CHEMICAL SOCIETY, Cleveland, Ohio, April 1951.

Solubility of Hydrogen, Oxygen, Nitrogen, and Helium in Water

AT ELEVATED TEMPERATURES

H. A. PRAY, C. E. SCHWEICKERT, AND B. H. MINNICH¹

Battelle Memorial Institute, Columbus 1, Ohio

THE increasing application of high temperatures and pressures to various processes has made a knowledge of the solubilities of compressed gases in water necessary for purposes of engineering design. A survey of the literature has revealed that considerable data are available on the solubilities of gases under partial pressures of more than 25 atmospheres and at relatively low temperatures. Data in the region from about 5 to about 25 atmospheres and from about 125° F. to temperatures near the critical point of water are very meager and incomplete. A determination of the solubilities of oxygen, hydrogen, helium, and nitrogen in water at temperatures from 125° to 650° F. and at pressures up to about 500 pounds per square inch absolute was, therefore, undertaken.

EXPERIMENTAL PROCEDURE. For determining the solubilities of gases in water, the apparatus shown in the schematic diagram (Figure 1) was used. A typical example of the use of this apparatus is as follows:

Valves *A* and *B* are closed, valves *C* and *D* are opened, and the 3-liter bomb contained in the rocking autoclave, *E*, is evacuated by means of the vacuum pump, *F*. Valve *A* is then opened and about 1500 ml. of distilled water are admitted to the bomb from

¹ Present address, Naval Ordnance Testing Station, Inyokern, Calif.




Figure 1. Diagram of Solubility Apparatus

Figure 2. S




Figure 3.




Figure 2. Solubility of Oxygen in Water with Varying Pressure

O. Authors
 Δ. Frohlich et al. (1)




Figure 4. Solubility of Hydrogen in Water with Varying Pressure

A. Ipatieff and Teodorovich (2)
 B. Authors
 C. Wiebe and Gaddy (3)




Figure 3. Solubility of Oxygen in Water with Varying Temperature




Figure 5. Solubility of Hydrogen in Water with Varying Temperature

TABLE I. SOLUBILITY OF OXYGEN IN WATER

O ₂ Partial Pressure, Lb./Sq. In. Abs.	Source	Ce. O ₂ /G. of Water					Average	Probable Error	Maximum Deviation
		77° F.							
140	(1)	0.28
245	0.56
370	0.70
325° F.									
100	Authors	0.14	0.16	0.16	0.15	0.01	+0.11 to -0.01
200	Authors	0.31	0.31	0.31	0.31	0.00	+0.09 to -0.09
300	Authors	0.47	0.47	0.45	0.46	0.01	-0.01 to -0.01
400° F.									
100	Authors	0.13	0.18	0.17	0.18	0.01	+0.01 to -0.01
150	Authors	0.30	0.28	0.27	0.28	0.01	+0.02 to -0.01
500° F.									
100	Authors	0.68	0.63	0.62	0.51	..	0.64	0.04	+0.35 to -0.17
200	Authors	0.92	0.89	0.89	0.59	..	0.91	0.02	+0.01 to -0.02
300	Authors	1.32	1.58	1.18	1.09	..	1.35	0.06	+0.33 to -0.26
400	Authors	1.37	1.24	1.71	0.03	+0.09 to -0.17
600° F.									
100	Authors	0.63	0.60	0.60	0.62	..	0.63	0.01	+0.06 to -0.03
200	Authors	1.39	1.45	1.43	1.42	0.02	+0.03 to -0.03
300	Authors	2.22	2.14	2.34	2.02	2.24	2.19	0.04	+0.15 to -0.17
650° F.									
104	Authors	1.17	1.26	1.22	0.01	+0.04 to -0.05
175	Authors	1.85	1.85
205	Authors	2.39	2.28	2.19	2.29	0.03	+0.10 to -0.10
280	Authors	2.96	2.56
289	Authors	2.51	2.61	2.56	0.03	+0.05 to -0.05
300	Authors	2.99	2.99

* At standard temperature and pressure.

is closed and the sampling line side of valve *B* is opened. About 25 ml. of water containing an amount of gas which depends on the partial pressure and water temperature are then collected over mercury in the measuring buret, *L*, which is surrounded by a water thermostat. The gas and water volumes are then measured and the needle valve, *M*, is opened. This allows the water that remained in the sample line, because of capillary action, to drain into the buret. After the total amount of gas and water have been determined, dry air is blown in through the inlet at *N* and allowed to escape through *M*. This procedure dries all of the sampling lines in preparation for the next sample. The solubility of the gas in water is then determined by reducing the gas and water volumes, as found in the measuring buret, to cubic centimeters of gas at normal temperature and pressure per gram of water.

EXPERIMENTAL RESULTS

The present experimental results and certain previously reported data for the solubility of hydrogen, oxygen, helium,

mined with the aid of a Leeds & Northrup Semi-Precision potentiometer, *H*. The thermocouple was calibrated against the melting points of metals obtained from the Bureau of Standards for that purpose. The temperature during any one run is held constant to within 2° F. After the temperature inside of the bomb reaches the desired temperature, the outlet valve, *A*, leading to the mercury U-tube is opened and the saturated vapor pressure of water is determined with the dead-weight gage, *J*. The mercury U-tube isolates the material in the bomb from the oil in the dead-weight gage. The pressure, as determined by the dead-weight gage, is checked against the vapor pressure of water given in the steam tables. The gas under investigation is then admitted to the bomb by opening one side of valve *C*. The pressure is allowed to build up to slightly over the desired partial pressure at which the solubility of the gas is to be determined. Valve *C* is then closed and the system is allowed to come to equilibrium. This is done by keeping the autoclave in motion overnight at the desired temperature. The temperature is then readjusted, if necessary, and the pressure of the gas is readjusted to its desired partial pressure. When the temperature and pressure have remained constant for about 2 hours, a sample is taken. This is done by circulating ice water through the condenser, *K*, and then opening the purging line side of valve *B*. After about 25 ml. of water have been taken off, the purging line valve

TABLE II. SOLUBILITY OF HYDROGEN IN WATER

H ₂ Partial Pressure, Lb./Sq. In. Abs.	Source	Ce. H ₂ /G. of Water					Average	Probable Error	Maximum Deviation	
		75° F.								
300	(1)	0.32	
367	(2)	0.44	
125° F.										
200	Authors	0.38	0.32	0.32	0.31	0.37	0.30	0.33	0.01	+0.05 to -0.03
300	Authors	0.41	0.42	0.40	0.41	0.41	0.00	+0.01 to -0.01
350	Authors	0.47	0.44	0.44	0.44	0.46	..	0.45	0.01	+0.02 to -0.01
300° F.										
100	(2)	0.13
200	(2)	0.28
300	(2)	0.40
375	(2)	0.52
500	(2)	0.70
345° F.										
100	(2)	0.15
200	(2)	0.30
300	(2)	0.43
375	(2)	0.56
500	(2)	0.75
390° F.										
100	(2)	0.18
200	(2)	0.34
300	(2)	0.52
375	(2)	0.68
435° F.										
100	(2)	0.22
200	(2)	0.49
300	(2)	0.75
375	(2)	0.94
500	(2)	1.26
500° F.										
100	Authors	0.45	0.38	0.31	0.32	0.39	0.02	+0.06 to -0.08
200	Authors	0.98	0.91	0.84	0.92	0.91	0.10	+0.07 to -0.09
300	Authors	1.23	1.23	1.28	1.25	0.01	+0.03 to -0.02
600° F.										
100	Authors	0.68	0.61	0.68	0.62	0.65	0.01	+0.03 to -0.04
200	Authors	1.24	1.31	1.34	1.41	1.32	0.02	+0.09 to -0.08
300	Authors	2.05	2.06	1.98	1.94	2.01	0.02	+0.05 to -0.03
650° F.										
100	Authors	1.40
115	Authors	1.63
120	Authors	1.68
125	Authors	1.74

* At standard temperature and pressure.




Figure 10. Solubility Constant versus Temperature near the Critical Point

and nitrogen are listed in Tables I, II, III, and IV, and are also shown graphically in Figures 1 to 9. The probable error shown in column 5 of the tables was calculated from the usual formula

$$\text{probable error} = 0.6745 \sqrt{\frac{\sum \Delta^2}{n(n-1)}}$$

TABLE IV. SOLUBILITY OF NITROGEN IN WATER

N ₂ Partial Pressure, Lb./Sq. In. Abs.	Source	Co. N ₂ /G. of Water				Average	Probable Error	Maximum Deviation
		77° F.						
294	(1)	0.28
367	(5)	0.35
588	(1)	0.55
122° F.								
367	(5)	0.27
167° F.								
367	(5)	0.25
212° F.								
367	(5)	0.26
500° F.								
150	Authors	0.47	0.43	0.41	..	0.44	0.01	+0.03 to -0.11
400	Authors	1.21	1.34	1.18	..	1.24	0.02	+0.10 to -0.58
600° F.								
150	Authors	0.56	0.54	0.56	..	0.55	0.00	+0.01 to -0.01
300	Authors	1.56
400	Authors	2.40	2.29	2.26	..	2.32	0.02	+0.08 to -0.34

* At standard temperature and pressure.

TABLE V. HENRY'S LAW CONSTANT, K, FOR VARIOUS GASES*

Temp., ° F.	Gas, K X 10 ⁻³			
	Oxygen	Hydrogen	Helium	Nitrogen
32	20.40	..
75	..	11.0
77	6.56	..	21.75	13.20
122	16.60
125	..	8.72
167	18.10	18.60
212	18.00
300	..	9.30
325	8.00	..	8.04	..
345	..	8.34
390	..	6.98
400	6.56
435	..	4.98
500	2.77	2.90	3.56	4.18
600	1.74	1.86	2.20	2.38
650	1.22	0.885

* $K = \frac{PA}{NA}$, where PA = partial pressure of gas, A, in pounds per square inch and NA = mole fraction of gas, A, in solution.

TABLE III. SOLUBILITY OF HELIUM IN WATER

He Partial Pressure, Lb./Sq. In. Abs.	Source	Co. He ² /G. of Water				Average	Probable Error	Maximum Deviation
		32° F.						
367	(4)	0.23
77° F.								
367	(4)	0.22
167° F.								
367	(4)	0.24
323° F.								
100	Authors	0.20	0.20	0.19	..	0.20	0.00	+0.00 to -0.01
200	Authors	0.31	0.31	0.30	..	0.31	0.00	+0.00 to -0.01
300	Authors	0.39	0.37	0.37	..	0.38	0.00	+0.01 to -0.01
500° F.								
100	Authors	0.42	0.38	0.42	0.38	0.40	0.01	+0.02 to -0.02
200	Authors	0.58	0.60	0.64	0.59
300	Authors	1.36	0.43	0.62	0.81	0.57	0.01	+0.01 to -0.03
400	Authors	1.15	1.07	0.87	1.03	1.03	0.05	+0.37 to -0.37
500	Authors	1.31	1.41	1.32	1.47	1.38	0.03	+0.09 to -0.07
500	Authors	1.74	1.64	1.86	1.70	1.85	1.76	+0.10 to -0.12
600° F.								
200	Authors	0.92	0.95	0.89	0.93	..	0.92	+0.03 to -0.04
300	Authors	1.64	1.61	1.70	1.66	..	1.66	+0.04 to -0.05
400	Authors	2.44	2.37	2.59	2.31
500	Authors	2.84	2.37
500	Authors	2.72	3.12	3.07	3.23	2.82	2.99	+0.35 to -0.18
500	Authors	+0.23 to -0.27

* At standard temperature and pressure.

which gives an indication of the precision of the data, where $\sum \Delta$ = the arithmetical sum of the deviations and n = the number of measurements.

It is interesting to observe from the tables and graphs that the solubilities of these gases in water increase with increasing temperature, in the high temperature range, whereas it has been established that at temperatures in the region from about 20° to 200° F. the solubilities decrease with increasing temperature.

Within experimental accuracy, the solubilities of hydrogen, oxygen, helium, and nitrogen appear to be linear functions of pressure over the range investigated. The resulting straight lines (Figures 2, 4, 6, and 8) show that the solubilities in question follow Henry's law and may be predicted within the limits of engineering accuracy over a fairly wide range of temperatures and pressures from the Henry's law constants, which are listed in Table V.

At and al
cases must
must become
cases in the
Figure 10.
stants tend
has indicat
cases are mi

Self

SELEC
meta
error basis
correlated
vary availa
ture, type
terfacial t
may be us
all possibl
studied, s
combinati
which need
developme
lated with
amount of
number of
for every
stratum i
The tim
the suitab
pounds in
substrata
that the s
can be ad
termining
process;
the vario
concentr
with refe
taining es
for neces
combinat
Once t
reactors
will indic
tants, as
builder d
tation o
numeric
ple adva
tion is a
factors are
solution
cific det

At and above the critical temperature of water (705° F.), the gases must be infinitely soluble and the Henry's law constant must come relatively very small. The constants for the four gases in the region of the critical temperature are plotted in Figure 10. It is apparent that in this region the solubility constants tend to converge and approach very low values at 705° F., thus indicating that the data are consistent with the fact that the gases are miscible in all proportions at the critical point for water.

LITERATURE CITED

- (1) Frolich *et al.*, *IND. ENG. CHEM.*, 23, 548 (1931).
- (2) Ipatieff and Teodorovich, *J. Gen. Chem. (U.S.S.R.)*, 4, No. 3, 395 (1931).
- (3) Wiebe and Gaddy, *J. Am. Chem. Soc.*, 55, 947 (1933).
- (4) *Ibid.*, 56, 76 (1934).
- (5) *Ibid.*, 57, 847 (1935).

RECEIVED for review July 14, 1950.

ACCEPTED December 31, 1951.

This work was carried out under contract with the Atomic Energy Commission, Contract 7405-eng-92.

Selection of Surface Active Agents for Detergent Applications

SUSPENDING POWER AND MICELLAR SOLUBILIZATION

A. M. MANKOWICH

Paint & Chemical Laboratory, Aberdeen Proving Ground, Aberdeen, Md.

SELECTION of surface active agents (surfactants) for specific metal cleaning applications is usually made on a trial and error basis, using laboratory detergency tests which have been correlated with field test results. Experience plus the fragmentary available information on such properties as molecular structure, type and chemical stability of surfactant, surface and interfacial tensions, and Draves and Clarkson sinking times (2) may be used as empirical screening media. It is imperative that all possible combinations of compatible types of surfactants be studied, since it is not possible at present to predict synergistic combinations. Builder action varies with type of agent and soil, which necessitates investigation of additional combinations. The development of a laboratory detergency test that can be correlated with field results is a problem. An obviously considerable amount of research must be performed even when only a limited number of surfactants are tested. This process has to be repeated for every detergent application in which the soil and/or substratum is varied.

The time-consuming, trial and error approach in determining the suitability of various surfactants for use in cleaning compounds intended for the removal of specific soils from specific substrata is viewed unfavorably in this laboratory. It is believed that the selection of surfactants for specific detergent applications can be accomplished more scientifically and economically by determining the fundamental or prime factors in the detergency process; studying each factor to establish numerical criteria for the various types of surfactants and builders under varying pH, concentration, and temperature conditions; and classifying soils with reference to the numerical values of the prime factors, obtaining cofactors (minimum numerical criteria for each prime factor necessary to accomplish soil removal in specific soil-surface combinations).

Once the prime factors for various types of surfactants and the cofactors for the soils are determined, an inspection of the data will indicate appropriate surfactants or combinations of surfactants, as well as suitable temperature, pH, concentration, and builder data. This is done by selecting the surfactant, or combination of surfactants, whose prime factors have equal or greater numerical ratings than the corresponding cofactors. The principle advanced is that detergency in a specific soil-surface application is accomplished only if the numerical ratings of all the cofactors are equaled or exceeded by the prime factors of the cleaning solution. The need for utilizing more than one surfactant for a specific detergency application will be readily apparent in those

cases where an otherwise satisfactory agent is deficient in one or more prime factors. When it is necessary to select two or more surfactants, the maximum numerical rating for each prime factor of the combination is estimated by adding the respective ratings of the individual surfactants involved. Preliminary work indicates that the numerical rating of a prime factor approaches a definite maximum which is not exceeded, regardless of the number of surfactants combined for a specific detergent application. This maximum is usually the highest value attained by any of the individual surfactants investigated. However, additiveness of numerical rating of a combination of surfactants is obtained until the maximum for the prime factors is reached. It is intended to cover the determination of cofactors and classification of soils and substrata in a later paper.

An advantage of the proposed method of selection is that it will indicate a number of surfactants or combinations of surfactants for each soil-surface application, thus permitting a final selection on an economic basis. No attempt is made to evaluate the relative importance of the various prime factors, and the method does not depend on such evaluation. The proposed method is not to be confused with the speculations (21) that detergency will eventually be calculated from a formula containing weighted physicochemical factors. Assuming that these speculations are realized eventually, they will not aid in the selection of surfactants for specific detergent applications. The formula will only give an index of detergency. The proposed method indicates the minimum physicochemical requirements for a detergent application, together with a number of surfactants or combinations of surfactants capable of meeting the requirements. It is important to realize that the proposed method indicates synergistic combinations of surfactants.

PHYSICO-CHEMICAL FACTORS OF DETERGENCY

Present-day knowledge indicates that detergency is the resultant of many factors (1, 12, 20, 22). It is understandable, therefore, that attempts to correlate detergency with one factor only have been unsuccessful. Reich and Snell (18) emphasize a further error made in attempting to evaluate detergency with one factor. Detergency is dependent on three groups of variables (12): those originating in the soil, in the surfactant, and in the surface. A factor involving only one of the groups, such as surface tension, or two of the groups, such as micellar solubilization, is basically not in correlation with detergency.

MAY 2 1979

MEMORANDUM TO: Mr. Tom Crimmins
Three Mile Island
General Public Utilities
Trailer 11
Middletown, Pa. 17057

MAY 8 1979
1500

FROM: J. Edward Vivian
Professor of Chemical Engineering
Massachusetts Institute of Technology
Cambridge, Mass. 02139

SUBJECT: Hydrogen Degassing

DATE: April 17, 1979

In response to a telephone call from Donald Rockwell on April 7 asking me to consider the operating conditions which would expedite the degassing of hydrogen from the Primary System loop during cool-down this memorandum is submitted to you and confirms my comments to Mr. Rockwell by telephone on April 8.

This analysis is based on the description given to me of the Primary System loop and its interaction with the Pressurizer and the Let-down System. The simplified schematic shown in Figure 1 was assumed. It was also assumed that the high recirculation rate in the Primary System gave the equivalent of a well stirred reactor and that the overall system was in pseudo-steady state for the two cases analyzed, i.e. hydrogen generation rate equalled venting rate. No data on the geometry of the system were available by which to allow input-output rates and accumulation or depletion to be included in the analysis. However, the pseudo-steady state assumption serves to indicate the effect of system parameters on the hydrogen venting rate.

Solubility data for the hydrogen-water system for the high temperature region are given by Pray, Schweickert and Minnich (Ind. Eng. Chem. 44, 1146 (1952)). A copy of this reference is attached. Low temperature solubility data given by Lange: Handbook of Chemistry were also used to prepare the smoothed data on Henry's law constant given in Figure 2. Solubilities are expressed in milliliters of hydrogen at standard conditions per gram of water and pressures in lb/sq. in. absolute. The Henry's law constant varies widely with temperature but appears to be independent of pressure at a given temperature.

The two pseudo-steady state cases analyzed are based on data provided by telephone concerning the pressure at which nucleation in the core began to occur. The nucleation pressure is taken to be the same as the saturation pressure for the mixture of hydrogen and water. Case I is based on a nucleation pressure of 950 lb/sq. in. and core outlet temperatures of 300°F to 350°F. Case II is based on a nucleation pressure of 535 lb/sq. in. and core outlet temperature of 300°F. These data permit estimates of the hydrogen concentration in the Primary System. For Case I the concentration was

calculated to be in the range of 1.15 to 1.22 ml/g H₂O (or an average of about 1.2 ml/g H₂O) and for Case II 0.61 ml/g H₂O. (Appendix A)

Because of the increase of hydrogen solubility with temperature above 200°F the effect of temperature on nucleation pressure is complex: at high hydrogen concentration increase in temperature lowers the nucleation pressure while at low concentration increase in temperature raises the nucleation pressure (Table I). Alternatively at high temperature and pressure the effect of change in solubility with temperature appears to reduce the effect of increase in vapor pressure of water.

An analysis of the Pressurizer venting system to remove hydrogen from the Primary System, within the assumptions indicated, is given in Appendix B. The calculations are summarized in Tables II and III to show the effect of venting rate and temperature (or pressure) in the Pressurizer. Since no information was available concerning the actual venting rate (either continuous or intermittent), the venting rate of steam with the hydrogen has been expressed as a fraction of the water supplied in the spray. The spray rate was assumed constant, and the indicated temperatures were assumed to be maintained by heat input to the Pressurizer. The relative hydrogen venting rate is given by the fraction of the constant spray water rate which is vented multiplied by the mols hydrogen per mole water in the vapor phase.

The calculations show that for both Case I and Case II at a given water vapor venting rate an increase in temperature (and pressure) reduces the hydrogen venting rate, although the effect is not large except at low venting rates. Thus unless other factors such as the effect of total pressure on the let-down rate indicate otherwise, the lowest feasible pressure to prevent nucleation in the Primary System appears to give the highest hydrogen purge rate through the Pressurizer vent for the assumed conditions.

The effect of temperature on vapor formation in the Let-down System is shown in Table IV for the reactor conditions assumed in Case II. Data on the geometry of the system were not available so that pressure drop considerations could not be included in the calculations. However, if it is assumed that the maximum mass discharge will occur with minimum vaporization in the system, the calculations indicate the advantage of cooling the let-down liquid before reducing the pressure significantly, even though the solubility of hydrogen decreases with decrease in temperature in the range above 200°F. These calculations are summarized in Table IV.

The Let-down System was assumed to discharge into a vented vessel at approximately atmospheric pressure (15 lb/sq. in. abs). The volume of vapor phase, v , generated in the system as the pressure is reduced at selected temperatures, (assuming essentially adiabatic conditions) has been expressed as ml vapor per gram water. These values may be interpreted to indicate approximately the volume of vapor flowing per volume of liquid at various locations in the Let-down System.

The calculations indicate that the residual hydrogen concentration in the liquid discharge decreases with increasing system temperature. However, the volume of vapor to be handled by the vapor venting system increases significantly with increase in temperature. At a Let-down system temperature of about 200°F there appears to be a reasonable balance between vent steam generation and hydrogen removal for Case II conditions.

Since my telephone conversation with Mr. Rockwell on April 8 Appendix C has been prepared to give a brief comparison of the relative venting rates of hydrogen by the Pressurizer vent system and by the Let-down System for conditions existing in Case II and an assumed Pressurizer vent rate ($B = 0.01$) and assumed spray and let-down rates. The venting rates appear to be the same order of magnitude for the conditions assumed.

J. Edward Moran





FIG. 1

FIG. 2



APPENDIX A

Estimation of hydrogen concentration in Primary System

Operating conditions (Case I)

Core outlet temperature: 300°F to 350°F
Minimum pressure without nucleation: 950 lb/sq. in. abs.

At 300°F

Steam partial pressure: 67.0 lb/sq. in. abs.
Hydrogen partial pressure: 950 - 67 = 883 lb/sq. in. abs.
Henry's law constant: $H_H = 765$
Hydrogen concentration: $C = 883/765 = 1.15 \text{ ml/g H}_2\text{O}$

At 350°F

Steam partial pressure: 135.5 lb/sq. in. abs.
Hydrogen partial pressure: 950 - 135.5 = 814.5 lb/sq. in. abs.
Henry's law constant: $H_H = 665$
Hydrogen concentration: $C = 814.5/665 = 1.22 \text{ ml/g H}_2\text{O}$

Case I average hydrogen concentration: $C \sim 1.2 \text{ ml/g H}_2\text{O}$

Operating conditions (Case II)

Core outlet temperature: 300°F
Minimum pressure without nucleation: 535 lb/sq. in. abs.

At 300°F

Steam partial pressure: 67.0 lb/sq. in. abs.
Hydrogen partial pressure: 535 - 67 = 468 lb/sq. in. abs.
Henry's law constant: $H_H = 765$
Case II hydrogen concentration: $C = 468/765 = 0.61 \text{ ml/g H}_2\text{O}$

TABLE I

Effect of core temperature on nucleation pressure

(P = lb/sq. on. abs. and C = ml/g H₂O at STP)

T°F	H _H	P _W	P(at C=1.2)	P(at C=0.61)	P(at C=0.3)
280	800	49	1009	537	289
300	765	67	985	534	297
350	665	135	933	540	335

APPENDIX B

Hydrogen removal in Pressurizer vent

Assumptions:

- (1) The liquid and vapor in the Pressurizer are in equilibrium (including the spray liquid after contact with the vapor).
- (2) A fraction, B, of the inlet spray water is vented continuously as steam with the hydrogen.
- (3) Steady-state conditions.
- (4) Only hydrogen and water are present in the Pressurizer.

Let C_0 = concentration of hydrogen outlet liquid, ml/g H_2O

P = total pressure in vapor space, lb/sq. in. abs.

p_H = partial pressure hydrogen, lb/sq. in. abs.

p_W = steam partial pressure, lb/sq. in. abs.

H_H = Henry's law constant, (lb/sq. in.)/(ml/g H_2O)

y = vent composition, mol fraction hydrogen

$$\text{Then } P = p_W + p_H$$

$$p_H = H_H C_0$$

$$\text{and } y = p_H/P$$

Vent composition, expressed as ml H_2 /g H_2O at NTP

$$\begin{aligned} &= \frac{(p_H) (22,400)}{(p_W) (18)} \\ &= \frac{(H_H C_0)(1244)}{P_W} \end{aligned}$$

Hydrogen balance around Pressurizer

(Basis: 1.0 g spray water)

APPENDIX B (cont'd)

$$C_s = (1244)B H_H C_0/p_W + (1.0 - B)C_0$$

where C_s = concentration of hydrogen in spray, assumed to be the same as in the Primary System.

B = water vented with hydrogen, expressed as a fraction of the spray water.

Solving for C_0 gives:

$$\frac{C_0}{C_s} = \frac{1.0}{[(1244) B H_H/p_W + (1 - B)]}$$

Calculations to show the effect of Pressurizer temperature and venting rate on hydrogen removal are summarized in Tables II and III.

The relative rates of hydrogen venting, given by the product of B and $y/(1 - y)$, are expressed in Tables I and II as $[B y/(1 - y)](10^3)$

TABLE II

Effect of Pressurizer Vent Rate and Temperature

Case I ($C_s = 1.2 \text{ ml/g } H_2O$)

B	T	$\frac{C_0}{C_s}$	C_0	P_H	P	y	Relative H_2 Vent Rate
0.1	520	0.030	0.036	8	*820	0.010	1.01
	540	0.041	0.050	9	972	0.009	0.91
	550	0.049	0.059	10	1055	0.009	0.91
0.01	520	0.237	0.285	60	*872	0.068	0.73
	540	0.301	0.360	65	1027	0.063	0.65
	550	0.339	0.407	67	1112	0.060	0.64
0.001	520	0.757	0.908	191	1003	0.218	0.28
	540	0.812	0.974	175	1138	0.154	0.18
	550	0.837	1.004	165	1210	0.136	0.16
0	550	1.00	1.2	198	1243	0.159	0

* Below core nucleation pressure for assumed core temperature.

TABLE III

Effect of Pressurizer Vent Rate and Temperature

Case II ($C_s = 0.61 \text{ ml/g H}_2\text{O}$)

B	T	$\frac{C_o}{C_s}$	C_o	P_H	P	y	Relative H ₂ Vent Rate
0.1	460	0.010	0.0062	2	*469	0.0048	0.48
	480	0.015	0.0091	3	569	0.0048	0.48
	500	0.021	0.013	3	684	0.0047	0.47
	550	0.049	0.030	5	1050	0.0047	0.47
0.01	460	0.093	0.057	21	*488	0.043	0.45
	480	0.132	0.080	24	590	0.041	0.43
	500	0.180	0.110	27	708	0.039	0.41
	550	0.339	0.207	34	1079	0.032	0.33
0.001	460	0.507	0.309	113	580	0.194	0.24
	480	0.602	0.367	111	677	0.163	0.19
	500	0.687	0.419	105	786	0.133	0.15
	550	0.837	0.511	84	1130	0.074	0.08
0	500	1.00	0.61	153	834	0.183	0
	550	1.00	0.61	101	1146	0.088	0

* Below core nucleation pressure for assumed core temperature.

TABLE IV

Vapor Generation during Let-down

Let-down temperature: 300°F

P lb/sq. in. abs.	>535	500	300	100	15
* v ml/g H ₂ O	0	0.0026	0.030	0.390	~186
* c ml/g H ₂ O	0.61	0.560	0.305	0.043	4.8 x 10 ⁻⁶

Let-down temperature: 200°F

P lb/sq. in. abs.	>570	500	300	100	15
v ml/g H ₂ O	0	0.0032	0.020	0.114	3.41
c ml/g H ₂ O	0.610	0.530	0.315	0.097	0.0038

Let-down temperature: 140°F

P lb/sq. in. abs.	>564	500	300	100	15
v ml/g H ₂ O	0	0.0025	0.0157	0.0933	0.891
c ml/g H ₂ O	0.610	0.540	0.323	0.105	0.013

v = actual volume of vapor, ml/g H₂O

c = dissolved hydrogen concentration, ml at STP per g water.

APPENDIX C

Comparison of vent rates (Case II)

Pressurizer vent rate

Spray rate (assumed) = 20 gpm (or 167 lb/min.)

Steam vent rate = B (167)

Assume B = 0.01

At 550°F: y = 0.032 (TABLE III)

$$\frac{\text{lb H}_2}{\text{lb steam}} = \frac{0.032(2)}{0.968(18)} = 0.00367 \text{ lb H}_2/\text{lb steam}$$

$$\begin{aligned} \text{H}_2 \text{ vent rate} &= (0.01)(167)(0.00367)(60) \\ &= 0.37 \text{ lb H}_2/\text{hr.} \end{aligned}$$

Let-down vent rate

Flow rate (assumed) = 20 gpm (or 167 lb/min.)

$$\begin{aligned} \text{Inlet H}_2 \text{ conc.} &= 0.61 \text{ ml/g H}_2\text{O} \\ &= \frac{(0.61)(2)}{22400} \frac{\text{lb H}_2}{\text{lb water}} \end{aligned}$$

$$= 0.0000545 \text{ lb H}_2/\text{lb water}$$

H₂ removal = 99% at 200°F (TABLE IV)

$$\begin{aligned} \text{H}_2 \text{ vent rate} &= (167)(0.99)(0.0000545)(60) \\ &= 0.54 \text{ lb/min.} \end{aligned}$$

6/7/72 - 3.058

7 1979
1400

TASK CLOSE OUT DOCUMENT

Task Scope 7/1/72 to 10/1/72
...
...

cc: RFW
R Long
J D. D. d
DRMG
ADA. Asst. GPU
File

To: M. Levenson
S. Levy
E. Zbroshk

Task No. 1.1 Date Complete 10/1/72

Reason felt task is complete:

Work has been completed as per RFP requirements.
...
...
...
...
...

Members of Committee

1.1/1.1
R. Christensen
...
...
...
...

3000

TASK 14 BORON AND GAS CONCENTRATIONS IN PRIMARY SYSTEMS

Problem:

Identify important factors in determining the boron and gas concentrations in the primary system in current mode of operation. (i.e. natural circ on "A", "B" stratified.)

Boron Concentration:

- 1) Make-up line enters primary system on discharge side of RCP 1B. Flow splits with part going into "B" steam generator and part going into Reactor Vessel.
- 2) Boron could be concentrating at Bottom of "B" steam generator if Tcold B is less than the make-up temperature.
- 3) Boron in pressurizer is concentrating because of low (or zero) flow out of pressurizer into coolant lines and because of steaming in pressurizer.
- 4) Let-down line comes off of suction side of RCP 1A. As long as there is natural circulation in "A" loop, boron concentrations measured from the let-down flow is representative of boron concentrations in core. However, if natural circulation on "A" loop is lost, it will be very difficult to interpret the results of boron concentration measurements. Depending on the mode of cooling, the measurements could be completely unreliable. In that case BWR operation would be the preferred alternative method of operation.

Gas Concentration:

- 1) Gas in make-up system should be reduced by degassing make-up water.
- 2) If local boiling occurs in the core, gas can be released. The gas content measured in the let-down line sample will be subject to the same uncertainties as the boron concentration.

REC'D 5/16/79
1943

copy
FILE

9 May 1979

To: R. A. Ambrosino
From: P. W. Harriott
Subject: THOUGHTS ON REDUCING PRESSURE TO ONE ATMOSPHERE AT TH1-2

For your request, here are some further thoughts on reducing pressure to one atmosphere (earlier thoughts were sent to Rockwell on April 10).

Desirable Features of Cooling Mode

(1) Remove decay heat in any of four ways:

- natural circulation to OTSG
- RHR operation
- pot boiling to containment via pressurizer
- reflux boiling to OTSG

(2) Minimize chance of core mechanical disruption

Another feature thought previously to be desirable for its own sake is avoidance of local boiling. It will be shown that local boiling may be a minor concern.

Removal of Decay Heat. Natural circulation may not persist indefinitely at one atmosphere without degassing because, assuming some local boiling in the core, a noncondensable bubble may form at the top of the hot leg candy-cane.* It is possible that noncondensibles stripped out by local boiling would go back into solution, depending on the extent of local boiling. The uncertainty could be avoided by installing a system which would degas primary coolant from one atmosphere (vacuum degasser). Given this, natural circulation will remove heat from the core indefinitely as long as the steam generator is cooled. So if the coolant can be kept degassed, there is no need to depart from natural circulation even at atmospheric pressure.

RHR operation will probably give dependable core flow. How such core flow is uncertain, because due to the higher-than-normal core resistance there will be more backflow in the steam generators than in normal RHR operation. We suggest that RHR operation be calculated, now that the core resistance can be inferred, before it is attempted.

* It is noted that degassing will also be needed while pressure is being reduced due to the lower solubility of noncondensibles at lower pressure.

For boiling and reflux boiling are modes of last resort. Either mode seems feasible, but both are subject to considerable uncertainty, and calculations are needed. Reflux boiling should work at one atmosphere even with some non-condensibles present, but some depressing is necessary and stability is of concern. With pot boiling and steaming out the pressurizer, noncondensibles should not matter. However, in pot boiling it may not be possible to obtain one atmosphere for some time due to the small size of the pressurizer relief valves and whether it will work at all without uncovering the core due to the loop seal in the pressurizer when line has yet to be evaluated.

Avoidance of Mechanical Disruption of Core. The uncertain condition of the core makes it desirable to avoid pressure or flow surges or other mechanical movement. Natural circulation is best. Risk is not greatly different from natural circulation except for the startup transient. The NRC startup transient could be accomplished gently by slowly opening the injection valve; in any event, it is hard to see why it would be more severe than when primary coolant pump 2A was started on April 6, which (apparently) had no ill effects. Reflux boiling is quite uncertain at least until calculations are done, because it is possibly very susceptible to flow and pressure surges. Pot boiling, though probably gentle mechanically, is yet to be evaluated for its feasibility.

Local boiling in the core may cause some potential for rearrangement of core fragments due to bubble formation. This is the best reason to avoid local boiling, but it is now well to consider how important it is.

Avoidance of Local Boiling. The criterion for subcooling (ref. IAS memo 41A-21, 4/21/74) has been for T_{hot} (bulk) to be at least 100° subcooled. At the current core ΔT of 10F, this would require the cold leg temperature to be $212 - 100 - 10 = 2$ F, which sounds attainable given the new water/water secondary side heat exchange equipment. But core exit TC #89 has consistently been about 135F over T_{hot} since natural circulation was attained on April 27, and this difference ($T_{89} - T_{hot}$) does not seem to be decreasing like the other "hot spots." The ($T_{TC} - T_{hot}$) values in the others, for reasons unknown, have been falling fairly consistently, approximately as the square root of core power. At this rate, it would take several months for the next hottest TC (#18) to reach 100F subcooling at one atmosphere. Thus at one atmosphere some local boiling appears to be inevitable, even if only in a few locations.

The effect of local boiling on heat transfer would probably not be of concern. This is certainly true for intact rods, and can be examined using scoping arguments for loose pellets. On July 1, when core power is down to 1.0 MW, the average power per fuel pellet will be about 0.1 watt. Assuming the pellets are still intact (or even fragmented into fairly large fragments) it is hard to imagine a geometry in which 0.1 watt per pellet could not be dissipated as long as the core region is entirely full of water (0.1 watt is about 0.003 D/sec.

which means that if pellet cooling were entirely by vaporization, about 10^{-7} lb/sec of water, certainly a miniscule amount, would have to find its way to the vicinity of each pellet). The vapor formation per pellet would be equivalent to about 10 bubbles of 0.1 inch diameter per second even if all the cooling were due to vaporization, which it would not be except perhaps in extremely obstructed regions. To check the significance of this semi-quantitatively, it would take about 1000 of such bubbles clinging to a pellet to lift it in water. The surface area of a pellet is such that less than 100 such bubbles could form from lower pellets. The pellets could also be disturbed by rising bubbles from lower pellets. However, a typical bubble rise velocity in stagnant water is about 1 ft/sec. Average flow velocity of subcooled liquid with one circulation pump running (a condition the core is known to be able to withstand) is about 4 ft/sec; and it would require at least 4 ft/sec to suspend a pellet in flowing subcooled water. Thus the chance of disruption due to rising bubbles seems small. These arguments (which, though numerically stated, are really only qualitative) suggest that local boiling does not pose much of a problem as far as core mechanical disruption is concerned.

In summary, the one real concern due to local boiling is exaggerated formation of non-dissolved gases, which could threaten natural circulation or reflux boiling if degassing of primary coolant is not possible.

These thoughts suggest that operation at one atmosphere after July 1 would not be undesirable. There is, of course, no clear cutoff date; similar arguments could be made for operating at one atmosphere now, particularly with K&R in service. The biggest advantage in waiting a month or so is to see what the core exit thermocouples do in that time. And as suggested in my April 10 memo, the core exit TC's could be monitored carefully during the depressurization for evidence of sudden increases, which would suggest the incidence of local boiling.

I hope these thoughts are useful in assisting in a decision on the end-point pressure and the timing of depressurization.

W. M. Merritt

P. W. Merritt, Chairman
Three Mile Island Task Force
M/C 124 Ext. 20246

/s/

cc: DC DiMarco
CC Dix
LE Nesbitt
N. Siegler
FF Strickland
DR Wilkins/ED Judge

10 UICK ...
 CC O TMI-2

11/11/73

MAY 9 1973
 39na

Notes from Telecon with P.W. Marshall on two phase flow volume swell for boiling at TMI-2

Assume: 2.7 Mwt/h, Nat. circ.
 150°F cold leg temp

The following is a monometer balance problem results summary with boiling in the hot leg.

	Cold leg level (50 in. SG)	
Hot leg level	19.7 psia	19.7 psia
Top of active fuel	19.6'	23'
Ev charge line level	23.0'	29.0'
Steam inside of condy cond	31.0'	45'

α RFW
 RUK
 JAD
 RL
 Damb
 GAO on site Tech-Sup.
 Stouff/ric

Notes by
 DJP

GC O TMI-2

Notes from Telecom with PW Material
on two phase flow volume small
for boiling at TMI-2

Assume: 2.9 Mwth, Nat. circ.
150°F cold leg temp

The following is a manometer balance
problem results summary with
boiling in the hot leg

Hot leg level	Cold leg level (12.5 SG)	
	19.9 psia	17.9 psia
Top of active fuel	19.6'	23'
IV surge line level	23.0'	29.0'
ten inches of candy cane	31.0'	00'

notes by
DA Bullen

6/7/2-J.e-60

PICKARD, LOWE AND GARRICK, INC.
1200 13TH STREET, N. W., SUITE 612
WASHINGTON, D. C. 20036

JAMES K. PICKARD
WILLIAM W. LOWE
B. JOHN GARRICK

THOMAS R. ROBBINS
JOHN M. VALLANCE
KEITH WOODARD
THOMAS E. POTTER
MARK ABRAMS
MICHAEL H. SCHWARTZ
WILLIAM DICKTER
PETER P. BIENIARZ
CARROLL L. CATE
ROLAND J. DURNILY
DOUGLAS C. IDEN
RICHARD V. CALABRESE
SHAHID AHMED

WASHINGTON, D. C.
TELEPHONE 202 396-8633

IRVINE, CALIFORNIA
TELEPHONE 714 752-2596

May 8, 1979

Mr. John Potman
Three Mile Island
Box 480
Middletown, Pennsylvania - 17057

Dear Mr. Potman:

I found that I have the original of the attached
copy of bubble calculations. I thought a copy should
probably be in your collection.

Very truly yours,

William W. Lowe

:jam

HOW TO FIND REFLECTOR VOLUME AVAILABLE

3/20/79 2:45 PM
WR.

(1)

$$P_1 V_1 = P_2 V_2$$

A

3A'd numbers

373"

326"

875 PSIG

951 PSIG

$$\left. \begin{aligned} P_1 &= 860 \text{ PSIG} + 15 = 875 \text{ psia} \\ P_2 &= 955 \text{ PSIG} + 15 = 970 \text{ psia} \\ V_1 - V_2 &= (373'' - 325'') 3.2 \text{ ft}^3/\text{in} \\ V_1 &= (373 - 325) 3.2 + V_2 = 153.6 \text{ ft}^3 + V_2 \end{aligned} \right\} \begin{array}{l} \text{At 12:45 P} \\ 3/29/79 \\ 30 \end{array}$$

$$P_1 [(373 - 325) 3.2 + V_2] = P_2 V_2$$

$$V_2 = \frac{860}{955} [(373 - 325) 3.2]$$

$$(875)(153.6 + V_2) = 970 V_2$$

$$134400 + 875 V_2 = 970 V_2$$

$$134400 = 95 V_2$$

$$V_2 = \frac{1414.7}{95} \text{ ft}^3 \text{ at } P_2 = 970 \text{ PSIG } (280^\circ \text{F})$$

Pressure Volume @ 7' Dia

$$A = \pi r^2 = \frac{3.14 (7')^2}{4} = \frac{153.86 \text{ ft}^2}{4} = 38.465 \text{ ft}^2$$

$$\frac{38.465 \text{ ft}^2}{12 \times 4 \text{ ft}} = 3.2 \text{ ft}^3/\text{in}$$

Makeup Tank changed 30 gal/inch 52-38

$$\frac{30 \text{ gal}}{\text{inch}} \times (52 - 38) = \frac{420 \text{ gallons}}{7.48 \text{ gal/ft}^3} = 56 \text{ ft}^3$$

$$V_2 = \frac{1414.7}{95} + 56 = \frac{1471}{95} \text{ ft}^3$$

(1500 kg) of H₂ in normal circuit.

* Refined correction made ~ 4/1/79 10PM

Joe: W.

By 10 reports Reactor Vessel Volume Above (2)
Nozzle: Free Volumes (Don Nitty & Jim Taylor)


Upper head = 560 ft³ 650
ft³

R.V. Upper Memm 411.

R.V. Outlet 158

1129 ft³ free Vol.

Procedure for Reducing gas bubble in Reactor Vessel head,



$$\frac{970 \text{ PSI}}{15156} \times 1446 \text{ ft}^3 = 93,508 \text{ ft}^3 \text{ STP of } \text{H}_2$$

$$93,508 \text{ ft}^3 \text{ H}_2 \text{ STP} \times \frac{1 \text{ mole}}{454 \text{ ft}^3} \times \frac{1 \text{ lb}}{356} = 203 \text{ lb Moles}$$

$$203 \text{ lb Moles of Zr.} \times \frac{119 \text{ lb Zr}}{1 \text{ lb Mole}} = 24,157 = 12 \text{ tons}$$

$$\frac{224 \text{ l}}{\text{gm mole}} \times \frac{454 \text{ gm}}{1 \text{ lb}} \times \frac{.035 \text{ ft}^3}{\text{lb}} = 356 \text{ ft}^3 / \text{lb mole}$$

$$\text{Diam} = 20 \text{ mils} = .020'' = 2 \times 10^{-3} \text{ ft, thick}$$

$$= 10^{-1} \text{ ft, uricle}$$

$$= 12'' \text{ ft. long}$$

$$= 2 \times 10^{-3} \text{ ft}^3 / \text{rod,}$$

$$\frac{200 \text{ lb}}{\text{ft}^3 \text{ Zr}} \times 2 \times 10^{-3} \frac{\text{ft}^3}{\text{rod}} \times .4 \text{ lb/rod.}$$

$$\frac{24,000 \text{ lb}}{.4} = 60,000 \text{ rods } \} \text{ Note H}_2 \text{ explosion}$$

Answers $117 \times \frac{208}{1.17} = 36,816 \text{ rods}$

Bubble has to be H₂. Vent out per using Springs. Use let down
max extent. up over 1000 ft as 11.5.

Second try

$$P_1 = 1065 \text{ psig} = 1080$$

$$P_2 = 1081 = 1096$$

3:30 AM
WZ
= +16 lbs

3

$$V_1 = 356.2$$

$$V_2 = 352.3$$

$$(356.2 - 352.3) 3.2 \frac{\text{ft}^3}{\text{in}} = 12.48 \text{ ft}^3 = V_1 - V_2 \quad V_1 = 12.48 + V_2$$

$$1065 V_1 = 1081 V_2$$

$$V_1 = \frac{1081 V_2}{1065} = 1.0150234 V_2 \quad V_1 = 12.48 + V_2$$

$$1065 \times 1.0150234 = V_2$$

$$1065(12.48 + V_2) = 1081 V_2$$

$$13291 + 1065 V_2 = 1081 V_2$$

$$13291 = 16 V_2$$

$$V_2 = 830.69$$

$$V_2 = 830.69 \times \frac{1081}{875} = 1026 \text{ ft}^3 \text{ at } 1081 \text{ psig}$$

$$P_1 V_1 = P_2 V_2$$

$$V_1 - V_2 = \Delta V$$

$$V_2 = V_1 - \Delta V$$

$$P_1 V_1 = P_2 (V_1 - \Delta V)$$

$$V_1 = \frac{P_2 \Delta V}{P_1 - P_2}$$

$$V_2 = \frac{P_1 \Delta V}{P_2 - P_1}$$

$$\Delta V = \frac{(P_2 - P_1) V_2}{P_1}$$

$$\Delta V = \frac{1096 \times 352.3 - 352.3}{1080} = 5.2$$

Date May 14, 1979



Subject TDR-TMI-104: PRIMARY SYSTEM GAS ANALYSES

To T. G. Broughton

Location Hartz Building

Enclosed is a collection of reports, memos, correspondence, etc. regarding the TMI-2 primary system gas analyses. This collection was assembled by Bob Ryan, a Combustion Engineering staff member temporarily assigned to the GPU Technical Planning Group. In addition to this material, J. Moore's 3-ring "Bubble Notebook" is on file in the TMI-2 Data Reduction and Management Center. Jerry Weiser is making a copy of the notebook which will be delivered to Parsippany in the next day or two.

The collection of material is probably not complete, but I hope it will serve as a basis for starting on TDR-TMI-104.

A handwritten signature in cursive script that reads 'R. L. Long'.

R. L. Long
Manager - Generation Productivity

RLl:g
Enclosure
cc: w/o encl.
R. W. Keaten
R. F. Wilson

6/7/72-3.e-62

Jim

RTW wants us
to use TOR format
where possible, i.e.
1. Purpose & Summary
2. References
etc per EC-001.

OUTLINE
TOR-TMI-104

PRIMARY SYSTEM GAS ANALYSIS

Outline in preparation by J. Moore.

Suggestions as to content and approach to presentation are welcomed.

RLC

Jim Moore,

I have a copy of Bill Lewis's original H_2 calculations
on the way. Will get you a copy of your draft (corrected).
RLC

Bubble analysis

Should exclude Containment bldg
gas analyses - but should probably
contain cross reference to
TOR-TMI-107 (G. Capodanno).

From RTW { include all early work on
gas substitution
depressing info.
etc
contain gas analyses

NOTE: TOR-TMI-103 will have brief discussion of
primary system gas analyses w/ cross reference to -104.

Effort should be made between J. Moore and G. Bond
to be certain that information in each TOR is
consistent.

RLC

6/5/72

FROM M&ED
5/15/77 SUBMITTAL
TO NRC

3.5 HYDROGEN EVALUATION

METAL-WATER REACTION WITH THE FUEL CLADDING GENERATED LARGE QUANTITIES OF HYDROGEN DURING THE INITIAL PHASES OF THE TMI-2 INCIDENT ON MARCH 28, 1979. THIS HYDROGEN FORMED A BUBBLE WHICH BECAME TRAPPED IN THE HEAD OF THE REACTOR VESSEL. THE LARGE QUANTITY OF HYDROGEN IN THE BUBBLE PRODUCED A HIGH PARTIAL PRESSURE WHICH CAUSED THE REACTOR COOLANT TO BECOME SATURATED WITH HYDROGEN. AFTER THE BULK OF THE BUBBLE WAS REMOVED ON APRIL 1, THE COOLANT REMAINED SATURATED WITH 1300 TO 1400 STD. CC OF HYDROGEN PER KILOGRAM OF COOLANT. EXTENSIVE DEGASSING OF THE REACTOR COOLANT DURING THE TIME PERIOD FROM APRIL 2 THROUGH APRIL 12 HAS SIGNIFICANTLY REDUCED THE CONCENTRATION OF DISSOLVED HYDROGEN. THE ANALYSIS OF A PRESSURIZED SAMPLE OF REACTOR COOLANT TAKEN ON APRIL 25, 1979 SHOWED THE FOLLOWING DISSOLVED GAS CONTENT:

HYDROGEN	41.6	STD. CC/Kg
NITROGEN	4.6	STD. CC/Kg
<hr/>		
TOTAL	46.2	STD. CC/Kg

A SMALL PORTION OF THE ORIGINAL GAS BUBBLE BECAME TRAPPED IN THE CONTROL ROD DRIVE MECHANISMS (CRDMs) AND HAS NOT READILY DISSOLVED INTO THE REACTOR COOLANT. DURING THE PERIOD FROM APRIL 1 THROUGH APRIL 12, MUCH OF THE TRAPPED HYDROGEN WAS REMOVED FROM THE CRDMs BY CYCLING THE REACTOR COOLANT SYSTEM PRESSURE TO PROGRESSIVELY LOWER PRESSURES, REACHING A MINIMUM PRESSURE OF 300 PSIG. THESE PRESSURE REDUCTIONS EXPANDED THE GAS TRAPPED IN THE CONTROL ROD DRIVES AND ALLOWED THE GAS TO BE ENTRAINED IN THE RC FLOW. THE AC NOISE SIGNALS ON THE

REACTOR COOLANT PRESSURE TRANSMITTERS CONFIRMED THAT BUBBLES WERE INDEED RELEASED EACH TIME THE PRESSURE REACHED A NEW LOW. THEREFORE, IT IS CLEAR THAT, AT PRESSURES ABOVE 300 PSIG, THE GAS WILL BE COMPRESSED BACK INTO THE CRDMs.

THE 46.2 CC OF GAS PER KILOGRAM OF REACTOR COOLANT CAN EXERT A MAXIMUM PARTIAL PRESSURE OF 74 PSI REGARDLESS OF THE COOLANT TEMPERATURE OR THE RELATIVE AMOUNTS OF HYDROGEN AND NITROGEN IN THE GAS MIXTURE. THEREFORE, ANY PRESSURE GREATER THAN 74 PSI ABOVE THE VAPOR PRESSURE OF WATER WILL KEEP ALL THE GAS IN SOLUTION. IF ALL THE GAS IN THE CRDM WERE TO DISSOLVE INTO THE COOLANT, IT WOULD INCREASE THE PARTIAL PRESSURE OF GAS BY A MAXIMUM OF 138 PSI. IF IT WERE TO BE ASSUMED THAT HALF OF THE FUEL RODS STILL CONTAINED THEIR PRE-PRESSURIZATION GAS AND STABLE FISSION GASES, FAILURE OF THESE FUEL RODS COULD INCREASE THE PARTIAL PRESSURE OF THE GAS BY 88 PSI. FIGURE 3.5-1 SHOWS A PLOT OF THE COMBINATION OF THESE THREE PRESSURES WHICH ACCOUNT FOR ALL THE GAS KNOWN TO BE IN THE REACTOR COOLANT SYSTEM. FIGURE 3.5-1 ALSO SHOWS THE AMOUNT OF MARGIN NEED TO ACCOMMODATE MAKEUP REQUIREMENTS AND RADIOLYTIC GAS GENERATION FOR ONE WEEK. THE MAKEUP RATE WAS ASSUMED TO AVERAGE 1 GPM AND WAS ASSUMED TO BE SATURATED WITH AIR AND TREATED WITH 20 PPM HYDRAZINE TO REMOVE THE OXYGEN. EVEN THOUGH NO NET RADIOLYTIC GAS PRODUCTION IS EXPECTED IF THE COOLANT IS DEOXYGENATED AND 5 TO 15 STD. CC OF H_2 REMAIN DISSOLVED IN THE WATER (REF. 1). FIGURE 3.5-1 ALLOWS MARGIN FOR A WEEKS BUILDUP OF RADIOLYTIC GAS PRODUCTION, USING A G-VALUE OF 0.025 HYDROGEN ATOMS PER 100 EV OF

6
ABSORBED IRRADIATION. AN ADDITIONAL MARGIN INCLUDED IN THE MINIMUM PRESSURE CURVES SHOWN IN FIGURE 3.5-1 IS THAT THE AMOUNT OF GAS REMOVED FROM THE SYSTEM WITH COOLANT LETDOWN AND LEAKAGE WAS NEGLECTED AND AT HIGH DISSOLVED GAS CONCENTRATIONS AMOUNT TO A SIGNIFICANT REMOVAL RATE.


PERIODIC ANALYSIS OF REACTOR COOLANT SAMPLES WILL PROVIDE A DIRECT MEASURE OF THE GAS CONTENT OF THE COOLANT AND WILL PROVIDE THE BASIS FOR REDUCING SOME OF THE CONSERVATISM. IN FIGURE 15.3-1 THIS PERMITTING FURTHER PRESSURE REDUCTIONS.

REFERENCES:

1. WATER COOLANT TECHNOLOGY OF POWER REACTORS, BY PAUL COHEN, GORDON AND BREACH SCIENCE PUBLISHERS OF NEW YORK, 1969.
- 5

REQUIRED TO KEEP GASES FROM FORMING BUBBLES

REACTOR COOLANT SYSTEM PRESSURE, PSIG



REACTOR COOLANT HOT LEG TEMPERATURE, °F

NOTES:
 1. GAS REMOVAL VIA 1" TYPICAL TUBING HAS BEEN ASSUMED
 2. AMOUNT OF DISSOLVED GAS SHOULD BE REMOVED WEEKLY FOR FIRST 3-4 WEEKS OF PLANT OPERATION

1/2" x 5/8" TO 1 1/4" INCH 46 00003
 MADE IN U.S.A.
 REUTEMAL & FISCHER CO.

CONFIDENTIAL

STANDARD NO.:

FP-001

ORIG. ISSUE DATE: 8/1/78

PAGE 1 OF 11

TITLE

PREPARATION OF TECHNICAL DATA REPORTS

REVISION	DATE	DESCRIPTION	APPROVAL
1	12/7/78	Basic reformat, clarification of format and how distribution is handled.	<i>Rw</i>
2	3/27/79	Added requirement for interfacing section review.	<i>Rw 3/27/79</i>

PREPARATION

RW Katen 12/7/78
DATE

AUTHORIZATION

Ja. Daniel 12/13/78
DATE

APPROVAL

[Signature] 12/13/78
DATE

<p>41110-01-001</p>	REV. NO. 2	ENG. PROCEDURE NO: EP-001
TITLE Preparation of Technical Data Reports	DATE OF REV. 3/27/79	PAGE 2 OF 11

CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
I	PURPOSE & SCOPE	3
II	APPLICABILITY	3
III	REFERENCES	3
IV	DEFINITIONS	3
V	PREPARATION	4
VI	RESPONSIBILITIES	7
VII	REVISIONS	7
VIII	APPENDICES	
	A TDR COVER PAGE	9
	B REVISION PAGE	10
	C PROCEDURAL FLOW DIAGRAM	11

<p>Engineering</p>	REV. NO. 2	ENG. PROCEDURE NO. EP-001
TITLE Preparation of Technical Data Reports	DATE OF REV. 3/27/79	PAGE 3 OF 11

I PURPOSE AND SCOPE

- A. This procedure establishes the methods for preparation and control of Technical Data Reports (TDR's).

TDR's consolidate and record results and conclusions generated in technical studies (e.g., trade studies, plant performance evaluations, plant transient analyses, material selection studies, nuclear fuel cycle options, economic evaluations, safety studies, evaluations of operating plants, and failure analyses, etc.) and summarize their impact on overall plant design, operating plant recommendations or input to baseline documents (e.g., plant criteria, SDD, tech specifications).

II APPLICABILITY

This procedure applies to activities performed by all departments within the Technical Functions Group, Generation Division.

III REFERENCES

- EP-006 "Preparation, Documentation & Control of Calculations"
 EP-016 "Records Retention and Control"

IV DEFINITIONS

Refer to "Glossary of Engineering Terms"

	REV. NO. 2	ENG. PROCEDURE NO. EP-001
TITLE Preparation of Technical Data Reports	DATE OF REV. 3/27/79	PAGE 4 OF 11

V PREPARATION of TDR's

A. Requirements

Each TDR shall:

1. Comprise a written document, prepared in accordance with the format as discussed in B below.
2. Be assigned a unique document number from Engineering Standards.
3. Be distributed by the Responsible Engineer and the master filed by the Engineering Standards Manager.

B. Format

1. Page 1

The first page of every TDR shall be the cover sheet shown in Appendix A. If additional pages are required, the numbering shall be 1a, 1b, 1c, etc.

The cover sheet shall be typed and include the following technical information in the abstract:

- a. Brief statement of problem
- b. Summary or Key Results
- c. Conclusion
- d. Recommendations

The Responsible Engineer(s) who prepared the TDR shall sign and date the document in the space provided on the cover sheet.


2. Revision Page

The page following the abstract shall be as shown in Appendix B. A brief description of each revision including page numbers shall be given and approval of the revision shall be signified by the initials of the Responsible Engineer and the Responsible Engineer's Manager. The revision pages shall be numbered page 1, 1i, etc.

3. Table of Contents

The next page of each TDR shall be a Table of Contents. A suggested format is as follows:

1. Purpose & Summary
2. References

	IS V. NO. 2	ENG. PROCEDURE NO: EP-001
TITLE Preparation of Technical Data Reports	DATE OF REV. 3/27/79	PAGE 5 OF 11

3. Methods
4. Evaluation
5. Results
6. Conclusions
7. Recommendations
8. Appendices

The format may be modified as necessary to suit the particular subject being addressed. However, the above format should be used whenever possible.

4. Subsequent Pages

All pages shall be sequentially numbered, starting with 2.

a. Discussion of Major Headings

(1) Purpose & Summary

This section clearly states the purpose of the TDR and a summary of what the report covers and how the material is used within the Report. Initials and acronyms to be used in the text such as HWR (Heavy Water Reactor) shall be identified the first time it occurs in the text.

(2) References

References such as Documents, Specifications, Drawings, Codes, Standards, Calculations, Texts, Reports, Computer Data and Equations shall be clearly noted to identify the source of the particular statement or formula. The reference shall be identified as to number, title, edition, date, volume, page or figure number, publisher, and revision number as appropriate.

Each reference in the list shall be consecutively numbered. The text of the Report shall indicate by reference No. the reference document for a particular operation or set of data. Where extensive referencing of pages in one document is required, page numbers shall be part of the text reference and shall not be shown in the Reference Listing.

(3) Methods

The Methods section shall clearly indicate the sequence of steps that have been used such that a competent Engineer can trace the analysis process without recourse to the originator.

(4) Evaluation

All significant sections of the material or referenced material should be highlighted.

(5) Results

All calculations and computer printouts upon which the results were based should be referenced. Extensive calculations shall not be reported in a TDR (see EP-006) but rather referencing to such documents using their results and conclusions to substantiate the point of the TDR. Graphs, tables, charts, etc. should be used and included to support the results, conclusions and/or recommendations generated by the TDR.

(6) Conclusions

State the conclusions reached based on the results.

(7) Recommendations

State any recommendations made based on the conclusions.

(8) Appendices

Appendices should be attached which serve to make the meaning of the report explicitly clear.

C. Directions to Prepare a TDR
(Refer to Procedural Flow Diagram Appendix C)

RESPONSIBLE ENGINEER The Responsible Engineer prepares the draft according to the format described in this procedure, obtains a TDR number from the Engineering Standards Manager, and forwards the TDR to his Manager and affected Section Managers for support or review.

ORIGINATING SECTION MANAGER The Responsible Engineer's Manager reviews the draft to insure that the TDR is technically sound and meets the requirements of this procedure. He may, at his discretion, request review by others.

RESPONSIBLE ENGINEER The Responsible Engineer resolves comments and obtains the concurrence signature of his Section Manager.

<p>4/1/79</p>	REV. NO. 2	ENG. PROCEDURE NO: EP-001
TITLE Preparation of Technical Data Reports	DATE OF REV. 3/27/79	PAGE 7 OF 11

RE SECTION MANAGER Reviews final TDR to insure that all comments were resolved and proper distribution is evident. The TDR is signed indicating approval for internal GPUSC distribution and forwarded to Engineering Standards Manager.

DIRECTOR OF TECHNICAL FUNCTIONS The Director of Technical Functions authorizes distribution outside of CPU by his approval signature in the appropriate block on the cover page.

VI RESPONSIBILITIES

- A. Director of Technical Functions
 - ° Authorizes Distribution Outside of GPUSC
- B. Responsible Engineer's Manager
 - ° Assigns Responsible Engineer
 - ° Reviews and Approves TDR
 - ° Establishes Distribution
- C. Responsible Engineer
 - ° Prepares TDR
 - ° Obtains TDR Number
 - ° Signs TDR as Responsible Engineer
 - ° Arranges for Typing
 - ° Obtains Approval from Section Manager.
- D. Engineering Standards Manager
 - ° Issues TDR Numbers
 - ° Files Originals

VII REVISIONS


1. The first issue of the approved TDR shall be identified as Revision 0. Subsequent revisions shall be identified in ascending numerical sequence.
2. Revisions shall be reviewed and approved by the Manager(s) that approved the original document.
3. A brief summary of the revision and the approval signatures of the originator(s) and manager(s) shall be documented as shown in Appendix B and placed immediately behind the abstract. Additional revisions can be documented on the same page or subsequent pages.

41141-2-100	REV. NO. 2	ENG. PROCEDURE NO: EP-001
TITLE Preparation of Technical Data Reports	DATE OF REV. 3/21/79	PAGE 8 OF 11

4. Minor changes to analyses shall be made as revisions on the original sheets. Revisions shall be identified by drawing a vertical line in the right hand margin next to the entire length of the revision. The revision shall be identified by placing the revision number immediately under the vertical line.

5. Revisions which cannot be completed on existing sheets shall be continued on additional sheets. Added sheets will be placed immediately after the revised page carrying the same page number with a suffix letter added. Example: page 10 supplemented by page 10a.

PROCEDURAL FLOW DIAGRAM
APPENDIX C



DATA USED TO GENERATE TRI-2 RC GAS BUBBLE


```

*****
*   TIME * BUFSIZE * LOCATION **   TIME * BUFSIZE * LOCATION *
*****
* 68.96 * 1839 * 0 ** 127 * 203 *
* 78 * 118.3 * ** 127.2 * 564 *
* 78.24 * 829 * ** 127.9 * 152 *
* 79 * 89.2 * ** 128.16 * 535 *
* 79.2 * 893 * ** 128.7 * 47 *
* 84.48 * 308 * ** 129.36 * 501 *
* 86.4 * 839 * ** 130.56 * 627 *
* 88.32 * 366 * ** 132 * 486 *
* 89.52 * 225 * ** 132.96 * 343 *
* 90.96 * 1806 * ** 133.5 * 208 *
* 91 * 82 * ** 134.5 * 194 *
* 96.3 * 999 * ** 134.64 * 224 *
* 96.9 * 717 * ** 135.12 * 347 *
* 97.3 * 894 * ** 136.25 * 175 *
* 98 * 848 * ** 136.56 * 224 *
* 101.4 * 333 * ** 137 * 48 *
* 101.9 * 606 * ** 137.04 * 635 *
* 102.24 * 250 * ** 137.52 * 223 *
* 103.3 * 710 * ** 139.2 * 438 *
* 104.75 * 564 * ** 142.56 * 199 *
* 106 * 535 * ** 143.5 * 221 *
* 106.32 * 980 * ** 144.24 * 215 *
* 107.3 * 501 * ** 145.2 * 543 *
* 109.44 * 800 * ** 146.16 * 211 *
* 110.3 * 486 * ** 147.12 * 205 *
* 112.08 * 621 * ** 148.08 * 254 *
* 113.28 * 742 * ** 149.04 * 130 *
* 113.7 * 224 * ** 149.52 * 203 *
* 115.2 * 901 * ** 150.42 * 118 *
* 115.7 * 223 * ** 150.48 * 152 *
* 116.4 * 765 * ** 151 * 89 *
* 117 * 438 * ** 151.44 * 47 *
* 117.36 * 999 * ** 152.4 * 60 *
* 118.56 * 294 * ** 156 * 208 *
* 119.52 * 717 * ** 156.24 * 195 *
* 120 * 191 * ** 157.2 * 174 *
* 120.9 * 855 * ** 160.08 * 48 *
* 120.96 * 848 * ** 161 * 82 *
* 121.92 * 818 * ** 162 * 143 *
* 122 * 198 * ** 164.16 * 222 *
* 123.12 * 800 * ** 172.56 * 118 *
* 124.25 * 205 * ** 181.44 * 163 *
* 124.32 * 833 * ** 183.36 * 0 *
* 124.56 * 606 * ** 184.08 * 82 *
* 125.1 * 130 * ** 202.7 * 0 *
* 126.24 * 710 * **
*****

```

6/112-3.e-63

6/7/12-3.0-64



TOM

... of our ...

2. ... (1970), we told ...

... to ...

... of ...

... and ...

... it to ...

... (before) ...

... for vessel ...

... to the vessel and the ...

... (i.e., it would not ...).

... the action items I agreed to on 4/4/72.

L. E. Schreiber

Regarding questions asked by GPO

... the amount of gas in solution at 1000 psi, T = 320°F (saturated ...)

$\frac{11.5 \text{ gms}}{1000 \text{ psi}}$	$\frac{11.5 \text{ gms}}{1000 \text{ psi}}$	$\frac{11.5 \text{ gms}}{1000 \text{ psi}}$
---------------------------------------------	---------------------------------------------	---------------------------------------------

... the time to drop from 1000 psi (sat) to 500 psi (sat) with T = 320°F

$\frac{11.5 \text{ gms}}{1000 \text{ psi}}$	$\frac{11.5 \text{ gms}}{500 \text{ psi}}$	$\frac{11.5 \text{ gms}}{500 \text{ psi}}$
---------------------------------------------	--------------------------------------------	--------------------------------------------

... that comes out of solution at 500 psi (sat)

$\frac{11.5 \text{ gms}}{1000 \text{ psi}}$	$\frac{11.5 \text{ gms}}{500 \text{ psi}}$	$\frac{11.5 \text{ gms}}{500 \text{ psi}}$
---------------------------------------------	--------------------------------------------	--------------------------------------------