



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

AUG 6 1979

NOTE TO: William Parler
FROM: Richard Hartfield
SUBJECT: REQUEST FOR NPRDS FAILURE DATA ON B&W PLANTS

Attached is a printout of all the failure data from B&W Plants that has been reported to the Nuclear Plant Reliability Data System (NPRDS). I have made some summary calculations and comments to help you in your review.

1. The headings are pretty much self-explanatory. The middle date is the failure event start (including time of day). The component and system codes are basically the same we use in the LER system. The sequence number is just an accounting control number. The description is generally three short paragraphs; failure description, cause of failure, and finally, corrective action.
2. Engineering data on the components is available, but I did not think it worthwhile to obtain at this time.
3. The fourth line just to the right and below event dates, in recent years, indicates who else was informed of this failure. Z means nobody and H indicates an LER was submitted to the NRC.
4. It seems to me that many of the "failures" reported are pretty routine maintenance items, like leaking packing, etc. This is not too surprising since the utility maintenance group is often responsible for NPRDS, rather than the Operations Group.
5. The facility codes are:
 - APLANO 1 - Arkansas 1
 - DPCNEE - Oconee
 - FPCCRP - Crystal River
 - MECTMI 1 - TMI 1
 - SMURSS 1 - Rancho Seco
6. There are no reports for Davis-Besse or TMI-2.
7. B&W failures account for about 5% of the total 5000 failures in the NPRDS data while they have about 10% of the plants.


8002100022

P

AUG 6 1979

8. A review of the plant by plant, year by year summaries show wide variations which indicate to me that the data cannot be trusted as more than a very qualitative thing. A review of LER caused by component failure for these same time periods indicates a minimum of reporting to NPRDS.

If anything, NPRDS should have more failures than LER because failure reporting should be broader in NPRDS.

A handwritten signature in dark ink, appearing to read "R.A. Hartfield". The signature is written in a cursive style with a long, sweeping tail that extends to the right.

Richard Hartfield

PLANT	YEAR	NPRDS FAILURE REPORTS	LER COMPONENT FAILURE
Arkansas 1	1974	1	
	1975	2	5
	1976	26	13
	1977	2	13
	1978	-	13
Crystal River	1977	35	59
	1978	32	35
Oconee 1	1973	12	
	1974	16	
	1975	16	7
	1976	5	11
	1977	26	21
	1978	8	12
Oconee 2	1974	8	
	1975	17	17
	1976	16	9
	1977	29	11
	1978	13	7
Oconee 3	1974	5	
	1975	18	10
	1976	24	10
	1977	19	7
	1978	9	15
TMI 1	1974	7	
	1975	5	23
	1976	0	19
	1977	1	5
	1978	0	7

Rancho Seco	1975	3	7
	1976	3	12
	1977	6	8
	1978	5	6

Davis-Besse	1977	-	38
	1978	-	52

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
APLANO1	741228 7412281230 741230	VALVEX CBD	RBV-77B 751 0090	PINHOLE LEAK ON VALVE WELD AREA INSTALLATION/CONSTRUCTION DEFECT WELD WAS GROUND OUT AND REWELDED
APLANO1	750329 7503292000 750331	VALVOP CBD	CV1009 752 0009	VALVE TORQUES OUT WHEN TRYIN& TO 0& 3 E.D. MOTOR AND TORQUE SWITCH REPLACED PARTS AND RE-ADJUSTED LIMITS
APLANO1	751203 7512032000 751223 Z	VALVOP WAB	CV3807 784C0041	POSITION INDICATOR INCORRECT LIMIT SWITCH SETTING DRIFT ADJUST SWITCH AND TIGHTEN CLUTCH ASSEMBLY
APLANO1	760115 7601151200 760318 Z	VALVEX SAB	CV-4803 784C0031	VENT HEADER ISOLATION VALVE WOULD NOT OPEN VALVE STEM TO SHORT, TOP 1.5 THREADS ARE STRIPPED. VALVE WILL OPEN WITH ASSISTANCE. NEW VALVE STEM ON ORDER

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
APLAND1	760223 7602231200 760318	MOTORX WAB	PM-4C 784C0016	SERVICE WATER PUMP EXCESSIVE MOTOR VIBRATION, INCREASING MOTOR TEMPERATURE WORN BEARING CAUSED BY DIRT AND DUST CLEANED WINDINGS, REPLACED LOWER BEARING, RE-ASSEMBLED, MEGGERED.
	Z			
APLAND1	760303 7603030800 760414	MOTORX WAB	PM-4C 784C0017	EXCESSIVE SERVICE WATER PUMP MOTOR VIBRATION. MOTOR DID NOT COMPLETELY FAIL. APPROXIMATELY 15 MILS LATERAL PLAY IN BEARING AT LOWER END BELL REPLACED LOWER BEARING
	Z			
APLAND1	760429 7604291400 760525	VALVEX SAB	CV-6203 784C0032	VALVE DID NOT PASS RX BLDG PENETRATION LOCAL LEAK RATE TEST. NORMAL WEAR LAPPED IN SEATS AND DISK, REPLACED BONNET GASKET.
	Z			
APLAND1	760512 7605121000 760526	BLOWER SCB	VSF1D 784C0007	ES SIGNAL DID NOT BLOCK HAND SWITCH OPERATION OF REACTOR BUILDING COOLING FAN. DEFECTIVE HANDSWITCH. REPLACED HANDSWITCH.
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
APLAN01	760613 7606130830 761130	INSTRU SFE	LT-2419 784C0011	CORE FLOOD LEVEL INDICATION GIVES FALSE READINGS
	Z			BAD VENT VALVES AND BELLOWS
				REPLACE VENT VALVES AND BELLOWS IN LEVEL TRANSMITTER
APLAN01	760716 7607160632 760924 760803	DLOWER SCB	VSF-30A 784C0005	HYDROGEN PURGE INLET FAN TRIPPED DURING H2 PURGE LEAD SYSTEM TEST
	H			THERMAL OVERLOAD SET TOO LOW IN ABNORMALLY HOT ENVIRONMENT.
				THERMAL OVERLOAD SETTING WAS INCREASED AND VENTILATION DAMPERS WERE ADJUSTED TO DECREASE ROOM TEMPERATURE.
APLAN01	760717 7607170250 760809	VALVOP SAB	CV-4400 784C0035	RB SUMP TO AUXILIARY SUMP DRAIN ESAS VALVE POSITION INDICATION INCORRECT.
	Z			NORMAL WEAR, SET POINT DRIFT
				ADJUSTED LIMIT SWITCHES
APLAN01	760807 7608070050 760924	PUMPXX CBD	P32B 784C0020	REACTOR COOLANT PUMP SEAL NOT STAGING CORRECTLY.
	Z			SEAL FAILURE DUE TO DEBRIS
				REMOVED AND REPLACED WITH REBUILT SEAL ASSEMBLY.

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
APLAN01	760807 7608070050 760924	PUMPXX CBD	P32C 784C0022	REACTOR COOLANT PUMP SEAL NOT STAGING PROPERLY.
	Z			UNKNOWN
				REMOVED SEAL AND REPLACED WITH REBUILT ASSEMBLY.
APLAN01	760808 7608080800 760902	VALVEX HBA	PSV-2695 784C0034	MAIN STEAM HEADER RELIEF VALVE LEAKING BY.
	Z			BROKEN LOWER RING RETAINING PIN.
				REPLACED BROKEN RETAINING PIN, LAPPED SEATING SURFACES, CHECKED SPINDLE STRAIGHT NESS AND REASSEMBLED.
APLAN01	760810 7608100800 760924 760823	SUPORT CBF	HS-10 784C0025	HYDRAULIC SHOCK SUPPRESSOR FLUID RESERVOIR LEVEL FOUND LOW. PZR RELIEF LINE
	H			LEAKING SEALS AND O-RINGS.
				REPLACED SEALS AND O-RINGS, TIGHTENED FITTINGS.
APLAN01	760810 7608100800 760924 760823	SUPORT CBF	HS-12 784C0026	HYDRAULIC SHOCK SUPPRESSOR FLUID RESERVOIR LEVEL FOUND LOW. PZR RELIEF LINE
	H			LEAKING SEALS AND O-RINGS
				REPLACED SEALS AND O-RINGS, TIGHTENED FITTINGS.

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
APLANO1	760810 7608100800 760924 760823 H	SUPPORT HBA	HS-3 784C0029	HYDRAULIC SHOCK SUPPRESSOR FLUID RESERVOIR FOUND LOW. MAIN STEAM HEADER LEAKING SEALS AND O-RINGS. TIGHTENED FITTINGS, REPLACED SEALS AND O-RINGS
APLANO1	760811 7608110800 760917 Z	SUPPORT CBF	HS-13 784C0027	PIPE HANGER BRACKET LOOSE MISSING BOLT PUT IN NEW BOLT TO HOLD BRACKET.
APLANO1	760811 7608110800 760917 Z	SUPPORT HHA	HS-34 784C0030	PIPE HANGER RESERVOIR BRACKET LOOSE MISSING BOLT. PUT IN NEW BOLT ON BRACKET.
APLANO1	760816 7608162308 760915 Z	VALVOP CBD	CV1008 784C0039	PZR SPRAY VALVE POSITION INDICATION NOT CORRECT. SET POINT DRIFT READJUSTED LIMITS.

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
APLAND1	760903 7609032250 770415	PUMPXX CBD	P32A 784C0019	REACTOR COOLANT PUMP SEAL WAS NOT STAGING PROPERLY AND SEAL CAVITY PRESSURES WERE OSCILLATING ABNORMALLY UNKNOWN REMOVED DAMAGED SEAL CARTRIDGE FROM PUMP AND REPLACED WITH REBUILT SEAL CARTRIDGE
	Z			
APLAND1	760903 7609031659 770415	PUMPXX CBD	P32B 784C0021	REACTOR COOLANT PUMP SEAL WAS NOT STAGING PROPERLY AND CHARTS INDICATED THAT THE LOWER SEAL HAD COMPLETELY FAILED PUTTING FULL PRESSURE ON THE ONE REMAINING SEAL UNKNOWN REMOVED DAMAGED SEAL CARTRIDGE FROM PUMP AND REPLACED WITH REBUILT SEAL CARTRIDGE
	Z			
APLAND1	760907 7609070800 760924	MOTORX CBD	PM32D 784C0018	RC PUMP MOTOR LUBE OIL LEAK. LOOSE FITTINGS. TIGHTENED FITTINGS.
	Z			
APLAND1	760910 7609040730 760924	VALVOP CBD	CV1055 784C0040	REACTOR COOLANT QUENCH TANK VENT HEADER VALVE OVERCURRENT TRIP CONTACTS NOT MAKING UP PROPERLY. CLEANED CONTACTS,REPLACED SPRINGS IN CONTACTOR,TIGHTENED ALL LOOSE WIRES, CHECKED FOR VALVE BINDING, CHECK VALVE OPERATION.
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
APLANS1	760926 7609262230 761021	INSTRU PCB	PDT-1238 784C0012	RCS MAKE-UP FLOW TRANSMITTER VENT LEAKING. LEAKING VENT VALVE. REPLACED VENT VALVE
	Z			
APLANS1	761021 7610211150 761027 761029	VALVOP SAB	CV-6202 784C0036	CHILLED WATER E.S. ISOLATION VALVE WOULD NOT REMAIN SHUT ON E.S. SIGNAL, BUT WOULD ON LOSS OF AIR. RUPTURED FILTER ON DISCHARGE OF INSTRUMENT AIR DRYER. AIR LINES FULL OF DESICCANT. SOLENOIDS, TRANSFER RELAY, AND AIR LINES BLOWN FREE OF DESICCANT.
	H			
APLANS1	761103 7611030655 770228	INSTRU CBD	TE1015 784C0014	FALSE READINGS WERE OBSERVED ABNORMAL SERVICE CONDITION CHANGED OUT TEMPERATURE ELEMENT AND BRIDGES AND CALIBRATED
	Z			
APLANS1	761103 7611030655 770228	INSTRU CBD	TE1039 784C0015	FALSE READINGS WERE OBSERVED ABNORMAL SERVICE CONDITION REPLACED RTD AND BRIDGES AND CHECKED CALIBRATION OF BRIDGES
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
APLAN01	761221 761221 1000 770131	CKTBRK HHB	52-5332 784C0008	BOTH INDICATING LIGHTS FOR OPEN AND CLOSE POSITION FOR VALVE CV-2670 ARE ON
	Z			WIRE SHORTED TOGETHER AT VALVE CAUSING COIL AT BREAKER TO BURN OUT
				REPAIRED SHORTED WIRES AND REPLACED COIL
APLAN01	770218 770218 1100 770315	VALVOP SAB	CV-6202 784C0037	THE VALVE WOULD NOT REMAIN CLOSED WHEN ACTUATED
	H			DIRTY SOLENOID VALVE
				THE SOLENOID BLOCK VALVES WERE REPLACED AND THE AIR SUPPLY LINES WERE CLEANED
APLAN01	770809 770809 0150 770930	INSTRU IBC	ESAS-5 784C0010	THE ON TEST ALARM IS IN WITH THE SWITCH IN OPERATE AT CABINET IN CONTROL ROOM PIECEPART - BAILEY TRIP LOGIC PT NO 6624010A1 BAD RELAY
	Z			REPLACED LOGIC TEST MODULE CHANNEL 5 WITH ONE FROM SPARE STOCK AND REPAIRED DEFECTIV E MODULE AND PLACED IN SPARE PARTS
DPCNEE1	731005 731005 0105 770114	VALVEX HHB	1FDW-99 764 7426	VALVE LEAKING AROUND SEAT
	Z			BAD GASKET
				REPLACED GASKET

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	731006 7310062300 731009	CRDRVE RBB	1CRD-G-7 734 0029	CONTROL ROD DRIVE STATOR SHORTED PHASE TO PHASE REPLACED STATOR
DPCNEE1	731006 7310062300 770114 Z	VALVEX CBD	1RC-4 764 7432	VALVE WILL NOT OPEN STRIPPED THREADS ON VALVE STEM REPLACED TORQUE LIMIT SWITCH AND MOTOR AND REBUILT THREADS
DPCNEE1	731007 7310070930 731007	VALVOP CBE	1RC-1 734 0036	RC-4 PRESSURIZER POWER RELIEF BLOCK MOTOR BURNED UP UNKNOWN REPLACED MOTOR
DPCNEE1	731007 7310070930 770114 Z	VALVOP CBD	1RC-4 764 7450	MOTOR BURNED OUT UNKNOWN REPLACED MOTOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	731120 7311201500 731125	CRDRVE RBB	1CRD-F-10 734 0030	CONTROL ROD DRIVE STATOR SHORTED PHASE TO PHASE REPLACED STATOR
DPCNEE1	731121 7311210238 731125	CRDRVE RBB	1CRD-M-9 734 0031	CONTROL ROD DRIVE STATOR SHORTED PHASE TO PHASE REPLACED STATOR
DPCNEE1	731125 7311251158 731213	CRDRVE RBB	1CRD-E-11 734 0032	CONTROL ROD DRIVE STATOR SHORTED PHASE TO PHASE REPLACED STATOR
DPCNEE1	731211 7312112000 731213	CRDRVE RBB	1CRD-M-13 734 0033	CONTROL ROD DRIVE STATOR SHORTED PHASE TO PHASE REPLACED STATOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	731212 7312122030 731213	CRDRVE RBB	1CRD-E-3 734 0034	CONTROL ROD DRIVE STATOR SHORTED PHASE TO PHASE
				REPLACED STATOR
DPCNEE1	731213 7312130605 731224	CRDRVE RBB	1CRD-C-11 734 0035	CONTROL ROD DRIVE STATOR SHORTED PHASE TO PHASE
				REPLACED STATOR
DPCNEE1	731227 7312270730 731227	VALVOP SFD	1HP-20 734 0037	VALVE WILL NOT CLOSE
				FAULTY TORQUE SWITCH REPLACED TORQUE SWITCH
DPCNEE1	740211 7402111525 740214	CRDRVE RBB	1CRD-E-13 741 0015	CONTROL ROD DRIVE STATOR SHORTED-PHASE TO PHASE
				REPLACED STATOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	740211 7402111337 740214	CRDRVE RBB	1CRD-P-6 741 0014	CONTROL ROD DRIVE STATOR SHORTED-PHASE TO PHASE REPLACED STATOR
DPCNEE1	740401 7404010830 740517	VALVEX HHA	1FDW-41 752 0233	VALVE LEAKS AROUND SEAT UNKNOWN REPLACED GASKETS
DPCNEE1	740423 7404230930 770114 Z	VALVEX CBD	1RC-4 764 7433	VALVE OPERATED SPURIOUSLY VALVE OFF SEAT REPAIRED VALVE
DPCNEE1	740522 7405221200 770114 Z	PUMPXX HHB	EFW PUMP 764 7418	PUMP FAILED WHILE OPERATING. SEALS RAN HOT CAUSING BEARINGS TO BURN OUT AND BEARING INSPECTION PLATE TO FALL OFF OPERATOR ERROR REPLACED BEARINGS AND INSPECTION PLATE

NPRDS OUTPUT ON FAILURES AT BABCOCK & WILCOX PLANTS

JUL 20, 1979

FACILITY EVENT/REPT COMP/SYS EQUIPMENT#

DESCRIPTION

DPCNEE1 740603 PUMPXX 1RC-P1B2
 740603 CBD 764 7423
 770114 Z
 UNKNOWN

LEAK FROM COUPLING AREA

PIPE COVER WAS SEALED WITH RTV SEALING
 COMPOUND

DPCNEE1 740629 CRDRVE 1CRD-K-11
 740629 RBB 764 7399
 770114 B

STATOR FAILED CAUSING ROD TO DROP

UNKNOWN

REPLACED STATOR

DPCNEE1 740808 VALVOP 1FDW-103
 740808 HHA 754 0150
 740809

BREAKER TO MOTOR TRIPS UPON TRYING TO OPEN
 THE VALVE FROM CONTROL ROOM

FAULTY MOTOR-LIKELY SHORTED
 REPLACED MOTOR

DPCNEE1 740916 PENETR EC-10
 740916 SAB 764 7402
 770114 Z

PENETRATION LEAKS

FAULTY 'O' RING SEALS

REPLACED 'O' RING SEALS AND NICKEL PLATED
 FLANGE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	741009 741009 741108	VALVEX SFD	1HP-15 752 0234	VALVE NOT OPERATING PROPERLY SLUGGISH AND RESETS BY ITSELF
				UNKNOWN REPLACED BAD CONTROL UNIT & RECALIBRATED
DPCNEE1	741028 741028 741122	VALVEX WBB	1CC-16 744 0553	VALVE STEM BROKEN OFF
				UNKNOWN REPLACED VALVE
DPCNEE1	741103 741103 741104	VALVOP SFD	1HP-2 754 0152	VALVE WILL NOT OPERATE ELECTRICALLY
				BLOWN FUSE REPLACED FUSE
DPCNEE1	741118 741118 750228	MOTORX CBD	1RC-P1B2 752 0217	LEAK
				SEAL FACES NEED LAPPING RELAPPED SEAL FACES - REPLACED 'O' RINGS

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	741210 741210 741223	VALVOP SFF	1LP-22 752 0245	FAULTY MOTOR UNKNOWN REPLACED WITH NEW MOTOR
DPCNEE1	741216 741216 741221	VALVOP SFF	1LP-21 744 0550	FAULTY MOTOR UNKNOWN REPLACED MOTOR
DPCNEE1	741227 741227 741228	VALVOP SFD	1HP-20 752 0241	MAKE UP FLOW CHANGES WITH NO APPARENT CHANGE IN VALVE POSITION FAULTY POSITIONER REPAIRED POSITIONER
DPCNEE1	750102 750102 750107	VALVEX SFF	1LP-79 752 0235	VALVE LEAKS AND IS NOT REPAIRABLE UNKNOWN REPLACED VALVE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	750104 750104 750110	VALVOP SFF	1LP-2 752 0244	VALVE NOT OPENING AT 300 PSIG
				FAULTY MICRO-SWITCH REPLACED MICRO-SWITCH
DPCNEE1	750105 750105 750113	PUMPXX CBD	1RC-P1A1 752 0230	WORN OUT SEAL
				NATURAL END OF LIFE REPLACED SEAL ASSEMBLY
DPCNEE1	750105 750105 750107	VALVOP SFD	1HP-228 752 0242	VALVE WILL NOT OPERATE BY MOTOR
				'B' FINGER INTERLOCK STUCK STRETCHED SPRING IN ORDER TO MAKE CONTACT
DPCNEE1	750114 750114 750217	MOTORX CBD	1RC-P1A1 752 0216	WORN SEALS
				NATURAL END OF LIFE REPLACED GASKETS, SEAL RING, RUNNER, AND CUP

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	750114 750114 750217	PUMPXX CBD	1RC-P1B2 752 0232	WORN SEALS NATURAL END OF LIFE REPLACED GASKETS,RING,RUNNER,SLEEVE,INSERT
DPCNEE1	750203 750203 750204	VALVEX CBD	1RC-66 754 0148	VALVE LEAKS PAST SEAT MANUFACTURING AND/OR INSTALLATION ERROR LAPPED SEAT
DPCNEE1	750225 750225 750310	PUMPXX CBD	1RC-P1A1 752 0231	FAULTY SEALS - LEAKING WORN SEALS - REPLACED SEAL INSERT,RINGS, SEAL HOUSING,RING ASSEMBLY,AND COLLAR
DPCNEE1	750314 7503141520 760826 Z	VALVEX SCC	1BS-3 764 7424	VALVE JAMS AFTER TRAVELING A SHORT DISTANCE. MOVING THE VALVE MANUALLY ALLOWS ELECTRICAL OPERATION. PACKING GLAND TOO TIGHT LOOSENED PACKING GLAND. REPAIR DELAYED DUE TO THE NON-CRITICAL NATURE OF THE FAILURE.

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	750502 7505021700 740503	VALVOP SFF	1LP-18 752 0243	VALVE STATUS INDICATOR DID NOT SHOW THE VALVE BEING OPEN WHEN IT WAS OPENED
				OPEN LIMIT SWITCH CONTACTS WERE CORRODED CLEANED CONTACTS
DPCNEE1	750804 7508040900 760830 Z	PENETR SAB	WA-5 764 7416	LEAKING SF6 GAS
				CRACK AROUND WELDS IN PENETRATION
				REPLACED PENETRATION
DPCNEE1	750804 7508040900 760830 Z	PENETR SAB	WB-1 764 7417	LEAKING SF6 GAS
				CRACK AROUND WELDS IN PENETRATION
				REPLACED PENETRATION
DPCNEE1	750923 7509232100 751027 A	PUMPXX SCC	1B5 211 764 7419	SEAL LEAK
				FAULTY GASKET
				REPLACED GASKET

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	751114 7511141230 751215	VALVOP SFF	1LP-17 761 5033	TORQUE SWITCH OUT OF ADJUSTMENT, CLOSES
	A			SET POINT DRIFT VALVE TOO TIGHT
				READJUSTED TORQUE SWITCH
DPCNEE1	751114 7511141230 751215	VALVOP SFF	1LP-18 761 5034	TORQUE SWITCH OUT OF ADJUSTMENT, CLOSES
	A			VALVE TOO TIGHT
				SET POINT DRIFT
				READJUSTED TORQUE SWITCH
DPCNEE1	751229 7512291515 760903	PUMPXX SFF	1LP-P1C 764 7421	PUMP IS HARD TO ROTATE
	A			CORRODED SHAFT SEALS
				INSTALLED MECHANICAL SEAL, 'O' RING GASKET, AND SHAFT SEAL
DPCNEE1	760109 7601090900 760903	VALVEX CBD	1RC-66 764 7435	VALVE LEAKING PAST SEAT
	Z			LIMIT BOX FAILURE
				REPLACED LIMIT BOX

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	760210 7602100830 760903 Z	PENETR SAB	ED-3 764 7403	'O' RING SEAL LEAKING SEAL IS CORRODED REPLACED SEAL
DPCNEE1	761101 7611011200 770214 Z	BLOWER SBB	1RBC-1A 764 7394	EXCESSIVE VIBRATION AND LOAD RUBBING CAUSED BY WORN PARTS CYCLIC FATIGUE REPLACED LUG, FAN BLADE, AND UPPER AND LOWER BEARINGS
DPCNEE1	761209 7612091200 770201 Z	VALVEX SFD	1HP-120 764 7428	VALVE LEAKING THROUGH SEAT SCARED VALVE SEAT LAPPED VALVE SEAT
DPCNEE1	761218 7612180800 770330 Z	VALVEX SFD	1HP-57 773B0029	VALVE HARD TO OPERATE AND LEAKING THROUGH SEAT NATURAL END OF LIFE REPLACED VALVE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	770113 7701131200 770330	VALVOP SFF	1LP-18 773B0031	BRAKE ENGAGING INCORRECTLY OUT OF ADJUSTMENT ADJUSTED BRAKE
	Z			
DPCNEE1	770116 7701161200 770201	VALVEX SFD	1HP-322 773B0028	VALVE LEAKING PAST SEAT SCARRED VALVE SEAT LAPPED AND REPACKED VALVE
	Z			
DPCNEE1	770119 7701190800 770201	VALVEX CBD	1RC-66 773B0030	VALVE LEAKING THROUGH SEAT SCARRED VALVE SEAT LAPPED VALVE SEAT
	Z			
DPCNEE1	770417 7704170400 770907	VALVEX SFD	1HP-71 773C0235	VALVE LEAKS BY SEAT UNKNOWN LAPPED SEAT, REPLACED SPRINGS AND GASKETS
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	770506 7705061100 770919	PUMPXX SFD	1HP-P1B 774A0279	EXCESSIVE VIBRATION
	Z			UNKNOWN
				REPLACED MECHANICAL SEAL
DPCNEE1	770721 7707211100 771104	VALVEX CBD	1RC-66 774A0288	VALVE LEAKS PAST SEAT
	Z			DEFECTIVE GASKET AND WORN DISC
				REPLACED GASKETS AND DISC
DPCNEE1	770729 7707291200 771104	VALVEX SFD	1HP-43 774A0285	VALVE LEAKS
	Z			UNKNOWN
				REPLACED DISC,STEM,SPRING
DPCNEE1	770730 7707301430 770817	VALVOP HHA	1FDW-106 774B0292	VALVE WOULD NOT OPERATE
	Z			DEFECTIVE SOLENOID
				REPLACED SOLENOID

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	770731 7707311200 771104	VALVEX CBD	1RC-5 774A0286	VALVE WILL NOT OPERATE MANUALLY
	Z			DEFECTIVE HANDWHEEL
				REPLACED HANDWHEEL AND STEM
DPCNEE1	770805 7708051930 770817	VALVOP SCB	1PR-2 773C0237	VALVE WOULD NOT CLOSE, AIR BLOWING CONTINUOUSLY FROM EXHAUST
	Z			RUPTURED DIAPHRAGM
				REPLACED DIAPHRAGM
DPCNEE1	770806 7708060415 770817	VALVOP SCB	1PR-2 773C0238	VALVE WILL NOT OPEN
	Z			RUPTURED DIAPHRAGM
				REPLACED DIAPHRAGM
DPCNEE1	770915 7709151100 771104	VALVEX SFD	1HP-285 774A0284	VALVE FAILED TO FUNCTION PROPERLY
	Z			UNKNOWN
				REPLACED VALVE W/KEROTEST S/N WA1-24

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	770916 7709160700 771104	VALVOP WBB	1CC-7 774A0293	VALVE WILL NOT OPEN ELECTRICALLY
	Z			TORQUE SWITCH OUT OF ADJUSTMENT
				ADJUSTED TORQUE SWITCH
DPCNEE1	770917 7709170900 771104	VALVEX SFD	1HP-147 774A0283	VALVE FAILED TO FUNCTION PROPERLY
	Z			UNKNOWN
				REPLACED VALVE W/KEROTEST S/NOBB7-7
DPCNEE1	770918 7709180930 771104	VALVEX SFD	1HP-126 774A0281	VALVE LEAK BY SEAT
	Z			UNKNOWN
				REPLACED GASKET, SPRING, AND SEAT
DPCNEE1	770918 7709180950 771104	VALVEX SFD	1HP-127 774A0282	VALVE LEAKS BY SEAT
	Z			UNKNOWN
				REPLACED DISK, SPRING, GASKET

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	770921 7709211130 771006 Z	VALVEX CBD	1RC-7 774A0292	REMOVE AND REPLACE VALVE TO ELIMINATE PREVIOUS PROBLEMS DEFECTIVE VALVE REPLACED VALVE WITH 2IN 1500# S/S GATE BORG WARNER S/N 24561
DPCNEE1	770926 7709261000 771104 Z	VALVEX CBD	1RC-67 774A0290	VALVE LEAKS THROUGH UNKNOWN REPLACED WITH IDENTICAL VALVE S/N BL8891
DPCNEE1	770926 7709261000 771104 Z	VALVEX CBD	1RC-68 774A0291	VALVE LEAKING THROUGH UNKNOWN REPLACED WITH IDENTICAL VALVE S/N BL08890
DPCNEE1	770926 7709261300 770926 Z	VALVOP WAB	1LPSW-4 774B0294	DID NOT MEET MAXIMUM STROKING TIME REQUIREMENTS LIMIT SWITCH OUT OF ADJUSTMENT ADJUSTED LIMIT SWITCH

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	770930 7709301630 771104	VALVEX CBD	1RC-5 774A0287	VALVE FAILED
	Z			UNKNOWN
				REPLACED VALVE
DPCNEE1	771004 7710041100 771104	CBD PUMPXX	774A0278	SEALS LEAKING
	Z			UNKNOWN
				REPLACED SEALS
DPCNEE1	771004 7710041100 771104	PUMPXX CBD	1RC-P1B1 774A0280	SEALS LEAKING
	Z			UNKNOWN
				REPLACED SEALS
DPCNEE1	771004 7710040800 771104	VALVEX CBD	1RC-66 774A0289	VALVE LEAKS BY SEAT
	Z			SEAT SCARRED
				LAPPED SEAT AND INSTALLED NEW GASKETS

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	771011 7710111940 771104	VALVOP SFF	1LP-22 774A0294	VALVE WILL NOT OPEN ELECTRICALLY
	Z			BAD COIL
				REPLACED COIL
DPCNEE1	771116 7711161300 780111	PUMPXX SCC	1BS-P1A 774B0290	MECHANICAL SEAL LEAKING
	Z			SEAL CRACKED
				REPLACED SEAL
DPCNEE1	780501 7805011200 780711	VALVEX CBD	1RC-4 783A0333	VALVE LEAKS AROUND PACKING
	Z			VALVE IMPROPERLY PACKED
				REPACKED VALVE, REPLACED BONNET ASSEMBLY
DPCNEE1	780504 7805041400 780711 780519	VALVEX SFF	1LP-2 783A0332	VALVE WOULD NOT REOPEN AFTER BEING CLOSED
	H			UNKNOWN-THE YOKE NUT AND STEM WERE BOUND
				REPLACED INTERNALS OF VALVE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	780512 7805121100 780711	VALVEX SFE	1CF-12 783A0331	VALVE LEAKING AT COVER PLATE
	Z			WORN SEALS
				REPLACED SEALS
DPCNEE1	780517 7805170600 780711	VALVOP CBD	1RC-7 783A0334	VALVE WILL NOT OPEN BY OPERATOR
	Z			WORN SOLENOID VALVE
				REPLACED SOLENOID VALVE
DPCNEE1	780803 7808031000 781009 780925	CRDRVE : 9B	1CRD-G-7 784B0125	CONTROL ROD 1 ON GP 7 DROPPED FORCING UNIT TO OPERATE AT REDUCED POWER
	H			STATOR SHORTED OUT ON A PHASE-TO-NEUTRAL
				REPLACED WITH NEW STATOR DURING REFUELING OUTAGE
DPCNEE1	780908 7809081600 781006	VALVEX SFD	1HP-31 784B0130	VALVE HP-31 LEAKS BY SEAT WHEN CLOSED
	Z			SEAT CUT BY PRESSURE
				REPLACED VALVE STEM AND SEAT

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE1	780910 7809101600 781006	VALVOP SCB	1PR-2 784B01 1	1PR-2 VALVE OPERATOR WILL NOT OPEN VALVE
	Z			WIRING SHORTED AND CHARRED
				REPLACED WIRING IN RELAYS AND SWITCHES
DPCNEE1	780918 7809181600 781006	VALVEX SFD	1HP-120 784B0129	VALVE LEAKS BY SEAT WHEN CLOSED
	Z			VALVE SEAT WORN AND NOT SEALING OFF
				REPLACE AND LAPPED VALVE SEAT
DPCNEE2	740925 7409251200 741231	VALVEX SFF	2LP-14 764 7486	VALVE WILL NOT OPERATE PER SPECIFICATIONS
	Z			FAULTY VALVE
				EPAIRED VALVE AND SET LIMITS
DPCNEE2	741003 7410031200 770208	VALVEX SFF	2LP-37 764 7490	VALVE LEAKING THROUGH SEAT
	A			UNKNOWN
				RELAPPED SEAT

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	741017 7410171200 770117	VALVOP SCC	2BS-2 764 7500	CONTROL ROOM INDICATES VALVE IN CLOSED POSITION. VISUAL INSPECTION SHOWS VALVE PARTIALLY OPEN. CHANGE IN LIMIT SWITCH SETTING READJUSTED LIMIT SWITCH
	Z			
DPCNEE2	741025 7410251200 770117	VALVOP CDD	2RC-1 764 7505	VALVE WOULD NOT OPEN ON DEMAND FAULTY TORQUE SWITCH REPLACED TORQUE SWITCH
	Z			
DPCNEE2	741119 7411191200 770208	GENERA EBG	2DIB 764 7463	ERRATIC OUTPUT UNKNOWN REPLACED STATOR CONTROL RECTIFIER
	A			
DPCNEE2	741209 7412091200 770117	VALVOP SFF	2LP-22 764 7502	VALVE WILL NOT OPERATE FAULTY MOTOR REPLACED MOTOR
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	741215 7412151200 770117	VALVOP SFF	2LP-22 764 7503	VALVE WILL NOT OPERATE
	Z			MOTOR FAILED DUE TO INSTALLATION ERROR
				REPLACED MOTOR
DPCNEE2	741225 7412251200 770117	VALVOP MAB	2LWD-1 764 7504	INDICATION LIGHTS IN CONTROL ROOM NOT WORKING
	Z			LIMIT SWITCH OUT OF ADJUSTMENT
				READJUSTED LIMIT SWITCH
DPCNEE2	750101 7501011200 770117	VALVEX HHB	2FDW-99 764 7479	VALVE LEAKING
	Z			FAULTY GASKET
				REPLACED GASKET
DPCNEE2	750121 7501211200 770117	VALVEX CBD	2RC-67 764 7496	VALVE LEAKS PAST SEAT
				FAULTY VALVE
				REPLACED VALVE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	750121 7501211200 770117	VALVEX CBD	2RC-68 764 7499	VALVE LEAKS PAST SEAT
	A			FAULTY VALVE
				REPLACED VALVE
DPCNEE2	750205 7502051200 770117	PUMPXX CBD	2RC-P2A1 764 7471	TEST NOZZLE 'J' CAP HAS A LEAK THROUGH WELD
	Z			FAULTY WELD
				REWELDED TO STOP LEAK
DPCNEE2	750205 7502051200 770117	PUMPXX CBD	2RC-P2A2 764 7473	TEST NOZZLE 'J' CAP HAS A LEAK THROUGH WELD
	Z			FAULTY WELD
				REWELDED TO STOP LEAK
DPCNEE2	750205 7502051200 770117	PUMPXX CBD	2RC-P2B1 764 7475	TEST NOZZLE 'J' CAP HAS A LEAK THROUGH WELD
	Z			FAULTY WELD
				REWELDED TO STOP LEAK

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	750205 7502051200 770117	PUMPXX CBD	2RC-P2B2 764 7477	TEST NOZZLE 'J' CAP HAS A LEAK THROUGH WELD FAULTY WELD REWELDED TO STOP LEAK
	Z			
DPCNEE2	750210 7502101200 770117	MOTORX CBD	2RC-P2B1 764 7465	LEAK AROUND SEALS UNKNOWN REPLACED GASKETS AND 'O' RING SEAL COVER
	Z			
DPCNEE2	750214 7502141200 770117	VALVEX SFD	2HP-58 764 7483	CRACK IN WEDGE FOR V-BEVEL UNKNOWN WELDED WEDGE
	Z			
DPCNEE2	750220 7502201200 770117	VALVEX SFF	2LP-17 764 7487	HANDWHEEL WILL NOT ENGAGE MANUALLY FAULTY SPRING REPLACED MANUAL ENGAGE SPRING
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	750224 7502241200 770117	VALVEX SFD	2HP-57 764 7482	VALVE STUCK ON BACKSEAT
	Z			FAULTY WOODRUFF KEY IN REACH ARM
				REPLACED WOODRUFF KEY
DPCNEE2	750320 7503200100 770117	VALVOP CBD	2RC-1 764 7506	VALVE DOES NOT FUNCTION PROPERLY
	Z			FAULTY MOTOR
				REPLACED MOTOR
DPCNEE2	750806 7508061500 760902	VALVEX CBD	2RC-67 764 7497	VALVE LEAKS PAST SEAT
	Z			INTERNAL PARTS WORN
				REPLACED BELLOWS ASSEMBLY AND NOZZLE
DPCNEE2	751026 7510260900 751215	PUMPXX CBD	2RC-P2A1 764 7472	SEALS LEAKING
	B C			THE ORIGINAL TWO SEAL PACK APPARENTLY CAN- NOT WITHSTAND TRANSIENT PRESSURES, THOUGH THEY ARE DESIGNED TO. THERE IS NO APPARENT REASON FOR THE FAILURE. REPLACING THE TWO SEAL PACK WITH A THREE SEAL PACK SEEMS TO CORRECT THE PROBLEM. NO ONE KNOWS WHY THE THREE SEAL PACK WORKS WHEN THE TWO SEAL PACK DOES NOT.

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	751026 7510260900 751215	PUMPXX CBD	2RC-P2A2 764 7474	SEALS LEAKING
	B	C		THE ORIGINAL TWO SEAL PACK APPARENTLY CAN- NOT WITHSTAND TRANSIENT PRESSURES, THOUGH THEY ARE DESIGNED TO. THERE IS NO APPARENT REASON FOR THE FAILURE. REPLACING THE TWO SEAL PACK WITH A THREE SEAL PACK SEEMS TO CORRECT THE PROBLEM. NO ONE KNOWS WHY THE THREE SEAL PACK WORKS WHEN THE TWO SEAL PACK DOES NOT.
DPCNEE2	751026 7510260900 751215	PUMPXX CBD	2RC-P2B1 764 7476	SEALS LEAKING
	B	C		THE ORIGINAL TWO SEAL PACK APPARENTLY CAN- NOT WITHSTAND TRANSIENT PRESSURES, THOUGH THEY ARE DESIGNED TO. THERE IS NO APPARENT REASON FOR THE FAILURE. REPLACING THE TWO SEAL PACK WITH A THREE SEAL PACK SEEMS TO CORRECT THE PROBLEM. NO ONE KNOWS WHY THE THREE SEAL PACK WORKS WHEN THE TWO SEAL PACK DOES NOT.
DPCNEE2	751026 7510260900 751215	PUMPXX CBD	2RC-P2B2 764 7478	SEALS LEAKING
	B	C		THE ORIGINAL TWO SEAL PACK APPARENTLY CAN- NOT WITHSTAND TRANSIENT PRESSURES, THOUGH THEY ARE DESIGNED TO. THERE IS NO APPARENT REASON FOR THE FAILURE. REPLACING THE TWO SEAL PACK WITH A THREE SEAL PACK SEEMS TO CORRECT THE PROBLEM. NO ONE KNOWS WHY THE THREE SEAL PACK WORKS WHEN THE TWO SEAL PACK DOES NOT.
DPCNEE2	760126 7601260900 760901	VALVEX SFF	2LP-17 764 7488	BREAK RELEASE NOT WORKING
	Z			BROKEN ROLL PIN
				REPLACE ROLL PIN

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	760127 760127 1130 760901	PUMPXX SFD	2HP-P2A 764 7468	PUMP BASE PLATE LEAKING ABNORMAL WEAR INSTALLED HEAD GASKET, INTAKE AND DISCHARGE GASKETS
	Z			
DPCNEE2	760322 760322 1200 760901	VALVEX SFF	2LP-22 764 7489	VALVE LEAKING AROUND STEM AND PACKING NATURAL END OF LIFE REPLACED STEM, BODY TO BONNET GASKET, AND REPACKED
	Z			
DPCNEE2	760408 760408 1445 760901	VALVEX SFF	2LP-5 764 7492	BODY TO BONNET LEAK NATURAL END OF LIFE REPLACED BODY TO BONNET GASKET, STUDS, AND REPACKED
	Z			
DPCNEE2	760413 760413 1130 760901	VALVEX SFF	2LP-4 764 7491	VALVE LEAKING PAST SEAT BAD VALVE DISC. NATURAL END OF LIFE. REPLACED VALVE DISC AND VALVE GASKET
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	760510 7605101300 760831	PENETR SAB	EMV-2 764 7466	LEAK AROUND 'O' RING SEALS CORROSION REPLACED 'O' RING SEALS
	Z			
DPCNEE2	760510 7605101300 760831	PENETR SAB	WMV-2 764 7467	LEAK AROUND 'O' RING SEALS CORROSION REPLACED 'O' RING SEALS
	Z			
DPCNEE2	760513 7605130900 760901	VALVEX SFD	2HP-286 764 7481	VALVE LEAKING THROUGH PACKING AND THROUGH VALVE SEAT NATURAL END OF LIFE REPACKED VALVE AND RELAPPED SEAT
	Z			
DPCNEE2	760610 7606101500 760831	VALVEX SFD	2HP-120 764 7480	LEAKING THROUGH THE VALVE SEAT NATURAL END OF LIFE INSTALLED NEW GASKETS,PACKING.LAPPED SEAT
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	760708 7607081830 761209	MOTORX SFD	2HP-P2A 764 7464	PUMP TRIPS ON ATTEMPTS TO START BAD ROTOR DRAWING HIGH STARTING CURRENT CAUSING MOTOR TO TRIP REPLACED ROTOR ASSEMBLY
	Z			
DPCNEE2	760920 7609200800 770725 760920	HTEXCH SFD H	2HP-C2B 773C0240	COOLER 2B HAS TUBE LEAK ABNORMAL WEAR REPLACED COOLER AT NEXT SCHEDULED REFUEL
DPCNEE2	761007 7610071200 761209	VALVEX MAB	2LWD-1 764 7493	BROKEN ROLL PIN NATURAL END OF LIFE REPLACED ROLL PIN
	Z			
DPCNEE2	761206 7612061200 770131	VALVEX SFD	2HP-58 764 7484	UNABLE TO OPEN VALVE BAD LINKAGE INSTALLED HANDWHEEL ON REACH ROD AND REPAIRED REACH ROD
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	761210 7612101200 770131	VALVEX CBD	2RC-67 764 7498	VALVE LEAKS
	Z			GASKET WORN OUT
				REPLACED STUDS AND GASKET
DPCNEE2	761211 7612111200 770131	VALVEX SFD	2HP-58 764 7485	VALVE WOULD NOT OPEN DUE TO A STRIPPED YOKE AND VALVE STEM
	Z			ABNORMAL SERVICE CONDITION
				LAPPED SEAT AND REWORKED NEW WEDGE, TAPPED AND PUT LIQUID METAL ON BODY AND BONNET
DPCNEE2	761227 7612270800 770712	VALVEX HHA	2FDW-31 773B0034	STUFFING BOX BLOW OFF PLUG LEAKING
	Z			WELD FAILURE
				GROUND AND REWELDED PLUG DURING OUTAGE
DPCNEE2	770113 7701131200 770131	VALVOP SCC	2B5-2 773B0036	VALVE STUCK ON SEAT AND WOULD NOT OPEN MANUALLY
	Z			DRIFT IN SET POINT OF LIMIT SWITCH ON VALVE OPERATOR
				RESET LIMIT SWITCH

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	770131 7701312047 770609	PENETR SAB	RB PER HTCH 773B0033	LIMIT SWITCH ON PERSONNEL HATCH INDICATES OPEN WHEN HATCH IS SHUT ADJUSTMENT ARM OUT OF ADJUSTMENT READJUSTED ARM AT TOP OF DOOR AND ADJUSTED LINKAGE SWITCH
	Z			
DPCNEE2	770405 7704051600 770609	VALVOP SFF	2LP-21 773B0037	LP-21 WILL NOT OPERATE FROM SWITCH IN CONTROL ROOM LOOSE SET SCREW ADJUSTED PINION GEAR TO MESH WITH GEAR ON LIMITORQUE AND TIGHTENED SET SCREW
	Z			
DPCNEE2	770419 7704191300 770907	VALVEX CBD	2RC-67 773C0249	2RC-67 LEAKS PAST SEAT REPLACE UNKNOWN REPLACED WITH IDENTICAL VALVE. S/N BL-8889
	Z			
DPCNEE2	770419 7704191300 770907	VALVEX CBD	2RC-68 773C0250	VALVE 2RC-68 LEAKS PAST SEAT UNKNOWN REPLACED WITH IDENTICAL VALVE. S/N BL8892
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	770526 7705260800 770725	VALVEX CBD	2RC-66 77380035	VALVE LEAKS THRU SEAT
	Z			ABNORMAL WEAR ON SEAT OF MAIN VALVE AND PILOT VALVE
				REMOVED VALVE, MACHINED SEATS, REPLACED VALV E
DPCNEE2	770606 7706061550 770817	VALVEX SFD	2HP-7 773C0247	VALVE WOULD ONLY STROKE 1/2 IN, SHOULD BE 1 IN
	Z			UNKNOWN
				STROKED VALVE AND REPACKED
DPCNEE2	770609 7706091300 770718	VALVEX CBD	2RC-2 773C0248	NO FAILURE MODIFICATION
	Z			NONE
				REPLACED VALVE WITH 2.5 IN. TARGET ROCK VALVE S/N2
DPCNEE2	770617 7706171345 770817	MOTORX SBB	2RBC-2A 773C0241	MOTOR BURNED OUT
	Z			UNKNOWN
				REPLACED MOTOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	770617 7706171345 770817	MOTORX SBB	2RBC-2C 773C0243	MOTOR BURNED OUT
	Z			UNKNOWN
				REPLACED MOTOR
DPCNEE2	770623 7706231600 770725	VALVEX SFD	2HP-35 773C0245	VALVE COULD NOT BE RE-ASSEMBLED DUE TO BACK SEAT BEING GAULDED
	Z			BACK SEAT GAULDED
				CUT VALVE OUT AND REPLACED
DPCNEE2	770625 7706250800 770725	VALVOP SCB	2PR-7 774B0306	VALVE WOULD NOT CLOSE ELECTRICALLY
	Z			TORQUE SWITCH FAILED TO FUNCTION NORMALLY
				ADJUSTED TORQUE SWITCH
DPCNEE2	770803 7708031300 770817	VALVOP SFF	2LP-22 773C0254	VALVE WOULD NOT OPERATE ON ES TEST
	Z			INSULATION CAUSED MECHANICAL INTERLOCK TO BIND PREVENTING OPEN CONTACTOR FROM OPERATING
				REMOVED EXCESS INSULATION

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	770804 7708041915 770817	MOTORX SBB	2RBC-2A 773C0242	MOTOR TRIPS OFF AT HIGH SPEED
	Z			BREAKER SET TO LOW
				RESET BREAKER
DPCNEE2	770812 7708120400 770825	VALVOP SFD	2HP-228 773C0251	VALVE WOULD NOT OPERATE ELECTRICALLY
	Z			UNKNOWN
				EXERCISED VALVE MANUALLY
DPCNEE2	770814 7708141300 770907	VALVEX SFD	2HP-285 773C0244	VALVE HAS CRACKED SEAT
	Z			UNKNOWN
				REPLACED STEM, SEAT, AND DIAPHRAM
DPCNEE2	770815 7708150315 771006	CRDRVE REB	D8 774B0297	CONTROL ROD WILL NOT MOVE
	Z			DEFECTIVE STATOR
				REPLACED STATOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	770816 7708161000 771006	CRDRVE RBB	E7 774B0298	CONTROL ROD WILL NOT MOVE
	Z			DEFECTIVE STATOR
				REPLACED STATOR
DPCNEE2	770822 7708221300 770907	VALVEX SFD	2HP-66 773C0246	VALVE LEAKS, REPLACE
	Z			ABNORMAL WEAR
				REPLACED VALVE
DPCNEE2	770825 7708251800 771006	CRDRVE RBB	D10 774B0296	CONTROL ROD WILL NOT MOVE
	Z			DEFECTIVE STATOR
				REPLACED STATOR
DPCNEE2	770826 7708261600 780110	VALVEX HHA	2FDW-100 782B0135	BODY TO BONNET LEAK
	Z			SEAL RING SCARRED
				REPLACED SEAL RING AND ADJUSTED PACKING

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	770830 7708300200 771004	VALVEX SFD	2HP-120 774A0296	VALVE DEMAND CHANGES 2% BUT FLOW CHANGES 20GPM TO 70GPM CAUSING SWING IN PZR LEVEL, RCS PRESSURE, LDST LEVEL, AND RCP SEAL FLOW AIR LEAK AROUND STEM SEAL REPLACED SEAL
	Z			
DPCNEE2	770907 7706241500 770907	VALVOP SFF	2LP-21 773C0253	MOTOR STARTED SMOKING DURING VALVE MOVE- MENT UNKNOWN REPLACED MOTOR
	Z			
DPCNEE2	770920 7709200015 771006	CRDRVE RBB	E9 774B0299	CONTROL ROD WILL NOT MOVE DEFECTIVE STATOR REPLACED STATOR
	Z			
DPCNEE2	770922 7709220015 771104	CRDRVE RBB	07 782B0131	STATOR FAILED UNKNOWN REPLACED STATOR
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	770924 7709240030 771104	CRDRVE RBB	H10 774B0300	STATOR FAILED
	Z			UNKNOWN
				REPLACED STATOR
DPCNEE2	771008 7710081215 771104	VALVEX SFD	2HP-234 774A0297	HANDWHEEL TURNS FREELY VALVE IS INOPERABLE
	Z			YOKE NUT STRIPPED
				REPLACED HANDWHEEL AND YOKE NUT
DPCNEE2	771113 7711132300 780109	VALVEX SFD	2HP-234 774B0304	VALVE WILL NOT MANUALLY OPERATE
	Z			WORN YOKE NUT AND STEM
				REPLACED YOKE NUT AND STEM
DPCNEE2	771230 7712301500 780111	CRDRVE RBB	N12 782B0130	LOC. \ BAD STATOR DURING INSPECTION
	Z			UNKNOWN
				REPLACED STATOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	780103 7801031110 780111	VALVOP HHA	2FDW-36 783A0336	VALVE WILL NOT OPERATE ELECTRICALLY
	Z			MOTOR BURNED OUT
				REPLACED MOTOR
DPCNEE2	780105 7801051135 780215 780215 H	CBD HTEXCH	782B0128	LEAK IN STEAM GENERATOR B
				UNKNOWN
				REPAIRED LEAK BY FILLING TUBE AND PLUGGING
DPCNEE2	780114 7801140800 780215	CRDRVE RBB	M7 782B0129	STATOR FAILED TO RESPOND
	Z			GROUNDED
				REPLACED STATOR
DPCNEE2	780117 7801172335 780215	VALVEX SCC	2BS-10 782B0134	VALVE WILL NOT OPERATE
	Z			DAMAGED RING AND PINION GEARS IN REACH ROD
				REPLACED GEARS

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	780215 7801241400 780215	PUMPXX SCC	2B5-P2A 782B0133	HIGH VIBRATION RECORDED DURING ROUTINE INSPECTION
	Z			BAD MOTOR BEARING
				REPLACED BEARING AND REALIGNED
DPCNEE2	780409 7804090830 780504 780505 H	CBD VALVEX	782C0138	DURING NORMAL OPERATION 2RC-3 DEVELOPED A PACKING LEAK CAUSING UNIT 2 TO BE TAKEN OUT OF SERVICE
				UNKNOWN
				VALVE REPACKED
DPCNEE2	780409 7804090830 780504 780505 H	VALVEX CBD	2RC-3 782C0139	PACKING LEAK
				UNKNOWN
				REPACKED VALVE
DPCNEE2	780609 7806091335 781009 780728 H	CRDRVE RBB	M5 784B0134	STATOR M5 WILL NOT OPERATE
				SHORT IN A PHASE
				REPLACED WITH NEW STATOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	780619 7806190100 781009	PUMPXX SCC	2BS-P2B 784B0135	BAD PUMP BEARING ON RB SPRAY PUMP 2B
	Z			POSSIBLE ALIGNMENT OR VIBRATION PROBLEM
				REPLACED WITH SPARE PUMP AND ALIGNED
DPCNEE2	780814 7808141120 781006	PUMPXX CBD	2RC-P2B1 784B0136	RCP 2B1 SEAL LEAKOFF FLOW RATE HIGH
	Z			SEAL LIFE SHORTER THAN EXPECTED
				REPLACED SEALS
DPCNEE2	780814 7808141118 781006	PUMPXX CBD	2RC-P2B2 784B0137	RCP 2B2 SEAL LEAKOFF FLOW RATE HIGH
	Z			SEAL LIFE SHORTER THAN EXPECTED
				REPLACED SEALS
DPCNEE2	780817 7808171600 781009	CRDRVE RBB	G5 784B0132	STATOR G5 TESTED BAD
	Z			PHASE SHORT INDICATED
				REPLACED WITH NEW STATOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE2	780817 7808170800 781009	CRDRVE RBB	H10 784B0133	STATOR H10 TESTED BAD PHASE GROUND INDICATED REPLACED WITH NEW STATOR
	Z			
DPCNEE2	741220 7412201200 770209	VALVEX SFD	3HP-120 764 7538	VALVE LEAKING FAULTY DIAPHRAGM REPLACED DIAPHRAGM
	Z			
DPCNEE3	741222 7412221200 770209	GENERA EDG	3DIA 764 7519	INVERTER SHIFTED FREQUENCY DRIFT IN SET POINT OF FREQUENCY CONTROL RESET FREQUENCY CONTROL
	Z			
DPCNEE3	741223 7412231200 770209	VALVEX SFD	3HP-259 764 7540	VALVE LEAKS BEYOND REPAIR UNKNOWN REPLACED VALVE
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	741224 741224 1200 770209	VALVOP SFF	3LP-5 764 7560	VALVE WILL NOT OPERATE ELECTRICALLY
	Z			BLOWN FUSE
				REPLACED FUSE
DPCNEE3	741230 741230 1200 770209	VALVEX SFE	3CF-1 764 7536	BODY TO BONNET LEAK
	Z			CORROSION
				CLEANED SEAL RING AND SEALING SURFACES
DPCNEE3	750106 750106 1200 770208	GENERA EBG	3DIC 764 7520	LOSS OF OUTPUT
	Z			BAD POWER FUSE
				REPLACED POWER FUSE
DPCNEE3	750107 750107 1200 770209	VALVEX HHA	3FDW-108 764 7537	VALVE WILL NOT OPERATE
	Z			CORROSION
				DISASSEMBLED, CLEANED, LUBRICATED, AND REASSEMBLED

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	750123 7501231200 770210	VALVOP HHA	3FDW-106 764 7553	NO OPEN INDICATION ON CONTROL ROOM PANEL WHEN VALVE IS OPEN
	Z			FAULTY ACTUATOR
				ADJUSTED ACTUATOR
DPCNEE3	750126 7501261200 770210	INSTRU IAB	NI-8 PR DET 764 7522	CHANNEL TRIPPED SEVERAL TIMES
	A			POWER RANGE DETECTOR OUT OF ADJUSTMENT
				ADJUSTED DETECTOR
DPCNEE3	750205 7502051200 770209	VALVEX CBD	3RC-66 764 7549	VALVE LEAKS PAST SEAT
	Z			UNKNOWN
				LAPPED SEAT
DPCNEE3	750205 7502051200 770209	VALVOP SFF	3LP-18 764 7559	VALVE WILL NOT OPERATE ELECTRICALLY
	Z			BLOWN FUSE
				REPLACED FUSE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	750214 7502141200 770209	VALVOP SFD	3HP-21 764 7556	VALVE WILL NOT OPEN
	Z			FAULTY PRESSURE SWITCH
				REPLACED PRESSURE SWITCH
DPCNEE3	750219 7502191200 770209	VALVEX SFD	3HP-284 764 7541	VALVE LEAKS
	Z			LOOSE LEAK-OFF PLUG
				TIGHTENED PLUG
DPCNEE3	750224 7502241200 770209	BLOWER SCB	3PR-E3A 764 7516	VENTILATION FAN LEAKS AROUND SUCTION GASKET
	A			RANDOM
				PLACED RTV SEALANT ON LEAK
DPCNEE3	750321 7503211200 770208	PENETR SAB	RB PER HTCH 764 7528	MECHANICAL INTERLOCK ON PERSONNEL HATCH IS BENT
	Z			UNKNOWN - LIKELY OPERATOR ERROR
				SET LOCKING CAM ON SHAFT TO MESH WITH GEAR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	750502 7505021000 770209	MOTORX CBD	3RC-P3A2 764 7526	SEAL LEAK
	Z			UNKNOWN
				REPLACED SEAL AND MODIFIED 'O' RING IN SEAL
DPCNEE3	750617 7506171500 770216	PUMPXX CBD	3RC-P3B1 764 7534	FAULTY SEALS
	Z			UNKNOWN
				REPLACED SEALS
DPCNEE3	750621 7506210600 770209	VALVOP SFD	3HP-26 764 7558	VALVE WOULD NOT OPERATE ELECTRICALLY
	Z			CONTACTS LOOSE
				TIGHTENED CONTACTS
DPCNEE3	750731 7507310830 770210	PENETR SAB	EMER P HTCH 764 7527	EMERGENCY PERSONNEL HATCH DOOR GASKETS FAULTY
	Z			NATURAL END OF LIFE
				REPLACED GASKETS

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	750809 7508091005 770209	PUMPXX SCC	3BS-P3B 764 7532	PUMP C. L LEAKING FAULTY MECHANICAL SEAL REPLACED SEAL
	Z			
DPCNEE3	751012 7510120915 770216	INSTRU IED	3RC3A-PT1 774A0299	ERRONEOUS PRESSURE READING - RPS CHANNEL A BAD TRANSMITTER REPLACED TRANSMITTER AND RECALIBRATED
	Z			
DPCNEE3	751012 7510120915 770216	INSTRU IED	3RC3B-PT2 774A0300	ERRONEOUS PRESSURE READING - RPS CHANNEL D BAD TRANSMITTER REPLACED TRANSMITTER AND RECALIBRATED
	Z			
DPCNEE3	751019 7510192200 760813	CRDRVE RBB	M3 764 7518	CONTROL ROD M3 SHOWS API POSITION OF ABOUT 93% WITH ROD OUT OF LIMIT LIGHT ON, CAUSING ASSEMBLY ROD FAULT ALARM. LOOSE CONNECTION OF THE API INPUT SIGNAL TIGHTENED CONNECTION
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	751104 7511041210 770211	INSTRU IBC	HP-27 UC 764 7521	CONTROL UNIT DOES NOT FUNCTION PROPERLY IN THE MANUAL MODE PUSHBUTTON SWITCH IS STICKING REPLACED SWITCH
	Z			
DPCNEE3	760115 7601151500 760817	VALVEX SFF	3LP-12 764 7542	VALVE CANNOT BE OPERATED LOCALLY SHAFT SHEARED OFF FABRICATED SHAFT AND INSTALLED
	Z			
DPCNEE3	760115 7601151500 760817	VALVEX SFF	3LP-14 764 7543	HANDWHEEL INOPERABLE RATCHET PAW STRIPPED OFF REPAIRED RATCHET PAW AND REPLACED HALF- MOON KEY
	Z			
DPCNEE3	760223 7602231000 760817	PUMPXX CBD	3RC-P3B1 764 7535	PUMP SEALS BAD NATURAL END OF LIFE REPLACED SEALS
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	760321 7603210606 760819	VALVEX SFF	3LP-6 764 7544	VALVE WOULD NOT OPERATE MANUALLY
	Z			SHAFT THAT ENGAGES FOR MANUAL OPERATION WOULD NOT FUNCTION DUE TO EXCESSIVE WEAR
				REPLACED SHAFT
DPCNEE3	760405 7604050830 760819	PENETR SAB	WD-3 764 7531	LEAKING SF6 GAS
	Z			UNKNOWN
				REPLACED PENETRATION
DPCNEE3	760428 7604281005 761026	PUMPXX SFD	3HP-P3C 764 7533	PUMP SHAFT SEALS LEAKING
	Z			NATURAL END OF LIFE
				REPLACED SEALS
DPCNEE3	760719 7607191440 760813	VALVOP SFD	3HP-24 764 7557	VALVE INOPERABLE - WILL NOT OPEN
	Z			LIMIT SWITCH OUT OF ADJUSTMENT
				ADJUSTED LIMIT SWITCH

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	760720 7607202230 761214	VALVEX CBD	3RC-66 764 7550	VALVE LEAKING PAST SEAT
	Z			VALVE SEAT WORN BADLY
				REMOVED VALVE, REPAIRED VALVE SEAT, AND REPLACED VALVE
DPCNEE3	760730 7607302230 761214	VALVEX CBD	3RC-67 764 7551	LEAKING PAST VALVE SEAT
	Z			VALVE SEAT WORN BADLY
				REMOVED VALVE, REPAIRED VALVE SEAT, AND REPLACED VALVE
DPCNEE3	760730 7607302230 761214	VALVEX CBD	3RC-68 764 7552	LEAKING PAST VALVE SEAT
	Z			VALVE SEAT WORN BADLY
				REMOVED VALVE, REPAIRED VALVE SEAT, AND REPLACED VALVE
DPCNEE3	760822 7608221130 761027	VALVOP HHA	3FDW-108 764 7554	VALVE OPERATOR WILL NOT CLOSE WITH A SYSTEM PRESSURE OF 920 LB. ON IT
	Z			BAD SPRING
				REPLACED SPRING

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	760918 7609181200 761027	VALVEX CBD	3RC-24 764 7548	PLUG AND PACKING LEAK CYCLIC FATIGUE REPLACED STEM, BACKSEAT ASSEMBLY, YOKE BUSHING, DISC, AND PLUG AND REPACKED VALVE
	Z			
DPCNEE3	760930 7609301200 761027	VALVOP HHA	3FDW-108 764 7555	VALVE OPERATED SPURIOUSLY BAD SOLENOID IN OPERATOR REPLACED SOLENOID
	Z			
DPCNEE3	761005 7610051200 761027	VALVEX SCB	3PR-1 764 7546	VALVE LEAKING PAST SEAT VALVE SEAT DRIED OUT AND OUT OF ADJUSTMENT LUBRICATED AND ADJUSTED VALVE SEAT
	Z			
DPCNEE3	761005 7610051200 761027	VALVEX SCB	3PR-2 764 7547	VALVE LEAKING PAST SEAT VALVE SEAT DRIED OUT AND OUT OF ADJUSTMENT LUBRICATED AND ADJUSTED VALVE SEAT
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	761006 7610061200 761027	VALVEX MAB	3LWD-1 764 7545	VALVE LEAKING PAST SEAT
	Z			BAD DIAPHRAGM
				REPLACED DIAPHRAGM
DPCNEE3	761014 7610141200 761027	PENETR SAB	RB PER HTCH 764 7529	PERSONNEL HATCH INTERLOCKS OUT OF ADJUSTMENT
	Z			CYCLIC FATIGUE CAUSING ADJUSTMENT PROBLEM
				ADJUSTED INTERLOCKS
DPCNEE3	761020 7610201200 761101	PENETR SAB	RB PER HTCH 764 7530	PERSONNEL HATCH INTERLOCKS OUT OF ADJUSTMENT
	Z			OUT OF ADJUSTMENT
				ADJUSTED INTERLOCKS
DPCNEE3	761020 7610201200 761130	VALVOP SCB	3PR-1 764 7561	VALVE WILL NOT OPERATE ON DEMAND
	Z			FAULTY MOTOR IN VALVE OPERATOR
				REPLACED MOTOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	761026 7610261200 761130	VALVOP CBD	3RC-5 764 7562	VALVE OPERATOR MOTOR SHORTED TO GROUND
	Z			BARE PLACE ON MOTOR LEAD
				TAPED BARE PLACE
DPCNEE3	761111 7611111200 761130	CRDRVE RBB	H10 764 7517	ROD H10 DROPPED TO THE BOTTOM OF THE CORE
	Z			BAD STATOR
				REPLACED STATOR
DPCNEE3	761121 7611211200 770405	VALVEX HHA	3FDW-108 773B0047	VALVE WILL NOT OPERATE FROM CONTROL ROOM SWITCH - CANNOT CLOSE
	Z			PACKING WAS TOO TIGHT AND HAD THE VALVE STEM IN A BIND NOT ALLOWING IT TO TRAVEL COMPLETELY CLOSED
				REPACKED VALVE PROPERLY
DPCNEE3	761206 7612061200 770128	INSTRU IED	3RC14A-DPT4 764 7525	RPS CHANNEL D TOTAL FLOW DOES NOT AGREE WITHIN 4.8 MILLION #/HR WITH CHANNELS A, B, AND C.
	Z			FAULTY EAJON-FITTING GASKET
				REPLACED GASKET AND RECALIBRATED

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	761212 7612121200 770128	VALVEX SFD	3HP-120 764 7539	VALVE DOES NOT OPERATE ON DEMAND
	Z			DIAPHRAGM IN VALVE OPERATOR LEAKS - VALVE AND VALVE OPERATOR ARE A SINGLE UNIT
				REPLACED DIAPHRAGM
DPCNEE3	770216 7702161500 770405	CRDRVE RBB	F2 773B0039	CONTROL ROD DRIVE MOTOR TUBE F2 ON REACTOR SERVICE CLCSURE HEAD LEAKS
	Z			NATURAL END OF LIFE
				REPLACED O-RINGS, VENT VALVE ASSEMBLY, AND CLOSURE INSERT ASSEMBLY.
DPCNEE3	770219 7702191900 770405	VALVEX SFD	3HP-236 773B0049	VALVE STEM BROKEN
	Z			UNKNOWN -BROKEN VALVE STEM
				REPLACED VALVE STEM, SPRING, AND DISC
DPCNEE3	770302 7703021430 770414	PENETR SAB	RB PER HTCH 774A0301	PERSONNEL LOCK INNER DOOR EQUILIZER VALVE NOT WORKING PROPERLY
	Z			OUT OF ADJUSTMENT
				ADJUSTED VALVE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	770610 7706102330 780110	VALVEX CBD	3RC-19 774B0317	VALVE LEAKS BY SEAT WORN DISC REPLACED DISC A.I.J REPACKED
	Z			
DPCNEE3	770624 7706240400 770725	PUMPXX SFF	3LP-P1A 783A0338	MECHANICAL SEAL LEAKING ABNORMAL WEAR OF SEAL REPLACED SHAFT SLEEVE, SEAL GLAND, AND GASKET
	Z			
DPCNEE3	770715 7707150500 770907	VALVEX CBD	3RC-43 773^0259	REPACK RC-43, VALVE LEAKS PAST SEAT CRACKED SEAT REPACKED VALVE AND SCHEDULED TO REPLACE DURING OUTAGE
	Z			
DPCNEE3	770720 7707201100 770825 770728	HTEXCH CBD	3RC-H3B 774B0310	TUBES ONE AND TWO ROW SEVENTY-SEVEN LEAK UNKNOWN PLUGGED TUBES
	H			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	770807 770807 1525 770817	VALVEX SCB	3PR-2 773C0258	VALVE WILL NOT OPEN
	Z			RUPTURED DIAPHRAGM
				REPLACED DIAPHRAGM
DPCNEE3	770820 770820 1430 771006	CRDRVE RBB	G9 774A0298	CONTROL ROD WILL NOT MOVE
	Z			DEFECTIVE STATOR
				REPLACED STATOR
DPCNEE3	771011 771011 1048 771104	VALVOP SFF	3LP-21 774B0323	VALVE WILL NOT CLOSE ELECTRICALLY
	Z			TORQUE SWITCH SET TO LOW
				RESET TORQUE SWITCH
DPCNEE3	771023 771023 1600 780110	VALVEX SFE	3CF-15 774B0314	VALVE BLOWS BY
	Z			DRIFT IN SET PRESSURE
				REMOVED VALVE, SET PRESSURE, REINSTALLED

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	771024 7710241400 771104	VALVOP SFD	3HP-4 774B0322	VALVE WILL NOT OPEN
	Z			CONTACTS CORRODED
				CLEANED CONTACTS
DPCNEE3	771114 7711141400 780110	VALVOP SFD	3HP-26 774B0320	VALVE WILL NOT CLOSE ELECTRICALLY
	Z			B.C FINGERS NOT OPENING
				ADJUSTED CONTACTS
DPCNEE3	771116 7711161600 780110	VALVOP SCC	3BS-2 774B0319	UNABLE TO CYCLE VALVE
	Z			GEARS WORN
				REBUILT GEAR MECHANISM
DPCNEE3	771122 7711221145 780215	VALVEX SFD	3HP-120 782B0144	VALVE WILL NOT SEAT
	Z			WORN STEM AND DISC
				REPLACED STEM AND SEAT

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	771122 7711220200 780110	VALVOP SFD	3HP-26 77B0321	NO CONTROL ROOM POWER TO OPERATE
	Z			WIRES BURNED
				RECONNECTED WIRES
DPCNEE3	771201 7712010030 780111	INSTR IAB	NI-5 PR DET 774B0311	CHANNEL A TRIPPED AT 6X10-8
	Z			BAD DETECTOR
				REPLACED DETECTOR WITH LIKE 3/N WL-23636-B
DPCNEE3	771228 7712281400 780111	VALVEX SFF	3LP-12 774B0315	VALVE WILL NOT OPERATE MANUALLY
	Z			ENGAGEMENT LEVER BROKEN
				REPAIRED LEVER
DPCNEE3	771228 7712281400 780111	VALVEX SFF	3LP-14 774B0316	VALVE WILL NOT OPERATE
	Z			LOOSE SETSCREWS ON HANDWHEEL
				TIGHTEN SET SCREWS ON HANDWHEEL

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	780113 7801130948 780215	VALVEX SFE	3CF-1 782B0142	VALVE HAS A BODY TO BONNET LEAK HAD WORN SEAL RING REPLACED SEAL RING
	Z			
DPCNEE3	780119 7801190900 780215	VALVEX SFD	3HP-154 782B0145	VALVE LEAKS BY SEAT USING VALVE AS A THROTTLE VALVE LAPPED SEAT REPLACED INTERNALS
	Z			
DPCNEE3	780120 7801201615 780215	VALVEX SFE	3CF-8 782B0143	VALVE LEAKS PAST SEAT WORN DISC AND SPRING REPLACED SPRING AND DISC
	Z			
DPCNEE3	780202 7802021100 780215 780223	VALVOP SCB	3PR-9 782B0148	VALVE WILL NOT CLOSE ELECTRICALLY DEFECTIVE TORQUE SWITCH IN OPERATOR REPLACED TORQUE SWITCH
	H			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCNEE3	780210 7802100830 780504	CRDRVE RBB	H12 782C0140	STATOR FAILED
	Z			UNKNOWN
				REPLACED STATOR
DPCNEE3	780620 7806200900 780711	VALVEX SFD	3HP-234 783A0339	HANDWHEEL SPINS ON STEM
	Z			YOKE NUT BROKEN
				REPLACED YOKE NUT
DPCNEE3	780706 7807061730 781009	VALVOP SFF	3LP-21 784B0142	3LP-21 OPERATOR NOT FUNCTIONING PROPERLY
	Z			OPERATOR STEM NUT THREADS STRIPPED
				REPLACED OPERATOR STEM NUT
DPCNEE3	780822 7808221226 781006 780919	VALVEX WAB	3LPSW-24 784B0140	VALVE WOULD NOT OPERATE TO CLOSE POSITION
	H			BAD TORQUE SWITCH
				TORQUE SWITCH WAS REPLACED

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
DPCHEE3	780823 7808230855 781006 780919 H	VALVEX WAB	3LPSW-21 784B0139	VALVE IN INTERMEDIATE POSITION POSITION INDICATOR SLIPPED ADJUSTED VALVE POSITION INDICATOR
FPCCRP3	770313 7802091200 780406 Z	MOTORX HBA	MSV-55 782B0153	VALVE IS NORMALLY CLOSED. DURING FUNCTION- AL TEST, VALVE WOULD NOT OPEN. VALVE MOTOR WOULD NOT FUNCTION DUE TO A FAULTY ROTOR REPLACED ROTOR ASSEMBLY
FPCCRP3	770323 7703231425 770509 D E	CRDRVE RBB	CRDM-C20 772 2076	DURING NORMAL STARTUP AFTER MANUAL RX TRIP, CONTROL ROD WOULD NOT RESPOND TO OUT COMMAND MEGGERED STATOR, A SHORT FROM PHASE TO GROUND WAS DISCOVERED REPLACED FAULTY STATOR, RX IN MODE 3, HOT STANDBY
FPCCRP3	770404 7704041055 770509 D E	CRDRVE RBB	CRDM-C59 772 2077	WHILE PERFORMING POWER TESTING OSCILLATION CONTROL ROD WAS FOUND TO BE INOPERABLE. RX. POWER AT = 45 % AT TIME MEGGERED STATOR, A SHORT FROM PHASE TO GROUND WAS DISCOVERED RX BROUGHT DOWN TO HOT STANDBY, STATOR REPLACED BY PLANT PERSONNEL.

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	770407 7704072300 770509	CRDRVE RBB	A07-CRDM 772 2075	WHILE PERFORMING BALANCE CORRECTION AT NORMAL POWER OPERATION, APSR'S BECAME INOPERABLE DUE TO PI MALFUNCTION OF ROD 5 RX POWER AT 92 %. ALL PI CABLING AND CONNECTIONS CHECKED, ALL NORMAL, CONCLUDED PI TUBE WAS DEFECTIV E RX BROUGHT TO MODE 3, HOT STANDBY, PI TUBE REPLACED WITH SPARE, PROBLEM WAS CORRECTED.
	D	E		
FPCCRP3	770426 7704261200 770606	INSTRU HBA	SP-1B-LR 772 2079	DURING NORMAL OPERATION IT WAS NOTED THAT A&B STEAM GENERATOR OPERATING LEVEL RECORDERS DID NOT AGREE WITHIN 2 % . BOTH INSTRUMENTS WERE CHECKED, SP-1B-LR HAD A BAD POWER SUPPLY FILTER CAPACITOR REPLACED DEFECTIVE PART AND RECALIBRATED
	Z			
FPCCRP3	770503 7705031200 770607	VALVEX CBD	RCV-8 772 2080	VALVE APPEARED TO BE LIFTING AND RESEATING AT 2155 PSIG VALVE REMOVED, SENT TO LAB FOR REPAIR. THE DISC AND NOZZEL SEAT WERE SCORED IN FIVE PLACES. REBUILT VALVE WITH NEW PARTS AND RE-SET LIFT PRESSURE
	D	G		
FPCCRP3	770513 7705131200 770711	INSTRU PCB	MU-14-LR 773A0118	WHILE RECORDING NORMAL LEVEL IN MAKE-UP TANK, CHART ADVANCE FAILED BOSS ON TAKE-UP REEL THAT ENGAGES CHART ROLL BROKE OFF. BUILT UP A BOSS ON TAKE UP REEL WITH SOLDER
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	770517 7705170700 770711	CRDRVE RBB	A02-CRDM 773A0114	DURING PERFORMANCE OF PREVENATIVE MAINTENANCE ON CONTROL ROD DRIVE SYSTEM STATOR FAILED ELECTRICAL TEST. RX POWER 0 % MODE 5 STATOR SHORTED TO GROUND ON ONE PHASE
	B D			REPLACED STATOR DURING OUTAGE
FPCCRP3	770517 7705170700 770711	CRDRVE RBB	CRDM-C03 773A0115	DURING PERFORMANCE OF PREVENATIVE MAINTENANCE ON CONTROL ROD DRIVE SYSTEM STATOR FAILED ELECTRICAL TEST. RX POWER 0 % MODE 5 STATOR SHORTED TO GROUND ON ONE PHASE
	B D			REPLACED STATOR DURING SAME OUTAGE
FPCCRP3	770517 7705170700 770711	CRDRVE RBB	CRDM-C09 773A0116	DURING PERFORMANCE OF PREVENATIVE MAIN. ON CONTROL ROD DRIVE SYSTEM STATOR FAILED ELECTRICAL TEST. RX POWER AT 0 % MODE 5 STATOR SHORTED TO GROUND ON ONE PHASE
	B D			REPLACED STATOR DURING SAME OUTAGE
FPCCRP3	770517 7705170700 770711	CRDRVE RBB	CRDM-C22 773A0117	DURING PERFORMANCE OF PREVENATIVE MAINTENANCE ON CONTROL ROD DRIVE SYSTEM STATOR FAILED ELECTRICAL TEST RX POWER 0 % MODE 5 STATOR SHORTED TO GROUND ON ONE PHASE
	B D			REPLACED STATOR DURING OUTAGE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	770530 7705301800 770711	VALVEX HHB	ASV-50 773A0119	DURING NORMAL START OF EMERGENCY FEEDWATER PUMP, ASV-50 FAILED TO OPEN BROKEN STEM AND RUST PREVENTED VALVE FROM OPERATING VALVE WAS DISASSEMBLED AND CLEANED, STEM WAS WELDED AND REPLACED IN VALVE. VALVE FUNCTIONED PROPERLY.
	Z			
FPCCRP3	770624 7706241200 771108	CRDRVE RBB	CRDM-C42 774A0309	DURING NORMAL POWER OPERATION ROD 6 OF GROUP 2 ABSOLUTE POSITION INDICATOR JUMPED AT ABOUT 5 % AND 10 % WHILE WITHDRAWING GROUP UNKNOWN REPLACED PI TUBE DURING SCHEDULED OUTAGE
	B D			
FPCCRP3	770627 7706271200 771108	CRDRVE RBB	CRDM-C36 774A0307	ROD 6 OF GROUP 1 FELL INTO CORE DURING POWER OPERATION WITHOUT COMMAND SHORTED WINDING ON STATOR REPLACED PI TUBE AND STATOR DURING SCHEDULED OUTAGE
	B D			
FPCCRP3	770630 7706301200 771108	CRDRVE RBB	A02-CRDM 774A0303	DURING NORMAL POWER OPERATION ABSOLUTE POSITION INDICATOR FOR ROD 1 GROUP 8 DROPPED TO ZERO UNKNOWN REPLACED PI TUBE DURING SCHEDULED OUTAGE
	B D			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	770703 7707031200 770914	VALVEX HHA	FWV-163 773C0264	<p>VALVE IS NORMALLY CLOSED. VALVE WAS OBSERVED LEAKING THRU SEAT AND AROUND BONNET BOLTS</p> <p>AFTER REMOVAL OF VALVE, SEAT WAS DISCOVERED PITTED, AND BONNET GASKET BAD</p> <p>RELAPPED SEAT AND INSTALLED NEW BONNET GASKET</p>
	Z			
FPCCRP3	770717 7707171200 771108	CRDRVE RBB	A07-CRDM 774A0304	<p>DURING NORMAL POWER OPERATION CRDM APPEARED TO HAVE PI PROBLEM AND ROD MOVED SLOWER THAN REST OF GROUP 8</p> <p>STATOR HAD SHORTED WINDINGS</p> <p>REPLACED STATOR DURING PLANT OUTAGE</p>
	A D			
FPCCRP3	770718 7707181200 771108	CRDRVE RBB	CRDM-C25 774A0305	<p>ABSOLUTE INDICATOR ON GROUPE 7 ROD 2 NOT MOVING AS FAST AS REST OF GROUP WHEN PULLING FROM 0 POSITION</p> <p>UNKNOWN</p> <p>REPLACED PI TUBE DURING SCHEDULED OUTAGE</p>
	B D			
FPCCRP3	770720 7707201200 780104	INSTRU CFC	DH-10-TTS 774B0325	<p>DURING NORMAL PLANT OPERATION TEMPERATURE SWITCH WAS NOT WORKING. HEATER ON BWST WAS ON WHEN TEMP OF TANK WAS 12 DEG HIGHER THAN SET POINT OF SWITCH. A BAD RELAY WAS FOUND IN SWITCH</p> <p>REPLACED DEFECTIVE RELAY AND RECALIBRATED</p>
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	770728 7707281200 771107	VALVEX HBA	MSV-25 774A0310	DURING NORMAL OPERATION, STEAM WAS NOTICED ESCAPING THRU ATMOSPHERIC DUMP VENTS, INDICATING SEAT LEAK SEAT LEAK ON VALVE SEAT VALVE WAS DISASSEMBLED DURING OUTAGE, SEAT WAS LAPPED AND NEW GASKETS INSTALLED.
	Z			
FPCCRP3	770728 7707281200 771107	VALVEX HBA	MSV-26 774A0311	DURING NORMAL OPERATION, STEAM WAS NOTICED ESCAPING THRU ATMOSPHERIC DUMP VENTS, INDICATING SEAT LEAK SEAT LEAK ON VALVE VALVE WAS DISASSEMBLED DURING OUTAGE, SEAT WAS LAPPED AND NEW GASKETS INSTALLED
	Z			
FPCCRP3	770805 7708051200 770914	VALVEX PCB	MUV-18 773C0265	SEAL RING CUT BY HI PRESSURE, CAUSING EXCESSIVE VALVE LEAKAGE. FAILURE OF SEAL RING TO CONTAIN SYSTEM PRESSURE SEAL WELDED BONNET ON VALVE. LEAKAGE CONTAINED
	B D			
FPCCRP3	770815 7708151200 770914	VALVOP CFC	DHV-4 773C0266	DURING COOL DOWN FOR MAINTENANCE DHV-4 COULD NOT BE OPENED FROM CONTROL ROOM OR AT LOCAL STATION AFTER QUICK INSPECTION BY PLANT ELECTRICIAN A BROKEN WIRE WAS DISCOVERED IN OPERATOR. REPAIRED BROKEN WIRE AND OPERATOR PERFORM ED PROPERLY.
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	770817 7708171200 770914	INSTRU CFC	DH-002-TE1 773C0261	INCORRECT READING WAS OBSERVED BY OPERATIONS WHILE RX PLANT SHUTDOWN AND DELAY HEAT SYSTEM IN SERVICE ELEMENT WAS FOUND TO BE BAD IN RTD BY PLANT INSTRU. TECH. REPLACED FAULTY ELEMENT WITH SPARE,RETURNE D COMPONET TO SERVICE
	Z			
FPCCRP3	770818 7708181200 770914	INSTRU IBB	RP-A39 773C0263	RPS SYSTEM WAS OUT OF SERVICE FOR A MODIFICATION. WHEN CHANNEL WAS ENERGIZED MODULE FAILED FAILURE OF PRINTED CIRCUIT BOARD. CALIBRATED SPARE MODULE AND INSTALLED IN SYSTEM
	Z			
FPCCRP3	770823 7708271200 770914	INSTRU PCB	MU-27-FI 773C0262	DURING YEARLY CALIB FLOW INDICATOR WAS INDICATING 40 % WITH NO MAKE-UP PUMP RUNNING A BAD METER MOVEMENT WAS DISCOVERED IN INDICATOR REPLACED METER MOVEMENT WITH SPARE AND RECALIBRATED STRING
	Z			
FPCCRP3	770824 7708241200 771108	CRDRVE RBB	CRDM-C40 774A0308	DURING PLANT STARTUP ROD 3 GROUP 3 GAVE A FAULTY POSITION INDICATION UNKNOWN REPLACED PI TUBE, RESUMED START-UP, GROUP 3 ROD 3 WAS NORMAL
	B D			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	770825 7708251200 780103	INSTRU IBB	NI-003-C5 774B0327	DURING PERFORMANCE OF SURVEILLANCE PROCEDURE, MODULE WAS FOUND TO BE OUT OF TOLERANCE. RX POWER 0 PERCENT CALIBRATION RESISTOR WAS FOUND TO BE BAD REPLACED COMPLETE MODULE AND CALIBRATED
FPCCRP3	770825 7708251200 780103	INSTRU IBB	NI-004-D5 774B0328	DURING PERFORMANCE OF SURVEILLANCE PROCEDURE MODULE WAS FOUND TO BE OUT OF TOLERANCE. RX POWER AT 0 PERCENT RAMP GENERATOR CARD FOUND BAD REPLACED RAMP GENERATOR CARD AND RECALIBRA TED MODULE.
FPCCRP3	770825 7708251200 770103	INSTRU IBB	NI-004-D9 774B0329	DURING PERFORMANCE OF SURVEILLANCE PROCEDURE RATE OF CHANGE AMPLIFIER WAS FOUND OUT OF TOLERANCE. RX POWER 0 PERCENT UNKNOWN REPLACED COMPLETE MODULE AND RECALIBRATE D
FPCCRP3	770912 7709121200 771107	VALVEX PCB	MUV-27 774A0312	DURING POWER OPERATION VALVE WAS DISCOVERED LEAKING EXCESSIVELY FROM SEAL RING UNKNOWN SEAL RING WELDED UP, VALVE WAS STROKED OPEN AND CLOSED AND VISUAL EXAM SHOWED NO LEAKAGE UNDER SYSTEM PRESSURE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	770919 7709191200 780103	INSTRU PCB	MU-22-PI2 774B0326	NEEDLE ON PRESSURE INDICATOR WAS GIVEN FALSE RESPONSE RX POWER 100 PERCENT NEEDLE WORN OUT PURCHASED NEW GAGE, CALIBRATED AND INSTALLED GAGE.
	B			
FPCCRP3	771001 7710010321 780103	INSTRU CBD	RC-14B-DPT2 774B0330	DURING NORMAL POWER OPERATION CHANNEL B OF REACTOR PROTECTION SYSTEM TRIPPED ON LOW FLOW . RX POWER AT 100 PERCENT A BAD AMPLIFIER ASSY WAS FOUND IN DIFF. PRESSURE TRANSMITTER REPLACED BAD AMPLIFIER ASSY. WITH SPARE. CALIBRATED STRING AND RETURNED TO SERVICE.
	B			
FPCCRP3	771020 7710201200 780104	INSTRU HHA	SP-008B-PT2 774B0331	DURING NORMAL PLANT OPERATION DIFF. PRESS TRANSMITTER STARTED GIVING BAD IMPUT TO COMPUTER. RX POWER AT 100 PERCENT BROKEN BELLOWS ON TRANSMITTER REPLACED BELLOWS WITH SPARE AND RECALIBRATED
	B			
FPCCRP3	771213 7712131200 780406	MOTORX CFC	DHV-42 782B0152	VALVE WOULD NOT OPEN CRACKED ROTOR REPLACED ROTOR
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	780206 7802061200 780406	INSTRU HHA	SP-12A-DPT 782B0151	INPUT FOR INTEGRATED CONTROL SYSTEM FOR FEEDWATER BYPASS VALVE WAS ERRONEOUS. SP-12A DPT HAD A BAD CURRENT BUFFER REPLACED CURRENT BUFFER
	Z			
FPCCRP3	780215 7802151200 780407	RELAYX IBC	ES-4A-AS 782B0154	DURING TESTING OF ENGINEERED SAFEGUARDS TEST BLOCK LOADING SEQUENCE, NORMAL ACTUA- TION INDICATING LIGHT WOULD NOT LIGHT RELAY ES-4A-AS WAS DISCOVERED TO HAVE BAD CONTACT ALIGNMENT. REPLACED RELAY SYSTEM FUNCTIONED NORMALLY.
	E			
FPCCRP3	780414 7804141200 781121	GENERA ECD	DP-INVTR-3A 784B0166	INVERTER 3A HAS HISTORY OF UNEXPLAINABLE TRIPS. UNKNOWN MODIFICATION TO CIRCUIT DESIGN WAS INIT- IATED (MAR#78-7-4) TO INCREASE INVERTER RELIABILITY. INVERTER IS PRESENTLY PERFORM- ING SATISFACTORY. TEST SAT PER IP78-7-4. UPON INITIATING REACTOR BUILDING PURGE, AHV-1D WOULD NOT OPEN.
	B D			
FPCCRP3	780422 7804220800 780815	VALVOP SCB	AHV-1D 783B0076	AHV-1D VALVE OPERATOR WAS LEAKING AIR REBUILT VALVE SOLENOID WITH ASCO REPAIR KIT#103-863. VALVE THEN FUNCTIONED PROPERLY
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	780519 7805191430 780815	INSTRU CFC	DH-1-FS1 783B0073	WHILE INTRODUCING BORATED WATER TO THE REACTOR VESSEL, USING THE DECAY HEAT REMOVAL SYSTEM, DH-1-FS1 WOULD NOT FUNCTION. BAILEY SIGNAL MONITOR HAD DEFECTIVE COMPONENTS REPLACED TRANSISTORS Q1(PART#2N2770)AND Q2(PART#2N4036) ON SIGNAL MONITOR(BAILEY METER COMPANY PART#6623819-A1).SIGNAL MONITOR THEN TESTED SATISFACTORILY. DURING TEST,RC-1-LT2 WAS INOPERABLE.
	Z			
FPCCRP3	780622 7806221400 780815	INSTRU CBD	RC-1-LT2 783B0075	POWER TRANSFORMER AND AN AMPLIFIER ASSEMBLY WERE DEFECTIVE. REPLACED POWER TRANSFORMER PART#6623040-2 (BAILEY METER COMPANY)AND AMPLIFIER ASSEMBLY PART#6619912A1(BAILEY METER CO.). TRANSMITTER THEN FUNCTIONED PROPERLY. SAMPLE CANNISTER FOR FILTER BANK AHFC-1 DID NOT MEET ACCEPTANCE CRITERIA OF METHYL IODIDE REMOVAL EFFICIENCY OF 99 PER CENT.
	Z			THIS FAILURE WAS TO BE EXPECTED DUE TO RECENT OUTAGE. MOISTURE CREATED DURING FUEL SHUFFLE AND VAPORS CREATED FROM PAINTING DOWNGRADED THE CHARCOAL FILTERS. REPLACED CHARCOAL FILTERS BEFORE STARTUP. TESTED SATISFACTORY.
FPCCRP3	780801 7508011000 781120	FILTER SCB	AHFL-1 784B0164	BS-PT-2,BUILDING SPRAY PUMP 3B DISCHARGE PRESSURE TRANSMITTER,INDICATES NO FLOW WHEN PUMP IS RUNNING. TRANSMITTER FILLED WITH WATER AND AIR VENTED AND FILLED TRANSMITTER.TRANSMITTER THEN FUNCTIONED PROPERLY.
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	780831 7808310800 781010	INSTRU CFC	DH-43-FIS 783B0074	DHV-110, DELAY HEAT REMOVAL HEAT EXCHANGER DISCHARGE VALVE, WILL NOT CONTROL IN AUTO- MATIC MODE. DH-43-FIS, FLOW SWITCH WAS OUT OF CALBRAT- ION CAUSING DHV-110 TO NOT CONTROL AUTO- MATICALLY. CALIBRATED DH-43-FIS PER SP-159. DHV-110 NOW CONTROLS PROPERLY.
	Z			
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	A02-CRDM 784B0147	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAILED TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
	Z			
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	CRDM-C08 784B0150	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAILED TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
	Z			
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	CRDM-C09 784B0151	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAILED TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	780907 7809071500 781010	CRDRVE RBB	CRDM-C13 783B0067	CRDM-C013, GROUP 1-RODS, BLOWS PHASE FUSES. SHORTED PIN IN STATOR CONNECTOR. STRAIGHTENED PINS IN STATOR CONNECTOR. CRDM THEN OPERATED SATISFACTORILY.
	Z			
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	CRDM-C19 784B0153	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAILED TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
	Z			
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	CRDM-C20 784B0154	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAILED TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
	Z			
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	CRDM-C30 784B0155	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAILED TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	CRDM-C43 784B0158	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAIL'D TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	CRDM-C45 784B0160	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAILED TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
FPCCRP3	780907 7809071500 781121	CRDRVE RBB	CRDM-C56 784B0162	DURING SP-102, CONTROL ROD DROP TIME TESTS, POSITION INDICATOR FAILED TO FUNCTION CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED-FUN- CTIONED PROPERLY
FPCCRP3	780907 7809071600 781120 780929	VALVOP SAB	CFV-15F 784B0167	DURING PERFORMANCE OF SURVEILLANCE PRO- CEDURE SP 417 ,A CLOSE POSITION INDICATION WAS NOT RECEIVED IN THE CONTROL ROOM WHEN CFV-15 WAS COMMANDED TO CLOSE. TROUBLESHOOTING, VALVE OPERATOR REVEALED A FAULTY TORQUE SWITCH. REPLACED TORQUE SWITCH, VALVE THEN OPERAT- ED SATISFACTORY.

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	780910 7809101200 781121	CRDRVE RBB	CRDM-C37 784B0156	DURING SURVEILLANCE TESTING, POSITION INDICATOR FAILED TO INDICATE CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED INDICATOR-FUNCTIONED PROPERLY
FPCCRP3	780910 7809101200 781121	CRDRVE RBB	CRDM-C43 784B0159	DURING SURVEILLANCE TESTING, POSITION INDICATOR FAILED TO INDICATE CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED INDICATOR-FUNCTIONED PROPERLY
FPCCRP3	780913 7809130712 781120	CRDRVE RBB	A02-CRDM 784B0148	DURING SURVEILLANCE TESTING, POSITION INDICATOR FAILED TO INDICATE CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED SATISFACTORY.
FPCCRP3	780913 7809130712 781121	CRDRVE RBB	CRDM-C37 784B0157	DURING SURVEILLANCE TESTING, POSITION INDICATOR FAILED TO INDICATE CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED INDICATOR-FUNCTIONED PROPERLY

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	780913 7809130712 781121	CRDRVE RBB	CRDM-C46 784B0161	DURING SURVEILLANCE TESTING, POSITION INDICATOR FAILED TO INDICATE CORRECTLY. UNKNOWN REPLACED POSITION INDICATOR. RETESTED INDICATOR-FUNCTIONED PROPERLY
	Z			
FPCCRP3	780918 7809182130 781010 780918	CRDRVE RBB	CRDM-C07 783B0066	ROD FAILED TO MOVE WHEN IT WAS COMMANDED TO MOVE LEADSCREW WAS UNCOUPLED WITH RESPECT TO THE CONTROL ROD. PLANT WAS BROUGHT DOWN FROM MODE 2 TO MODE 5, DEPRESSURIZED. ROD WAS THEN RECOUPLED TO THE LEADSCREW. ROD THEN FUNCTIONED NORMALLY.
	H			
FPCCRP3	780927 7809270645 781120	BATTERY ECD	DPC-5 784B0144	BATTERY CHARGER E KEEPS TRIPPING. HIGH VOLTAGE SHUTDOWN CARD KBC2136A WAS FOUND TO BE DEFECTIVE. REPLACED HIGH VOLTAGE SHUTDOWN CARD AND CLEANED LEAD CONNECTIONS. ALSO REPLACED 'A' PHASE CONTROL CARD.
	Z			
FPCCRP3	781018 7810201420 781120	BLOWER SCB	AHF-1C 784B0146	FAN BEARINGS SHOWED SIGNS OF DETERIORATION WHEN TESTED FOR EXCESSIVE VIBRATION. FAN WAS TAKEN OUT OF SERVICE. THIS FAN IS A REACTOR BUILDING COOLING FAN. BEARINGS FAILED DUE TO UNKNOWN REASONS. REMOVED BEARINGS, DISCONNECTED COUPLINGS, SCREENS, INST. LINES, AND LUBRICATION LINES. REPLACED NEW BEARINGS, RECONNECTED LINES, SCREENS, ETC., REALIGNED COUPLINGS. FAN SAT.
	D			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
FPCCRP3	781018 7810180200 781120	VALVOP PCB	MUV-58 784B0168	WHILE PERFORMING SURVEILLANCE PROCEDURE SP-340,MUV-58 WOULD NOT CLOSE VALVE WOULD NOT CLOSE DUE TO A FAULTY TORQUE SWITCH. REPAVED TORQUE SWITCH.VALVE THEN TESTED SATISFACTORY.
	Z			
FPCCRP3	781024 7810241200 781120	FILTER SCB	AHFL-2A 784B0165	CHARCOAL SAMPLE CANNISTER FOR FILTER BANK AHFL-2A DID NOT MEET ACCEPTANCE CRITERIA OF METHYL IODIDE REMOVAL EFFICIENCY OF 95 PERCENT. RECENT REFUELING ACTIVITIES CREATED MOIS- TURE AND PAINT FUMES WHICH DETERIORATED THE EFFICIENCY OF THE CHARCOAL. REPLACED CHARCOAL FILTERS AND THEY TESTED SATISFACTORY
	Z			
FPCCRP3	781104 7811041030 781120	BATTERY ECD	DPC-6 784B0145	BATTERY CHARGER 'F' KEEPS TRIPPING. DEFECTIVE HIGH VOLTAGE SHUTDOWN CARD,KBC- 2136A. REPLACED DEFECTIVE CARD.BATTERY CHARGER OPERATED SATISFACTORY.
	Z			
FPCCRP3	781121 7811212215 790108	CRDRVE RBB	CRDM-C57 784C0174	ABSOLUTE POSITION INDICATION FOR CONTROL ROD C-57 DOES NOT CHANGE WHEN MOVING THE ROD. CONTACTS OF POSITION INDICATOR'S REED SWITCH WERE STUCK. A VARIABLE A.C. FREQUENCY WAS APPLIED TO THE POSITION INDICATOR TO ALIGN MAGNET- IC FIELD. POSITION INDICATOR THEN FUNCTI- ONED PROPERLY.
	Z			

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
MECTMI1	740903 7409030001 740906	CKTBRK EDA	1P-480V BUS 743 0070	WHEN THE DV DEVICE FOR THE 1P 480V BUS ARE TESTED THEY DO NOT PRINT OUT ON THE COMPUT

ER WIRING PROBLEM FOUND AND REPAIRED

MECTMI1	740903 7409030001 740910	INSTRU IBC	63Z2B/RB3A 743 0074	INDICATION LIGHT DOES NOT COME ON
---------	--------------------------------	---------------	------------------------	-----------------------------------

DIRTY CONTACT CLEANED CONTACTS

MECTMI1	740903 7409030001 740910	INSTRU IBC	63Z2B/RC3A 743 0073	INDICATION LIGHT DOES NOT COME ON
---------	--------------------------------	---------------	------------------------	-----------------------------------

DIRTY CONTACT CLEANED CONTACTS

MECTMI1	740911 7409110001 740913	MOTORX SCC	BS-V-1B 743 0071	BLDWS CONTROL FUSES WHEN OPENING WITH T54 RBB SWITCH IN TEST2 & TEST3 POSITIONS.
---------	--------------------------------	---------------	---------------------	-------------------------------------------------------------------------------------

REMOVED EXTRA WIRE LEFT THERE DURING
CONSTRUCTION.

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
MECTMI1	740918 7409180001 740921	ANNUNC SBB	FS-241-ABC 744 0010	RX BLDG COOLING EXCESS CONDENSATE FLOW ALARMS REMOVED GLASS CLEAN AND CHECKED ALARM POINTS WITH CONTROL ROOM
MECTMI1	740919 7409190001 740921	INSTRU IBB	RTM RPS-C 743 0075	FAULTY TEST TRIP CHANNEL 4 REPLACE SWITCH
MECTMI1	740926 7409260001 740927	INSTRU PCB	CRC-56 743 0076	METER AND RECORDER DO NOT AGREE. PH TO CURRENT CONVERTOR REPLACED AND CALIBRATED BOTH CONVERTOR AND RECORDER
MECTMI1	750523 7505230000 750701	MOTORX CFC	DRPM1B 754 0230	DR-P-1B MOTOR SHAFT IS SHEARED AT THE END BELL HOUSING ON THE DRIVE END OF MOTOR REPLACE SHAFT

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
MECTMI1	750530 7505301600 750701	MOTORX CFC	DRPM1A 754 0229	LOWER END BRACKET (ENDBELL) IS CRACKED AND REQUIRES REPLACEMENT
				END BRACKET REPLACED
MECTMI1	751113 7511130000 760110	CRDRVE RBB	CRDM #25 754 0226	BAD STATOR \$ B CABLE ON MECH #25
				REPLACED STATOR \$ B CABLE
MECTMI1	751113 7511130000 760110	CRDRVE RBB	CRDM #7 754 0228	BAD STATOR \$ B CABLE ON MECH 7
				REPLACED BAD STATOR \$ CABLE
MECTMI1	751121 7511210200 760110	CRDRVE RBB	CRDM #31 754 0227	CRDM#31 STATOR HAS LOW INSULATION RESISTAN CE
				REPLACED STATOR ON MECH #31 ALSO CABLE B

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
MECTMI1	771022 7710221110 771028 771115 H	VALVOP PCB	MU V 0014B 774A0313	WHILE PERFORMING ES TESTING MU V 0014B FAILED TO OPERATE AND TRIPPED ITS THERMAL OVERLOAD DEVICES. THE VALVE WAS OPERATED MANUALLY. THE CAUSE OF FAILURE WAS DUE TO BROKEN MOUNTING BOLTS LODGED IN MOTOR WINDINGS. THE MOTOR WAS REMOVED AND A NEW MOTOR INSTALLED AND TESTED SATISFACTORILY.
SMURSS1	750827 7508270800 760108 750925 H	VALVEX SCB	SFV-53604 761 0027	EXCESSIVE AIR LEAKAGE FOR REACTOR BUILDING PURGE OUTLET VALVE WAS DETECTED DURING SURVEILLANCE TESTING VALVE SEATS ON 66 INCH VALVE HAD BEEN IMPROPERLY ADJUSTED READJUSTED VALVE SEAT AND RETESTED.
SMURSS1	750911 7509110331 760108 Z	VALVEX SCB	SFV-53604 761 0028	EXCESSIVE LEAKAGE THRU VALVE DURING SURVEILLANCE TEST VALVE SEAT ON 66 INCH VALVE HAD BEEN IMPROPERLY ADJUSTED REPLACED VALVE SEAT
SMURSS1	751231 7512311930 760910 Z	VALVEX CFC	PSV-20004 763 0588	RELIEF VALVE LEAKING THRU AND WILL NOT SEAT LEAK TIGHT UNKNOWN DISASSEMBLED VALVE, LAPPED SEAT, BENCH TESTED, RESET TO 300 PSIG AND REINSTALLED

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
SMURSS1	760207 7602071900 761312 7 304 H	VALVEX SFF	..V-26106 761 5071	DURING SURVEILLANCE TESTING EMERGENCY SUMP SUCTION VALVE FAILED TO OPEN ON COMMAND CAUSE OF FAILURE WAS EITHER DUE TO PACKING BEING TOO TIGHT OR VALVE DISC STICKING IN THE SEAT VALVE WAS MANUALLY OPENED FOR A PORTION OF THE STROKE WHICH ALLEVIATED THE PROBLEM
SMURSS1	761009 7610091505 761206 D	VALVEX CBD-01	RCS-001 764 0099	VALVE LEAKING BETWEEN BODY AND BONNET POOR QA AT MANUFACTURER VALVE BODY SEAL AR EA LARGER THAN STANDARD SIZE SEAL GASKET FABRICATED AND INSTALLED LARGER SEAL RING
SMURSS1	761025 7510251400 761029 Z	CKTBRK EBE-03	2B121 763 3287	DURING TEST OF FIRE PROTECTION SYSTEM EMER GENCY SUPPLY FAN WAS STARTED AND COULD NOT BE STOPPED FROM REMOTE CONTROL AUXILIARY CONTACTS ON CLOSING COIL FOR BRE AKER WERE BINDING AND WOULD NOT RELEASE CO IL REPLACED AUXILIARY CONTACT SET, TESTED AND RETURNED TO SERVICE
SMURSS1	770726 7707261100 771219 771220 H	VALVOP CBD-02	SFV-70001-L 774B0407	THE INSIDE CONTAINMENT ISOLATION VALVE ON THE SAMPLE LINE FAILED TO CLOSE THE VALVE WOULD NOT CLOSE DUE TO A FAILED MOTOR OPERATOR REPLACED MOTOR

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
SMURSS1	770921 7709211400 771219 771219 H	VALVEX SCB	SFV-53504 774B0404	LLRT WAS BEING PERFORMED AND EXCESSIVE LEAKAGE WAS NOTICED DEGRADATION OF VALVE SEAT WAS CAUSE OF LEAKAGE INSTALLED NEW VALVE SEAT AND RETESTED
SMURSS1	770921 7709211400 771219 771219 H	VALVEX SCB	SFV-53605 774B0405	LLRT WAS BEING PERFORMED AND EXCESSIVE LEAKAGE WAS NOTICED DEGRADATION OF VALVE SEAT WAS CAUSE OF LEAKAGE INSTALLED NEW VALVE SEAT AND RETESTED
SMURSS1	771001 7710280001 771219 771031 D H	VALVOP SFF	SFV-25003-L 774B0406	SEVERE WEAR WAS DISCOVERED IN THE MOTOR OPERATOR CLUTCH ASSEMBLY OF SFV-25003-L UNKNOWN-INVESTIGATION IS IN PROGRESS INSTALLED NEW GEARS AND CLUTCH
SMURSS1	771101 7711010930 771219 771129 H	SUPPORT CBD-01	SS-17 774B0402	DURING SURVEILLANCE INSPECTION, FOUND FLUID ACCUMULATOR FOR SNUBBER DRY A LEAKING O RING WAS THE CAUSE OF THE EMPTY ACCUMULATOR THE ACCUMULATOR WAS REBUILT AND RETURNED TO SERVICE

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
SMURSS1	771116 771117, 1715 771119 771209 H	VALVEX CBD	HV-21515 774B0403	EXCESSIVE LEAKAGE FROM RCS. FOUND LEAKAGE TO BE FROM PACKING GLAND OF HV-21515 UNKNOWN BACKSEATED VALVE TO STOP LEAKAGE
SMURSS1	780521 7805210800 780710 780705 H	VALVEX CBD	HV-21505 783A0358	DURING OPERATION THE PRESSURIZER CODE SAFE TY DEVELOPED LEAKAGE AND THE LEAKAGE CONTI NUED IN SEVERITY UNTIL REPAIR WAS REQUIRED LEAKAGE THRU SEAT OF VALVE POLISHED AND RELAPPED VALVE SEAT
SMURSS1	780521 7805210800 780710 780705 H	VALVEX CBD	PSV-21506 783A0359	DURING OPERATION THE PRESSURIZER CODE SAFE TY DEVELOPED LEAKAGE AND THE LEAKAGE CONTI NUED IN SEVERITY UNTIL REPAIR WAS REQUIRED LEAKAGE THRU SEAT OF VALVE POLISHED AND RELAPPED VALVE SEAT
SMURSS1	780521 7805210800 780710 780705 H	VALVEX CBD	PSV-21507 783A0360	DURING OPERATION THE PRESSURIZER CODE SAFE TY DEVELOPED LEAKAGE AND THE LEAKAGE CONTI NUED IN SEVERITY UNTIL REPAIR WAS REQUIRED LEAKAGE THRU SEAT OF VALVE POLISHED AND RELAPPED VALVE SEAT

FACILITY	EVENT/REPT DATES	COMP/SYS	EQUIPMENT# SEQUENCE#	DESCRIPTION
SMURSS1	780622 7806220300 780629 780628 H	PUMPXX CFC	P261B 782C0181	<p>WHILE IN CSD WITH DHR SYS A IN SERVICE, EXCESSIVE LEAKAGE WAS NOTED FROM THE PUMP SEAL</p> <p>UPON DISASSEMBLY OF THE PUMP SEAL NOTHING UNUSUAL WAS NOTED, CAUSE OF LEAKAGE IS UNKNOWN</p> <p>REPLACED PUMP SEAL</p>
SMURSS1	781024 7810241150 781106 781106 H	GENERA EDA-02	GEA 784B0460	<p>DURING STEADY STATE OPERATION A DIESEL GENERATOR, OPERABILITY OF THE A DIESEL GENERATOR WAS LOST. LOSS WAS DUE TO PROBLEMS WITH THE VOLTAGE REGULATOR.</p> <p>PRIMARY FUSES ON THE CONTROL POWER CIRCUIT FOR THE VOLTAGE REGULATOR HAD FAILED.</p> <p>FUSES WERE REPLACED, THE UNIT TESTED AND RETURNED TO SERVICE.</p>