

THREE MILE ISLAND
REACTOR TRIP REPORT # 2

Date 4/19/78

1. Time 0601

2. Cause of trip.

LOSS OF F.W. WHICH CAUSED THE REACTOR TO TRIP ON HIGH PRESSURE.

3. Plant conditions prior to trip

Dryer Level 15%

Reactor Coolant System Pressure 2155 psig

Flow 582 gpm

Reactor Coolant System Flow 62 %

High Pressure Tank Level 44.80 inches

Pressurizer Level 220 inches H₂O

WT Boron 1437 ppm.

FPD 0

Control Rod Positions (withdrawn)

Group 1 100 %

Group 3 100 %

Group 5 100 %

Group 7 85 %

Group 2 100 %

Group 4 100 %

Group 6 85 %

Group 8 27 %

ACS Stations in Hand

Re Demand, DIAMOND, BOTH F.W. PUMPS, ΔTc, HLD, SGR

4. Evolutions in progress prior to trip.

a) STEADY STATE 15% F.P. PREPARING TO ROLL MAIN TURBINE

b) BLOWING DOWN SUCTION STRAINERS TO COND. & BOOSTER PUMPS

5. Corrective actions to prevent recurrence.

INSTRUCT OPERATORS NOT TO BLOW DOWN SUCTION STRAINERS ON RUNNING PUMPS

6. Time and date next criticality achieved.

1355 4/19/78

H. R. High
Shift Supervisor

James R. Floyd
Supervisor of Operations

POOR ORIGINAL

8002100073