

Georgia Power Inspection - Hatch
Khuckle Section Incident Notes
3-22 & 3-26, 1970

On above dates [REDACTED] J. Varsla
inspected construction in progress at Hatch
[REDACTED] the Principal Inspector and Varsla
the Construction Specialist
Report of Varsla's findings were submitted to
[REDACTED] Supervisor. [REDACTED] stated on 4-6-70 "It's
a good report" and added "We should
consider the Khuckle section incident a
Safety item". Both [REDACTED]
agreed with Varsla that a CDN would
be issued to GPC for failure to comply
with Code requirements - viz: Failure
to notify the Code Inspector, approval of
repair procedure, qualification of the
procedure and the weldors assigned etc
- not to forget, notification to AEC
The following day [REDACTED] asked the
writer to come to his office — I did so
and found two GP upper management
people there Rudy Staffa QA and CW
Hays. Staffa asked "How are you going
to report the khuckle section incident?"
I advised him that we would issue
a Construction Deficiency Notice (CDN)
for the violations of the Boiler Code
Staffa became angry and stated "We are
all aware of the seriousness of the incident"

A.10
E

8002110

527

but since we are going to report
of the buckled section we should not
be cited with a CDH".
Staff was obviously alerted or he
and Hayes would not have come to
AEC offices. I reminded him that
had I not accidentally stumbled upon
the illegal hasty repair it would have
been overlooked. It was an obvious
attempt to conceal a defect and
save money.

I advised Staff that his inspectors
were not familiar with the Boiler Code.
Staff answered "I realize that some
of my people are lacking in experience
but we are doing our best to do a
good job". I countered "you have a
problem" Staff countered "yes",
there are people in the AEC that are
also inexperienced" - looking at his
former sergeant VB Staff was then
called to the phone and without ex-
cusing myself I walked out.
Following day [redacted] showed me
my report which he had excised and
whitewashed. I objected and stated
that I would not sign it. A day later
[redacted] agreed that a CDH would
be sent but that the citation would
state that it was a weakness in CQ QA

I said no, it's a failure to conform
to with the construction requirements,
namely Section VIII of the Boiler Code.

[redacted] became angry and stated

"I'm fed up with all the phone calls from
Georgia Power" I told him that it was his fault
for trying trying to protect Staffa and his
unwillingness to accept my report as written.
I added "Tell em to go to hell"

Later [redacted] advised me that he and
Norris Howard had arrived at a perfect
CDN which they had written on a black
board—it read "A stress relieved sect
ion of the containment which was
damaged was repaired without any
approved procedure necessitating its
removal and subsequent stress reliev
ing" I said, "that's not correct and
added "Welding the stress relieved
knock to the containment is permissa
ble and that we simply quote the
Code no fatigues verbatim. Howard
agreed and erased the board but
expressed the opinion that the CDN
should be written against the GP
Quality Control

[redacted] continued to harass me and
Staffa his attempts to induce me to change
my position. I then asked John Davis to
advise Staffa to discontinue his visits to
my office

Finally [redacted] again threatened me by stating "If you don't cooperate you won't work on any of my sites

SEE MY COMMENTS ON [redacted]
MEMO