



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 2 1979

MEMORANDUM FOR: William Parler, Task Leader, Group 1

FROM: Wayne D. Lanning, Group 1

SUBJECT: ADDITIONAL PRECURSOR EVENT

Reference: Cordle, H. et. al., Technical Report on Beznau Unit
One Incident of August 20, 1974: TG-1 TRIP/REACTOR
TRIP/SAFETY INJECTION ACTUATION, Westinghouse Report
SA/251, September 2, 1974 (Proprietary Information)

The Reference describes an incident at a foreign reactor which is similar to the event at TMI-2 and could have provided some insight into the behavior of the pressurizer level indication resulting from a failed-open relief valve.

A turbine trip on the Beznau reactor followed by failure of the steam dump system to operate resulted in a reactor trip and the opening of the pressurizer relief valves (2). One of these valves subsequently failed to close and the resulting blowdown of the pressurizer resulted in the rupture of the pressurizer relief tank bursting disk. Steam was formed in the RCS hot legs and the pressurizer level was high off-scale for 3 to 5 minutes. The operator isolated the open relief valve, and the transient was mitigated in approximately 10 minutes after turbine trip.

I suggest we determine if this event was reported by Westinghouse to the NRC or to its customers. If not, we should determine what Regulatory requirements are applicable (if any) and make an appropriate recommendation in our report.

Agree
5/2

Wayne D. Lanning
Wayne D. Lanning
Group 1

Thome
Dwell after

cc w/o encl.
Group 1 members

POOR ORIGINAL

1/2

I agree - you or I on first part,

7/3/79
In telephone call with Ken Jordan, he indicated that we had not notified the NRC or its customers concerning this event. We concluded it was not of safety significance. When questioned about multiple failures, he said that they had not considered it from that viewpoint. WDL

8002110695