

Shirley Oliver

- By six minutes into the accident, steam voids could have formed in the reactor. Reading out hot leg temperature and reactor pressure and checking these against a control table will tell you if the temperature is high enough for boiling at the pressure in question (saturation). The operators were trained to avoid a solid pressurizer and appeared to assume that high pressurizer level meant that the core was covered. They did not appear to worry about saturation but were about pressurizer level. Does training } address saturation conditions or only } avoidance of a solid pressurizer? } A<sup>O</sup>  
C<sup>O</sup>  
S<sup>O</sup>?
- After the steam generator leaked dry due to the closed check valves (EUV 12 A & B), the operators re-established flow and brought the SG levels back to low limits (30 min). They did not start feeding the A generator up to operating range until about 112 minutes. During this time, not much heat was transferred from the reactor to the secondary system. Is there some training program element that would tell the operators to keep SG levels in the start-up range during an emergency?

800219Q615

POOR ORIGINAL

**POOR ORIGINAL**

• a form of language change

quarantine or removal

Translators' preface

homework - assignment

Additional notes

Opposite surgery

most confident

Syphilis and congenital - effects

Course + learning output - questions for this class? (not just NRE/NRE exams)

such underground as a refuge

" " " Many animals were present at

membership comes from current members and new members

Simulafix - mit dem Leben fertig

~~an upgrade from the original~~

of numbered parts of original

2 ways to do it

Tricholepidium adspersum (Möller)

the same time

Urgent and immediate present represent

H. D.

Referring to about 6 minutes into the accident:

What is there in the training program that prepares the CBO to recognize ~~abnormal~~ conditions? And, what actions should the CBO take?

Referring to the 26 minute point on the time line:

What are the CBO's trained to do when the pressure is too high and the temperature goes low?  
TRAINING & PROCEDURES SAY TO COOL DOWN  
at 30 inches. Could higher levels promote  
heat transfer from primary?

Referring to the 80 minute point on the time line:

EMERGENCY TEMPS at 283, 285 were  
NOT RECOGNIZED AS INDICATING EXPLOSION.  
ARE THE CBO'S TRAINED TO RECOOL THIS  
1000 gpm shaft leak - did training cover this open experience?

Referring to the 101 minute point:

TRAINING & PROCEDURES SAY TO SHUT off  
RC PUMPS, largely BASED ON INFORMATION  
SINCE THE ACCIDENTS HAVE TRAINING &  
PROCEDURES CHANGED? & IF SO, HOW?

How has the basic training program changed, ie  
how does the current program differ from  
the training received by the operators who were  
on duty / at the time of the accident?

**POOR ORIGINAL**