

Washington Public Power Supply System A JOINT OPERATING AGENCY

3000 GEO. WASHINGTON WAY

RICHLAND, WASHINGTON 99352 PHONE (509) 375-5000

February 11, 1980 G01-80-66

Docket Nos. 50-460 and 50-513

Mr. R. H. Engelken, Director U.S. Nuclear Regulatory Commission Suite 202, Walnut Creek Plaza 1990 N. California Boulevard Walnut Creek, California 94596

SUBJECT: WPPSS NUCLEAR PROJECT NOS. 1 & 4

IE BULLETIN 79-25, "FAILURES OF WESTING-HOUSE BFD RELAYS IN SAFETY-RELATED SYSTEMS"

Dear Mr. Engelken:

The following is a response to the subject IE Bulletin:

At the present, WNP-1/4 is neither using nor intending to use BFD relays in their design. UE&C, the Architect Engineer for the projects, is completing a review to see if any Class IE contracts contain Westinghouse BFD relays. Completion of the review is scheduled for the end of February 1980.

Very truly yours,

It Renberger

D. L. RENBERGER ASSISTANT DIRECTOR TECHNOLOGY

DLR: FJ: crw

cc: U. S. Nuclear Regulatory Commission Office of Inspection & Enforcement Division of Reactor Operations Washington, D.C. 20555

> 8003 280090 80-09 00