

Unit 3

LICENSEE EVENT REPORT

Report No. 3-80-8/1T-0

CONTROL BLOCK: [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[1] [1] [P] [A] [P] [B] [S] [3] [2] [0] [0] [-] [0] [0] [0] [0] [-] [0] [0] [3] [4] [1] [1] [1] [1] [4] [] [] [5]
8 9 14 15 25 26 30 37 38

REPORT SOURCE [L] [6] [0] [5] [0] [-] [0] [2] [7] [8] [7] [0] [3] [0] [5] [8] [0] [1] [0] [3] [1] [9] [8] [0] [9]
60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0] [2] While at power, E334 Load Center was shed automatically due to loss of
[0] [3] Unit 3 startup source but failed to recover automatically. Failure was
[0] [4] observed by loss of power to 'A' core spray system valves. The 'A'
[0] [5] LPCI system had been declared inoperable at the time (LER 3-80-03/3L)
[0] [6] E334 breaker was immediately reclosed from the control room. 'A' core
[0] [7] spray system valves were without power for less than 2 minutes. The 'B'
[0] [8] core spray and 'B' LPCI systems were operable during this event.

SYSTEM CODE [E] [B] (11) CAUSE CODE [E] (12) CAUSE SUBCODE [B] (13) COMPONENT CODE [R] [E] [L] [A] [Y] [X] (14) COMP. SUBCODE [H] (15) VALVE SUBCODE [Z] (16)
LER/RO REPORT NUMBER [8] [0] (17) SEQUENTIAL REPORT NO. [0] [0] [8] (24) OCCURRENCE CODE [] (27) REPORT TYPE [] (30) REVISION NO. [0] (32)
ACTION TAKEN [A] (18) FUTURE ACTION [Z] (19) EFFECT ON PLANT [Z] (20) SHUTDOWN METHOD [Z] (21) HOURS [0] [0] [0] [0] (22) ATTACHMENT SUBMITTED [Y] (23) NPRD-4 FOHM SUB. [Y] (24) PRIME COMP. SUPPLIER [A] (25) COMPONENT MANUFACTURER [A] [1] [0] [9] (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1] [0] Agastat time delay relay, Model 7012PC, did not pick up on restoration
[1] [1] of 4KV power which prevented the E334 breaker from reclosing. The relay
[1] [2] was replaced and tested. Previous occurrence on 12/20/77 LER 3-77-62/1T.

FACILITY STATUS [E] (28) % POWER [1] [0] [0] (29) OTHER STATUS [NA] (30) METHOD OF DISCOVERY [A] (31) DISCOVERY DESCRIPTION [Alarm Annunciator] (32)

ACTIVITY CONTENT [Z] (33) RELEASED OF RELEASE [Z] (34) AMOUNT OF ACTIVITY [NA] (35) LOCATION OF RELEASE [NA] (36)

PERSONNEL EXPOSURES NUMBER [0] [0] [0] (37) TYPE [Z] (38) DESCRIPTION [NA] (39)

PERSONNEL INJURIES NUMBER [0] [0] [0] (40) DESCRIPTION [NA] (41)

LOSS OF OR DAMAGE TO FACILITY TYPE [Z] (42) DESCRIPTION [NA] (43)

PUBLICITY ISSUED DESCRIPTION [N] (44) (NA) (45)

8008280435

M. J. Cooney

NAME OF PREPARER

(215) 841-5020