

TEKHA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 6, 1980

Docket No. 50-206

Mr. R. Dietch
Vice President
Nuclear Engineering and Operations
Southern California Edison Company
2244 Walnut Grove Avenue
Post Office Box 800
Rosemead, California 91770

Dear Mr. Dietch:

RE: ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 1

Reference 1: Guidelines for evaluating environmental qualification of Class 1E Electrical Equipment in operating reactors - Enclosure 1 to NRC letter to licensees, dated February 15, 1980.

Reference 2: Guidelines for identification of that safety equipment of SEP operating reactors for which environmental qualification is to be addressed - Enclosure 2 to NRC letter to licensees dated February 15, 1980.

In our meeting of February 21, 1980 regarding the subject program, we indicated that an accelerated review schedule was being developed for this program. The schedule is attached as Enclosure 1, which includes the required date for your submittal showing conformance to the qualification guidelines of reference 1.

The information to be provided in your submittal, as required by references 1 and 2, is summarized in Enclosure 2. Where you have previously submitted some of the required information, it is sufficient to incorporate information already on the docket by specific reference. It is not necessary to resubmit. However, an orderly organization of the information should be maintained. For example, if any previously submitted table is changed, revised pages should be submitted.

Enclosure 1 does not show submittal dates for Palisades and Oyster Creek, since the scheduled site visits for these plants precede any practical submittal date. Material provided for these two plants will be upgraded to the level of other plant submittals through a question-and-answer process.

8004020 013


Mr. R. Dietch

- 2 -

March 6, 1980

With respect to containment environmental conditions and systems required for accident mitigation we will request additional information, some of it prior to the dates listed in the enclosure, and provide some clarification of the guidelines.

Sincerely,

for 
Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosures:
As stated

March 6, 1980

cc w/enclosures:
Charles R. Kocher, Assistant
General Counsel
Southern California Edison Company
Post Office Box 800
Rosemead, California 91770

David R. Pigott
Samuel B. Casey
Chickering & Gregory
Three Embarcadero Center
Twenty-Third Floor
San Francisco, California 94111

Jack E. Thomas
Harry B. Stoehr
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92112

Resident Inspector
c/o U. S. NRC
P. O. Box 3550
San Onofre, California 92672

Mission Viejo Branch Library
24851 Chrisanta Drive
Mission Viejo, California 92676

Mayor
City of San Clemente
San Clemente, California 92672

Chairman
Board of Supervisors
County of San Diego
San Diego, California 92101

California Department of Health
ATTN: Chief, Environmental
Radiation Control Unit
Radiological Health Section
714 P Street, Room 498
Sacramento, California 95814

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection
Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Region IX Office
ATTN: EIS COORDINATOR
215 Fremont Street
San Francisco, California 94111

K M C, Inc.
ATTN: Richard E. Schaffstall
1747 Pennsylvania Avenue, N. W.
Suite 1050
Washington, D. C. 20006

SEP QUALIFICATION PROGRAM SCHEDULE

<u>Plant</u>	<u>Licensee Submittal Date</u>	<u>Site Visit (week of)</u>	<u>Consultant Final Report</u>
Palisades	Currently under review	1/21	6/30
Oyster Creek	Currently under review	3/10	7/21
GINNA	4/25	5/5	8/4
Zion 2	5/1	5/19*	8/11
Indian Pt. 3	5/1	6/2	8/18
Zion 1	5/1	6/9	8/11
Indian Pt. 2	5/1	6/16	9/2
Millstone 1	6/2	6/23	9/8
Haddam Neck	6/2	7/7	9/15
Dresden 2	6/2	7/14	9/22
San Onofre	6/2	7/21	9/29
Dresden 1	6/2	7/28	10/6
Yankee Rowe	6/2	8/4	10/14
LaCrosse	7/1	8/11	10/20
Big Rock Point	7/1	8/18	10/27

*Effort will be made to perform a significant portion of the Zion 1 site evaluation at this time.

SEP QUALIFICATION PROGRAM SUBMITTAL CONTENT

1. The emergency procedures and list of safety-related systems addressed in reference 2.
2. The definition of and basis for the hostile service conditions both inside and outside containment addressed in reference 1 section 4.0, Service Conditions.
3. The identification and justification of equipment considered qualified by experience in accordance with reference 1 section 4.3.3, Areas Normally Maintained at Room Conditions.
4. The tabulation of safety-related equipment located in a hostile environment, with identification of the service conditions and qualification testing for each, in the format used for either SEP Topic III-12 or IE Bulletin 79-01B submittals.
5. The list of equipment in the tabulation of item 4 that is not qualified in accordance with the specific requirements of reference 1, together with justification for the deviations from the guidelines.

Reference 1: Guidelines for evaluating environmental qualification of Class 1E Electrical Equipment in operating reactors.

Reference 2: Guidelines for identification of that safety equipment of SEP operating reactors for which environmental qualification is to be addressed.