



FORM EG&G-398
(Rev. 12-78)

INTERIM REPORT

Accession No _____

Report No. EGG-EA-5092

Contract Program or Project Title: LER Failure Rate Analysis Program

Subject of this Document: "Data Summaries of Licensee Event Reports of Diesel Generators at U.S. Commercial Nuclear Power Plants from January 1, 1976 to December 31, 1978"

Type of Document: Data Summary Report

Author(s): J. P. Poloski, W. H. Sullivan

Date of Document: February 1980

Responsible NRC Individual and NRC Office or Division: W. E. Vesely, Probabilistic Analysis

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

EG&G Idaho, Inc.
Idaho Falls, Idaho 83401

Ray Rose
for H. P. Pearson, Supervisor
Information Processing

Prepared for the
U.S. Nuclear Regulatory Commission
and the U.S. Department of Energy
Idaho Operations Office
Under contract No. EY-76-C-07-1570
NRC FIN No.

A6276

INTERIM REPORT

NRC Research and Technical
Assistance Report

PDR
8004020142


February 1980

DATA SUMMARIES OF LICENSEE EVENT REPORTS OF DIESEL
GENERATORS AT U.S. COMMERCIAL NUCLEAR POWER PLANTS
FROM JANUARY 1, 1976 TO DECEMBER 31, 1978

John P. Poloski
Walter H. Sullivan

U.S. Department of Energy

Idaho Operations Office • Idaho National Engineering Laboratory



This is an informal report intended for use as a preliminary or working document

NRC Research and Technical
Assistance Report

Prepared for the
U.S. Nuclear Regulatory Commission
Under DOE Contract No. DE-AC07-76ID01570
FIN No. A6276

POOR ORIGINAL



INTERIM REPORT

Accession No. _____

Report No. EGG-EA-5092**Contract Program or Project Title:**

LER Failure Rate Analysis Program

Subject of this Document:Extraction of Diesel-Generator Reliability Data from Licensee Event Reports (LERs)
for Use in Risk Assessments**Type of Document:**

Data Summary Report

Author(s):John P. Poloski
Walter H. Sullivan**Date of Document:**

February 1980

Responsible NRC Individual and NRC Office or Division:

William E. Vesely, Probabilistic Analysis Staff, Nuclear Regulatory Research

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

EG&G Idaho, Inc.
Idaho Falls, Idaho 83415Prepared for the
U.S. Nuclear Regulatory Commission
Washington, D.C.
Under DOE Contract No. DE-AC07-76ID01570
NRC FIN No. A6276**INTERIM REPORT**

ABSTRACT

We present data summaries of Licensee Event Reports (LERs) of diesel generators at U.S. commercial nuclear power plants, from January 1, 1976 to December 31, 1978. We classified the events contained in the LERs as failures and nonfailures. We further classified the events according to failure mode, failure mechanism, common cause, recurring, and various other classifications useful in risk assessment. The events reported in the LERs that we classified as failures, were used to estimate gross standby, operating, and demand failure rates, in units of failures per hour and failures per demand, for the diesel generators. Explanation and summary tables of all classifications and estimations are provided.

FOREWORD

This report is one in a series summarizing the statistics of Licensee Event Reports (LERs) as recorded by the U.S. Nuclear Regulatory Commission. The goal of the report is twofold: (a) to summarize the data for risk and statistical analyses, and (b) to obtain gross constant failure rate estimations and gross categorizations of the failures.

Because subjective judgments had to be made regarding population sizes and pertinence of recorded events, and because some component failures may not be recorded in the LERs, the component failure rates estimated in this report should be interpreted as being only tentative gross indicators of the true failure rates. The analyst himself must validate the applicability of the LER-derived failure rates for his own particular use. Furthermore, because LER reporting requirements can differ from plant to plant, comparisons of plant-to-plant failure rates should be interpreted with care: a higher failure rate may simply be due to stricter reporting requirements. As more data are collected and more analyses are performed in the future, improved failure rate estimations will be produced.

The failure rates given in the report are only one of many kinds of information presented. The tables and discussions give important information on failure classifications, according to failure modes, failure causes, and systems affected. Gross time trends are examined. Human errors are identified as are common-cause failures and recurring failures. Each LER analyzed is presented in a useful, summarized form, and all evaluations are presented such that you can modify the authors' calculations or perform your own evaluations if you so desire.

William E. Vesely
Project Manager
November 16, 1979

ACKNOWLEDGMENTS

We wish to express our sincere appreciation to the following persons for their assistance in the preparation of this report:

D. R. Pack for his editing skills used in the final revision of this report.

J. A. Johnston for her timely efforts in the word processing and text composition of this report.

CONTENTS

ABSTRACT	11
FOREWORD	111
ACKNOWLEDGMENTS	1V
INTRODUCTION	1
DESCRIPTION OF THE LER ANALYSIS AND EVALUATION METHODOLOGY	3
Component Definition	3
Assumptions and Definitions	3
Failure Mode	3
Failure Mechanisms	4
Type of Event	5
Event Date	6
Manufacturer/kW Rating	6
Subsystems	6
Failure Classification	6
Method of Discovery	7
Repair Time	7
Data Collection	8
Time	8
Demands	10
Populations	11
Failures	13
LER Rate Estimations	13
SUMMARY OF RESULTS	15
Failure Modes	17
Does Not Start	19
Does Not Continue to Run	21
Unavailable/Nonfailure	21
Failure Mechanisms	23
Unknown	26
Human Error	26
Procedural Discrepancy	26
Foreign Material Contamination	27
Subsystem	27

Type of Event	30
Common Cause and Recurring Common Cause	30
Recurring	33
Command Faults and Recurring Command Faults	34
Failure Classification	34
Repair Time	35
Method of Discovery	39
Manufacturer/kW Rating	41
LER Rates	50
Does Not Start	52
Does Not Continue to Run	52
Does Not Operate	53
Scatter Plots	53
NSSS Vendor Rates	79
Yearly Failure Summaries	81
Plant Data	85
APPENDIX A – DISCUSSION OF THE CAUSES OF VARIATIONS IN LER REPORTING	91
APPENDIX B – ONE-LINE LER CODING SCHEME	95
APPENDIX C – LER RATE ESTIMATIONS	111
APPENDIX D – FACILITY OPERATING LICENSES ISSUED WITH STANDARD TECHNICAL SPECIFICATIONS	117
APPENDIX E – DIESEL-GENERATOR EVENT DATA FILE	121
APPENDIX F – DIESEL-GENERATOR EVENTS CLASSIFIED AS DOES NOT START FAILURES	147
APPENDIX G – DIESEL-GENERATOR EVENTS CLASSIFIED AS DOES NOT CONTINUE TO RUN FAILURES	161
APPENDIX H – DIESEL-GENERATOR EVENTS CLASSIFIED AS UNAVAILABLE/NONFAILURE	171
APPENDIX I – DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY FAILURE MECHANISM	181

APPENDIX J – DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY SUBSYSTEM	205
APPENDIX K – DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY TYPE OF EVENT	227
APPENDIX L – DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY FAILURE CLASSIFICATION	241
APPENDIX M – DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY REPAIR-TIME INTERVAL	261
APPENDIX N – DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY MANUFACTURER/KW RATING	283
APPENDIX O – RESULTS OF THE DIESEL-GENERATOR, DOES NOT START, FAILURE RATE ESTIMATIONS	309
APPENDIX P – RESULTS OF THE DIESEL-GENERATOR, DOES NOT CONTINUE TO RUN, FAILURE RATE ESTIMATIONS	343
APPENDIX Q – RESULTS OF THE DIESEL-GENERATOR, DOES NOT OPERATE, FAILURE RATE ESTIMATIONS	377

FIGURES

1a. Demand failure rate estimates (failures per demand) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Start, assuming weekly testing	55
1b. Demand failure rate estimates (failures per demand) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Start, assuming weekly testing	56
1c. Demand failure rate estimates (failures per demand) of diesel generators of Westinghouse plants for the failure mode, Does Not Start, assuming weekly testing	57
1d. Demand failure rate estimates (failures per demand) of diesel generators of General Electric plants for the failure mode, Does Not Start, assuming weekly testing	58
2a. Demand failure rate estimates (failures per demand) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Start, assuming monthly testing	59
2b. Demand failure rate estimates (failures per demand) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Start, assuming monthly testing	60
2c. Demand failure rate estimates (failures per demand) of diesel generators of Westinghouse plants for the failure mode, Does Not Start, assuming monthly testing	61

2d.	Demand failure rate estimates (failures per demand) of diesel generators of General Electric plants for the failure mode, Does Not Start, assuming monthly testing	62
3a.	Operating failure rate estimates (failures per hour) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Continue to Run, assuming weekly testing	63
3b.	Operating failure rate estimates (failures per hour) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Continue to Run, assuming weekly testing	64
3c.	Operating failure rate estimates (failures per hour) of diesel generators of Westinghouse plants for the failure mode, Does Not Continue to Run, assuming weekly testing	65
3d.	Operating failure rate estimates (failures per hour) of diesel generators of General Electric plants for the failure mode, Does Not Continue to Run, assuming weekly testing	66
4a.	Operating failure rate estimates (failures per hour) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Continue to Run, assuming monthly testing	67
4b.	Operating failure rate estimates (failures per hour) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Continue to Run, assuming monthly testing	68
4c.	Operating failure rate estimates (failures per hour) of diesel generators of Westinghouse plants for the failure mode, Does Not Continue to Run, assuming monthly testing	69
4d.	Operating failure rate estimates (failures per hour) of diesel generators of General Electric plants for the failure mode, Does Not Continue to Run, assuming monthly testing	70
5a.	Demand failure rate estimates (failures per demand) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Operate, assuming weekly testing	71
5b.	Demand failure rate estimates (failures per demand) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Operate, assuming weekly testing	72

5c.	Demand failure rate estimates (failures per demand) of diesel generators of Westinghouse plants for the failure mode, Does Not Operate, assuming weekly testing	73
5d.	Demand failure rate estimates (failures per demand) of diesel generators of General Electric plants for the failure mode, Does Not Operate, assuming weekly testing	74
6a.	Demand failure rate estimates (failures per demand) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Operate, assuming monthly testing	75
6b.	Demand failure rate estimates (failures per demand) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Operate, assuming monthly testing	76
6c.	Demand failure rate estimates (failures per demand) of diesel generators of Westinghouse plants for the failure mode, Does Not Operate, assuming monthly testing	77
6d.	Demand failure rate estimates (failures per demand) of diesel generators of General Electric plants for the failure mode, Does Not Operate, assuming monthly testing	78

TABLES

1.	Accounting of LERs Analyzed	17
2.	Summary of Diesel-Generator Events by Failure Mode and Year	18
3.	Summary of the Unavailable/Nonfailure Diesel-Generator Events by Failure Mechanism and Year	23
4.	Summary of Diesel-Generator Failures by Failure Mechanism, Failure Mode, and Year	24
5.	Summary of Diesel-Generator Failures by Subsystem, Failure Mode, and Year	28
6.	Summary of Diesel-Generator Failures by Subsystem and Failure Mechanism	29
7.	Summary of Diesel-Generator Failures by Type of Event and Failure Mode	31
8.	Summary of Diesel-Generator Failures by Type of Event and Failure Mechanism	32
9.	Summary of Diesel Generator Failures by Failure Classification and Failure Mode	34
10.	Summary of Diesel-Generator Failures by Repair Time, Failure Mode, and Year	36

11.	Summary of Diesel-Generator Failures by Subsystem and Repair Time	37
12.	Summary of Diesel-Generator Failures by Failure Mechanism and Repair Time	38
13.	Summary of Diesel-Generator Failures by Method of Discovery and Failure Mode	40
14.	Summary of Diesel-Generator Failures by Manufacturer/kW Rating, Failure Mode, and Year	42
15.	Summary of Diesel-Generator Populations by Manufacturer/kW Rating and Year	43
16.	Summary of Diesel-Generator Failures by Manufacturer/kW Rating and Failure Mechanism	44
17.	Summary of Diesel-Generator Failures by Manufacturer/kW Rating and Subsystem	45
18.	Summary of Diesel-Generator Failures by Manufacturer/kW Rating and Repair Time	46
19.	Summary of Failure Data by Manufacturer/kW Rating and Subsystem	48
20.	Summary of Diesel-Generator Failure Rates by Failure Mode and Testing Interval	51
21.	Summary of Diesel-Generator Failure Rates by NSSS Vendor, Failure Mode, and Testing Interval	80
22.	Summary of Diesel-Generator Failures by Plant and Year	82
23.	Plant Data	86
B-1.	General Plant Information	99

DATA SUMMARIES OF LICENSEE EVENT REPORTS
OF DIESEL GENERATORS AT U.S. COMMERCIAL NUCLEAR POWER PLANTS
FROM JANUARY 1, 1976 TO DECEMBER 31, 1978

INTRODUCTION

In support of the Nuclear Regulatory Commission's (NRC's) data gathering and analysis effort, we selectively analyzed Licensee Event Reports (LERs) of various diesel-generator events that were submitted to the NRC between January 1, 1976 and December 31, 1978. Initially, we obtained all reports in the NRC file with the component code, ENGINES, INTERNAL COMBUSTION, submitted during this period. Subsequently, however, to ensure that all LERs pertaining to diesel generator events were retrieved from the NRC file, a text search for the word "diesel" was conducted on the remaining, unretrieved LERs. We believe that these sorts yielded all of the LERs pertaining to diesel-generator events for the period of January 1, 1976 through December 31, 1978.

We qualitatively evaluated the data reported in these Licensee Event Reports, and coded the pertinent information contained in each LER that described a diesel-generator event (for example, failure mode, failure mechanism, event date) into a one-line description of the event. Each one-line description was then stored in a computer-based data file for future use. The computer has the capability to search, collate, retrieve, update, and display the coded one-line LERs of the file by almost any item of data contained in the original LER, for example, plant, Nuclear Steam Supply System (NSSS) vendor, event date, failure mode, failure mechanism. This capability makes the LER data file a useful tool for obtaining various LER summary statistics for use in further analyses of diesel-generator events.

One type of summarization used for this report was to estimate from the LER data file, LER-based standby, demand, and operating failure rates (or "standby LER rates," "demand LER rates," and "operating LER rates," for short). Specifically, we estimated various standby, demand, and operating LER rates for the diesel generators used by all operating U.S. commercial

nuclear power plants, with the exceptions of Fort St. Vrain, Humboldt Bay, and LaCrosse, which were considered atypical, and Indian Point Unit 1, which has been shut down and defueled for a significant period. We then averaged these estimates to obtain various LER rates for the four NCS vendors considered. Finally, we averaged specific plant failure data to obtain various rates for Pressurized Water Reactors (PWRs), Boiling Water Reactors (BWRs), and for the aggregate population.

LER rates, as well as the one-line LERs, are useful for probabilistic assessment, such as gross risk and reliability evaluations. However, when using the LER rates, the analyst must apply them with caution. Our LER rates are estimates based on information contained in the LERs, and may not represent actual failure rates of nuclear plant, emergency diesel generators. A difference between the actual failure rate and the LER rate may be due to the averaging performed, but also to the various interpretations of the criteria used for LER reporting. In Appendix A, we give a brief explanation of the causes of these variations.

The body of our report has two major parts. First, we describe our LER analysis. Included are the definitions, ground rules, coding schemes, and assumptions we used in carrying out the analysis. Next, we evaluate the data provided by our analysis and summarize the results of the data evaluation. In Appendix A, we explain the causes for the variations in LER reporting. In Appendix B, we describe the LER coding scheme used to encode the original LERs into the data file. In Appendix C, we discuss our methods to estimate the LER failure rates. In Appendix D, we list those plants to which operating licenses with standard technical specifications were issued.

DESCRIPTION OF THE LER ANALYSIS AND EVALUATION METHODOLOGY

In order to analyze and evaluate the data contained in the LERs, we found it was first necessary to define the diesel-generator component in a way that was generally applicable for our use in this evaluation. Once we accomplished this task, we made various assumptions and definitions that were necessary for encoding the applicable LER data. When the data were encoded, we collected pertinent component information and applied the statistical methods necessary for estimating the diesel-generator LER rates.

Component Definition

After considering several references^{1,2,3} and performing a cursory evaluation of the information contained in the available LERs, we decided to define the diesel-generator unit in terms that would generally parallel the accepted industry definitions, as well as encompass the scope of the diesel-generator LERs. For the context of this report, we defined the diesel-generator unit as the diesel engine(s) and attached generator, and their corresponding support systems, up to and including the generator output breaker.

Assumptions and Definitions

In light of this definition, we encoded the appropriate LERs into one-line data records, and stored them in a computer-based file. A detailed explanation of the coding scheme is given in Appendix B. Specific descriptions of the assumptions and definitions used to encode these data are provided below.

Failure Mode

For this report, we identified two diesel-generator failure modes, Does Not Start and Does Not Continue to Run. There are three kinds of diesel-generator failures represented in the Does Not Start failure mode: in the first, a "start" command was given to the standby diesel generator and the unit failed to respond, that is, roll over and "fire"; in the

second, the "start" command was met and the diesel generator "started," that is, began running under its own power, but failed to reach rated speed and voltage in the required time; and in the third, the diesel-generator unit "started" successfully, that is, reached rated speed and voltage in the required time, but failed to achieve the expected load. As you can see, only after the unit had "started"--achieved rated speed and voltage in the required time, and had been loaded to the expected value--did we consider the unit to be running, that is, a successful "start." Due to the limited information available in most of the LERs, we did not differentiate between the automatic and manual start of the diesel-generator sets. When either of these types of start commands resulted in a diesel-generator starting failure, the failure was classified under the general failure mode, Does Not Start. Any diesel-generator failure that occurred after the unit had completed a successful start, as we have here defined, was classified under the general failure mode, Does Not Continue to Run.

When an LER reported an event that involved placing the diesel in an inoperable status, or reported problems with units that were already in an inoperable status, we put these events in the Unavailable/Nonfailure, failure mode category. We do not consider this category as a true diesel-generator failure mode, because no demand was placed on the unit. Only if the demand was made and the unit failed to respond to the demand could a definite failure be counted. No "implied" failures were considered in this report. We also used the Unavailable/Nonfailure category to record other events of interest that were not considered to be diesel-generator failures, such as technical specification violations.

Failure Mechanisms

The failure mechanisms (causes of failure) used in our report are generally the mechanisms reported in the respective LERs, and should be self-explanatory. However, a mechanism reported may or may not be the true, root cause of a failure. The quality of the LERs vary, and an intermediate mechanism may be reported as the cause. A study conducted by Boner and Hanners of the University of Dayton further discusses this problem.⁴

Type of Event

Five types of events were classified: common cause, recurring, recurring common cause, command faults, and recurring command faults. All other events were considered to be random events.

We define common cause failures as the failure of two or more diesel generators resulting from a single causal event (for example, fire, flooding, human error). If an event was recorded as a single diesel-generator failure, and yet we felt that there was potential for a common cause failure, we assumed the event was a common cause candidate and we coded it as a common cause failure.

When we determined that the same diesel generator was reported to have failed two or more times, each of these events was coded as a recurring failure.

If the same common cause failure or the same common cause candidate was reported more than one time as a result of the same cause, we coded this event as a recurring common cause event.

We classified events as command faults when there was not an actual physical failure of the diesel-generator unit, but, due to inputs (or lack of inputs) from other components external to the unit, the diesel generators failed to function as expected. This failure could be the result of some other failed component, human error, or, as in some cases, an environmental condition. A command fault does not involve actual diesel-generator failure. For instance, if a diesel generator were commanded to start but failed to do so because the fuel day tank was empty as a result of an improper valve lineup, we did not consider this a diesel-generator failure in itself, because, barring other unforeseen circumstances, the diesel would have operated satisfactorily if fuel had been available. However, since the diesel generator does fail to function, given a demand and the existence of a command fault, these events were included in our failure rate estimations, and were encoded under the appropriate failure mode.

Recurring command faults, of course, are command faults that involve the same diesel-generator unit, and occur two or more times.

Event Date

Our data field, FAIL DATE, corresponds to the event date reported in the LER. But the event date is not necessarily the date of occurrence. Though this is ostensibly the date of occurrence--and in most cases it probably is--there could be instances when the component had been in a failed state for some time before discovery, and the event date will actually correspond to the date of failure discovery, not occurrence. For our purposes, we assumed that the event date always corresponds to the date of component failure.

Manufacturer/kW Rating

The diesel-generator manufacturer and kW rating were usually not available in the LERs. However, we felt that this information would be useful for comparison to the AEC study⁵ and the University of Dayton study⁶, among others. So, we consulted the respective plant Final Safety Analysis Reports (FSARs), the AEC study, and the questionnaires used in the University of Dayton study. The information from these sources was combined to form our list of manufacturers and kW ratings.

Subsystems

The diesel-generator-unit support systems, or subsystems, were chosen to encompass the scope of the diesel-generator LERs, and to parallel the industry's definitions of diesel-generator support systems.^{2,3,7,8}

Failure Classification

In our attempt to extract as much additional, significant information as possible from an original LER, we analyzed each diesel-generator failure to determine if the failure was related to the exposure time or to the actual demand. As the standby time or running time increases, the chance

of a time-related failure increases. The chance of a demand-related failure increases as the demands or cycling of the component increases, not directly as the time increases. For example, a diesel generator that failed by reason of the failure mechanism, Corrosion/Erosion, would be classified as a "time related" failure. But a diesel-generator failure that resulted from a jammed air-start motor pinion gear, would be considered a "demand related" failure. We used the classification, Unknown, for any failure that could not be specifically classified.

For the most part, we subjectively analyzed each event to determine its Failure Classification. Specific Failure Classification information was seldom available in the LERs. Consequently, an analyst may find it difficult to arrive at the same classifications as we did for some events. Again, we emphasize that our classifications are largely subjective and care should be exercised in their use.

Method of Discovery

We also attempted to classify the failures according to the activity taking place when the event occurred or was discovered. Unlike the Failure Classification discussed above, this information was usually available in the LERs and very few subjective decisions about the appropriate discovery category were necessary.

Repair Time

Finally, we attempted to classify each event by the duration necessary to repair the unit and restore it to standby status. Some of the more recent LERs provided this information. Unfortunately, the majority of the LERs did not provide this information, and, again, we were required to make subjective decisions, based on our experience, about the length of time necessary to effect the appropriate repairs.

We put the repair times into intervals to simplify the estimating technique and to increase the accuracy of our decisions. We assumed that maintenance practices varied from plant to plant. Consequently, we were

more likely to put the repair time in a correct interval than to provide a correct, "discrete" repair time for each event.

The 8-24 hour interval is probably the only interval that needs some explanation. We chose this longer interval rather than breaking it into several smaller intervals (that is, 8-12, 12-16, 16-20, 20-24) because we assumed that if the repair was going to take longer than one shift, it would take until the following day shift to have the qualified maintenance personnel available to continue repairs--no qualified maintenance personnel would be available on backshifts.

Again, we must emphasize that our repair time classifications are largely subjective and care should be exercised in their use.

Data Collection

For our analysis, the data necessary to estimate diesel-generator LER rates were collected from a variety of sources. It was necessary to determine standby time, operating time, demands, populations, and the number of failures for the diesel generators in each plant in our study. The discussion below gives a summary of each of these data gathering efforts and the assumptions and sources used to arrive at values for each of the data needs mentioned above.

Time

In order to estimate standby hourly LER rates and operating hourly LER rates, it was necessary to know the time the diesel generator was in a standby and an operating condition.

Standby Time. The emergency diesel-generator units are primarily used as the emergency power source in the event of a loss of site power. Consequently, we inferred, the diesel generators would ideally be in a standby condition at all times, regardless of the status of the reactor plant. And we assumed, therefore, that the total calendar time in hours for the time interval in question, that is, 1976, 1977, 1976-1978, etc., would adequately

represent the standby time for the diesel generators. However, in order to eliminate "initial" failures, that is, failures due to initial testing and running of a new unit, standby time was calculated from the date of a plant's initial criticality. So, all plants that went critical before the time interval in question would have the same number of standby hours. All plants that went critical subsequent to the beginning of the time interval in question, would have their standby hours calculated from their corresponding date of initial criticality. Due to the limited scope of this report, we made no attempt to determine individual diesel-generator outages, nor long periods of operation, nor to correct the corresponding standby hours accordingly. We assumed these periods to be insignificant compared to the usual total standby time of the diesel generator. Consequently, we made no attempt to adjust standby time for these periods.

Calendar hours were determined to the 8760-hour year. This is based on a 24-hour day and a 365-day year. Initial criticality dates for all plants were obtained from the NRC "Gray Book."⁹

Operating Time. In order to estimate an operating LER rate, the diesel-generator operating hours should be known. Since it was impractical for us to gather all operating data for each diesel generator unit, we consulted a number of sources¹⁰⁻¹⁴ and assumed that the diesel generators are run for one hour, as part of the test to demonstrate operability. Generally, the requirements for demonstrating diesel-generator operability are as follows:

At least once per 31 days, on a STAGGERED TEST BASIS,^a

1. Verify the fuel level in the day and engine-mounted fuel tanks
2. Verify the fuel level in the fuel storage tank

a. STAGGERED TEST BASIS is defined by dividing the 31-day period by the number of diesel generators at the particular plant.¹⁵

3. Verify that the fuel transfer pump starts and transfers fuel from the storage system to the day and engine-mounted tank
4. Verify that the diesel generator starts from ambient conditions and accelerates satisfactorily.
5. Verify that the diesel generator is synchronized and loaded, and operates for at least 60 minutes
6. Verify that the diesel generator is aligned to provide standby power to the associated emergency buses.

However, some of the same sources also imply that the test interval may be as short as every three days. Boner and Hanners also state that testing frequency for diesel generators varies from weekly to monthly.¹⁶ Due to these variations, we based our total number of operating hours for each diesel generator on both weekly and monthly testing.

Since there was usually no mention of how long a unit operated before tripping or being shut down, the one-hour-run test requirement was assumed for estimating the operating hourly LER rates for the diesel generators. We assumed that the diesel-generator operating failures were experienced before one hour of run time had expired.

We also assumed that there would be 12 operating hours per year for each diesel generator, based on monthly testing, and 52 operating hours per year, based on weekly testing. Again, any plant whose date of criticality falls after the initial date of the time interval in question, had its operating time (hours) adjusted accordingly.

Demands

In order to estimate a demand LER rate, one should know the number of demands placed on the diesel generator during a specific time interval. We

assumed that the diesel-generator demands corresponded to the testing frequency (weekly or monthly) outlined in the above mentioned sources (see References 10-14). Therefore, each diesel generator would be subject to 12 demands per year, based on monthly testing, and 52 demands per year, based on weekly testing. Again, the demands were adjusted according to the initial criticality date of the plant.

We know that the actual number of demands may vary from the assumed number of demands, due to unexpected transients that require the use of the diesel generators (for example, a loss of offsite power), and due to special tests (for example, refueling or an annual) that may be run in addition to the periodic operability tests. We assume that the additional number of demands are relatively small, however, compared to the number resulting from the weekly or monthly tests. And, due to the limited scope of this analysis, we made no further attempt to account for these additional demands.

Populations

Diesel-generator populations for our failure rate estimations were generally unavailable. The Crooks and Vissing¹⁷ and Boner and Hanners (see Reference 6) studies provided some information. However, we determined most of our population information from the individual plant FSARs. A number of different diesel-generator-to-plant configurations exist in the plants considered in this study. For some configurations, where diesel generators are shared between plants, we found it was necessary to make some assumptions about individual plant diesel-generator populations. We identified the following configurations:

No Diesel Generator Units: Of all of the operating U.S. nuclear power plants considered in this study, Oconee Units 1, 2, and 3 are the only plants that do not have emergency diesel generators as their standby source of onsite A.C. power. This station has its own onsite hydroelectric plant, which is its standby source of emergency power; and, consequently, has no need for onsite emergency diesel generators. Therefore, these three plants are not included in our study.

One Plant, One Diesel Generator Unit. Three plants included in our study have this configuration. They are Big Rock Point, Dresden Unit 1, and Millstone Unit 1.

One Plant, Two Diesel Generator Units. The majority of plants included in our study have this configuration.

One Plant, Three Diesel Generator Units. Four plants included in our study have this configuration. They are Indian Point Units 2 and 3, Salem Unit 1, and Yankee Rowe.

One Plant, Four Diesel Generator Units. James A. Fitzpatrick is the only plant with this configuration.

Two Plants, Two Diesel Generator Units. Point Beach Units 1 and 2 are the only units equipped with this configuration. We assume that each plant has a diesel-generator population of two.

Two Plants, Three Diesel Generator Units. Eight plants have this configuration. They are Dresden Units 2 and 3, North Anna Units 1 and 2 (Unit 2 is not used in our study), Quad-Cities Units 1 and 2, and Surry Units 1 and 2. In this configuration, each plant has one diesel generator unit. The remaining diesel generator is shared between plants. Since we could not determine which plant had the responsibility for reporting the LER for the shared diesel generator, we included the shared diesel generator in the population count for each plant.

Two Plants, Four Diesel Generator Units. Brunswick Units 1 and 2, and Peach Bottom Units 2 and 3, have this configuration. All four diesel generators are shared between the two plants. In this case, the oldest units, Brunswick 2 and Peach Bottom 2, were assigned the total population (4) and all plant-specific LER rates were estimated for these plants only. The newer plants, Brunswick Unit 1 and Peach Bottom Unit 3, were then assigned the LER rate estimated for the older plant.

Three Plants, Four Diesel Generator Units. Browns Ferry Units 1, 2, and 3 are the only plants with this configuration. All four diesel generators are shared among three plants. Again, the oldest plant, Browns Ferry Unit 1, was assigned the total population (4) and all plant-specific LER rates were estimated for this plant only. Browns Ferry Units 2 and 3 were then given the LER rate estimated for Browns Ferry Unit 1.

Three other unusual arrangements were found in Joseph M. Farley Unit 1, St. Lucie, and Trojan. Joseph M. Farley Units 1 and 2 (Unit 2 is not included in this study) have a total of five diesel generators between them. As far as we could determine, all five diesel generators can be shared between either plant. Consequently, we gave Farley Unit 1 a population of five diesel generators. St. Lucie and Trojan each have two diesel-generator units. However, each diesel-generator unit is driven by tandem diesels. So, in actuality, St. Lucie has four diesels and two generators and Trojan has four diesels and two generators. However, for the purpose of this report, these plants are given a diesel-generator population of two.

Failures

We extracted the number of failures used for estimating the LER rates from the coded one-line LERs stored in the computer-based data file. Not all coded one-line LERs were considered as failures for this study. Only those one-liners categorized as Does Not Start or Does Not Continue to Run events were considered to be failures.

LER Rate Estimations

We estimated diesel-generator failure rates for all operating U.S. nuclear power plants, with the exceptions discussed above (pp. 1-2). Our method for estimating these rates is discussed in Appendix C. We grouped our estimations for each failure mode, or combination of failure modes, as follows:

1. An LER rate for each licensed operating plant
2. An LER rate for each NSSS
3. An LER rate for PWRs and BWRs
4. An overall LER rate based on aggregating the failure data of each licensed operating plant.

All LER rates given in this report are either standby failure rates calculated in units of failures per hour, demand failure rates calculated in units of failures per demand, or operating failure rates calculated in units of failures per hour. The analyst must decide, according to the particular problem being analyzed, which rates are applicable when he uses these LER rates in risk or reliability assessments.

In addition to our LER rate estimations, we also obtained associated chi-square confidence bounds. These confidence bounds apply strictly only when all the components combined have exactly the same failure rate. When components have different failure rates--which is due to individual component variations, different plant environments, and so forth--the confidence bounds will tend to bound only the average of the failure rates combined, and not individual component variations.

SUMMARY OF RESULTS

We received from the NRC, 627 LERs identified as diesel-generator events of the period, January 1, 1976 through December 31, 1978. These LERs were obtained by making two searches of the NRC LER file for diesel-generator events. The first search yielded events that were coded, ENGINES, INTERNAL COMBUSTION. This search resulted in 253 LERs. The second search of the NRC LER file was based on the same period as the first search, January 1, 1976 through December 31, 1978, but a text search of the LER narrative was made for the word "diesel," or any word in the narrative that contained "diesel" as part of the word. This search netted an additional 374 LERs for our study. The second search did not include any LERs that were coded as ENGINES, INTERNAL COMBUSTION. These two searches obtained a total of 627 LERs to be screened for diesel-generator failures. We believe these 627 LERs are all the LERs pertaining to diesel-generator events that have been reported by the U.S. commercial nuclear power plants during the period covered in this study.

These 627 LERs were then screened, and those that were not directly applicable to this analysis were excluded. Examples of inapplicable LERs are those reported prior to a plant's initial criticality date, reports of component failures other than the diesel-generator component (that is, diesel-driven fire pumps, diesel-driven auxiliary feed pumps, etc.), and reports received from atypical plants. For this report, we considered six plants to be atypical. They were Fort St. Vrain (gas-cooled), Humboldt Bay (BWR/1, only 63 MW), LaCrosse (NSSS is Allis-Chalmers), and Oconee 1, 2, and 3 (supplied with a standby source of electrical power from a hydroelectric plant located onsite). Indian Point 1 was also not considered because it had been shut down and defueled for a significant time.

After our screening of the 627 LERs, there were 408 LERs available for analysis. We found LERs in our analysis that reported information describing more than one diesel-generator event. For example, at Salem 1, the 1A and 1B diesel generators were reported as inoperable (LER Control No. 018799) because they failed to reach rated speed on start. In this situation, we made two one-line description entries into the data base, 018799A and

018799B, for the respective diesel-generator, 1A and 1B, failures. Such multiple events resulted in an additional 17 one-line descriptions being inserted into the data base. Thus, after having analyzed the 408 LERs, we had 425 one-line events available for coding. We then coded these into one-line descriptions of the original LER and input them to the computer-based data file for use in our data summarizations. Appendix E is a complete listing of the 425 diesel-generator-event one-liners contained in our data file.

As stated earlier, not all of these one-line descriptions pertained to an actual hardware failure of the diesel-generator unit, but were events that occurred outside the boundaries of the diesel-generator unit, as defined by this report, and prevented the diesel-generator unit from achieving its intended function to supply power to emergency buses. We classified only 18% (53) of these one-line descriptions as command faults or recurring command faults. A significant number of the one-line LERs, 30% (127), were neither failures nor command faults but rather technical specification violations (for example, not completing a test of the diesel-generator unit on time) or events indicating that the diesel generator was declared inoperable because preventive maintenance was to be performed on the unit, or events indicating that the diesel-generator unit was found to be in an inoperable state and no demand was placed on the diesel generator (for example, a person tagged out the wrong starting air pilot valves for a diesel generator at D. C. Cook Unit 1, LER Control No. 021634). One-line descriptions of this type were considered nonfailures for this report. These nonfailures were not used in any of the LER rate estimates, but we will discuss them later because the diesel was placed in an inoperable state by personnel error. Table 1 provides an accounting of the LERs analyzed for this report.

All of the LER rate estimations and data summaries include data for the period January 1, 1976 through December 31, 1978. We chose the starting date of January 1, 1976 for several reasons: more plants began operating with standard technical specifications in 1976, studies were conducted of diesel generators prior to this time by other organizations, and better LER reporting requirements were implemented during this time.

TABLE 1. ACCOUNTING OF LERS ANALYZED

NRC ENGINE, INTERNAL COMBUSTION events	253
NRC events not coded as ENGINE, INTERNAL COMBUSTION but containing the word "diesel"	<u>374</u>
Total LERs available for screening	627
Minus LERs not applicable	<u>-219</u>
Total LERs available for analysis	408
Multiple events contained in a single LER	<u>17</u>
Total one-Line descriptions in data file	425
Minus one-line descriptions of nonfailures	<u>-127</u>
Total one-liners used for LER rate estimations	298

The closing date was chosen in order to cover three full years. To have extended the period into 1979, we believe, would not have allowed us to obtain all of the LERs submitted by the utilities in the additional 1979 period. We base this on the fact that facilities do not have to immediately fill out an LER for a particular event; there exists a "grace" period. Also, when the LER is received by the NRC, it takes some time to be filed. For these reasons, then, only data from January 1, 1976 through December 31, 1978 were used.

We included command faults in all of our LER failure rate estimations. We felt that since the LERs apply to safety system degradation, the LER rates should reflect this by including all events that degrade a diesel generator to a state where it no longer functions properly. All LER rates stated in this report include command faults.

Failure Modes

Table 2 summarizes the 425 one-liners used in this report by mode and year.

TABLE 2. SUMMARY OF DIESEL-GENERATOR EVENTS BY FAILURE MODE AND YEAR

<u>Failure Mode</u>	<u>1976</u>	<u>Percent of Total</u>	<u>1977</u>	<u>Percent of Total</u>	<u>1978</u>	<u>Percent of Total</u>	<u>1976-1978</u>	<u>Percent of 1976-1978 Total</u>
Does Not Start	56	44	71	45	59	42	186	44
Does Not Continue to Run	39	30	39	25	34	24	112	26
Unavailable/Nonfailure	<u>33</u>	26	<u>47</u>	30	<u>47</u>	34	<u>127</u>	30
Total	128		157		140		425	

Does Not Start

Appendix F lists all of the diesel-generator events that were classified as Does Not Start failures.

Remember that the failure mode, Does Not Start, encompasses diesel-generator failures that resulted from the diesel failing to start (physically "rolling over"), failing to reach rated speed and voltage once a start sequence was initiated, and failing to achieve expected loading (kW).

The Does Not Start events, 186 in all, accounted for 44% of the 425 one-liners used in this report. When strictly considering the 298 events used for estimating LER rates, this failure mode accounted for 62% of the events.

Of the 186 Does Not Start failures, four plants, Big Rock Point, Dresden 2, Beaver Valley, and Joseph M. Farley 1, accounted for 32% (59) of these failures. The diesel generator at Big Rock Point was credited with 19 of these 59 failures. A majority of these 19 failures classified as Does Not Start were the failure of the diesel generator to meet its required starting time. These events, as recorded in our 1976-1978 data file, started appearing on 8/5/76 and continued through 2/2/78. During this period, 13 LERs were submitted by Big Rock Point relating to the failure of the diesel generator to meet the required starting time. Causes for these failures, as specified in the LERs, ranged from possible water jacket failure, to possible fuel system failure, possible governor control failure, and possible voltage drop on the starting cables and unknown reasons. In an attempt to correct this problem, the governor was replaced (2/19/76), governor lube oil supply modified (1/10/77), and fuel control valve modified (5/27/77). After all these modifications, the last LER (No. 020575), relating to the starting time not being met, reported the cause as unknown.

The Does Not Start failures (16) submitted by Dresden 2 resulted from low air receiver pressure, overspeed trips, air-start motor mechanical problems, etc. The low air receiver pressure prevented the diesel generator from starting on two different occasions. One reason reported for this low

air pressure was a loose wire at terminal 25A5, while the other occurrence had a ruptured regulator diaphragm reported as the cause. The reported causes for the various overspeed trips at Dresden 2 were possible out-of-adjustment governor compensation (6/30/77), probable out-of-adjustment governor compensation (7/12/77 and 3/8/78), and governor setting found set too high (5/22/78). The air-start motor events described problems such as the air-start motor pinion gear jammed (3/22/77), pinion gear not engaged (8/24/78), and finally, air-start motors engaging for only a few seconds as compared with the normal 15-second air start (12/16/78).

Of the 13 Does Not Start failures reported by Beaver Valley, 9 failures pertained to either the No. 1 or the No. 2 diesel generator output breaker failing to close onto the emergency bus. The remaining failures resulted from moisture in the starting air (5/20/76 and 4/29/77) and the generator failing to flash (7/17/77 and 7/28/78). The generator failing to flash on 7/28/78 was not detected during a test but later, when an actual demand was placed on the unit. The sequence of events that created the demand for the diesel generator was a fault in the station main transformer, resulting in a generator trip, turbine trip, reactor trip, and safety injection, followed in four minutes by a loss of offsite power.

The remaining plant, Joseph M. Farley 1, had 11 failures in the Does Not Start failure mode. Two failures indicate the diesel tripped on overspeed, due to the main air-start valve failing to close completely (8/17/77 and 8/28/77). Corrosion products clogging air-start valves contributed to two more failures at Joseph M. Farley 1 (3/2/78 and 3/8/78). Blown fuses in the motor-operated potentiometer (MOP) and motor-operated transformer (MOT) also resulted in two failures (8/27/78 and 9/5/78) at Joseph M. Farley 1. The remaining five failures had the following reported causes: speed switch failure due to wrong voltage rating (120 volt versus 130 volt), main air-start valve pusher assembly missing, loose coupling, out-of-alignment auxiliary switches in the output breaker, and incorrect installation of a jumper for Unit 1/Unit 2 separation.

Does Not Continue to Run

Appendix G lists the Does Not Continue to Run events.

We define the Does Not Continue to Run failure mode as any failure of an operating diesel generator to supply power to the emergency bus, given that the diesel generator had undergone a successful start (that is, starting, coming up to rated speed and voltage in the required time, closing of the output breaker to electrically connect the diesel generator to the emergency bus, and assuming the expected load).

The 112 Does Not Continue to Run events comprised 26% of the 425 one-liners in our data file. Compared to all of the events that were classified as failures (298 total failures), the Does Not Continue to Run events accounted for 38% of the failure events.

Millstone Unit 2 accounted for 14% (16) of the 112 Does Not Continue to Run failures. Five failures described by this failure mode at Millstone Unit 2 indicated that the 12U diesel generator was shut down because a low-flow, cooling water alarm sounded due to excessive mussel fouling of the diesel-generator heat exchanger (9/22/76, 8/17/77, 9/20/77, 5/8/78, and 12/5/78). The causes of the remaining Does Not Continue to Run failures at Millstone Unit 2 ranged from dirty fuel oil filters, to carbon in the crank-case vent, lack of lubrication, dried leather washers, failed bearings, leakage of lube/fuel oil, and dry starts of the diesel generator.

Unavailable/Nonfailure

Appendix H lists the diesel-generator events in our data file that were classified as Unavailable/Nonfailure.

The failure mode, Unavailable/Nonfailure, is defined as the mode for those events where the diesel generator was in an inoperable state, given that no demand (test or actual) was placed on the diesel generator to detect this state. Had a test or actual demand been experienced by the diesel generator while in this state, an appropriate failure mode, Does Not Start,

or Does Not Continue to Run, would have been assigned to this event mode. But, since no demand was made, no diesel-generator failure could be assumed. Also, the Unavailable/Nonfailure failure mode classifies LERs that indicate surveillance tests that were not performed, and diesel-generator design deficiencies. Even though the Unavailable/Nonfailure events are not considered as failures in the estimation process, we feel that they are important, since problems with the diesel generator existed and are described in these events.

We classified 30% (127) of the 425 diesel-generator one-liners as Unavailable/Nonfailure. Among the 47 plants that reported LERs classified under this failure mode, no plant dominated the 127 one-liners. At Surry 1, three LERs reported the discovery of flooded cylinders in the No. 1 diesel generator (No. 1 cylinder on 5/8/76, No. 19 cylinder on 7/2/76, and No. 7 cylinder on 7/23/76). D. C. Cook Unit 2 submitted an LER (6/15/78) which stated that, due to human error, both diesel generators were placed in a condition of not being capable of auto starting (an operator tagged out the wrong starting air pilot valves, when he was supposed to have tagged out the pilot valves for the diesel generators serving Unit 1). At Browns Ferry Unit 1, the 1C diesel-generator field breaker tripped, rendering the diesel generator inoperable. The field breaker tripped due to overheating caused by an inoperable fan. These are only some of the many events that are classified by the Unavailable/Nonfailure failure mode.

Table 3 summarizes the Unavailable/Nonfailure events by failure mechanism. Human error (personnel operation, personnel maintenance, and personnel testing) was the major mechanism for these events. Thirty-two percent (41 events) were attributed to human error. When design error, fabrication/construction/quality control, and procedural discrepancy are added to human error, these failure mechanisms accounted for 51% (65) of the 127 events classified by this failure mode.

TABLE 3. SUMMARY OF THE UNAVAILABLE/NONFAILURE DIESEL-GENERATOR EVENTS BY FAILURE MECHANISM AND YEAR

<u>Failure Mechanism</u>	<u>1976</u>	<u>1977</u>	<u>1978</u>	<u>Total</u>	<u>Percent of Total</u>
Personnel Operation	3	7	5	15	12
Personnel Maintenance	6	1	5	12	9
Personnel Testing	3	4	7	14	11
Design Errors	1	3	8	12	9
Fabrication/Construction/ Quality Control	--	1	2	3	2
Procedural Discrepancy	5	1	3	9	7
Corrosion/Erosion	1	1	--	2	2
Foreign Material Contamination	1	3	1	5	4
Mechanical/Electrical Control	4	7	8	19	15
Hi/Low Ambient Temperature	3	3	3	9	7
Lube/Fuel/Water/Air Leakage	5	9	5	19	15
Vibration	--	5	--	5	4
Out of Adjustment/Calibration	1	2	--	3	2
Total	33	47	47	127	

Failure Mechanisms

Table 4 summarizes the diesel-generator failure mechanisms by failure mode and time.

In general, the failure mechanisms given in Table 4 are self-explanatory. However, we will discuss the failure mechanisms Unknown, Human Error, Procedural Discrepancy, and Foreign Material Contamination in more detail.

TABLE 4. SUMMARY OF DIESEL-GENERATOR FAILURES BY FAILURE MECHANISM, FAILURE MODE, AND YEAR

Failure Mechanism	Failure Modes								Total	Percent of Total
	Does Not Start				Does Not Continue to Run					
	1976	1977	1978	1976-1978	1976	1977	1978	1976-1978		
Unknown	14	17	12	43	3	2	4	9	52	17
Personnel Operation	2	4	1	7	--	--	2	2	9	3
Personnel Maintenance	5	1	5	11	5	5	1	11	22	7
Personnel Testing	2	--	--	2	--	--	--	--	2	1
Design Error	2	8	1	11	4	3	--	7	18	6
Fabrication/Construction/ Quality Control	1	--	1	2	--	2	1	3	5	2
Procedural Discrepancy	3	2	3	8	1	3	--	4	12	4
Defective Fuel Injector(s)	--	--	--	--	1	1	3	5	5	2
Corrosion/Erosion	1	1	--	2	1	--	--	1	3	1
Foreign Material Contamination	6	9	7	22	10	4	4	18	40	13
Mechanical/Electrical Control	15	18	23	56	6	7	12	25	81	27

TABLE 4. (continued)

Failure Mechanism	Failure Modes								Total	Percent of Total
	Does Not Start				Does Not Continue to Run					
	1976	1977	1978	1976-1978	1976	1977	1978	1976-1978		
Hi/Low Ambient Temperature	--	--	2	2	--	--	1	1	3	1
Lube/Fuel/Water/Air Leakage	1	4	--	5	5	2	3	10	15	5
Vibration	2	4	2	8	3	6	1	10	18	6
Out of Adjustment/Calibration	2	3	2	7	--	4	2	6	13	4
Total	56	71	59	186	39	39	34	112	298	

Appendix I contains a sorted listing of the diesel-generator failures by failure mechanism.

Unknown

The failure mechanism, Unknown, accounted for 17% (52) of the 298 diesel-generator failures. Of these 52 failures, 83% (43) were reported with the diesel-generator failure mode Does Not Start, and 60% (31) were classified as recurring failures.

Human Error

We define human error as any failure resulting from personnel operation, personnel maintenance, or personnel testing. Human error accounted for 11% of the 298 failures. When classifying the failures caused by human error, either as an act of commission or omission, there was approximately a 50% split for each act. Looking at a yearly summary of the diesel-generator failures (14 in 1976, 10 in 1977, and 9 in 1978), it appears that the number of LERs indicating human error as the cause of failure, are declining. It is not known whether this gradual reduction is the result of better administrative practices, better training/maintenance programs, or some other function (such as recording anomalies in LERs).

Procedural Discrepancy

Even though Table 4 indicates that a small percentage of the diesel-generator failures were attributed to procedural discrepancies, we feel that it is important to cite several incidents where inadequate procedures resulted in failures of the diesel generator. The first incident occurred at Millstone 2 on 12/18/76 (LER No. 016755). During a surveillance test on the 13U diesel generator, the bearing-cap capscrews in the No. 3 upper piston connecting rod, sheared. This resulted in ejection of the rod through the upper crankcase cover. The cause description for this failure stated that "the diesel generator probably failed from a series of unlubricated or dry starts. Emergency starting of the diesels under non-emergency conditions have been eliminated." The second incident occurred on 9/20/77

at Kewaunee (LER No. 019171). The LER stated, "While conducting a monthly test run of diesel generator 1A, smoke and a lazy orange flame was observed coming from the turbocharger." The cause description for this event stated that the fire was caused by carbon buildup in the exhaust path through the turbocharger, which was the result of intermittent, short-duration operation of the diesel generator. The diesel generator was eventually run at high load for four hours, at the advice of the manufacturer, to reduce the exhaust residue buildup. As pointed out by Boner and Hanners,¹⁸ excessively long periods of no-load and light-load operation tend to be practiced in nearly all plants. The diesel manufacturers oppose this practice, and in the industry it is considered bad practice.

Foreign Material Contamination

Based on the 298 failures, a summary of this mechanism by failure mode indicates that it was the third most numerous mechanism (13%) contributing to Does Not Start failures, and the second largest mechanism contributing to the Does Not Continue to Run failures. A majority of the Does Not Start failures (25%) were attributed to corrosion deposits in the starting air system. The Does Not Continue to Run failures that were attributed to this failure mechanism referred to sludge, scale, or mussel fouling as the specific cause for the diesel failure. Thirty percent of the Foreign Material Contamination failures occurred in the diesel-generator cooling system.

Subsystem

Appendix J provides a sorted list of the diesel-generator failures by subsystem; Table 5 summarizes those subsystem events by failure mode. Fuel oil, starting, and governor systems comprised 44% of the 298 diesel generator failures. Over half of the diesel-generator failures, attributed to the governor, 28 of 52, were coded as recurring events. Table 6 summarizes the subsystem events by failure mechanism.

TABLE 5. SUMMARY OF DIESEL-GENERATOR FAILURES BY
SUBSYSTEM, FAILURE MODE, AND YEAR

Subsystem	Failure Modes								Total	Percent of Total
	Does Not Start				Does Not Continue to Run					
	1976	1977	1978	1976-1978	1976	1977	1978	1976-1978		
Fuel Oil	5	9	6	20	9	1	6	16	36	12
Lube Oil	1	4	4	9	5	2	2	9	18	6
Starting	15	12	12	39	--	4	1	5	44	15
Cooling	3	6	--	9	4	8	6	18	27	9
Scavenging Air	--	--	--	--	--	5	3	8	8	3
Engine Frame/Internals	3	--	4	7	4	5	2	11	18	6
Governor	10	10	13	33	8	7	4	19	52	17
Exhaust	--	--	--	--	3	--	--	3	3	1
Shutdown	2	6	--	8	--	3	--	3	11	4
Output Breaker	5	9	8	22	--	1	2	3	25	8
Exciter/Voltage Regulator	3	7	5	15	2	2	6	10	25	8
Generator	--	2	1	3	1	1	--	2	5	2
Other/Unknown	9	6	6	21	3	--	2	5	26	9
Total	56	71	59	186	39	39	34	112	298	

TABLE 6. SUMMARY OF DIESEL-GENERATOR

Failure Mechanism	Fuel Oil	Lube Oil	Starting	Cooling	Scavenging Air	Engine Frame/Intake
Unknown	5	--	7	2	2	2
Personnel Operation	1	--	--	1	--	1
Personnel Maintenance	3	4	2	3	--	2
Personnel Testing	--	--	--	--	--	--
Design Error	2	2	--	--	3	1
Fabrication/Construction/ Quality Control	--	--	--	--	1	2
Procedural Discrepancy	2	--	--	--	2	2
Defective Fuel Injector(s)	5	--	--	--	--	--
Corrosion/Erosion	--	--	1	--	--	--
Foreign Material Contamination	6	1	10	12	--	5
Mechanical/Electrical Control	5	5	18	1	--	--
Hi/Low Ambient Temperature	--	--	--	--	--	--
Lube/Fuel/Water/Air Leakage	4	5	1	3	--	--
Vibration	3	--	3	1	--	3
Out of Adjustment/Calibration	--	1	2	4	--	--
Total	36	18	44	27	8	18

OR FAILURES BY SUBSYSTEM AND FAILURE MECHANISM

Subsystem								Total
Externals	Governor	Exhaust	Shutdown	Output Breaker	Exciter/Voltage Regulator	Generator	Other/Unknown	
	8	--	1	5	--	2	18	52
	1	--	1	--	3	--	1	9
	5	--	--	2	1	--	--	22
	--	--	--	1	--	--	1	2
	1	2	--	7	--	--	--	18
	1	--	--	--	--	1	--	5
	1	--	2	1	1	--	1	12
	--	--	--	--	--	--	--	5
	1	--	--	--	1	--	--	3
	4	--	--	--	1	--	1	40
	24	--	2	9	16	1	--	81
	--	--	--	--	--	--	3	3
	1	1	--	--	--	--	--	15
	3	--	2	--	1	1	1	18
	2	--	3	--	1	--	--	13
	52	3	11	25	25	5	26	298

Types of Event

Appendix K provides a sorted list of the diesel-generator events by event type, that is, common cause, recurring, recurring common cause, command faults, and recurring command faults. All other diesel-generator events were considered to be random. Table 7 is a summary of the diesel-generator events by type of event and failure mode. Table 8 is a summary of diesel events by type of event and failure mechanism.

Common Cause and Recurring Common Cause

Diesel-generator events coded as common cause and recurring common cause, accounted for 16% of the 298 events that were considered as failures for this report. Some of the reasons for the common cause events were winter weather, corrosion products clogging air start valves (Foreign Material Contamination), lack of lubrication resulting in binding fuel racks, a rag found in an oil strainer (Personnel Maintenance), water grounding out a cooling-water motor, and leaks in the air-line supply to a master shutdown valve.

Recurring Common Cause events were the result of such things as dirty fuel oil, dirty filters, carbon in crankcase vents (Foreign Material Contamination), lack of lubrication, dried leather washers in booster servomotors, mussel fouling of diesel generator cooling heat exchangers (Foreign Material Contamination), dirty relay contacts (Design Error), and failure of a main air-start valve to fully shut. Of the 26 events classified as recurring common cause, 15 occurred at Millstone Unit 2. And all but two of these failures referred to the 12U diesel generator at Millstone 2. Beaver Valley 1 reported dirty relay contact failures, which we classified as a design error, since a request for a design change for sealed relays was indicated by Beaver Valley in the LERs submitted. Joseph M. Farley Unit 1 reported that failure of the main air-start valve to shut fully, caused the diesel generator to trip on overspeed. Air leaking through the partially-open valve maintained the mechanical booster in the high-rack position, which overrode the governor and caused an overspeed trip of the diesel generator. This occurred four times at Joseph M. Farley 1.

TABLE 7. SUMMARY OF DIESEL-GENERATOR FAILURES BY
TYPE OF EVENT AND FAILURE MODE

<u>Type of Event</u>	<u>Does Not Start</u>		<u>Does Not Continue to Run</u>		<u>Total</u>	
	<u>Failures</u>	<u>Percent</u>	<u>Failures</u>	<u>Percent</u>	<u>Failures</u>	<u>Percent</u>
Common Cause	11	6	11	10	22	7
Recurring	69	37	25	22	94	32
Command Fault	30	16	13	12	43	14
Recurring Common Cause	9	5	17	15	26	9
Recurring Command Fault	3	2	7	6	10	3
Other (i.e., Random)	64	34	39	35	103	35
Total	186		112		298	

TABLE 8. SUMMARY OF DIESEL-GENERATOR FAILURES BY
TYPE OF EVENT AND FAILURE MECHANISM

Failure Mechanism	Random Failure	Recurring Common Cause	Common Cause	Recurring	Command Faults	Recurring Command Faults	Total	Percent of Total
Unknown	21	--	--	29	2	--	52	17
Personnel Operation	1	--	--	1	7	--	9	3
Personnel Maintenance	5	--	3	--	11	3	22	7
Personnel Testing	--	--	--	1	1	--	2	1
Design Error	2	6	2	7	1	--	18	6
Fabrication/Construction/ Quality Control	4	--	1	--	--	--	5	2
Procedural Discrepancy	4	--	1	--	7	--	12	4
Defective Fuel Injector(s)	3	--	--	2	--	--	5	2
Corrosion/Erosion	3	--	--	--	--	--	3	1
Foreign Material Contamination	11	10	6	13	--	--	40	13
Mechanical/Electrical Control	36	7	2	31	5	--	81	27
Hi/Low Ambient Temperature	--	--	2	--	1	--	3	1
Lube/Fuel/Water/Air Leakage	6	2	3	4	--	--	15	5
Vibration	7	1	2	6	2	--	18	6
Out of Adjustment/Calibration	--	--	--	--	6	7	13	4
Total	103	26	22	94	43	10	298	

In the Unavailable/Nonfailure listing of Appendix H, you will also find diesel-generator events classified as common cause. At Peach Bottom 3 (LER No. 018059), an air leak caused the starting air banks to depressurize, making three of the four diesel generators inoperable. Further compounding this situation, the depressurization finally resulted in overloading of the start air compressors. This caused a thermal overload trip of the air compressors, which prevented the air banks from being repressurized to their normal operating pressure.

Recurring

Recurring diesel-generator failures accounted for 44% of the 298 failures (32% for recurring, 9% for recurring common cause, and 3% for recurring command faults). A sequence of recurring events, other than those at Big Rock Point, which we discussed in our Does Not Start, failure mode section, occurred at Surry 1. This sequence of events started on 4/16/76 and ended 7/23/76, three and one-half months later. The first LER (No. 014869) stated that the engine was started with No. 17 piston cylinder flooded with water. The cause description on the LER stated, "Personnel Error: Engine had a crack in No. 17 cylinder head which extended between two exhaust valve seats and into the water jacket. This area of high heat stress probably [our emphasis] caused the crack." Nowhere in the LER was there any indication that the operator was at fault. On 5/8/76, the next LER (No. 014840) reports, "While preparing to start No. 1 DG, water was observed coming out of the air box drain. The cause was a crack in No. 1 cylinder head which extended from the exhaust valve seat to the injector well and through to the water jacket." The next occurrence (LER No. 015521), on 7/2/76, stated that No. 9 cylinder head had a crack. On 7/23/76 (LER No. 015523), No. 7 cylinder head had a crack in it. For all of these events, no cause was listed except the "probable high heat stress area." In an investigation into the "root" causes for diesel generator failures, Boner and Hanners learned that a water temperature control switch mounted on the engine skid assembly failed. Vibration caused the switch to fail, which, in turn, caused the radiator shutters to fall closed, resulting in overheating of the engine.¹⁹

Command Faults and Recurring Command Faults

Again, command faults are events that did not result in an actual physical failure of the diesel-generator unit, but, due to inputs, or the lack of inputs, from other components external to the unit, the diesel generator failed to function as expected. Command faults and recurring command faults accounted for 18% (53) of the 298 failures. Human error accounted for 42% (22) of the command fault and recurring command fault classification. Examples of command faults due to human error were as follows: incorrect valve lineups, failure to reset trips, improper voltage settings prior to paralleling, airbound cooling systems (not vented), and improper adjustment of the governor and various electrical components (for example, pressure switches, and overspeed relays).

Failure Classification

Table 9 is a summary of the failures by failure classification and failure mode. Appendix L is a sorted list of the diesel-generator failures by the three failure classifications: Demand, Time, and Unknown.

TABIF 9. SUMMARY OF DIESEL-GENERATOR FAILURES BY FAILURE CLASSIFICATION AND FAILURE MODE

<u>Failure Classification</u>	<u>Does Not Start</u>		<u>Does Not Continue to Run</u>		<u>Total</u>	
	<u>Failures</u>	<u>Percent</u>	<u>Failures</u>	<u>Percent</u>	<u>Failures</u>	<u>Percent</u>
Demand	95	51	43	38	138	46
Time	53	28	62	55	115	39
Unknown	38	20	7	6	45	15
Total	186		112		298	

As mentioned, we attempted to classify all diesel-generator failures as either "time related" or "demand related"; that is, we asked if the failure was related to exposure time (age) or to the frequency of demand.

As the stand-by time or running time increases, the chance of a time-related failure increases. The chance for a demand-related failure increases as the demands on the component increase, not directly as time increases. Failures due to human errors that occurred during testing or maintenance of the diesel generator were considered to be demand related, since the probability of this kind of failure increases as the frequency of test or maintenance acts increases, and not directly as time increases.

Due to the limited information contained in the LER, our classification method is highly subjective. Therefore, care should be exercised in drawing conclusions from these data.

Repair Time

Table 10 is a summary of diesel-generator failures by failure mode and repair times. Appendix M is a listing of diesel-generator failures sorted by the repair-time intervals.

We created this classification to provide information for risk modeling. That is, given an accident that requires the diesel generators to supply power to the emergency buses, and the diesel generator(s) fails to function as expected, how long would the emergency buses be without power before a diesel generator would become available (be repaired) to supply power to these buses? Again, we note that this classification is mostly determined subjectively and is based on our experience with diesel generators. However, there were LERs that stated exactly how long it took to repair the diesel generator. But the number of these LERs is small, approximately 19% of the 425 one-liners, compared to the number of LERs that did not state how long the repair took.

To provide additional insight into the repair-time classifications, we provide various summaries. Table 11 summarizes the diesel-generator failures by subsystem and repair times. Table 12 summarizes the diesel-generator failures by failure mechanism and repair times.

TABLE 10. SUMMARY OF DIESEL-GENERATOR FAILURES BY REPAIR TIME, FAILURE MODE, AND YEAR

Repair Times	Does Not Start			Total 1976-1978	Percent of Total	Does Not Continue to Run			Total 1976-1978	Percent of Total	Grand Total	Percent Grand Total
	1975	1977	1978			1976	1977	1978				
0 to 1 Hour	14	19	18	51	27	7	4	7	18	16	69	23
1 to 4 Hours	13	21	11	45	24	7	14	10	31	28	76	26
4 to 8 Hours	9	13	18	40	22	11	7	9	27	24	67	22
8 to 24 Hours	7	2	5	14	8	9	5	2	16	14	30	10
Greater Than 24 Hours	3	4	6	13	7	4	9	6	19	17	32	11
Unknown/Not Applicable	10	12	1	23	12	1	--	--	1	1	24	8
Total	56	71	59	186		39	39	34	112		298	

TABLE 11. SUMMARY OF DIESEL-GENERATOR FAILURES BY
SUBSYSTEM AND REPAIR TIME

Subsystem	Repair Time						Total
	0 to 1 Hour	1 to 4 Hours	4 to 8 Hours	8 to 24 Hours	Greater Than 24 Hours	Unknown/ Not Applicable	
Fuel Oil	13	7	6	5	1	4	36
Lube Oil	4	7	4	2	1	--	18
Starting	5	16	12	7	1	3	44
Cooling	3	9	3	4	8	--	27
Scavenging Air	--	1	--	--	7	--	8
Engine Frame/Internals	?	5	1	1	8	--	18
Governor	12	14	19	--	1	6	52
Exhaust	--	--	--	3	--	--	3
Shutdown	3	4	3	1	--	--	11
Output Breaker	8	6	6	2	2	1	25
Exciter/Voltage Regulator	7	3	10	3	2	--	25
Generator	1	2	1	--	--	1	5
Other/Unknown	10	2	2	2	1	9	26
Total	69	76	67	30	32	24	298

TABLE 12. SUMMARY OF DIESEL-GENERATOR FAILURES BY
FAILURE MECHANISM AND REPAIR TIME

Failure Mechanisms	Repair Time						Total
	0 to 1 Hour	1 to 4 Hours	4 to 8 Hours	8 to 24 Hours	Greater Than 24 Hours	Unknown/ Not Applicable	
Unknown	21	2	5	3	3	18	52
Personnel Operation	6	1	1	--	1	--	9
Personnel Maintenance	7	8	3	3	1	--	22
Personnel Testing	--	--	1	--	--	1	2
Design Error	1	7	--	3	5	2	18
Fabrication/Construction/ Quality Control	--	1	1	1	2	--	5
Procedural Discrepancy	7	2	--	--	3	--	12
Defective Fuel Injector(s)	--	1	4	--	--	--	5
Corrosion/Erosion	--	--	1	2	--	--	3
Foreign Material Contamination	6	11	9	6	8	--	40
Mechanical/Electrical Control	16	21	33	5	4	2	81
Hi/Low Ambient Temperature	1	1	--	--	1	--	3
Lube/Fuel/Water/Air Leakage	2	4	1	6	1	1	15
Vibration	2	12	3	--	1	--	18
Out of Adjustment/Calibration	--	5	5	1	2	--	13
Total	69	76	67	30	32	24	298

Method of Discovery

This is a classification of the diesel-generator events by the activity taking place when the failure was detected. Note that the diesel generator could have been in a failed state prior to this activity. Table 13 summarizes the diesel-generator failures by failure mode and Method of Discovery. As Table 13 indicates, 83% of the diesel-generator failures were detected by testing.

TABLE 13. SUMMARY OF DIESEL-GENERATOR FAILURES BY METHOD OF DISCOVERY AND FAILURE MODE

<u>Method of Discovery</u>	<u>Does Not Start</u>		<u>Does Not Continue to Run</u>		<u>Total</u>	
	<u>Failures</u>	<u>Percent</u>	<u>Failures</u>	<u>Percent</u>	<u>Failures</u>	<u>Percent</u>
During Maintenance	5	3	2	2	7	2
During Normal Operation	25	13	16	14	41	14
During Testing	154	83	24	84	248	83
Unknown	2	1	0	--	2	1
Total	186		112		298	

Manufacturer/kW Rating

We also provide data summaries of failures by manufacturer/kW rating. The data are provided so that further analyses of the failures can be done to determine if there exists a correlation between the manufacturer/kW rating and the diesel-generator failures. Note that the manufacturers listed are those that manufacture or package the diesel. The generator is usually built by another manufacturer. Note also that though these are the manufacturers of the diesel, they do not necessarily package the complete diesel-generator unit.

Appendix N is a list of the diesel-generator failures sorted by manufacturer/kW rating. Table 14 summarizes the diesel-generator failures by failure mode, year, and manufacturer/kW rating. Table 15 is a yearly summarization of the diesel-generator population by manufacturer/kW rating. Table 16 is a summarization of the diesel-generator failures by manufacturer/kW rating and failure mechanism. Table 17 summarizes the diesel-generator failures by manufacturer/kW rating and subsystem. Table 18 summarizes the diesel generator failures by repair time and manufacturer/kW rating. And Table 19 provides a summary of all the failure data (demands, operating hours, plant, etc.) by manufacturer/kW rating and subsystem.

TABLE 14. SUMMARY OF DIESEL-GENERATOR FAILURES BY MANUFACTURER

Manufacturer/kW Rating	Does Not Start			Total	Percent of Total	Does Not Continue to Run	
	1976	1977	1978			1976	1977
<u>Alco</u>							
1750 to 1950	--	--	1	1	1	3	--
2500 to 2850	--	2	--	2	1	2	2
<u>Caterpillar</u>							
200 to 400	11	7	1	19	10	2	--
<u>Cooper-Bessemer</u>							
4000 to 4418	2	--	5	7	4	3	4
<u>De Laval</u>							
500 to 1000	--	--	2	2	1	--	--
<u>Fairbanks Morse</u>							
2500 to 2850	15	10	8	33	18	18	15
3000 to 3500	2	9	9	20	11	2	3
4000 to 4418	--	3	5	8	4	--	2
<u>General Motors</u>							
200 to 400	--	1	--	1	1	--	2
500 to 1000	--	--	5	5	3	--	--
2500 to 2850	20	31	19	70	38	6	6
3000 to 3500	2	4	1	7	4	1	2
4000 to 4418	--	1	--	1	1	--	1
<u>Nordberg Manufacturing</u>							
3000 to 3500	3	3	1	7	4	2	2
<u>Worthington</u>							
3000 to 3500	1	--	2	3	2	--	--
Total	56	71	59	186		39	39

FACTURER/kw RATING, FAILURE MODE, AND YEAR

<u>Year</u>	<u>Total</u>	<u>Percent of Total</u>	<u>Grand Total</u>	<u>Population</u>	<u>Percent of Grand Total</u>	<u>Percent of Total Population</u>
--	3	3	4	8	1	6
1	5	4	7	7	2	5
1	3	3	22	1	7	1
5	12	11	19	7	6	5
--	--	--	2	2	1	2
7	40	36	73	21	24	16
4	9	8	29	16	10	13
--	2	2	10	3	3	2
--	2	2	3	3	1	2
--	--	--	5	1	2	1
12	24	21	94	43	32	34
--	3	3	10	6	3	5
--	1	1	2	2	1	2
1	5	4	12	4	4	3
3	3	3	6	4	2	3
<u>34</u>	<u>112</u>		<u>298</u>	<u>128</u>		

TABLE 15. SUMMARY OF DIESEL-GENERATOR POPULATIONS BY MANUFACTURER/KW RATING AND YEAR

<u>Manufacturer/kw Rating</u>	<u>Diesel Generator Population</u>			<u>Percent of Total</u>
	<u>1976</u>	<u>1977</u>	<u>1978</u>	
<u>Alco</u>				
1750 to 1950	8	8	8	6
2500 to 2850	7	7	7	5
<u>Caterpillar</u>				
200 to 400	1	1	1	1
<u>Cooper-Bessemer</u>				
4000 to 4418	7	7	7	5
<u>De Laval</u>				
500 to 1000	2	2	2	2
<u>Fairbanks Morse</u>				
2500 to 2850	13	15	21	16
3000 to 3500	12	14	16	13
4000 to 4418	--	3	3	2
<u>General Motors</u>				
200 to 400	3	3	3	2
500 to 1000	1	1	1	1
2500 to 2850	41	43	43	34
3000 to 3500	6	6	6	5
4000 to 4418	2	2	2	2
<u>Nordberg Manufacturing</u>				
3000 to 3500	4	4	4	3
<u>Worthington</u>				
3000 to 3500	2	2	4	3
Total	109	118	128	

TABLE 16. SUMMARY OF DIESEL-GENERATOR FAILURES BY MANUFACTURER

Manufacturer/ kW Rating	Unknown	Personnel Operation	Personnel Maintenance	Personnel Testing	Design Error	Fabrication/ Construction/ Quality Control	Procedural Discrepancy	Defective Fuel Injector(s)	Corrosion/Erosion
<u>Alco</u>									
1750 to 1950	--	--	2	--	--	--	--	--	--
2500 to 2850	--	1	--	--	3	--	--	--	--
<u>Caterpillar</u>									
200 to 400	12	--	--	1	3	--	--	--	--
<u>Cooper- Bessemer</u>									
4000 to 4418	3	--	1	1	--	--	--	--	1
<u>De Laval</u>									
500 to 1000	--	--	--	--	--	--	1	--	--
<u>Fairbanks Morse</u>									
2500 to 2850	13	2	8	--	2	1	4	3	1
3000 to 3500	4	1	2	--	--	1	3	--	--
4000 to 4418	--	--	1	--	--	--	--	--	--
<u>General Motors</u>									
200 to 400	--	--	--	--	--	--	--	--	--
500 to 1000	--	--	--	--	--	--	--	--	--
2500 to 2850	17	2	7	--	6	2	4	--	--
3000 to 3500	--	2	--	--	2	--	--	--	--
4000 to 4418	1	--	--	--	--	--	--	--	--
<u>Nordberg Manufacturing</u>									
3000 to 3500	1	1	1	--	2	1	--	1	1
<u>Worthington</u>									
3000 to 3500	1	--	--	--	--	--	--	1	--
Total	52	9	22	2	18	5	12	5	3

MANUFACTURER/kw RATING AND FAILURE MECHANISM

Foreign Material Contamination	Mechanical/Electrical Control	Hi/Low Ambient Temperature	Lube/Fuel/Water/Air Leakage	Vibration	Out of Adjustment/Calibration	Total Failures	DG Population	Percent of Total Failures	Percent of DG Population
--	2	--	--	--	--	4	8	1	6
--	2	--	--	1	--	7	7	2	5
2	3	--	1	--	--	22	1	7	1
1	7	--	1	3	1	19	7	6	5
--	1	--	--	--	--	2	2	1	2
14	12	--	5	4	4	73	21	24	16
7	5	--	1	4	1	29	16	10	13
1	8	--	--	--	--	10	3	3	2
2	1	--	--	--	--	3	3	1	2
--	3	2	--	--	--	5	1	2	1
9	29	1	5	5	7	94	43	32	34
3	2	--	1	--	--	10	6	3	5
--	1	--	--	--	--	2	2	1	2
1	2	--	1	--	--	12	4	4	3
--	3	--	--	1	--	6	4	2	3
40	81	3	15	18	13	298	128		

TABLE 17. SUMMARY OF DIESEL-GENERATOR FA

<u>Manufacturer/ kW Rating</u>	<u>Fuel Oil</u>	<u>Lube Oil</u>	<u>Starting</u>	<u>Cooling</u>	<u>Scavenging Air</u>	<u>Engine Frame/ Internals</u>	<u>Governor</u>	<u>Exhaust</u>
<u>Alco</u>								
1750 to 1950	--	--	--	--	--	--	2	--
2500 to 2850	2	--	--	1	1	--	--	2
<u>Caterpillar</u>								
200 to 400	4	--	4	5	--	--	6	--
<u>Cooper- Bessemer</u>								
4000 to 4418	2	2	2	--	--	1	3	--
<u>De Laval</u>								
500 to 1000	2	--	--	--	--	--	--	--
<u>Fairbanks Morse</u>								
2500 to 2850	7	5	4	14	--	8	11	1
3000 to 3500	3	4	1	3	--	7	6	--
4000 to 4418	--	--	6	--	--	--	3	--
<u>General Motors</u>								
200 to 400	--	--	1	2	--	--	--	--
500 to 1000	1	1	1	--	--	--	--	--
2500 to 2850	8	4	21	2	5	2	15	--
3000 to 3500	2	--	--	--	2	--	2	--
4000 to 4418	--	--	--	--	--	--	1	--
<u>Nordberg Manufacturing</u>								
3000 to 3500	3	2	2	--	--	--	2	--
<u>Worthington</u>								
3000 to 3500	2	--	2	--	--	--	1	--
Total	36	18	44	27	8	18	52	3

ILURES BY MANUFACTURER/kW RATING AND SUBSYSTEM

Subsystem								
Shutdown	Output Breaker	Exciter/ Voltage Regulator	Generator	Other/ Unknown	Total Failures	DG Population	Percent of Total Failures	Percent of DG Population
--	1	--	1	--	4	8	1	6
--	--	1	--	--	7	7	2	5
--	1	--	--	2	22	1	7	1
2	1	4	--	2	19	7	6	5
--	--	--	--	--	2	2	1	2
1	4	5	1	12	73	21	24	16
2	1	--	1	1	29	16	10	13
--	1	--	--	--	10	3	3	2
--	--	--	--	--	3	3	1	2
--	--	--	--	2	5	1	2	1
5	13	12	2	5	94	43	32	34
1	1	1	--	1	10	6	3	5
--	--	--	--	1	2	2	1	2
--	2	1	--	--	12	4	4	3
--	--	1	--	--	6	4	2	3
11	25	25	5	26	298	128		

TABLE 18. SUMMARY OF DIESEL-GENERATOR FAILURES BY MANUFACTURER/kW RATING AND REPAIR TIME

<u>Manufacturer/ kW Rating</u>	<u>0 to 1 Hour</u>	<u>1 to 4 Hours</u>	<u>4 to 8 Hours</u>	<u>8 to 24 Hours</u>	<u>Greater Than 24 Hours</u>	<u>Unknown/ Not Applicable</u>	<u>Total</u>	<u>Population</u>	<u>Percent of Total</u>	<u>Percent of Population</u>
<u>Alco</u>										
1750 to 1950	1	1	2	--	--	--	4	8	1	6
2500 to 2850	--	3	1	2	1	--	7	7	2	5
<u>Caterpillar</u>										
200 to 400	1	4	3	--	2	12	22	1	7	1
<u>Cooper- Bessemer</u>										
4000 to 4418	3	6	4	3	2	1	19	7	6	5
<u>De Laval</u>										
500 to 1000	2	--	--	--	--	--	2	2	1	2
<u>Fairbanks Morse</u>										
2500 to 2850	21	13	17	6	12	4	73	21	24	16
3000 to 3500	10	9	8	--	1	1	29	16	10	13
4000 to 4418	--	1	4	3	--	2	10	3	3	2

TABLE 18. (continued)

<u>Manufacturer kW Rating</u>	<u>0 to 1 Hour</u>	<u>1 to 4 Hours</u>	<u>4 to 8 Hours</u>	<u>8 to 24 Hours</u>	<u>Greater Than 24 Hours</u>	<u>Unknown/ Not Applicable</u>	<u>Total</u>	<u>Population</u>	<u>Percent of Total</u>	<u>Percent of Population</u>
<u>General Motors</u>										
200 to 400	--	1	--	2	--	--	3	3	1	2
500 to 1000	1	--	--	1	3	--	5	1	2	4
2500 to 2850	22	28	24	8	9	3	94	43	32	34
3000 to 3500	5	2	1	--	2	--	10	6	3	5
4000 to 4418	--	1	--	--	--	1	2	2	1	2
<u>Nordberg Manufacturing</u>										
3000 to 3500	1	4	2	5	--	--	12	4	4	3
<u>Worthington</u>										
3000 to 3500	2	3	1	--	--	--	6	4	2	3
Total	69	76	67	30	32	24	298	128		

TABLE 19. SUMMARY OF FAILURE DATA BY MANUF

Diesel Generator Manufacturer and Plant Name	Plant Code	Generator kW Rating	Population	Minimum Number of Demands per Component		Minimum Number of Operating Hours per Component		Standby Hours per Component	Fuel Oil System	Lube Oil System	Starting System
				Weekly	Monthly	Weekly	Monthly				
<u>Alco</u>											N O
Indian Point 2	IP2	1750	3	156	36	156	36	26280	--	--	--
Indian Point 3	IP3	1750	3	142	33	142	33	23925	--	--	--
Robert E. Ginna	RG1	1950	2	156	36	156	36	26280	--	--	N O
Falisesades	PA1	2500	2	156	36	156	36	26280	--	--	--
Pilgrim 1	PI1	2600	2	156	36	156	36	26280	2A	--	--
Salem 1	SA1	2600	3	107	25	107	25	17976	(2A)	--	--
(Subtotal)			(15)	(873)	(202)	(873)	(202)	(147021)	(2A)	--	--
<u>Caterpillar</u>									4A	--	4A
Big Rock Point	BP1	200	1	156	36	156	36	26280	4A	--	4A
<u>Cooper-Bessemer</u>									1B	--	--
Cooper Station	CO1	4000	2	156	36	156	36	26280	1B	1A	2A
Zion 1	ZI1	4000	5 ^b	156	36	156	36	26280	--	1B	--
Zion 2	ZI2	4000	(7)	(468)	(108)	(468)	(108)	(78840)	(2B)	(1A,1B)	(2A)
(Subtotal)											
<u>De Laval</u>									2A	--	--
San Onofre 1	SO1	600	2	156	36	156	36	26280	2A	--	--
<u>Fairbanks Morse</u>									--	1B	--
Calvert Cliffs 1	CC1	2500	3 ^b	156	36	156	36	26280	--	--	2A
Calvert Cliffs 2	CC2	2500		108	25	108	25	18264	--	--	--
H. B. Robinson 2	RO2	2500	2	156	36	156	36	26280	2B	--	1A
Joseph M. Farley 1 ^c	JF1	2600	2	72	17	72	17	12192	--	--	N O
Millstone 1	MI1	2664	1	156	36	156	36	26280	1A,3B	2B	--
Millstone 2	MI2	2750	2	156	36	156	36	26280	--	--	N O
North Anna 1	NA1	2750	2	38	9	38	9	6456	--	--	N O
Arkansas Nuclear One 2	AR2	2850	2	4	1	4	1	600	--	--	--
Duane Arnold	DA1	2850	2	156	36	156	36	26280	1B	1B	--
Edwin I. Hatch 1	EN1	2850	5 ^b	155	36	156	36	26280	--	1B	1A
Edwin I. Hatch 2	EN2	2850		26	6	26	6	4296	--	--	--
Crystal River 3	CR3	3000	2	102	24	102	24	17184	1A	1A	--
Prairie Island 1	PR1	3000	2	156	36	156	36	26280	--	--	--
Prairie Island 2	PR2	3000	2	156	36	156	36	26280	--	2A	--
Three Mile Island 1	TI1	3000	2	156	36	156	36	26280	--	--	--
Three Mile Island 2	TI2	3000	2	40	9	40	9	6648	1A	--	1A
Vermont Yankee	VY1	3000	2	156	36	156	36	26280	--	1B	--
Peach Bottom 2	PB2	3250	4 ^b	156	36	156	36	26280	--	--	N O
Peach Bottom 3	PB3	3250		156	36	156	36	26280	--	--	4A,2B
Joseph M. Farley 1 ^c	JF1	4000	3	72	17	72	17	12192	--	--	(3A,6B) (9A,2B)
(Subtotal)			(40)	(2334)	(540)	(2334)	(540)	(393192)	(3A,7B)	(3A,6B)	(9A,2B)
<u>General Motors</u>									--	--	1A
Yankee Rowe	YR1	400	3	156	36	156	36	26280	--	1A	1A
Dresden 1	DR1	500	1	156	36	156	36	26280	1A	1A	4A
Fort Calhoun	FC1	2500	2	156	36	156	36	26280	--	--	--

ACTURER/KW RATING AND SUBSYSTEM

Number and Mode of Failures^a

Cooling System	Scavenging Air System	Engine Frame/Internals	Governor	Exhaust System	Shutdown System	Output Breaker	Exciter/Voltage Regulator	Generator	Other/Unknown	Totals
FAILURES REPORTED			2B							
								1B		3B
FAILURES REPORTED						1A				1A
1B	1B			2B			1B			3B
(1B)	(1B)		(2B)	(2B)		(1A)	(1B)	(1B)		2A,2B
2A,3B			6A							(3A,8B)
		1A				1A			2A	19A,3B
			1B			1A	1B			2A,2B
			2B				1B		2A	5A,3B
		(1A)	(3B)		2B		2B			7B
					(2B)	(1A)	(4B)		(2A)	(7A,12B)
1A,1B		1B								2A
1A,1B						1A	1A	1A	3A,2B	7A,5B
			1B						1A	4A,2B
		1A				1A				3B
FAILURES REPORTED		4B	3A,1B							3A
FAILURES REPORTED										6A,16B
FAILURES REPORTED										
1B		2A	1B	1B						3A,5B
3B		1B	2A				1A,2B			8A,9B
			2A						4A,2B	2A
			2A		1A					6A
			1B						1A	1B
										1B
		1A,2B				1A				3A
1B		1A,2B								2A,2B
2A			3A							2A,4B
FAILURES REPORTED										7A,1B
FAILURES REPORTED		3A						1A		
(A,12B)		(4A,11B)	(16A,4B)	(1B)	(2A,1B)	(5A,1B)	(3A,2B)	(2A)	(9A,4B)	(61A,51B)
2B										8A,2B
										1A,2B
			1B						2A	5A
						1A,2B			1A	6A,3B

Diesel Generator Manufacturer and Plant Name	Plant Code	Generator kW Rating	Population	Minimum Number of Demands per Component		Minimum Number of Operating Hours per Component		Standby Hours per Component	Fuel Oil System
				Weekly	Monthly	Weekly	Monthly		
<u>General Motors (continued)</u>									
Monticello	M01	2500	2	156	36	156	36	26280	--
Maine Yankee	MY1	2500	2	156	36	156	36	26280	1A
Oyster Creek 1	OC1	2500	2	156	36	156	36	26280	--
Turkey Point 3	TU3	2500	2	156	36	156	36	26280	2A,1B
Turkey Point 4	TU4	2500	2	156	36	156	36	26280	
Nine Mile Point 1	NM1	2560	2	156	36	156	36	26280	
Beaver Valley 1	BV1	2600	2	137	32	137	32	23136	1B
Davis-Besse 1	DB1	2600	2	68	16	68	16	11424	--
James A. Fitzpatrick	FP1	2600	4	156	36	156	36	26280	--
Arkansas Nuclear One 1	AR1	2750	2	156	36	156	36	26280	--
Rancho Seco	RS1	2750	2	156	36	156	36	26280	1B
Surry 1	SU1	2750	3 ^b	156	36	156	36	26280	--
Surry 2	SU2	2750		156	36	156	36	26280	
Dresden 2	DR2	2850	3 ^b	156	36	156	36	26280	1B
Dresden 3	DR3	2850		156	36	156	36	26280	--
Haddam Neck	HN1	2850	2	156	36	156	36	26280	1A
Kewaunee	KE1	2850	2	156	36	156	36	26280	--
Point Beach 1	PT1	2850	2	156	36	156	36	26280	--
Point Beach 2	PT2	2850	2	156	36	156	36	26280	
Quad-Cities 1	QC1	2850	3 ^b	156	36	156	36	26280	--
Quad-Cities 2	QC2	2850		156	36	156	36	26280	
Browns Ferry 1	BF1	3500	4 ^b	156	36	156	36	26280	--
Browns Ferry 2	BF2	3500		156	36	156	36	26280	
Browns Ferry 3	BF3	3500		125	28	125	28	20976	--
St. Lucie	SL1	3500	2	140	32	140	32	23592	2A
Trojan	TR1	4418	2	156	36	156	36	26280	--
(Subtotal)			(55)	(4370)	(1008)	(4370)	(1008)	(736128)	(7A,4B)
<u>Nordberg Manufacturing</u>									
Brunswick 1	BR1	3500	4 ^b	116	27	116	27	19512	1B
Brunswick 2	BR2	3500		156	36	156	36	26280	1A,1B
(Subtotal)			(4)	(272)	(63)	(272)	(63)	(45792)	(1A,2B)
<u>Worthington</u>									
Donald C. Cook 1	DC1	3500	2	156	36	156	36	26280	--
Donald C. Cook 2	DC2	3500	2	42	10	42	10	7080	1A,1B
(Subtotal)			(4)	(198)	(46)	(198)	(46)	(33360)	(1A,1B)
(Total)	(63) ^c		(128)	(8827)	(2039)	(8827)	(2039)	(1486893)	(20A,16B)

a. A and B are failure modes. A is Does Not Start; B is Does Not Continue to Run.

b. See Table 23 for explanation.

c. The diesel generators at Joseph M. Farley have two ratings, hence two entries, but the plant is only counted once.

19. (continued)

Number and Mode of Failures ^a												
Tube 11 System	Starting System	Cooling System	Scavenging Air System	Engine Frame/ Internals	Governor	Exhaust System	Shutdown System	Output Breaker	Exciter/ Voltage Regulator	Generator	Other/ Unknown	Totals
--	1A	--	--	--	--	--	--	--	--	--	--	1A
--	--	--	--	--	1A	--	--	--	--	--	--	2A
--	1A	--	--	--	--	--	--	--	2A	--	--	3A
--	--	--	--	--	--	--	--	--	--	--	--	2A,1B
	NO FAILURES REPORTED						NO FAILURES REPORTED					
	NO FAILURES REPORTED						NO FAILURES REPORTED					
1B	2A	--	--	--	--	--	--	9A	2A	1B	--	13A,3B
--	--	--	2B	1A	1A	--	--	--	1A	--	1B	3A,3B
2A	--	--	--	--	1A	--	2A	1B	--	--	--	5A,1B
--	2A	--	1B	--	--	--	--	--	--	--	--	2A,1B
--	1A	--	--	--	1B	--	--	--	--	--	2A	3A,2B
--	--	--	--	1A	--	--	--	--	--	--	--	1A
	NO FAILURES REPORTED						NO FAILURES REPORTED					
--	9A	2B	1B	--	4A	--	2A	1A	1B	--	--	16A,5B
1B	--	--	--	--	3A,2B	--	--	--	1A	--	--	4A,3B
--	--	--	--	--	--	--	--	--	--	--	--	1A
--	--	--	1B	--	1B	--	--	--	--	--	1A	1A,2B
--	--	--	--	--	--	--	1A	2A	--	--	--	3A
	NO FAILURES REPORTED						NO FAILURES REPORTED					
--	1A	--	--	--	--	--	--	--	2A	1A	--	4A
	NO FAILURES REPORTED						NO FAILURES REPORTED					
--	--	--	--	--	1A,1B	--	--	--	--	--	--	1A,1B
	NO FAILURES REPORTED						NO FAILURES REPORTED					
--	--	--	--	--	--	--	--	--	1A	--	--	1A
--	--	--	2B	--	--	--	1A	1A	--	--	1A	5A,2B
--	--	--	--	--	1B	--	--	--	--	--	1A	1A,1B
A,2B)	(23A)	(4B)	(7B)	(2A)	(11A,7B)	--	(6A)	(13A,1B)	(10A,3B)	(1A,1B)	(8A,1B)	(84A,30B)
2A	1A	--	--	--	1B	--	--	1B	--	--	--	3A,3B
--	1A	--	--	--	1B	--	--	1A	1A	--	--	4A,2B
2A)	(2A)	--	--	--	(2B)	--	--	(1A,1B)	(1A)	--	--	(7A,5B)
--	--	--	--	--	--	--	--	--	1A	--	--	1A
--	1A,1B	--	--	--	1B	--	--	--	--	--	--	2A,3B
--	(1A,1B)	--	--	--	(1B)	--	--	--	(1A)	--	--	(3A,3B)
A,9B)	(41A,3B)	(7A,20B)	(8B)	(7A,11B)	(33A,19B)	(3B)	(8A,3B)	(22A,3B)	(15A,10B)	(3A,2B)	(21A,5B)	(186A,112B)

LER Rates

LER rates in this report are based on LER information and classified either as standby failure rates, calculated in units of failures per standby hour; demand failure rates, calculated in units of failures per demand; or as operating failure rates, calculated in units of failures per operating hour. The LER rates are estimated for selected failure modes. The LER rates include both failures and command faults. Command faults were included in the estimation process because LERs generally report safety system degradation; the LER rates should reflect this by including all events that would prevent the diesel generator from supplying emergency power on demand. Again, all LER rates found in this analysis include command faults. Table 20 summarizes the diesel-generator LER rates estimated in this report. WASH-1400²⁰ failure rates for diesel generators (complete plant) were included in this table for comparison purposes only.

Since the diesel-generator operability testing schedules vary throughout the industry, we estimated LER rates based on different test-interval assumptions. Our monthly test-interval assumption is based on technical specification guidelines discussed earlier. The monthly test interval is usually the minimum requirement if a diesel generator demonstrates high reliability. We also estimated the LER rates based on a weekly test interval. This assumption was based on the information contained in Reference 18, which stated that testing frequency varied from weekly to monthly.

The results of all the LER estimations are contained in Appendices O, P, and Q. The plants are grouped by NSSS vendor. The "Final Statistics" section for each estimation contains the averaged NSSS vendor LER rates, averaged PWR (pressurized water reactors) LER rates, and an overall LER rate. Along with the LER rates contained in this "Final Statistics" section, the upper 95% confidence limit and lower 5% confidence limit are given and expressed as a multiple of the LER rate estimate. To obtain the upper 95% chi-square confidence limit, multiply the given LER rate estimate by the upper multiple associated with this estimate. To get the corresponding lower 5% chi-square confidence limit, divide the LER rate estimate by the lower multiple associated with this estimate.

TABLE 20. SUMMARY OF DIESEL-GENERATOR FAILURE RATES BY FAILURE MODE AND TESTING INTERVAL

Failure Mode	LER Rates								WASH-1400 ^a
	Weekly Testing				Monthly Testing				
	1976	1977	1978	1976-1978	1976	1977	1978	1976-1978	
Does Not Start ^b	1E-2/d	1E-2/d	9E-3/d	1E-2/d	4E-2/d	5E-2/d	4E-2/d	4E-2/d	3E-2/d
Does Not Continue to Run ^c	7E-3/hr	6E-3/hr	5E-3/hr	5E-3/hr	3E-2/hr	5E-2/hr	2E-2/hr	3E-2/hr	3E-3/hr
Does Not Start Combined with Does Not Continue to Run				2E-2/d ^b 1E-4/hr ^d				7E-2/d ^b 1E-4/hr ^d	

51

- a. Computation median for diesels (complete plant); see Reference 23.
- b. Demand failure rate.
- c. Operating, hourly failure rate.
- d. Standby, hourly failure rate.

For example:

X.X upper 95% confidence multiple

Y.YE-YY LER rate estimate

Z.Z lower 5% confidence multiple

Multiply X.X times Y.YE-YY to obtain upper 95% confidence limit.

Divide Z.Z into Y.YE-YY for lower 5% confidence limit.

Does Not Start

LER rates for the failure mode Does Not Start were estimated for each year (1976, 1977, and 1978) and for the total period covered in this report (1976 through 1978). The LER rates are estimated in both units of failures per demand and failures per standby hour. Each of the estimations were done with the monthly test interval assumption and then with the weekly test interval assumption. The yearly LER rates were estimated in order to determine if the LER rate was increasing, decreasing, or remaining constant. As shown in Table 20, the Does Not Start LER rate appears to be constant with time in this gross classification. Appendix D lists the results of all the Does Not Start estimations.

Does Not Continue to Run

The Does Not Continue to Run LER rates were also estimated yearly and collectively for the total time period 1976 through 1978. Again, we point out that only diesel-generator failures that resulted after the diesel generator had completed a successful start, that is, starting, coming up to rated speed and voltage, closing of the output breaker to the emergency bus, and assuming expected load, were classified as Does Not Continue to Run failures. Operating LER rates calculated in units of failures per diesel-generator operating time (hours) were estimated, based on the weekly and monthly test assumption. Again, we point out that the diesel-generator operating time was based on the requirement that the diesel should be run for a minimum of one hour when the test to demonstrate operability is

conducted. Therefore, the LER rate for Does Not Continue to Run is based only on the one-hour-run period, and may not be representative of the operating failure rate for long-term operation. Comparing the LER rate with the WASH-1400 rate for this failure mode, shows that the LER rate to be an order of magnitude higher than the WASH-1400 rate ($3E-2/hr$ versus $3E-3/hr$). Appendix P lists the results of all the Does Not Continue to Run estimations.

Does Not Operate

We combined the Does Not Start failures and the Does Not Continue to Run failures for the time period 1976 through 1978 and estimated an LER rate for these aggregate failures. The results of these estimations are listed as Does Not Operate LER rates. The LER rates for Does Not Operate were estimated in units of failures per demand and failures per standby time (hours). We felt that this estimation would allow an analyst to have an additional representation of the diesel-generator LER rates. If the one-hour run assumption for the Does Not Continue to Run failures was too restrictive, the one-hour interval being an insufficient time to estimate a diesel-generator operating failure rate, these failures could be considered as start failures, since the one-hour-run could be considered an extension of the start-test interval. Therefore, the Does Not Operate estimates can be thought of as hybrid Does Not Start estimates if one feels the one-hour interval is too short, and failures occurring in this period are considered as part of the starting sequence (that is, start and stabilize). Appendix Q lists the results of the Does Not Operate estimations.

Scatter Plots

We incorporate scatter plots of the specific plant LER rates to illustrate the plant-to-plant variability associated with these estimates. Figures 1 through 6 reproduce these plots.

For each failure mode and for each test interval assumption (weekly or monthly), a plot of the specific plant LER rate is grouped according to the NSSS vendor. This grouping provides four plots for each failure mode and test assumption, one for each NSSS vendor and its corresponding plants. A

pound sign (#) immediately following the coded plant name, indicates that there were no failures reported for that plant. The LER rate plotted for a plant that reported no failures is the averaged LER rate of the NSSS vendor of which the plant is a member. All the LER rates plotted are for the period 1976 through 1978.




Figure 1a. Demand failure rate estimates (failures per demand) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Start, assuming weekly testing.




Figure 1b. Demand failure rate estimates (failures per demand) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Start, assuming weekly testing.

DOES NOT START (WEEKLY TESTING)




Figure 1c. Demand failure rate estimates (failures per demand) of diesel generators of Westinghouse plants for the failure mode, Does Not Start, assuming weekly testing.




Figure 1d. Demand failure rate estimates (failures per demand) of diesel generators of General Electric plants for the failure mode, Does Not Start, assuming weekly testing.




Figure 2a. Demand failure rate estimates (failures per demand) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Start, assuming monthly testing.




Figure 2b. Demand failure rate estimates (failures per demand) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Start, assuming monthly testing.




Figure 2c. Demand failure rate estimates (failures per demand) of diesel generators of Westinghouse plants for the failure mode, Does Not Start, assuming monthly testing.

DOES NOT START (MONTHLY TESTING)




Figure 2d. Demand failure rate estimates (failures per demand) of diesel generators of General Electric plants for the failure mode, Does Not Start, assuming monthly testing.




Figure 3a. Operating failure rate estimates (failures per hour) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Continue to Run, assuming weekly testing.

DOES NOT CONTINUE TO RUN (WEEKLY TESTING)




Figure 3b. Operating failure rate estimates (failures per hour) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Continue to Run, assuming weekly testing.




Figure 3c. Operating failure rate estimates (failures per hour) of diesel generators of Westinghouse plants for the failure mode, Does Not Continue to Run, assuming weekly testing.




Figure 3d. Operating failure rate estimates (failures per hour) of diesel generators of General Electric plants for the failure mode, Does Not Continue to Run, assuming weekly testing.




Figure 4a. Operating failure rate estimates (failures per hour) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Continue to Run, assuming monthly testing.




Figure 4b. Operating failure rate estimates (failures per hour) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Continue to Run, assuming monthly testing.




Figure 4c. Operating failure rate estimates (failures per hour) of diesel generators of westinghouse plants for the failure mode, Does Not Continue to Run, assuming monthly testing.

DOES NOT CONTINUE TO RUN (MONTHLY TESTING)




Figure 4d. Operating failure rate estimates (failures per hour) of diesel generators of General Electric plants for the failure mode, Does Not Continue to Run, assuming monthly testing.




Figure 5a. Demand failure rate estimates (failures per demand) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Operate, assuming weekly testing.




Figure 5b. Demand failure rate estimates (failures per demand) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Operate, assuming weekly testing.




Figure 5c. Demand failure rate estimates (failures per demand) of diesel generators of Westinghouse plants for the failure mode, Does Not Operate, assuming weekly testing.

DOES NOT OPERATE (WEEKLY TESTING)




Figure 5d. Demand failure rate estimates (failures per demand) of diesel generators of General Electric plants for the failure mode, Does Not Operate, assuming weekly testing.




Figure 6a. Demand failure rate estimates (failures per demand) of diesel generators of Babcock & Wilcox plants for the failure mode, Does Not Operate, assuming monthly testing.




Figure 6b. Demand failure rate estimates (failures per demand) of diesel generators of Combustion Engineering plants for the failure mode, Does Not Operate, assuming monthly testing.




Figure 6c. Demand failure rate estimates (failures per demand) of diesel generators of Westinghouse plants for the failure mode, Does Not Operate, assuming monthly testing.

DOES NOT OPERATE (MONTHLY TESTING)




Figure 6d. Demand failure rate estimates (failures per demand) of diesel generators of General Electric plants for the failure mode, Does Not Operate, assuming monthly testing.

NSSS Vendor Rates

Table 21 summarizes the NSSS vendors' diesel-generator LER rates by weekly and monthly testing. These rates were taken from the "Final Statistics" sections of the appendices used to display the results of the LER rate estimations.

TABLE 21. SUMMARY OF DIESEL-GENERATOR FAILURE RATES BY N

NSSS	Standby Hours	Minimum Number of Starts		Does Not Start			Minimum Number Operating Hours	
		Weekly	Monthly	Q_d		Total Failures	Weekly	Monthly
Babcock & Wilcox	228,192	1,356	314	1E-2/d	6E-2/d	19	1,356	314
Combustion Engineering	347,712	2,064	476	2E-2/d	6E-2/d	30	2,064	476
Westinghouse	1,363,848	8,093	1,873	6E-3/d	3E-2/d	40	8,093	1,873
General Electric	1,169,208	6,942	1,602	1E-2/d	6E-2/d	50	6,942	1,602
Overall	3,108,960	18,455	4,265	1E-2/d	4E-2/d	186	18,455	4,265

NOTES:

- Q_d = demand failure rate
 λ_o = operating, hourly failure rate
 λ_s = standby, hourly failure rate.

- WASH-1400 failure rates:

Does Not Start $Q_d = 3E-2/d$

Does Not Continue to Run $\lambda_o = 3E-3/hr$

SSS VENDOR, FAILURE MODE, AND TESTING INTERVAL

<u>Does Not Continue to Run</u>			<u>Does Not Start Combined with Does Not Continue to Run</u>					
λ_0			Q_d			λ_s		
<u>Weekly</u>	<u>Monthly</u>	<u>Total Failures</u>	<u>Weekly</u>	<u>Monthly</u>	<u>Total Failures</u>	<u>Weekly</u>	<u>Monthly</u>	<u>Total Failures</u>
6E-3/hr	3E-2/hr	8	2E-2/d	9E-2/d	27	1E-4/hr	1E-4/hr	27
1E-2/hr	6E-2/hr	28	3E-2/d	1E-1/d	58	2E-4/hr	2E-4/hr	58
4E-3/hr	2E-2/hr	34	1E-2/d	4E-2/d	81	6E-5/hr	6E-5/hr	81
5E-3/hr	3E-2/hr	42	2E-2/d	8E-2/d	132	1E-4/hr	1E-4/hr	132
5E-3/hr	3E-2/hr	112	2E-2/d	7E-2/d	298	1E-4/hr	1E-4/hr	298

Yearly Failure Summarizations

Table 22 summarizes the diesel-generator failures identified in our report. The failures are listed by reporting plant and year of the event. The plants are grouped by vendor, with yearly vendor totals given.

TABLE 22. SUMMARY OF DIESEL-GENERATOR FAILURES BY PLANT AND YEAR

<u>Plant</u>	<u>1976</u>	<u>1977</u>	<u>1978</u>	<u>Total</u>
BABCOCK & WILCOX				
Arkansas 1	1	1	1	3
Crystal River 3	--	4	2	6
Davis-Besse 1	--	1	5	6
Rancho Seco	3	1	1	5
Three Mile Island 1	1	--	2	3
Three Mile Island 2	--	--	4	4
Total	5	7	15	27
COMBUSTION ENGINEERING				
Arkansas 2	--	--	--	--
Calvert Cliffs 1	4	5	3	12
Calvert Cliffs 2	1	3	2	6
Fort Calhoun	4	2	3	9
Millstone 2	13	6	3	22
Maine Yankee	--	--	2	2
Palisades	--	--	--	--
St. Lucie 1	1	5	1	7
Total	23	21	14	58

TABLE 22. (continued)

Plant	1976	1977	1978	Total
WESTINGHOUSE				
Beaver Valley	2	8	6	16
Cook 1	1	--	--	1
Cook 2	--	--	5	5
Farley 1	--	5	8	13
Ginna	--	--	1	1
Haddam Neck	1	--	--	1
Indian Point 2	--	--	--	--
Indian Point 3	3	--	--	3
Kewaunee	--	3	--	3
North Anna 1	--	--	--	--
Prairie Island 1	--	1	--	1
Prairie Island 2	1	--	--	1
Point Beach 1	--	2	1	3
Point Beach 2	--	--	--	--
Robinson 2	1	1	1	3
Salem 1	--	4	--	4
San Onofre 1	--	--	2	2
Surry 1	1	--	--	1
Surry 2	--	--	--	--
Trojan	--	2	--	2
Turkey Point 3	--	2	1	3
Turkey Point 4	--	--	--	--
Yankee Rowe	--	3	--	3
Zion 1	2	--	6	8
Zion 2	--	4	3	7
Total	12	35	34	81

TABLE 22. (continued)

<u>Plant</u>	<u>1976</u>	<u>1977</u>	<u>1978</u>	<u>Total</u>
GENERAL ELECTRIC				
Big Rock Point 1	13	7	2	22
Browns Ferry 1	2	--	--	2
Browns Ferry 2	--	--	--	--
Browns Ferry 3	--	1	--	1
Brunswick 1	--	5	1	6
Brunswick 2	5	--	1	6
Cooper Station	3	--	1	4
Duane Arnold	5	2	1	8
Dresden 1	--	--	5	5
Dresden 2	4	9	8	21
Dresden 3	4	3	--	7
Duane Arnold	5	2	1	8
Fitzpatrick	2	2	2	6
Hatch 1	9	8	--	17
Hatch 2	--	--	2	2
Millstone 1	--	--	--	--
Monticello	1	--	--	1
Nine Mile Point 1	--	--	--	--
Oyster Creek	2	--	1	3
Peach Bottom 2	--	4	4	8
Peach Bottom 3	--	--	--	--
Pilgrim 1	2	--	1	3
Quad-Cities 1	1	3	--	4
Quad-Cities 2	--	--	--	--
Vermont Yankee	<u>2</u>	<u>3</u>	<u>1</u>	<u>6</u>
Total	<u>55</u>	<u>47</u>	<u>30</u>	<u>132</u>
Grand Total	95	110	93	298

Plant Data

Table 23 summarizes all events, failures and nonfailures, by plant and diesel-generator subsystem. We included this table so that you may conveniently identify our data and perform your own estimations, if you so desire.

TABLE 23. PLANT

BABCOCK & WILCOX

Plant Code	Plant Name	Diesel Generator Population	Minimum Number of Demands per Component		Minimum Operating Hours per Component		Standby Hours per Component	Fuel Oil	Lube Oil	Starting	Cooling
			Weekly	Monthly	Weekly	Monthly					
AR1	Arkansas Nuclear One 1	2	156	36	156	36	26280	--	--	2A	--
CR3	Crystal River 3	2	102	24	102	24	17184	1A	1A	--	--
DB1	Davis-Besse 1	2	68	16	68	16	11424	--	--	--	--
RS1	Rancho Seco	2	156	36	156	36	26280	1B	--	1A	--
TI1	Three Mile Island 1	2	156	36	156	36	26280	--	2A,1U	--	--
TI2	Three Mile Island 2	2	40	9	40	9	6648	1A	--	--	--
	(Subtotal)							(2A,1B)	(3A,1U)	(3A)	--

COMBUSTION ENGINEERING

AR2	Arkansas Nuclear One 2	2	4	1	4	1	600			N O	F A I L U R E S
CC1	Calvert Cliffs 1	1 ded., 1 shared	156	36	156	36	26280	--	1B,3U	--	1A,1B
CC2	Calvert Cliffs 2	1 ded., 1 shared	108	25	108	25	18264	--	2U	2A	1A,1B,1U
FC1	Fort Calhoun	2	156	36	156	36	26280	1U	--	4A	--
M12	Millstone 2	2	156	36	156	36	26280	1A,3B,1U	2B,2U	--	1A,5B,1U
MY1	Maine Yankee	2	156	36	156	36	26280	1A	--	--	--
PA1	Palisades	2	156	36	156	36	26280	1U	--	1U	--
SL1	St. Lucie	2	140	32	140	32	23592	2A	--	1U	--
	(Subtotal)							(4A,3B,3U)	(3B,7U)	(6A,2U)	(3A,7B,2U)

a. A and B are failure modes. A is Does Not Start. B is Does Not Continue to Run. U indicates events that were not classified as diesel-generated.

NT DATA

Number and Mode of Events^a

Scavenging Air	Engine Frame/Internals	Governor	Exhaust	Shutdown	Output Breaker	Exciter/Voltage Regulator	Generator	Other Unknown	Total
1B	--	--	--	--	--	--	--	2U	2A,1B,2U
--	--	2A	--	1A	--	--	--	1A	6A
2B	1A	1A	--	--	--	1A	--	1B,2U	3A,3B,2U
--	--	1B	--	--	--	1U	--	2A	3A,2B,1U
--	--	--	--	--	1A	--	--	--	3A,1U
--	1A,2B	--	--	--	--	--	--	--	2A,2B
(3B)	(2A,2U)	(3A,1B)	--	(1A)	(1A)	(1A,1U)	--	(3A,1B,4U)	(19A,8B,6U)

REPORTED					NO FAILURES REPORTED				
--	1B	--	--	--	1A	1A	1A	3A,2B	7A,5B,3U
--	--	--	--	--	1B	--	--	1A	4A,2B,3U
--	--	1B	--	--	--	1A,2B	--	1A	6A,3B,1U
--	4B	3A,1B	--	1B	--	1A	--	3U	6A,16B,7U
--	--	1A	--	--	--	--	--	--	2A
--	--	--	--	--	--	--	--	--	2U
2B	--	--	--	1A	1A	--	--	1A	5A,2B,1U
(2B)	(5B)	(4A,2B)	--	(1A,1B)	(2A,1B)	(3A,2B)	(1A)	(6A,2B,3U)	(30A,28B,17U)

erator failures.

WESTINGHOUSE

Plant Code	Plant Name	Diesel Generator Population	Minimum Number of Demands per Component		Minimum Operating Hours per Component		Standby Hours per Component	Fuel Oil	Lube Oil	Starting
			Weekly	Monthly	Weekly	Monthly				
BV1	Beaver Valley 1	2	137	32	137	32	23136	1B	1B	2A
DC1	Donald C. Cook 1	2	156	36	156	36	26280	--	--	--
DC2	Donald C. Cook 2	2	42	10	42	10	7080	1A,1B,1U	--	1A,1B
HN1	Haddam Neck	2	156	36	156	36	26280	1A	--	--
IP2	Indian Point 2	3	156	36	156	36	26280	--	3U	1U
IP3	Indian Point 3	3	142	33	142	33	23952	1U	--	--
JF1	Joseph M. Farley 1	5	72	17	72	17	12192	--	--	5A,2B,2U
KE1	Kewaunee	2	156	36	156	36	26280	--	--	--
NA1	North Anna 1	2	38	9	38	9	6456			N O F A I L
PR1	Prairie Island 1	2	156	36	156	36	26280	1U	--	--
PR2	Prairie Island 2	2	156	36	156	36	26280	--	--	--
PT1	Point Beach 1	2	156	36	156	36	26280	--	--	--
PT2	Point Beach 2	2	156	36	156	36	26280			N O F A I L
RG1	Robert E. Ginna	2	156	36	156	36	26280	1U	--	--
RO2	H. B. Robinson 2	2	156	36	156	36	26280	2B	--	--
SA1	Salem 1	3	107	25	107	25	17976	2A	1U	--
SO1	San Onofre 1	2	156	36	156	36	26280	2A,1U	--	--
SU1	Surry 1	1 ded., 1 shared	156	36	156	36	26280	--	--	--
SU2	Surry 2	1 ded., 1 shared	156	36	156	36	26280			N O F A I L
TR1	Trojan	2	156	36	156	36	26280	3U	--	--
TU3	Turkey Point 3	2	156	36	156	36	26280	2A,1B	--	--
TU4	Turkey Point 4	2	156	36	156	36	26280			N O F A I L
YR1	Yankee Rowe	3	156	36	156	36	26280	--	--	1A,2B
Z11	Zion 1	2 ded., 1 shared	156	36	156	36	26280	1B	1A,2U	2A
Z12	Zion 2	2 ded., 1 shared	156	36	156	36	26280	--	1B	--
(Subtotal)								(8A,6B,8U)	(1A,2B,6U)	(11A,5B,3U)

a. A and B are failure modes. A is Does Not Start. B is Does Not Continue to Run. U indicates events that were not classified.

23. (continued)

Number and Mode of Events^a

Cooling	Scavenging Air	Engine Frame/ Internals	Governor	Exhaust	Shutdown	Output Breaker	Exciter/ Voltage Regulator	Generator	Other Unknown	Total
--	--	--	--	--	--	9A	2A	1B	3U	13A,3B,3U
--	--	--	--	--	--	--	1A,1U	--	3U	1A,4U
1U	--	--	1B	--	--	--	--	--	3U	2A,3B,5U
--	--	--	--	--	--	--	--	--	1U	1A,1U
1U	--	--	--	1U	--	--	--	--	--	6U
--	--	--	2B	--	--	--	--	1B	1U	3B,2U
--	--	--	4A	--	--	2A	--	--	--	11A,2B,2U
--	1B	--	1B	--	1U	--	--	--	1A	1A,2B,1U
URES	REPORTED					NO	FAILURES	REPORTED		
--	--	--	1B	--	--	--	--	--	1U	1B,2U
1U	--	1B	--	--	--	--	--	--	2U	1B, 3U
--	--	--	--	--	1A	2A	--	--	--	3A
URES	REPORTED					NO	FAILURES	REPORTED		
--	--	--	--	--	--	1A,1U	--	--	--	1A,2U
--	--	--	1B	--	--	--	--	--	--	3B
1B	1B	--	--	--	--	--	--	--	--	2A,2B,1U
--	--	--	--	--	--	--	--	--	--	2A,1U
--	--	1A,3U	--	--	--	--	--	--	1U	1A,4U
URES	REPORTED					NO	FAILURES	REPORTED		
--	--	--	1B	--	--	--	--	1U	1A	1A,1B,4U
2U	--	--	--	--	--	2U	--	--	--	2A,1B,4U
URES	REPORTED					NO	FAILURES	REPORTED		
1U	--	--	--	--	--	--	--	--	--	1A,2B,1U
--	--	--	1B	--	--	--	1B	--	2A	5A,3B,2U
--	--	--	2B	--	2B	--	2B	--	--	7B
(1B,6U)	(2B)	(1A,1B,3U)	(4A,10B)	(1U)	(1A,2B,1U)	(14A,3U)	(3A,3B,1U)	(2B,1U)	(4A,15U)	(47A,34B,48U)

^a as diesel generator failures.

TABLE 23. (con)

GENERAL ELECTRIC

Plant Code	Plant Name	Diesel Generator Population	Minimum Number of Demands per Component		Minimum Operating Hours per Component		Standby Hours per Component	Fuel Oil	Lube Oil	Starting	Cooling
			Weekly	Monthly	Weekly	Monthly					
BF1	Browns Ferry 1	4	156	36	156	36	26280	--	--	1U	--
BF2	Browns Ferry 2		156	36	156	36	26280			N O	F A I L U R E S
BF3	Browns Ferry 3		125	28	125	28	20976	--	--	1U	--
BP1	Big Rock Point	1	156	36	156	36	26280	4A	--	4A	2A,3B
BR1	Brunswick 1	4	116	27	116	27	19512	1B	2A	1A	--
BR2	Brunswick 2		156	36	156	36	26280	1A,1B	--	1A	--
CO1	Cooper Station	2	156	36	156	36	26280	1B,1U	--	--	--
DA1	Duane Arnold	2	156	36	156	36	26280	1B,1U	1B	--	1B
DR1	Dresden 1	1	156	36	156	36	26280	1A,2U	1A	1A,1U	--
DR2	Dresden 2	1 ded., 1 shared	156	36	156	36	26280	1B	--	9A	2B,1U
DR3	Dresden 3	1 ded., 1 shared	156	36	156	36	26280	2U	1B	--	3U
EN1	Edwin I. Hatch 1	2 ded., 1 shared	156	36	156	36	26280	1U	1B	1A	3B
EN2	Edwin I. Hatch 2	2 ded., 1 shared	26	6	26	6	4296	--	--	--	--
FP1	James A. Fitzpatrick	4	156	36	156	36	26280	--	2A,2U	--	--
M11	Millstone 1	1	156	36	156	36	26280	2U	--	--	--
MO1	Monticello	2	156	36	156	36	26280	--	--	1A	--
NM1	Nine Mile Point 1	2	156	36	156	36	26280			N O	F A I L U R E S
OC1	Oyster Creek	2	156	36	156	36	26280	--	--	1A	--
PB2	Peach Bottom 2	4	156	36	156	36	26280	1U	1B,3U	1U	2A
PB3	Peach Bottom 3		156	36	156	36	26280	--	--	1U	--
P11	Pilgrim 1	2	156	36	156	36	26280	--	--	--	--
QC1	Quad-Cities 1	1 ded., 1 shared	156	36	156	36	26280	2U	--	1A	1U
QC2	Quad-Cities 2	1 ded., 1 shared	156	36	156	36	26280	--	--	--	2U
VY1	Vermont Yankee	2	156	36	156	36	26280	1B	--	1A	1B
	(Subtotal)							(6A,6B,12U)	(5A,4B,5U)	(21,5U)	(4A,10B,7U)
	(Overall Total)							(20A,16B,23U)	(9A,9B,19U)	(41A,5B,10U)	(7A,18B,15U)

a. A and B are failure modes. A is Does Not Start. B is Does Not Continue to Run. U indicates events that were not classified as diesel-generated.

nued)

Number and Mode of Events⁶

Avenging Air	Engine Frame/Internals	Governor	Exhaust	Shutdown	Output Breaker	Exciter/Voltage Regulator	Generator	Other Unknown	Total
--	--	1A,1B	--	--	--	1U	--	--	1A,1B,2U
R T E D					N O F A I L U R E S R E P O R T E D				
--	--	--	--	--	1U	1A	--	--	1A,2U
--	--	6A,1U	--	--	1A	--	--	2A	19A,3B,1U
--	--	1B	--	1U	1B	--	--	2U	3A,3B,3U
--	--	1B	--	--	1A	1A	--	2U	4A,2B,2U
--	1A	--	--	--	1A,2U	1B	--	--	2A,2B,3U
--	2A	1B	1B	--	1A	--	--	2U	3A,5B,3U
--	--	--	--	--	--	--	--	2A	5A,3U
1B	--	4A	--	2A	1A	1B	--	1U	16A,5B,2U
--	--	3A,2B	--	--	--	1A,1U	--	1U	4A,3B,7U
--	1B	2A	--	--	--	1A,2B	--	4A,2B,5U	8A,9B,6U
--	--	2A	--	--	--	--	--	3U	2A,3U
--	--	1A	--	2A	1B	1U	--	--	5A,1B,3U
--	--	--	--	1U	--	--	--	--	3U
--	--	--	--	--	--	--	--	--	1A
R T E D					N O F A I L U R E S R E P O R T E D				
--	--	--	--	--	--	2A	--	--	3A
--	--	3A	--	1A	--	--	1A	--	7A,1B,5U
--	--	--	--	--	--	--	--	--	1U
--	--	--	2B	--	--	1B	--	--	3B
--	--	--	--	--	--	2A	1A	2U	4A,5U
--	--	--	--	--	--	--	--	--	2U
--	1A,2B	--	--	--	--	--	--	--	2A,4B
(1B)	(4A,3B)	(22A,6B,1U)	(3B)	(5A,2U)	(5A,2B,3U)	(8A,5B,3U)	(2A)	(8A,2B,18U)	(90A,42B,56U)
(8B)	(7A,11B,3U)	(33A,19B,1U)	(3B,1U)	(8A,3B,3U)	(22A,3B,6U)	(15A,10B,5U)	(3A,3B,1U)	(21A,5B,40U)	(186A,112B,127U)

ator failures.

REFERENCES

1. J. L. Crooks and G. S. Vissing, Diesel Generator Operating Experience at Nuclear Power Plants, OOE-ES-002, June 1974, p. 2.
2. IEEE Standard Criteria for Diesel-Generator Units Applied as Standard Power Supplies for Nuclear Power Generating Stations, IEEE Standard 387-1977, pp. 7-9.
3. Periodic Testing of Diesel-Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants, U.S. Nuclear Regulatory Commission Regulatory Guide 1.108, Revision 1, August 1977, p. 1.108-2.
4. G. L. Boner and H. W. Hanners, Enhancement of On-site Emergency Diesel Generator Reliability, NUREG-CR-0660, UDR-TR-79-07, February 1979, pp. I-3, I-5 through I-7, IV-5, V-12.
5. Crooks and Vissing (see Ref. 1) pp. A-1 through A-4.
6. Boner and Hanners (see Ref. 4) pp. I-10 and I-11.
7. Boner and Hanners (see Ref. 4) pp. I-10, I-12, I-17, and I-18.
8. Crooks and Vissing (see Ref. 1) pp. 6 and 9.
9. Operating Units Status Report, 3, 1, NUREG-0020, January 1979.
10. Regulatory Guide 1.108 (see Ref. 3), p. 1.108-3.
11. IEEE Standard 387-1977 (see Ref. 2), p. 16.
12. Standard Technical Specifications for Combustion Engineering Pressurized Water Reactors, Revision of March 15, 1977, NUREG-0212, March 1977, pp. 3/4 8-2 and 8-3.

13. Standard Technical Specifications for General Electric Boiling Water Reactors, Revision of April 1, 1978, NUREG-0123, Revision 1, April 1, 1978, p. 3/4 8-3.
14. Standard Technical Specifications for Westinghouse Pressurized Water Reactors, Revision of July 1979, NUREG-0452, Revision 2, July 1979, pp. 3/4 8-2 and 8-3.
15. Standard Technical Specifications for Westinghouse Pressurized Water Reactors, Revision of July 1979, (see Ref. 16), p. 1-4.
16. Boner and Hanners (see Ref. 4,) p. IV-5.
17. Crooks and Vissing (see Ref. 1), pp. 3, 4, A-1 through A-4.
18. Boner and Hanners (see Ref. 4), pp. I-25 and I-26.
19. Boner and Hanners (see Ref. 4), pp. I-6 and I-7.
20. Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Reactor Plants, Apendices III and IV, WASH-1400, NUREG-75/014, October 1975, Table III 4-2, p. III-47/48.

APPENDIX A

DISCUSSION OF THE CAUSES OF LER VARIATIONS

APPENDIX A

DISCUSSION OF THE CAUSES OF VARIATIONS IN LER REPORTING

There are generally two criteria used by the utilities to determine reporting requirements for failures. These are (a) technical specifications for each individual plant and (b) Regulatory Guide 1.16^{A-1}. Variation exists in the reporting requirements for individual plants. For example, generally, the technical specifications for plants licensed prior to January 1, 1976 were independently written by each specific plant without any planned uniformity between plants. All plants licensed after this date used standardized technical specifications, which helped create more uniform reporting. Also, there have been changes in the rules that govern LER reporting, to ensure greater uniformity. These changed reporting rules, and the standardized technical specifications, are expected to result in more uniform LER reporting after January 1, 1976.

The above "mechanical" causes for LER reporting variations are explainable and expected. However, there are further reporting variations. Differences in interpretation of the rules for submitting incident reports cause these variations. Also, variation is caused by the difficulty of determining the extent of safety and non-safety systems, and therefore, by the questions of what failures are, or are not, required to be reported. Finally, variation can be caused by the degree of importance assigned to the LER reports by the management of each utility. We have seen variation in both the quantity and quality of LERs between similar plants, where one would expect a more uniform reporting. We have attributed these variations to the reasons mentioned above.

The one thing that seems to have most hindered the development of uniform reporting is the lack of agreement of what is intended by an LER. Many persons feel that LERs are intended to highlight problem areas within the safety systems. Some feel that the LERs ought to be used to highlight generic problem areas. And, many of these same people do not feel that

these uses are compatible with the need to determine failure rate information.

All of these points may serve to confuse the individual responsible for reporting events. Hence the variations in the quality and quantity of LERs received by the Nuclear Regulatory Commission may be explained, in part, by these points. For further discussion of the causes of variations in LER reporting, see Reference A-2.

Reference

- A-1. Reporting of Operating Information--Appendix A Technical Specifications, U.S. Nuclear Regulatory Commission Regulatory Guide 1.16, Revision 4, August 1975.
- A-2. Gerald L. Boner and Harvey W. Hanners, Enhancement of On-site Emergency Diesel Generator Reliability, University of Dayton Research Institute, NUREG/CR-0660, 1979, pp. I-4, I-5, IV-5, IV-6, V-10, and V-13

APPENDIX B

ONE-LINE LER CODING SCHEME

APPENDIX B

ONE-LINE LER CODING SCHEME

In order to extract as much pertinent information as possible from the information provided in the original LER, and, at the same time, to restrict the information to one line of computer output per LER, we developed the following code scheme.

In general, the order of discussion follows the order in which the various fields appear in the one-line descriptions of the diesel-generator events. The acronyms used for the corresponding fields in the one-line descriptions are contained in parentheses following the topic headings used below.

Vendor (VEN)

The VEN field indicates the NSSS vendor associated with the plant submitting the LER report. A single-character field is used to store and display the vendor code. This field can be used as a sort key. The following list gives the code and corresponding NSSS vendor.

<u>Code</u>	<u>NSSS Vendor</u>
B	Babcock & Wilcox
C	Combustion Engineering
G	General Electric
W	Westinghouse

Plant (PLANT)

We used a three-character field to identify the commercial power plant responsible for the submission of each LER. Due to the relatively large number of plants used in our report, a list of the plants and codes will

not be given here. Table B-1 provides this information. The PLANT field can be used as a sort key.

Control Number (CONTROL NO.)

To identify each one-line LER within the data file, and to provide a cross-reference with the actual LER submitted to NRC, we entered the unique six-digit control number assigned to the report by the NRC into the CONTROL NO. field. There were some instances of several different reports being listed in the narrative summary of a single LER. To accommodate this situation, we added an alphabetic character to the six-digit number in order to separately identify each report, and we encoded each report separately. Thus, traceability back to the original LER number was maintained, yet each report remained unique. When a single report contained more than one instance of the same event in the summary description, we placed an asterisk (*) after the control number to flag the coded one-line LER in the data file. The corresponding number of events was then entered in the FAIL NUM field so that each event could be accounted for. The CONTROL NO. field can be used as a sort field, but it is intended for data record identification within the data file and not for use as a sorting key.

Number of Failures (FAIL NUM)

The FAIL NUM field, mentioned above, was used to store a count of the number of events per one-line LER description. Due to the limited space available on a line of computer output, and to the fact that only diesel-generator unavailabilities/nonfailures contained multiple events, this field is not displayed in the one-line LER descriptions. A blank in this field implies that the value of the field is one. Should there be more than one event per report, the corresponding number of events is entered in this field. A list of those one-line LER descriptions that contain multiple events is given below.

TABLE B-1. G

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	Arch
AR1	Arkansas Nuclear One 1 (50-313)	850	8/6/74	12/19/74	AR	Bechte
CR3	Crystal River 3 (50-302)	825	1/14/77	3/13/77	FL	Gilber
DB1	Davis-Besse 1 (50-346)	906	9/10/77	11/20/77	OH	Bechte
OE1	Oconee 1 (50-269)	887	4/19/73	7/15/73	SC	Duke P Bechte
OE2	Oconee 2 (50-270)	887	11/11/73	9/9/74	SC	Duke P Bechte
OE3	Oconee 3 (50-287)	887	9/5/74	12/16/74	SC	Duke P Bechte
RS1	Rancho Seco (50-312)	918	9/16/74	4/17/75	CA	Bechte
TI1	Three Mile Island 1 (50-289)	819	6/5/74	9/2/74	PA	Gilber
TI2	Three Mile Island 2 (50-320)	906	3/28/78	12/30/78	PA	Burns

GENERAL PLANT INFORMATION

COCK & WILCOX

<u>Architect/Engineer</u>	<u>Constructor</u>	<u>DG Manufacturer</u>	<u>kW Rating</u>	<u>Population</u>	<u>Remarks</u>
1	Bechtel	General Motors	2750	2	
t Associates	J.A. Jones Const.	Fairbanks Morse	3000	2	
1	Bechtel	General Motors	2600	2	
ower Co. and 1	Duke Power Co.	}			Emergency power for Oconee 1, 2, and 3 is supplied by an on-site hydroelectric plant
ower Co. and 1	Duke Power Co.				
ower Co. and 1	Duke Power Co.				
1	Bechtel	General Motors	2750	2	
t Associates	United Engineers & Constructors	Fairbanks Morse	3000	2	
& Roe	United Engineers & Constructors	Fairbanks Morse	3000	2	

TABLE B-1. (cc

COMBUSTION ENGI

<u>Plant Code</u>	<u>Plant Name (Docket Number)</u>	<u>Design Electrical Rating (MWe)</u>	<u>Criticality Date</u>	<u>Date of Commercial Operation</u>	<u>Location (State)</u>	<u>Architect/Eng</u>
AR2	Arkansas Nuclear One 2 (50-368)	912	12/5/78	N/A	AR	Bechtel
CC1	Calvert Cliffs 1 (50-317)	845	10/7/74	5/8/75	MD	Bechtel
CC2	Calvert Cliffs 2 (50-318)	845	11/30/76	4/1/77	MD	Bechtel
FC1	Fort Calhoun (50-285)	457	8/6/73	9/26/73	NB	Gibbs & Hill, I
MI2	Millstone 2 (50-336)	830	10/17/75	12/16/75	CT	Bechtel
MY1	Maine Yankee (50-309)	825	10/23/72	12/28/72	ME	Stone & Webster
PA1	Palisades (50-255)	805	5/24/71	12/31/71	MI	Bechtel
SL1	St. Lucie (50-335)	802	4/22/76	12/21/76	FL	Ebasco

inued)

ERING

<u>eer</u>	<u>Constructor</u>	<u>DG Manufacturer</u>	<u>kW Rating</u>	<u>Population</u>	<u>Remarks</u>
	Bechtel	Fairbanks Morse	2850	2	
	Bechtel	Fairbanks Morse	2500	3	{ 1 dedicated to Unit 1 1 shared between Units 1 and 2 1 dedicated to Unit 2
	Bechtel	Fairbanks Morse	2500		
	Gibbs & Hill, Inc. and Durham & Richardson, Inc.	General Motors	2500		
	Bechtel	Fairbanks Morse	2750	2	
	Stone & Webster	General Motors	2500	2	
	Bechtel	Alco	2500	2	
	Ebasco	General Motors	3500	2	Both generators are driven by tandem diesels

TABLE B

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	Architect
BV1	Beaver Valley 1 (50-334)	852	5/10/76	10/1/76	PA	Stone & America Service
DC1	Donald C. Cook 1 (50-315)	1054	1/18/75	8/27/75	MI	America Service
DC2	Donald C. Cook 2 (50-316)	1100	3/10/78	7/1/78	MI	America Service
HN1	Haddam Neck (50-213)	575	7/24/67	1/1/68	CT	Stone & America Service
IP2	Indian Point 2 (50-247)	873	5/22/73	8/73	NY	United & Const
IP3	Indian Point 3 (50-286)	965	4/6/76	8/30/76	NY	United & Const
JF1	Joseph M. Farley 1 (50-348)	829	8/9/77	12/1/77	AL	Bechtel Service
KE1	Kewaunee (50-305)	535	3/7/74	6/74	WI	Pioneer & Eng.
NA1	North Anna 1 (50-338)	907	4/5/78	N/A	VA	Stone & America Service
PR1	Prairie Island 1 (50-282)	530	12/1/73	12/16/73	MN	Pioneer & Eng.
PR2	Prairie Island 2 (50-306)	530	12/17/74	12/21/74	MN	Pioneer & Eng.
PT1	Point Beach 1 (50-266)	497	11/2/70	12/21/70	WI	Bechtel
PT2	Point Beach 2 (50-301)	497	5/30/72	10/1/72	WI	Bechtel
RG1	Robert E. Ginna (50-244)	490	11/8/69	7/70	NY	Gilbert

-1. (continued)

STINGHOUSE

Contract/Engineer	Constructor	DG Manufacturer	kW Rating	Population	Remarks
Webster	Stone & Webster	General Motors	2600	2	
Indiana Electric Power Corporation	Indiana & Michigan Power Company	Worthington	3500	2	
Indiana Electric Power Corporation	Indiana & Michigan Power Company	Worthington	3500	2	
Webster	Stone & Webster	General Motors	2850	2	
Engineers Constructors	J.A. Jones/U.E.&C.	Alco	1750	3	
Engineers Constructors	WEDCO	Alco	1750	3	
Southern States, Inc.	Daniel	Fairbanks Morse	4000	3	All five units have the capability to be shared between Units 1 and 2
		Fairbanks Morse	2600	2	
Services Co.	Pioneer Services & Eng. Co.	General Motors	2850	2	
Webster	Stone & Webster	Fairbanks Morse	2750	2	1 dedicated to Unit 1 1 shared between Unit 1 and 2
Services Co.	Northern States Power Company	Fairbanks Morse	3000	2	
Services Co.	Northern States Power Company	Fairbanks Morse	3000	2	
	Bechtel	General Motors	2850	2	Both shared with Unit 2
	Bechtel	General Motors	2850	2	Both shared with Unit 1
	Bechtel	Alco	1950	2	

TABLE B-1. (con)

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	WESTINGHOUSE (con)
						Architect/Eng
R02	H. B. Robinson 2 (50-261)	700	9/20/70	3/7/71	SC	Ebasco
SA1	Salem 1 (50-272)	1090	12/11/76	6/30/77	NJ	PSE&G
S01	San Onofre 1 (50-206)	436	6/14/67	1/1/68	CA	Bechtel
SU1	Surry 1 (50-280)	822	7/1/72	12/22/72	VA	Stone & Webster
SU2	Surry 2 (50-281)	822	3/7/73	5/1/73	VA	Stone & Webster
TR1	Trojan (50-344)	1130	12/15/75	5/20/76	OR	Bechtel
TU3	Turkey Point 3 (50-250)	693	10/20/72	12/14/72	FL	Bechtel
TU4	Turkey Point 4 (50-251)	693	6/11/73	9/7/73	FL	Bechtel
YR1	Yankee Rowe (50-029)	175	8/19/60	7/61	MA	Stone & Webster
Z11	Zion 1 (50-295)	1040	6/19/73	12/31/73	IL	Sargent & Lund
Z12	Zion 2 (50-304)	1040	12/24/73	9/17/74	IL	Sargent & Lund

nued)

nued)

Owner	Constructor	DG Manufacturer	kW Rating	Population	Remarks
	Ebasco	Fairbanks Morse	2500	2	
	United Engineers & Constructors	Alco	2600	3	
	Bechtel	De Laval	600	2	
	Stone & Webster	General Motors	2750	3	1 dedicated to Unit 1 1 shared between Units 1 and 2 1 dedicated to Unit 2
	Stone & Webster	General Motors	2750		
	Various	General Motors	4418	2	Both generators are driven by tandem diesels
	Bechtel	General Motors	2500	2	
	Bechtel	General Motors	2500	2	
	Stone & Webster	General Motors	400	3	
	Various	Cooper-Bessemer	4000	5	2 dedicated to Unit 1 1 shared between Units 1 and 2 2 dedicated to Unit 2
	Various	Cooper-Bessemer	4000		

Plant Code	Plant Name (Docket Number)	Design Electrical Rating (MWe)	Criticality Date	Date of Commercial Operation	Location (State)	GENE
						Arch
BF1	Browns Ferry 1 (50-259)	1065	8/17/73	8/1/74	AL	Tennes Author
BF2	Browns Ferry 2 (50-260)	1065	7/20/74	3/1/75	AL	Tennes Author
BF3	Browns Ferry 3 (50-261)	1065	8/8/76	3/1/77	AL	Tennes Author
BP1	Big Rock Point (50-155)	72	9/27/62	3/29/63	MI	Bechte
BR1	Brunswick 1 (50-325)	821	10/8/76	3/18/77	NC	United & Cons
BR2	Brunswick 2 (50-324)	821	3/20/75	11/3/75	NC	United & Cons
CO1	Cooper Station (50-298)	778	2/21/74	7/1/74	NB	Burns &
DA1	Duane Arnold (50-331)	538	3/23/74	2/1/75	IA	Bechte
DR1	Dresden 1 (50-010)	200	10/15/59	7/4/60	IL	Bechte
DR2	Dresden 2 (50-237)	794	1/7/70	6/9/72	IL	Sargen
DR3	Dresden 3 (50-249)	794	1/31/71	11/16/71	IL	Sargen
EN1	Edwin I. Hatch 1 (50-321)	786	9/12/74	12/31/74	GA	Southe Inc.
EN2	Edwin I. Hatch 2 (50-366)	790	7/4/78	N/A	GA	Southe Inc./B
FP1	James A. Fitzpatrick (50-333)	821	11/17/74	7/28/75	NY	Stone &
MI1	Millstone 1 (50-245)	660	10/26/70	3/71	CT	Ebasco

1. (continued)

RAL ELECTRIC

itect/Engineer	Constructor	DG Manufacturer	kw Rating	Population	Remarks
see Valley ity	Tennessee Valley Authority	General Motors	3500	4	4 available for use by Units 1, 2, or 3
see Valley ity	Tennessee Valley Authority				
see Valley ity	Tennessee Valley Authority				
	Bechtel	Caterpillar	200	1	
Engineers ructors	Brown & Root	Nordberg Manufacturing	3500	4	4 available for use by either Unit 1 or 2
Engineers ructors	Brown & Root				
Roe	Burns & Roe	Cooper- Bessemer	4000	2	
	Bechtel	Fairbanks Morse	2850	2	
	Bechtel	General Motors	500	1	
& Lundy	United Engineers & Constructors	General Motors	2850	3	1 dedicated to Unit 2 1 shared between Units 2 and 3 1 dedicated to Unit 3
& Lundy	United Engineers & Constructors	General Motors	2850		
Services, echnical	Georgia Power Company	Fairbanks Morse	2850		
Services, echnical	Georgia Power Company	Fairbanks Morse	2850	5	2 dedicated to Unit 1 1 shared between Units 1 and 2 2 dedicated to Unit 2
Webster	Stone & Webster	General Motors	2600	4	
	Ebasco	Fairbanks Morse	2664	1	

TABLE B-1. (co

GENERAL ELECTRIC (

<u>Plant Code</u>	<u>Plant Name (Docket Number)</u>	<u>Design Electrical Rating (MWe)</u>	<u>Criticality Date</u>	<u>Date of Commercial Operation</u>	<u>Location (State)</u>	<u>Architect/En</u>
MO1	Monticello (50-263)	545	12/10/70	6/30/71	MN	Bechtel
NM1	Nine Mile Point 1 (50-220)	620	9/5/69	12/69	NY	Utility
OC1	Oyster Creek 1 (50-219)	650	5/3/69	12/69	NJ	Burns & Roe
PB2	Peach Bottom 2 (50-277)	1065	9/16/73	7/5/74	PA	Bechtel
PB3	Peach Bottom 3 (50-278)	1065	8/7/74	12/13/74	PA	Bechtel
PI1	Pilgrim 1 (50-293)	655	6/16/72	12/72	MA	Bechtel
QC1	Quad-Cities 1 (50-254)	789	10/18/71	2/18/73	IL	Sargent & Lundy
QC2	Quad-Cities 2 (50-265)	789	4/26/72	3/10/73	IL	Sargent & Lundy
VY1	Vermont Yankee (50-271)	514	3/24/72	11/30/72	VT	Ebasco

inued)

ntinued)

Year	Constructor	DG Manufacturer	kW Rating	Population	Remarks
	Bechtel	General Motors	2500	2	
	Stone & Webster	General Motors	2560	2	
	J. A. Jones	General Motors	2500	2	
	Bechtel	Fairbanks Morse	3250	4	{ 4 available for use by either Unit 2 or 3
	Bechtel	Fairbanks Morse	3250		
	Bechtel	Alco	2600	2	
	United Engineers & Constructors, Inc.	General Motors	2850	3	{ 1 dedicated to Unit 1 1 shared between Units 1 and 2 1 dedicated to Unit 2
	United Engineers & Constructors, Inc.	General Motors	2850		
	Ebasco	Fairbanks Morse	3000	2	

<u>VEN</u>	<u>PLANT</u>	<u>CONTROL NO.</u>	<u>FAIL NUM</u>
C	MI2	014164*	2
C	MI2	017837*	2
G	FP1	015050*	4
G	PB3	018059*	3
W	DC2	021634*	2
W	S01	017760*	2
W	SU1	022919*	2

This field is normally used for counting events rather than sorting them.

Component Type

The Component Type field distinguishes different components within the data file. We used the code, DG, to identify diesel generators. Since the code is the same for all diesel-generator events, it is not displayed on the computer printout of the diesel-generator one-line LER descriptions. This field can be used as a sort key.

Event Date (FAIL DATE)

We used a six-digit field to record the date of the event: two digits each, for the month, day, and year. The event date corresponds to the EVENT DATE listed in the LER for each event. The month, day, and year can be used as sort keys.

Manufacturer (MFG, KW)

A four-character field identifies the diesel-generator manufacturer and the size or kw output rating of the unit. This is accomplished by dividing the four-character field into two, subordinate, two-character fields. One of the two-character fields (MFG) is used to identify the

manufacturer, the other (KW) is used to identify the continuous generator output rating. The four-character field or either of the two-character fields can be used as sort keys. A list of the manufacturer and kW rating codes is given below.

<u>Code</u>	<u>Manufacturer</u>
AL	Alco
CA	Caterpillar
CB	Cooper-Bessemer
DL	De Laval
FM	Fairbanks Morse
GM	General Motors
NM	Nordberg Manufacturing
WO	Worthington

<u>Code</u>	<u>kW Rating</u>
02	200-400 kW
10	500-1000 kW
18	1750-1950 kW
25	2500-2850 kW
30	3000-3500 kW
40	4000-4418 kW

Subsystem (SUB/SYS)

The diesel-generator unit support systems (subsystems) discussed in the "Component Definition" in the text, were identified and coded according to the following scheme. We used a single-character field to indicate the subsystem in which the event occurred. This field can be used as a sort key.

<u>Code</u>	<u>Subsystem</u>
A	Fuel Oil System
B	Lube Oil System
C	Starting System
D	Cooling System
E	Scavenging Air System
F	Engine Frame/Internals
G	Governor
H	Exhaust System
I	Shutdown System
J	Output Breaker
K	Exciter/Voltage Regulator
L	Generator
M	Other/Unknown

Failure Code (FAIL MODE, FAIL MECH)

A three-character field indicates the failure code. A single-character subordinate field indicates the failure mode. And a two-character subordinate field indicates the failure mechanism. We used the following scheme to encode the various failure modes and mechanisms identified in the LERs. These fields can be used as sort keys.

<u>Code</u>	<u>Failure Mode</u>
A	Does Not Start
B	Does Not Continue to Run
U	Unavailable/Nonfailure

<u>Code</u>	<u>Failure Mechanism</u>
00	Unknown

<u>Code</u>	<u>Failure Mechanism</u>
01	Personnel Operation
02	Personnel Maintenance
03	Personnel Testing
04	Design Error
05	Fabrication/Construction/Quality Control
06	Procedural Discrepancy
07	Defective Fuel Injector(s)
08	Corrosion/Erosion
09	Foreign Material Contamination
10	Mechanical/Electrical Control
11	High/Low Ambient Temperature
12	Lube/Fuel/Water/Air Leakage
13	Vibration
14	Out of Adjustment/Calibration

Type of Event (TYPE)

A single-character field indicates the type of event identified in the LER, that is, random, recurring, common cause, etc. A blank in this field implies a random event. Otherwise, we used the following scheme to identify the event types. This field can be used as a sort key.

<u>Code</u>	<u>Type of Event</u>
B	Recurring Common Cause
C	Common Cause
R	Recurring
S	Command Fault
T	Recurring Command Fault

Failure Classification (CLASS)

We used a single-character field to classify the events as "time related" or "demand related." A "D" in this field was used for demand related events, and a "T" was used for time-related events. If no identification could be made, a "U" was inserted in this field. This field can be used as a sort key.

Repair Time (REPAIR)

The REPAIR field indicates the approximate time interval necessary to return the diesel generator back to service (i.e. operable condition). This is a single-character field with the following coding scheme. This field can be used as a sort key.

<u>Code</u>	<u>Repair Time</u>
1	All times greater than 0, but less than or equal 1 hour
4	All times greater than 1 hour, but less than or equal to 4 hours
8	All times greater than 4 hours, but less than or equal to 8 hours
D	All times greater than 8 hours, but less than or equal to 24 hours
G	All times greater than 24 hours
U	Unknown/Not Applicable

Method of Discovery (DISCOVERY)

We used a single-character code to indicate the activity taking place when the event occurred or was discovered. The coding scheme for this field is as follows.

<u>Code</u>	<u>Method Of Discovery</u>
M	During Maintenance
N	During Normal Operations
R	During Records Review
T	During Training
U	Unknown

Failure Mode Description (FAILURE MODE)

We condensed the LER narrative summary of the failure mode into a 50-character alphanumeric field. This field provides a short, concise description of the failure mode. It is not a sort field.

Failure Mechanism Description (FAILURE MECHANISM)

We used a 41-character alphanumeric field for a narrative description of the failure mechanism. If no mechanism was reported, this field provided an additional description of the LER. It is not a sort field.

For convenience, these codes are summarized on a single page and included at the beginning of each listing of one-line LER sorts given in the appendices of this report.

APPENDIX C

LER RATE ESTIMATIONS

APPENDIX C

LER RATE ESTIMATIONS

To estimate the LER failure rates for components, we used the following well-known statistical methods for Type-I censored data with replacement (for example, see Reference C-1).

The general methods for estimating rates on an hourly basis and on a demand basis are

$$\hat{\lambda}(\text{hourly}) = \frac{N}{T} \quad (\text{C-1})$$

$$\hat{\lambda}(\text{demand}) = \frac{N}{D} \quad (\text{C-2})$$

where

- $\hat{\lambda}$ = estimated failure rate
- N = number of reported component failures
- T = total time accrued by all components
- D = total number of demands on all components.

The general computational formulas, Equations (C-1) and (C-2), may be applied to particular situations. The failure rate for a component in a particular plant is estimated by setting

$$N = N_1$$

$$T = T_1$$

$$D = D_1$$

where

- N_i = the number of component failures in plant i
- T_i = the total accrued hours of all like components in plant i
- D_i = total accrued number of demands on all like components in plant i.

In a similar manner, failure rates may be estimated for components manufactured by a particular vendor, for components in a particular plant type (for example, PWR or BWR), or for components present in all plants.

We based confidence limits for hourly failure rates on the assumption that the underlying component failure distributions are exponential, so, the resulting LER data are representable by a Poisson process. In demand evaluations, N is binomially distributed. However, when the probability of failure is small and the number of demands is large, the Poisson distribution may be used to approximate this variable. The generalized formulas for estimating 90% confidence limits on the failure rates are

$$\frac{\chi^2_{0.05} (2N)}{2T} \leq \hat{\lambda}(\text{hourly}) \leq \frac{\chi^2_{0.95} (2N+2)}{2T} \quad (C-3)$$

and

$$\frac{\chi^2_{0.05} (2N)}{2D} \leq \hat{\lambda}(\text{demand}) \leq \frac{\chi^2_{0.95} (2N+2)}{2D} \quad (C-4)$$

where

- $\chi^2_{0.05} (2N)$ = the chi-square variate at 0.05 cumulative probability with 2N degrees of freedom
- $\chi^2_{0.95} (2N+2)$ = the chi-square variate at 0.95 cumulative probability with (2N+2) degrees of freedom.

In this work, when we observed no failures, we estimated an upper 95% confidence limit for the failure rate by

$$\hat{\lambda}(\text{hourly}) = \frac{\chi^2_{0.95}(2)}{2T} \quad (\text{C-5})$$

or by

$$\hat{\lambda}(\text{demand}) = \frac{\chi^2_{0.95}(2)}{2D} \quad (\text{C-6})$$

depending on whether temporal data or demand data are involved.

In estimating the above confidence limits, we assumed that all components in the sample had exactly the same true failure rate. No effort was made to account for possible variations arising from the mixture of populations having different true failure rates. For further discussion of the assumptions and limitations of these confidence limits, see Reference C-1.

Reference

- C-1. L. J. Bain, Statistical Analysis of Reliability and Life-Testing Models, New York: Marcell Dekker, Inc., 1978, p. 157.

APPENDIX D

FACILITY OPERATING LICENSES ISSUED WITH
STANDARD TECHNICAL SPECIFICATIONS

APPENDIX D

FACILITY OPERATING LICENSES ISSUED WITH
STANDARD TECHNICAL SPECIFICATIONS

Facility	Vendor	Issue Date
Crystal River Unit 3	B	December 3, 1976
Davis-Besse Unit 1	B	April 22, 1977
Three Mile Island Unit 2	B	February 8, 1978
Arkansas Unit 2	C	July 18, 1978
Calvert Cliffs Unit 1 (STS Conversion)	C	February 11, 1977
Calvert Cliffs Unit 2	C	August 13, 1976
Millstone Unit 2	C	August 1, 1975
St. Lucie Unit 1	C	March 1, 1976
Brunswick Unit 1	G	September 8, 1976
Brunswick Unit 2 (STS Conversion)	G	November 23, 1977
Hatch Unit 2	G	June 13, 1978
Beaver Valley Unit 1	W	January 30, 1976
D. C. Cook Unit 1	W	October 25, 1974
D. C. Cook Unit 2	W	December 23, 1977
Joseph M. Farley Unit 1	W	June 25, 1977
North Anna Unit 1	W	November 21, 1977
Salem Unit 1	W	August 13, 1976
Trojan	W	November 21, 1975
Yankee Rowe (STS Retrofit)	W	January 1, 1977

APPENDIX E

DIESEL-GENERATOR EVENT DATA FILE

CODES USED IN LER ONE-LINE DESCRIPTIONS

REPAIR TIME
CODE DESCRIPTION
1 - 0 TO 1 HOURS
4 - 1 TO 4 HOURS
8 - 4 TO 8 HOURS
D - 8 TO 24 HOURS
G - GREATER THAN 24 HOURS
U - UNKNOWN / NOT APPLICABLE

FAILURE MODE
CODE DESCRIPTION
A - DOES NOT START
B - DOES NOT CONTINUE TO RUN
U - UNAVAILABLE / NONFAILURE

FAILURE CLASSIFICATION
CODE DESCRIPTION
D - DEMAND
T - TIME
U - UNKNOWN

SUB-SYSTEM
CODE DESCRIPTION
A - FUEL OIL SYSTEM
B - LUBE OIL SYSTEM
C - STARTING SYSTEM
D - COOLING SYSTEM
E - SCAVENGING AIR SYSTEM
F - ENGINE FRAME / INTERNALS
G - GOVERNOR
H - EXHAUST SYSTEM
I - SHUTDOWN SYSTEM
J - CUMMINS BREAKER
K - EXCITER / VOLTAGE REGULATOR
L - GENERATOR
M - OTHER / UNKNOWN

FAILURE MECHANISM
CODE DESCRIPTION
G0 - UNKNOWN
01 - PERSONNEL OPERATION
02 - PERSONNEL MAINTENANCE
03 - PERSONNEL TESTING
04 - DESIGN ERROR
05 - FABRICATION / CONSTRUCTION / QUALITY CONTROL
06 - PROCEDURAL DISCREPANCY
07 - DEFECTIVE FUEL INJECTOR(S)
08 - CORROSION / EROSION
09 - FOREIGN MATERIAL CONTAMINATION
10 - MECHANICAL / ELECTRICAL CONTROL
11 - HI / LOW AMBIENT TEMPERATURE
12 - LUBE / FUEL / WATER / AIR LEAKAGE
13 - VIBRATION
14 - OUT OF ADJUSTMENT / CALIBRATION

METHOD OF DISCOVERY
CODE DESCRIPTION
M - DURING MAINTENANCE
N - DURING NORMAL OPERATION
R - DURING RECORDS REVIEW
T - DURING TESTING
U - UNKNOWN

TYPE OF EVENT
CODE DESCRIPTION
B - RECURRING COMMON CAUSE
C - COMMON CAUSE
R - RECURRING
S - COMMAND FAULTS
T - RECURRING COMMAND FAULTS

NSSS VENDOR
CODE DESCRIPTION
B - BABCOCK & WILCOX
C - COMBUSTION ENGINEERING
G - GENERAL ELECTRIC
M - WESTINGHOUSE

DG MANUFACTURER

CODE DESCRIPTION
AL - ALLCO
CA - CATERPILLAR
CB - CLOPER-BESSEMER
DL - DE LAVAL
FM - FAIRBANKS MORSE
GM - GENERAL MOTORS
MM - NORDBERG MANUFACTURING
WG - WORTHINGTON

KW RATING

CODE DESCRIPTION
02 - 200-400 KW
10 - 500-1000 KW
18 - 1750-1950 KW
25 - 2500-2850 KW
30 - 3000-3500 KW
40 - 4000-4418 KW

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	CONTROL NO.	FAIL DATE	FAIL TIME	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
B	AK1 11858	051176	GM25 C	01	FAIL TO START ON SIMULATED E.S. ACTIVATION	FAIL DUE TO IN AUTO START CIRCUIT
B	AK1 01646	112276	GM25 M	04	UNOPERABLE DUE TO WET CIRCUITRY	INADVERT OPER OF FIRE DELUGE SYSTEM
B	AK1 01647	080577	GM25 M	03	MONTHLY SURVEILLANCE TEST NOT PERFORMED ON TIME	THIS IS A REPETITIVE OCCURRENCE
B	AK1 01927	102377	GM25 C	14	FAIL TO START:DRIFT OF TD RELAY SETPOINT	ALSO DIODE CR-1 FOUND SHORTED
B	AK1 02163	032078	GM25 E	00	ON FIRE DUE TO LUBE OIL GETTING INTO EXHAUST TURBOCHARGER BEING FAILED:CAUSING SEAL FAILURE	
B	AK1 01823	060277	FM30 A	13	MAN DG FAIL TO START ON MONTHLY TEST	LOOSE INJECTOR HOLD-DOWN NUTS
B	AK1 01826	072677	FM30 I	06	DIESEL TRIPS WERE NOT RESET	REVISED PROCEDURES TO RESET TRIPS
B	AK1 01932	092877	FM30 B	10	START PERMISSIVE LOST	DUE TO LOW LUBE OIL PRESSUR
B	AK1 02021	122777	FM30 G	09	REPEAT OCCURANCE	SMALL PIECES OF INSULATION PREVENT GOVERNOR
B	AK1 02027	010378	FM30 G	09	REPEAT OCCURANCE	FOREIGN MATTER IN SERVO MOTOR
B	AK1 02106	111778	FM30 M	00	START ON TWO CONS. ATTEMPTS	STARTED SUCCESSFULLY TWICE AFTER ANOMALY
B	AK1 01961	122977	GM25 G	14	START AND TRIP ON OVERSPEED	IMPROPER SETTINGS OF HI SPEED AND OVERSPD
B	AK1 02073	010978	GM25 F	09	TRIP ON HI CRANKCASE PRESSURE	DILTY CRANKCASE VENT OIL COLLECTOR
B	AK1 02076	020878	GM25 E	05	DUE TO DILTY TURBOCHARGER	DESIGN/FABRICATION OR COMPONENT FAILURE,REPLACD
B	AK1 02158	050978	GM25 E	00	GEN LOAD FLUCTUATING AIR INTAKE LU PRESS ALARM	CAUSE UNKNOWN EXTENSIVE MAINT PERFORMED
B	AK1 02182	060478	GM25 K	10	FAIL TO OPERATE WITH PROPER FREQ/VOLT	FAIL PRIMARY POTENTIAL FUSE FOR DG 1-1
B	AK1 02204	071978	GM25 M	06	DIESEL START TIME NOT CHECKED	PROCEDURES MODIFIED
B	AK1 02262	091478	GM25 M	03	PERFORMANCE TEST NOT PERFORMED	PERSONNEL ERROR
B	AK1 02307	103178	GM25 M	01	ROOM TEMP ROSE TO 116 DEG.	OUTSIDE AIR DAMPER WOULD NOT OPEN
B	AK1 01959	071976	GM25 M	00	SEVERAL ATTEMPTS TO START WERE UNSUCCESSFUL	NO DEFINITE CAUSE COULD BE FOUND

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	UNIT	CONTROL NO.	FAIL DATE	FAIL TIME	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
B	R01	016056	080676	GM25	C A10	U 4 T	IMPROPER GEAR ENGAGEMENT-AIR START MTR OCC
B	R01	016056	120676	GM25	G B10	D B T	SPEED CONT SW FLD CLOSED SPD DECR TO TRIP
B	R01	016053	082477	GM25	M A00	R U I T	NO SPECIFIC CAUSE COULD BE DETERMINED
B	R01	022613	100478	GM25	A B01	S D I N	FUEL LEAK-EXCESSIVELY LOOSENED STMP PKG GLMC
B	R01	022827	110278	GM25	K J10	D B T	BLOWN CONT. POWER FUSE IN VOLT. REGULATOR
B	T11	014298	022176	FM30	J A06	S O I T	FRCCD ERROR-IMP GOV SETTING-FREQ TOO LOW
B	T11	017050	020377	FM30	B G10	D B N	AN ES SIGNAL-FAULTY PRESSURE SWITCH
B	T11	020295	011278	FM30	B A14	S T 4 T	OIL PRESS LIM SW PRESS SETTING DRIFTED
B	T11	020997	031878	FM30	B A10	F B T	DEFECTIVE OIL PRESSURE LIMIT SWITCH
B	T12	021009	042578	FM30	F B00	K U I T	NO ABNORMAL PARAMETERS WERE FOUND
B	T12	021007	052078	FM30	F A05	C D G T	VERT SHFT B1M UP E LWR CRANKS FLD-IMP MTL
B	T12	021005	052378	FM30	F B09	K T B M	PART PLUGD CRIFICE PLATE-TO-CRCKSE VAC EJA
B	T12	023430	122878	FM30	A A09	I B T	PARTIALLY CLOGGED FUEL OIL FILTER
C	CC1	015987	072976	FM25	D A02	A D N	JACKET COOLING H2O SYS AIRBOUND NOT VENTD
C	CC1	015984	080776	FM25	J A02	S D G T	WILL NOT CLOSE--COLD SOLDER CONN TO ERA
C	CC1	016405	102576	FM25	M B00	K U I T	CAUSE FOR BLOWN FUSE NOT DETERMINED
C	CC1	017443	111876	FM25	M A00	H U I T	BLOWN FUSE--REPLACED CONTROLLER COIL ??
C	CC1	017024	051577	FM25	M A09	R F B T	DIRT ON FAN MAIN BRK CONTACTS
C	CC1	018041	060377	FM25	B U13	R T 4 N	FITTINGS VIBRATED LOOSE --TIGHTENED THEM
C	CC1	018306	061777	FM25	F B02	D I T	VALVE VIBRATED LOOSE AND FELL OFF DG

 ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

V L N	P L A N T	CONTROL NO.	FAIL DATE	M F G	K W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
C	CC1	018468	071177	FM25	B	B02	C	D	4	M	#11	DG	ON FIRE DUE TO L.O. HITTING HOT EXHAUST	O-RING SEAL ON STRNR NOT GLUED PROPERLY
C	CC1	018487	071377	FM25	D	B02	S	D	1	T	#11	DG	TRIPPD ON LOW JACKET COOLNT PRESS WHEN SIAS	SIGNAL REMOVED;OP SWITCH ISOLATED
C	CC1	019592	101077	FM25	K	A13		T	8	T	#12	DG	FAILED TO REACH VOLTAGE WITHIN 10 SEC.	2 LOOSE FUSE HLDRS IN EXCITATION CIRCUIT
C	CC1	019655	111577	FM25	B	U13	R	T	0	T	#12	DG	OOS DUE TO MINOR FUEL LUBE COOLING H2O LEAK	LOOSE FITTINGS OLD GASKETS LOOSE FLANGES
C	CC1	019738	111677	FM25	B	U13	R	T	4	N	#12	DG	OOS TO REPAIR MINOR LEAKS FUEL & LUBE OIL	TIGHTENED FITTINGS,FLANGES
C	CC1	021060	041078	FM25	L	A00		U	1	T	#12	DG	OVERSPED & TRIPPED RESTARTED SUCCESSFULLY	CAUSE NOT DETERMINED TESTED SAT NEXT TIM
C	CC1	021055	041378	FM25	M	A00		U	1	N	#11	DG	FAILED TO START ON LOSS OF OFFSITE POWER	START/FAILURE ALARM DISPLAYD NO ABNORMALS
C	CC1	023380	121878	FM25	M	B00	R	D	1	T	#11	DG	SHUTDOWN DUE TO ROOM VENT,FAN FAILED TO STRT	FAN FAILURE--RESET OVERLOADS
C	CC2	016722	121576	FM25	C	A09		T	4	T	#21	DG	FAILED TO START FROM CONTROL ROOM & LOCALLY	CLOGGED AIR STRT DISTRIBUTOR PILOT VALVES
C	CC2	018422	022277	FM25	C	A00		U	8	T	#21	FA	ILED TO START & ASSUME RATED SPEED IN 10 SEC	AIR START SYS DISASSMRLD & INSPECTED
C	CC2	017457	031777	FM25	M	A00	R	U	1	T	#12	DG	VENT FAN FAILED TO START ON SIAS SIGNAL	OVERLOADS TRIPPD ON FAN; RESET OVERLOADS
C	CC2	017986	060177	FM25	D	A12		T	0	T	#21	DG	FAILED TO MEET START TIME CRITERIA	SERVICE WATER INLET VALVE LEAKING EXCESVL
C	CC2	018428	062177	FM25	B	U13		T	4	N	#21	DG	OOS DUE TO MINOR OIL LEAKS	FUEL OIL LEAKS FROM LOOSE FITTINGS
C	CC2	018489	071877	FM25	B	U12		T	8	N	#21	DG	OOS TO REPAIR CRACKED BULLSEYE (GLASS)	REPLACED GLASS WITH PLEXIGLASS WINDOW
C	CC2	019481	110177	FM25	D	U13		T	0	N	#21	S/D	FOR 7 HRS. FOR PMS LEAKS ON H2O JACKT REL	1/4" FUEL OIL TUBN TO INJ TIGHTENED
C	CC2	020226	011078	FM25	J	B10		T	1	T	#21	DG	TRIPPED AFTR 29 MIN. DUE TO GEN FAULT	LOSS OF FIELD & REVERSE POWER RELAYS
C	CC2	021791	080178	FM25	D	B10	S	D	4	T	#21	DG	TRIPPD ON HI JACKET COOLNT TEMP	SERV H2O SUPPLY VALV FAILED TO OPEN
C	FC1	014559	040776	GM25	M	A06	S	D	1	T	START	ON	SECONDARY AIR REQUD 10.6 SECS.VS. 10SECS.	PROCEDURE WAS INADEQUATE
C	FC1	014596	042776	GM25	C	A02	F	D	8	U	DG-2	PRIMARY	AIR START MTR FAILED TO DISENGAGE	IMPRPR SETNG FOR MAG PKUP ON SWTCHG TACH
C	FC1	015614	081576	GM25	G	B10		T	8	N	SMOKE	COMING	FROM DG-2 GOVENOR MOTOR E-CLOSURE	ARMATURE HAD OPEN WINDING

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	CONTROL NO.	FAIL DATE	FAIL TIME	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
C	FC1	015722	081576	GM25 C 14 T 0 B U	PRIMARY AIR START MTR FAILED TO DISENGAGE	SETTING FOR MAG PUMP ON SWITCH EACH DRIFTED
C	FC1	017628	040677	GM25 C 409 M T 4 T	DG-1 FAILED TO START WHEN 10 SEC START OK ON PRI AIR	DEPOSITS FOUND ON SECONDARY AIR MOTORS
C	FC1	017661	040777	GM25 A 001 0 G R	FUEL OIL STORAGE READINGS SLIGHTLY BELOW TECH.SP.	DISCOVERED FOUR DAYS LATER, TANKS WERE FILLED
C	FC1	017662A	041477	GM25 C 409 R F 4 T	DG-2 FAILED TO START IN 10 SEC START OK ON PRIMARY	DEPOSITS IN SECONDARY AIR MOTORS
C	FC1	021692	061978	GM25 K 810 R 0 T 0 G	DG-1 FAILED TO REACH RATED TERM VLTG ON STARTUP	BLOWN FUSE IN GEN FIELD CIRCUIT
C	FC1	021799	071278	GM25 K 810 R 0 T 0 G	DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN	3 EXCITER SUBCOMPONENT FAILURE(SICINCIDENT)
C	FC1	022249	080978	GM25 K 810 R 0 T 0 G	DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN	REFER VOLTAGE ZENER DIODE OUTPUT DRIFTED
C	M12	014164*	012876	FM25 M 003 0 B T	DG 120 E 130 005 W/O PERFORMANCE OF SURV TESTING	OPEN THROUGHT SURV TEST UNNEC IF DGS - PMS
C	M12	014266A	021776	FM25 A 809 B T 1 N	DG 120 FAILED TO START - SIMILAR OCCUR, LER (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRKCSSE VENT
C	M12	014260B	021876	FM25 A 809 B T 1 N	DG 120 TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRKCSSE VENT
C	M12	014260C	022076	FM25 A 809 B T 1 N	DG 120 TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRKCSSE VENT
C	M12	014260D	022376	FM25 F 804 B T 1 G	DG 120 TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	UPPER ROD BEARING FAILURE - LACK OF LUBRI
C	M12	014452	032476	FM25 M 003 0 L M	DG 130 NOT TESTED AFTER DG 120 DECLARED INOPERABLE	OPER UNANWARE OF REGMT TC TEST ALL DIESEL
C	M12	015106	060276	FM25 F 809 B T 1 T	DG 130 TRIPPED ON HI CRANKCASE PRESS - 11 MIN RUN	CRKCSSE AIR EDUCATOR FOUND DIRTY
C	M12	015216	061776	FM25 B 011 T 4 N	130 DG STBY LO PMP TRIPPED, LG TEMP DECREASED	NO CAUSE FOR TRIP, TEMP WOULD PREV DG STRI
C	M12	015283A	081676	FM25 G 810 B T 4 T	DG 120 FAILED TO START	DRIED LEATHER WASHER IN BOOSTER SERVO MOTOR
C	M12	015283B	081776	FM25 G 810 B T 4 T	DG 120 FAILED TO START	DRIED LEATHER WASHER IN BOOSTER SERVO MOTOR
C	M12	015283C	082376	FM25 G 810 B T 4 T	DG 120 TRIPPED OFF-LINE	DRIED LEATHER WASHER IN BOOSTER SERVO MOTOR
C	M12	015906	090176	FM25 B 812 C T 1 N	DG 130 SHUTDOWN - FIRE ON EXHAUST MANIFOLD	LUBE & FUEL OIL ACCUM UNDER MANIF INJULAY
C	M12	016036	091976	FM25 B 812 B 0 4 N	120 DG HAD TO BE SECURED AND DECLARED INOPERABLE	EXCSV LEAKAGE OF LUBE OIL FILTER GASKET

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	UNIT	CONTR NO.	FAIL DATE	MODE	DESCRIPTION	MECHANISM
C	M12	016031	092276	FM25 D	12U DG RECVD LOW CW FLD ALA-UNIT UNLOADED, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12	016020	120176	FM25 D	13U DG STARTED, NO CW FLOW, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12	016755	121876	FM25 F	06 T 06 13U W3 UPPER PISTON CON ROD BRNG CAP SHEARED	CAPSCREWS FAILED - PROB DUE TO DRY STARTS
C	M12	017620	011077	FM25 F	06 T 06 13U SHUTDOWN DUE TO HIGH VIBRATION	SKID MOUNT IN RESONANCE WITH ENG FREQUEN
C	M12	022371	026977	FM25 B	06 U 13U DG REMOVED FROM SERVICE	REMOVE & RECALB LUBE OIL TEMP SWITCH
C	M12	017837*	051577	FM25 A	06 U N BOTH DG'S FUEL SUPPLY VLVS FOLWD SHUT-8CTH DG INDP	REASON FOR SHUT VALVES WAS UNKNOWN
C	M12	016923	081077	FM25 G	06 I N DG 12U FAILED TO RESTART ON DEMAND	GOVERNOR STILL IN "NO FUEL" FROM PREV STD
C	M12	016972	081777	FM25 D	06 T 12U DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12	016974	082377	FM25 M	06 U N 12U DG RETURNED TO SERVICE WITHOUT OPERABILITY TEST	OPER DIDNT KNOW TEST REQD AFTER PREV MIN
C	M12	01676A	082677	FM25 D	06 T 06 T DISCOVERED 13U DG SW HA MUSSEL FOULED	INSUF CL INJECTION FOR ADD MUSSEL CONTROL
C	M12	016976B	092077	FM25 D	06 T 06 N COOLING WTR LGW FLOW ALARM - 12U DIESEL GEN	INSUF CL INJECTION FOR ADD MUSSEL CONTROL
C	M12	019259	092477	FM25 I	06 T 12U DG APPEARED TO TRIP ON GEN OVERCURRENT	MICRO SW CUT OF ADJ ON DG DVSPD TRIP MECH
C	M12	01929	110977	FM25 K	06 I T 06 13U TRIPPED WHILE PARALLELING WITH #160W BUS	IMPROPER VOLTAGE SETTING PRIOR TO PARALL
C	M12	021986	050878	FM25 D	06 T 12U DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12	022131	080378	FM25 A	06 T 06 T 13U SHUTDOWN DUE TO LEAKING INJECTOR	CRACK IN INJ PUMP DISCH VALVE CAGE
C	M12	023243	120578	FM25 D	06 T 12U DG S/D DUE TO LOW COOLING WATER FLOW	MUSSEL SHELLS IN THE HEAT EXCHANGER
C	M11	020733	021878	GM25 G	06 T 06-1A FAILED TO RESPOND DURING TEST RUN FOR TRAINING	DIRTY CONTACT CN SPEED CONTROL PC BOARD
C	M11	022719	092578	GM25 A	06 I T 06-18 COULD NOT BE LOADED DURING TEST AFTER MAINT	AIR WAS NOT PURGED FROM FUEL LINES
C	PAL	017219	021177	AL25 C	06 I N DG 3-2 HAD 1 OF ITS AIR START MUFFERS CYCLE	DEPLETED AIR SUPPLY, WATER LRG GND MOTOR
C	PAL	019409	082377	AL25 A	06 C I N M LEVEL IN DIESEL FUEL OIL STG TANK DECRSD TO 53 PCT	SUPPLIER FAILED TO DELIVER PER SCHEDULE

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	CONTROL	FAIL DATE	PK	FAILURE MODE	FAILURE MECHANISM
NO.	NO.	---	---	OUT OF SERVICE	
C SL1 015003	051876	GM30 C U09	F 6 T	"A" DG PLACED OUT OF SERVICE	AIR START SYS VALVES & LINES CLOGGED W/DIRT
C SL1 016881	110276	GM30 M A01	D 4 T 1A	DG FAILED TO START	PERSUNNEL ERROR - INCORRECT VALVE LINEUP
C SL1 017134	011877	GM30 E B04	R 1 G T 1B	DG RAN FOR 55 MIN THEN TRIPPED ON LOCKOUT	TURBOCHARGER SHAFT AND CIL SEAL DAMAGED
C SL1 017135A	011977	GM30 A A09	R 1 T THE 1A	DIESEL GENERATOR FAILED TO START	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C SL1 017135B	011977	GM30 A A09	R 1 T THE 1A	DG FAILED TO START AGAIN - LATER SAME DAY	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C SL1 017441	030177	GM30 I A01	S 0 1 T 1A	DIESEL GENERATOR FAILED TO START	CPER FAILED TO RESET OVERSPEED TRIP
C SL1 019511	092677	GM30 E B04	R 1 G T 1A	DG SHUTDOWN WHEN SMOKE ISSUED FROM TURBOCHARGER	FAILED TURBO CHARGER UNIT
C SL1 022532	090578	GM30 J A10	T 6 T "A"	DG OUTPUT BREAKER WOULD NOT CLOSE REMOTELY	DIRTY CONTACTS ON ITS OPERATION RELAY
G BFI 214162	011476	GM30 G A12	T 1 T	FAILED TO RESPOND TO ELEC. GOVNR SIGNALS DG #0	OIL DRAINED FROM HYDRAULIC ACTUATOR
G BFI 016261	110376	GM30 G B09	C 4 T 1 G	DG ERRATIC SPEED BEHAVIOR UNDER LOAD	DIRTY OIL IN GOVERNOR
G BFI 016396	112276	GM30 C U02	U 4 M	ONE START CIRCUIT ON B DG INOP; 2ND START CRT. OK	BROKEN STLD HOLDER ON BREAKER, REPLACED
G BFI 022084	070978	GM30 K U11	D 4 T 1 C	DG FIELD BRK TRIPPED; DG INOPERABLE	OVERHEATING OF BRK DUE TO INOPERABLE FAN
G BFI 016817	112676	GM30 C U02	U 8 M	START CRT. 1 OF DG 3D INOP DUE TO RELAY FAILURE	NOT ABLE TO SENSE SPEED IN START CRT.
G BFI 019233	091977	GM30 K A10	0 1 T 3D	DG TRIPPED ON OVERSPEED; GOVERNOR INOPERABLE	TO FUSE OPEN DISENABLING FIELD CIRCUIT
G BFI 021760	070678	GM30 J U10	U 8 M	4-KV STANDBY POWER CRT BRK DEFECTIVE; DG INOPERABLE	SHORT IN WINDING OF A SPRING CHARGE MOTOR
G BFI 019417	032476	CA02 D B09	R 1 B T 1 B	DG TRIPPED ON HI COOLING WATER TEMP	WATER PUMP SUCT SCREEN PLUGGED
G BFI 019094	051676	CA02 D B09	R 1 G M	DG TRIPPED ON HI COOLING WATER TEMP PUMP SHAFT SCORRED	INLET SCREEN PARTIALLY PLUGGED
G BFI 019448	080576	CA02 M A03	R 1 U T 1 G	DG FAILED TO START WITHIN 15 SEC NOT RETESTED	OPERATOR NOT AWARE OF SIGNAL OF START LIM
G BFI 019449	080576	CA02 D A00	R 1 U B M	DG FAILED TO START WITHIN 15 SECONDS DURING WEEKLY	POSSIBLE WATER JACKET HEATER FAILURE
G BFI 019444	041276	CA02 C A10	R 1 B T	WEEKLY TEST FAILED TO START	STARTING BATTERY CABLE FAILED LOOSE CONNCT

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

E N	P L A N T	C O N T R O L N O .	F A I L D A T E	M F G N O .	S E C S	F A I L M O D E				F A I L M E C H A N I S M	F A I L U R E M E C H A N I S M
						A	R	U	T		
G BP1	016072	090276	CA02	A	A00	R	U	C	T	FAILED TO MEET 15 SEC START TIME DURING WEEKLY TEST	POSSIBLE FUEL SYSTEM FAILURE
G BP1	016304	102876	CA02	G	A00	R	U	U	T	DG FAILED TO START WITHIN 15 SEC	POSSIBLE FUEL GOVERNOR CONTROL PROBLEM
G BP1	016460	110476	CA02	G	A00	R	U	U	I	START TIME 2.2 SEC SLOWER THAN REQUIRED	POSSIBLE FUEL GOVERNOR PROBLEM
G BP1	016587	111876	CA02	C	A10	R	D	4	T	FAILED TO START IN AUTO TEST; STARTER MOTOR PROBLEM	BROKEN SPRING IN BENDIX MECHANISM
G BP1	016597	120276	CA02	G	A00	R	U	U	T	FAILED TO MEET 12 SEC START TIME DURING AUTO TEST	FUEL GOVERNOR REPLACED ON 12/19/76
G BP1	016913	122076	CA02	G	A04	R	U	U	T	START TIME EXCEEDED CRITERIA BY 4 SEC	GOVERNOR LUBE & FUEL SYS UNDER INVESTIGTN
G BP1	016912	122776	CA02	A	A04	R	U	U	T	START TIME GT. CRITERIA 15 VS 12	FUEL GOV. LUBE OIL SUPPLY MODIFIED 1/10/77
G BP1	016911	122876	CA02	C	A10	R	D	4	M	DEFECTIVE STARTER DRIVE, DG FAILED TO START	BROKEN SPRING DELCO PART #1945487
G BP1	016910	010377	CA02	G	A00	R	U	U	T	FAILED TO START IN AUTO TEST	CAUSE UNKNOWN LUBE OIL RETENTION IN GOV.?
G BP1	017022	011077	CA02	G	U04	R	U	B	N	REMOVED FROM SERVICE FOR CORRECTIVE MODIFICATION	LUBE OIL SUPPLY TO GOV. MODIFIED
G BP1	020296	032477	CA02	G	A00	R	U	U	T	EDG STARTING TIME EXCEEDED 12 SEC. BY .8 SEC.	GOVERNOR LUBE SYS MODIFIED ON 1/10/77
G BP1	018102	051877	CA02	D	A00	R	I	4	T	H2O JACKET HEATER FAILURE--EDG TESTED; DID NOT MEET	T TIME CRITERIA; EXCEEDED BY 12 SECONDS
G BP1	018103	052677	CA02	A	A00	R	U	U	T	START TIME 16.5 SEC, SHOULD BE LT 13.9 SEC	FUEL CONTROL VALVE MODIFIED
G BP1	018742	080577	CA02	J	A04	S	D	G	T	TESTED EDG WITH 2A-2B BKR RACKD OUT; AUTO TRANSFER	AND MAN TRANSFER FAILED TO CLOSE OUTPUT BKR
G BP1	019541	102077	CA02	C	A00	R	U	U	T	START TIME 21.8 SEC VS. 13.9 SEC	CHECKD VOLTAGE DRGP ON START CABLES
G BP1	019993	112477	CA02	A	A00	R	U	U	T	START TIME 33 SECS TESTED SAT WITHIN ONE HOUR	FUEL CHECKED OK PREM GRADE OF FUEL USED
G BP1	020575	020278	CA02	M	A00	R	U	U	T	START TIME 28.5 SECS VS 13.9 SECS	CAUSE UNKNOWN
G BP1	020580	020978	CA02	D	B12	F	4	T	DG	TRIPPED ON HI WATER TEMP AFTR 25 MIN OF OPS	AIR LEAKAGE ON PUMP COOLING WATER SHAFT
G BR1	016854A	010477	NM30	B	A04	C	D	4	I	#3 DG TRIPPED R/A AT POWER LOW LUBE OIL TEMP	LOW SETPOINT FOR PRE-FILTER HEATER #JACKI
G BR1	016854B	010477	NM30	B	A04	C	D	4	I	#4 DG TRIPPED R/A AT POWER; TO SWITCH NGT RESET	L.C.PRESS SWITCH TIME DELAY INCORRECT

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

V E N T	P L A N T	CONTROL NO.	FAIL DATE	M F K W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I S C O N N E C T E D	FAILURE MODE		FAILURE MECHANISM
												FAILURE MODE	FAILURE MECHANISM	
G BK1	019275A	091277	NM30	M	U01	R	D	U	N	R/X AT PWR #1 DG REMOVED FROM SERVICE FOR ANN. INSP T.S.4.5.F NOT PERFORMED ON 9/15/77				
G BR1	019275B	092877	NM30	M	U01	R	D	U	N	#3 DG OUT FOR ANN. INSP. T.S.4.5.F NOT PERFORMD #4DG OPERATOR ERROR				
G BK1	019391	101177	NM30	G	B05	D	B	T	#2 DG UNABLE TO MAINTAIN LOAD CYCLING 500KW	SHORTED LEADS TO GOVERNOR; INCORRECT A3MB				
G BR1	020008	120977	NM30	C	A09	T	D	T	#3 DG START TIME 10.2 SEC VS 10	CARBON BUILDUP ON AIR VALVE STUCK SHUT				
G BR1	019948	121077	NM30	J	B00	D	D	T	SMOKE COMING FROM 320 RELAY AND 80DB RELAY FLAMING	REPLACED AND CALIBRATED RELAYS				
G BR1	020246	010678	NM30	I	U01	S	D	4	N	#2 DG SECURED OPERATOR FAILED TO RESET LOCKOUT	#2 DG INOPRBLE FOR 1.5 HOURS			
G BR1	022454	091178	NM30	A	B07	T	4	T	#1 DG CYLINDER #1 NOT FIRING--HEAVY LOADING ???	FAULTY FUEL PUMP REPLACED				
G BR2	014136	010976	NM30	J	A10	D	4	N	#1 DG STARTED BUT OUTPUT BKR FAILED TO CLOSE TO E-1	BROKEN LUG WIRE DUE TO STRESS				
G BR2	014614	031476	NM30	A	B12	T	D	T	AT 96% POWER #2 DG STARTED TO CYCLE IN LOCAL-MANUL	FUELOIL SHIFT VALVE LEAKN GASKET RENEWED				
G BR2	014609	032576	NM30	M	U01	D	G	N	REFUEL MODE, 3DG BEING PM'D; FAILED TO TEST S8GT B	#8M TRAIN NOT TESTED TILL 3/29/76				
G BR2	015461	061176	NM30	A	A02	C	D	D	T	#1 DG STALLED & FAILED TO TIE INTO E-BUS R/X AT PR	40 GAL H2O IN SADDLE & 4 DAY TANK			
G BR2	016399	111176	NM30	C	A08	T	D	T	DG FAILED OPER TEST--12.2 ON #2 AIR RECIEVER	CHECK VALVE RUSTED SHUT				
G BR2	016823	122976	NM30	G	B10	T	B	T	#2 DG FAILD OPERABILITY TEST --LOSS OF SPEED CONT.	CLUTCH ADJUSTED AND STATOR VOLTMTR REPLAC				
G BR2	018177	060777	NM30	M	U03	D	V	T	WHILE SECURING DG1 OPERATOR REDUCED LOAD TOO FAST	BKR TRIPPED ON REVERSE POWER AND DG LOCOUT				
G BR2	020612	021378	NM30	K	A01	S	D	1	N	FOLLOWING SCRAM ON UNIT 1 ;#1 DG LG RELAY WOULDN'T	RESET;LOSS OF EXCITATION RELAY NOT RESET			
G C01	015872	082976	CB40	A	B00	U	B	T	FUEL LINE TO AN INJECTOR OF #1 DG BURST	CAUSE UNDETERMINED				
G C01	016560	110776	CB40	K	B08	T	D	T	DG-2 LOST ELECT GOVERNOR CONTROL AND VOLTAGE	POT. TRANSFORMER FUSE CONTACTS OXIDIZED				
G C01	016712	111076	CB40	J	A03	S	D	B	T	EG-1 OUTPUT BKR FAILED TO CLOSE--BLOWN FUSE 59RELAY	DISCONNECTED ONLY ONE WIRE ON 11/8/76			
G C01	017064	121576	CB40	J	U10	B	D	U	I	COMPLETE DG TEST; BKR. IFS WOULD NOT CLOSE AUTG IF	BKR IAF CR IFA TRIPPED--AUX CONTACTS POOR			
G C01	019417	091277	CB40	A	U04	D	G	N	FUEL OIL RETURN LINE SHEARD AT INLET TO DAY STORAG	RIGID HANGER WORKED LOOSE CAUSN EX MOVEM				

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

V C N	P L A N T	C O N T R O L N U. N O.	F A I L D A T E	M F K W	S Y S T E M	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	K E Y W O R D S	D I S C U S S I O N	F A I L M O D E	F A I L M E C H
G	CU1	020803	011778	CB40	J	010	B	D	U	1		AUX SWITCHES FAILED TO CLOSE ON DG OUTPUT BKR THIS	WOULD PREVENT SHUTTING BKPS. IFS AND 145
G	CU1	023044	091278	CB40	F	A09	T	G	T	#2	DG	TRIPPD APPROX 1 MIN AFTR REACH RATED SPEED	MAIN BEARING FAILED DUE TO LOW LUBE OIL
G	DA1	014334	022775	FM25	B	812	R	T	D	T		SMALL FIRE ON EXHAUST MANIFOLD OF DG 1G21	OIL LEAK FROM FRONT COVER PLATE
G	DA1	014337	031776	FM25	H	812	R	T	D	T		SMALL FIRE NEAR EXHAUST MAN-FURBOCHGR FRANGE	1G21 LEAKY FLANGE GASKET
G	DA1	014953	062276	FM25	D	809	C	T	H	T		1G-31 DG TRIPPD ON HI JACKET TEMP-DECLARED INOPRBL	ESW LOW FLOW DUE TO MUD IN STRAINER
G	DA1	015943	100776	FM25	F	A05	D	D	T			1G21 BROKEN LOWER VERT DRIVE COUPLNG HUB	HUB MADE OF WRONG MATERIAL
G	DA1	016449	110276	FM25	M	006	D	G	R			1G-21 & 1G-31 ANNUAL INSPECT NOT PERFORM ON TIME	COMPLETED 10/21/76 VS 9/15/76
G	DA1	016452	110476	FM25	A	804	D	D	T			DG 1G-21 S/D DUE TO FIRE -FUEL LINE FRACTURE	INADEQUATE DESIGN
G	DA1	017726	051077	FM25	J	A10	S	D	B	T		1G-21 DG OUTPUT BKR FAILED TO CLOSE	AUX CONTACTS OF STNDBY TRANSFORMER OPEN
G	DA1	017963	051277	FM25	G	806	S	D	I	T		1G-31 DG WOULD NOT REACH FULL LOADING ONLY 2500 KW	SPEED SETTING ADJUSTMNT NOT RESET
G	DA1	019448	100677	FM25	A	004	D	G	M			STNDRY DG FUEL STRGE TANK INDICATOR INCORRECTLY CAL	ACTUALLY 2000 GAL LESS THAN INDICATED
G	DA1	021171	040578	FM25	F	A06	D	G	M			BEARING WIPED ON 4/13/77 NOT DUE TO MISALIGNMENT	LUBE OIL FILTER DRAIN VALVE WAS OPEN
G	DA1	023503	122778	FM25	M	001	D	G	N			CORE LOADING 1G-21 INOP; T.S.3.7.8 VIOLATED	1G-31 NOT TESTD DAILY--12/25 TO 12/31
G	DR1	016167	093076	GM10	A	002	C	D	B	N		BACK-HOE SEVERED FUEL OIL TRANSFER LINE TO UNIT1 DG	AND FIRE PUMP; PROMPTLY REPAIRED
G	DR1	020408B	012778	GM10	M	A11	C	D	I	M		U-1 B/U DG FAILED TO START 1ST 3 TIMES-LOW TEMPERAT	WINTER WEATHER
G	DR1	020408A	012978	GM10	M	A11	C	D	G	N		U-1 FAILED TO START DUE TO COLD WEATHR & HEATPS	INSTALLED & ROOM WINTERIZED
G	DR1	020812	030478	GM10	C	A10	D	G	T			D-1 B/U FAILED TO START R/X IN HOT S/D MODE	SYNCHRO START SWITCH FAILED
G	DR1	021518	050378	GM10	C	002	S	D	D	N		LOW STARTN AIR PRESS DUE TO LEAKING PILCI AIR REG.	IMPROPERLY POSITIONED O-RING
G	DR1	021517	050778	GM10	B	A10	T	D	N			TEMPORARY DG FAILED TO START DUE TO LOW LUBE OIL PRS	L.O. PUMP COUPLING DAMAGED
G	DR1	021516	051178	GM10	A	A10	K	D	G	T		TEMP. DG FAILED TO START-BLOW FUSES IN CONT LOGIC	SHORTED DIODE ACROSS FUEL PRIMING PUMP

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

V E N T	P L A N T	C O N T R O L N O.	F A I L D A T E	M F G K W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE		FAILURE MECHANISM	
												FAILURE MODE	FAILURE MECHANISM		
G DR1	021537	060678	GM10	A	U01	D	G	N	BACKUP DG DAY TANK EMPTY AND TRANSFER PUMP WAS OFF	PUMP STARTER FAILED AND PERSONEL ERROR					
G DR2	014913	052376	GM25	C	A00	U	L	T	UNIT 2/3 DG FAILED TO START	CAUSE UNKNOWN BUT POSSIBLE AIR START SYST					
G DR2	015242	071076	GM25	D	U11	D	L	N	U-2 DG COOLING H2O PUMP BKR FOUND TRIPPD	EXCESSV TEMP IN BKR SUBICLE					
G DR2	016018	090576	GM25	M	U08	C	T	G	N H2O LEAKAGE INTO U 2/3 DG ROOM; SMALL HOLE IN HPCI	TEST RETURN LINE; CHLORIDE STRESS CORROSN					
G DR2	016168	093076	GM25	K	B09	T	D	T	2/3 DG OUTPUT ERRATIC AFTR CONTRD PLACED IN "STOP"	SHORTR SILENIUM RECIFIER DUE TO DIRT					
G DR2	016443	102976	GM25	I	A14	S	T	D	UNIT 2 DG FAILED TO START TWICE MALFUNCT S/D SOLEND	SOLENOID PLUNGER OUT OF ADJUSTMENT					
G DR2	016654	121876	GM25	A	B02	S	D	D	UNIT 2 DG FAILED TO CARRY REQD LOAD ;2000KW MAX	H2O IN FUEL SUPPLY FROM FLUSHING OPERATOR					
G DR2	017397	032277	GM25	C	A10	R	D	I	UNIT 2/3 FAILED TO START	AIR START MOTOR PINION GEAR JAMMED					
G DR2	018283	063077	GM25	G	A00	R	D	I	2/3 DG TRIPPD ON OVERSPEED DURING 2 ATTEMPTS	POSSIBLE CUT-OF-ADJUST GOVNR COMPENSATION					
G DR2	018454	071277	GM25	G	A00	R	D	I	U 2/3 D/G TRIPPD ON OVERSPEED--OCCURD ALSO 6/30/77	PROBABLE CUT-OF-ADJUST GOVNR COMPENSATION					
G DR2	019051	103077	GM25	E	B06	T	G	T	UNIT 2/3 UNLOADED TRIPPD ON LOW H2O PRESS RESTART	TURBO-CHARGER CLUTCHSHAFT BEARING					
G DR2	019732	111677	GM25	I	A00	S	D	I	AUTO-START SIGNAL SENT TO UNIT 2/3 DURING CORE SPRY	RESET START FAILURE RELAY & DIESEL STARTED					
G DR2	019728	112977	GM25	D	B12	C	D	D	2/3 DG S/D DUE TO COOL H2O PUMP TRIP 10MIN. LOADED	WATER LEAKD GROUNDED PUMP STATOR					
G DR2	019723	120277	GM25	C	A13	R	T	I	UNIT 2 DG AIR RECIEVR LOW PRESS TERMINATED START	LOOSE WIRE AT TERMINAL 25A5					
G DR2	019810	120377	GM25	C	A12	D	4	T	2/3 DG FAILED TO ROLL OVER--LOW START AIR PRESSURE	RUPTURED REGULATOR DIAPHRAM					
G DR2	019905	120477	GM25	J	A00	U	L	T	U2 DG OUTPUT BKR FAILED TO CLOSE--NO APPARENT CAUSE	3 SUBSEQUENT TESTS WERE SUCCESSFUL					
G DR2	020242	010378	GM25	C	A13	R	T	I	UNIT 2 DG FAILED TO START WEEKLY SURV TEST	LOOSE WIRE AT TERMINAL 25A5					
G DR2	021048	030778	GM25	C	A00	S	D	B	I OPERATOR SHOOK AIR START SOLENOID & UNIT 2/3 STARTED	POSSIBLE WIRE DAMAGED DUE TO FREQ INSPEC					
G DR2	020855	030878	GM25	G	A14	S	D	B	T ENGINE OVERSHOT AT 1010 RPM WHILE OS SET AT 1020	HI OVERSHOOT BY OUT-OF-ADJUST GOVNR COMP					
G DR2	021538	052278	GM25	G	A02	D	B	T	U-2 DG TRIPPD 4 TIMES ON OVERSPEED;R/X IN S/D MODE	GOVNR SETTING FOUND SET TOO HIGH					

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

V E N T	P L A N T	CONTROL NO.	FAIL DATE	M F G W	S E R V I C E	F A I L M O D E	F A I L M E C H A N I S M	C L A S S I F I C A T I O N	D I S C R I M I N A T O R	FAILURE MODE		FAILURE MECHANISM	
										DESCRIPTION	REASON	DESCRIPTION	REASON
G DR2	021982	063078	GM25	D	B14	T	D	G	F	2/3 DG COOLING H2O PUMP TRIP ON HI AMPS; REPLACED	OVERLOAD TRIP SET CLOSE TO RUNNING AMPS		
G DR2	022262	082478	GM25	C	A10	R	U	4	T	2/3 UNIT 005 UNIT 2 FAILED TO START ON 1ST ATTEMP	PINION GEAR NOT ENGAGED ON AIR START MTR		
G DR2	022589	092278	GM25	C	A00	R	U	8	T	UNIT 2/3 FAILED TO START; AIR STRT MTRS ENGAGED	AIR-START SYS WILL BE MODIFIED		
G DR2	023337	121678	GM25	C	A00	R	U	4	T	2/3 DG AIR START MOTORS DISENGAGED AFTER FEW SECS.	TD2 RELAY CLEANED; TD2 AND AIR VALVE T		
G DR3	014439	030376	GM25	G	A13	R	T	4	T	DG COULD NOT BE LOADED FROM CONTROL ROOM	GOVNR CONTROL WIRE VIBRATED FREE FROM LUG		
G DR3	016615	092176	GM25	B	B09	T	4	T	DIESEL 3 RECEIVED HI TEMP ALARM	PARTIALLY CLOGGD STRAINER IN L.O. CIRC PMP			
G DR3	016187	100976	GM25	G	A13	R	T	4	T	LOSS OF CONTROL ROOM SPEED CONTROL	LOOSE WIRE ON GOVNR CONTROL CIRCUIT		
G DR3	016455	110576	GM25	G	B10	R	T	8	T	LOST SPEED CONTROL FROM CONTROL ROOM	FAILED OVERTRAVL LIMIT SWITCH ON GOVNR		
G DR3	017509	032277	GM25	K	A10	D	G	M		GEN FIELD FAILED TO FLASH	INTERMITTENT CAPACITOR SHORT IN FLASH CIRC		
G DR3	018449	070177	GM25	K	U10	T	8	T	DAY TANK FOR DIESEL NOT AT NORMAL LEVEL	LOOSE WIRE IN LEVEL SWITCH PREVENT PMPRUN			
G DR3	015379	071277	GM25	D	U09	B	D	B	N	U3 DG COOLING H2O PUMP CKT. BKR. FOUND TRIPPD; RESET	TRIPPD AGAIN--WORN PMP BEARINGS; REPLACED		
G DR3	018370	071277	GM25	D	U11	B	D	L	N	DG COOLING WTR PMP BKR. FOUND TRIPPD ; RESET OK	ABNORMALLY HI AMB TEMP FROM CURRENT DEMND		
G DR3	018986	091477	GM25	D	U09	B	D	U	N	DG COOLN WTR PMP BKR. FOUND TRIPPD; WORN OUT BRNGS	DUE TO DETERIATION CF IN-LINE FILTER		
G DR3	019318	100477	GM25	A	U01	K	D	4	N	U3 DIESEL OIL STORAGE LEVEL 8700 VS 10000 GALLONS	LO LEVEL ALARM INOP--OPERATOR NOT INFORMD		
G DR3	019722	112277	GM25	G	A10	R	U	8	T	3 DG STARTD/LOADED-OVERLOAD ALARM-DG TRIPPD	BAD CAPACITOR IN SPEED SENSING CKT.?		
G DR3	019727	112977	GM25	G	B10	R	D	B	N	3 DG TRIPPD 30 MIN AFTER START AND LOADING	SHORTED CAPICITOR ON SPEED SENSING BOARD		
G DR3	019655	122877	GM25	M	U03	S	D	4	M	2/3 DG UDS-OPERATOR PULD 3076 TO BUS 34-1 SWITCH	TO LOCK-PLACED 005 CARD-3HOURS UNDETECTD		
G DR3	021461	080178	GM25	A	U09	R	D	1	N	U3 DIESEL STORAGE LEVEL 9000 GALS.--STUCK VALVE	2/3 FIRE PMP DAY TANK LEVEL CONTRL VALV		
G EN1	014778	031576	FM25	C	A10	D	D	T	1A	DG FAILED TO START DURING SURVEILLANCE	SOL OPER AIR VLV IN START SYS STUCK SHUT		
G EN1	014795	050176	FM25	M	B13	S	T	8	T	NORMAL SURV. TEST DG 1C TRIPPD; LOOSE WIRE	NOT VIBRATED OFF WIRE-PANEL R43-POOLC		

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

EVENT	PLANT CONTROL NO.	FAIL DATE	MFG	SUBSYS	FAIL MDCHE	TYPE	CLASS	REPAIR	DISCOVERY	FAILURE MODE	FAILURE MECHANISM
G EN1	014796	051576	FM25	M	AVC		U	U	T	1B DG FAILED TO START ON FIRST ATTEMPT	UNKNOWN WILL DO WEEKLY START TO DETERMINE
G EN1	015557	062676	FM25	B	802	S	D	B	T	DG 1C TRIPPED DUE TO LUBE OIL SWITCH NOT CALIBRATED	PERSONNEL DID NOT CALIBRATE SWITCH
G EN1	015568	080576	FM25	K	A06	S	D	I	T	DG 1A TRIPPED DUE TO LOSS OF EXCITATION DRNG SYNCH	DEFECTIVE PROCEDURE - PARALLELED OUT OF SYN
G EN1	019947	081476	FM25	M	A00	R	D	U	T	1C DG FAILED TO START DURING SURV TEST - RECURRING	EXACT CAUSE OF START FAILURE NOT KNOWN
G EN1	016065	091176	FM25	G	A10	R	D	I	T	1A DG FAILED TO START - SURV TEST - OCCURRED PREV	LOW OIL LEVEL IN GOVERNOR
G EN1	016842	122576	FM25	M	800	R	U	U	T	DG 1C TRIPPED APPROX 45 MIN. OF RUN TIME; REPETITIVE	CHECKING OUT LOGIC ON 1C DG
G EN1	016543	123176	FM25	M	A00	R	U	I	T	MAN START OF 1A DG FAILED THIS HAS HAPPND BEFORE	INSPECTED & RETESTED SATISFACTORILY
G EN1	018141	052877	FM25	M	A00		U	U	T	1A DG FAILED TO COME UP TO RATED VOLT IN REQD. TIME	TOOK 16 SEC VS 12 SEC RETESTED SATISFAC
G EN1	018644	061377	FM25	D	B14	T	D	4	T	1C DG TRIPPED RESTARTED SATISFACT LO JACKET CLNT	LOW COOLNT PRESS SWITCH TO BE CALIBRATED
G EN1	018646	061677	FM25	D	B14	T	D	4	T	1C DG TRIPPED ON LO COOLNT JACKET PRESSURE	POSSIBLE INCORRECT PRESSURE SETPOINTS
G EN1	018647	062577	FM25	D	B14	T	D	4	M	1C DG TRIPPED ON LO COOLNT JACKET PRESS	OPERT PRESSURE WAS ABOVE TRIP SETPOINT
G EN1	018639	081277	FM25	K	810		D	B	T	1A DG LOST MANUAL VOLTAGE CONTROL	MAN REG MTR OPER XFMR PWR SUP DIODES FAIL
G EN1	020631	081877	FM25	F	800	R	U	G	T	DURING SURV TESTING, DG 1B GEN INBOARD BRNG FAILED	BEARING OVERHEATED - EXACT CAUSE UNKNOWN
G EN1	020013	111977	FM25	K	802	S	D	4	T	1B DG OUTPUT VOLTAGE TOO HIGH - 1B DG SHUTDOWN	IMPROPER ADJUSTMENT OF AUTO REG SETPOINT
G EN1	020214	112577	FM25	G	A08		T	B	T	1A DG FAILED TO START; STUCK GOVNR BOOSTR SERVOMOTOR	AIR PISTON WAS CORRODED
G EN1	020191	120977	FM25	A	U01	S	D	B	N	1A DG FUEL OIL XFER PUMP DISCH VLVS FOUND SHUT	PERSONNEL ERROR - IMPROPER VALVE LINEUP
G EN1	021249	033078	FM25	M	U04	C	D	U	T	BUS 2C FOR BREAKER CONT PWR DESIGN COULD CAUSE A	LOSS OF 2 DSLS IF BATT LOST COINCT & LUSP
G EN1	021250	033078	FM25	M	U04	C	D	U	T	DSL LOAD SEQ TIMER DESIGN COULD RESULT IN OVLD OF	DG 1B IF LOCA FOLLOWS LUSP OR VICE VERSA
G EN1	021476	060278	FM25	M	U04	C	D	U	T	VLTG LOGIC ON DGS 1A, 1B, 1C SUCH THAT VIBRN OF TIE	BRKR DGRM WLD CAUSE BRKR TO CLOSE
G EN1	021714	062778	FM25	M	U02	C	U	U	U	1C DG BATTERY PLT CELL SURV NOT COMPLETED IN INTVL	SPECIF IN TECH SPEC-PERSONNEL OVERSIGHT

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

V E N T	P L A N T	C O N T R O L N O .	F A I L D A T E	M F G M	S U B S Y S	F A I L M O D E	F A I L T Y P E	C L A S S I F I C A T I O N	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
G EN1	022476	092078	FM25	M	U04	C	D	L	R	DGS THAT FAIL TO START OR ARE S/D DURING LOCA OR	LOSP MAY NOT RESTART FROM CONTROL ROOM
G EN2	022213	080978	FM25	M	U03	D	U	R		SURVEILL ON DG "B" NOT PERFORMED	PERSONNEL OVERSIGHT
G EN2	022493	092078	FM25	M	U04	C	D	L	R	DGS THAT FAIL TO START OR ARE S/D DURING A LOCA OR	LOSP MAY NOT RESTART FROM THE CONTROL RM
G EN2	022751A	102678	FM25	G	A10	R	D	B	I	"C" DIESEL FAILED TO REACH 250RPM IN 7 SEC.	STICKING GOVNR BOOSTR SERVO
G EN2	022751B	103178	FM25	G	A10	R	T	B	N	"C" DIESEL FAILED TO REACH 250RPM IN 7 SEC.	FAULTY ELECTRONIC SPEED SWITCH SIGNAL
G EN2	023635	111378	FM25	M	U03	D	B	N		POWER AT 1464 MW, TESTING 2C DG, TS-9-B-1-1-1-A	SURV TIME LIMIT ON OTHERS RAN OUT--8 HOUR
G FP1	015656*	061676	GM25	K	U14	C	D	U	T	A,B,C,ED DGS WERE UNSTABLE DURING TESTING	DRIFT IN DROOP CKT--NOT NECSRY FOR EMERGCY
G FP1	016496	111776	GM25	I	A10	R	D	B	T	"B" EDG FAILED TO START DURING SURVEILLANCE TEST	GEN TACH RELAY DID NOT OPERATE, DEF CNVTR
G FP1	016600	121576	GM25	B	A10	R	D	I	T	DURING TESTING "A" EDG FAILED TO START	LOW LUBE OIL PRESS - RELIEF VLV LEAKAGE
G FP1	016471	011977	GM25	B	A10	R	D	I	T	DURING SURV, EDG TRIPPED ON EMERGENCY START	LOW LUBE OIL PRESS, SECOND ATTEMPT SUCCESSFL
G FP1	017725	042677	GM25	I	A10	R	D	B	T	DURING ROUTINE SURV TEST, EDG FAILED TO START	TACHOMETER RELAY FAILED
G FP1	020518	021578	GM25	J	B10	T	I	T		"A" EDG TRIPPED DURING SURVEILLANCE TEST	BLOWN FUSE IN SYNCH C/T FOR OUTPUT BRKR
G FP1	022115	073178	GM25	B	U03	D	G	T		L.O. SAMPLES NOT TAKEN IN REQD TIME INTERVAL	SAMPLE EQUIPMENT FAILURE
G FP1	022276	082678	GM25	B	U05	D	G	N		EDG INOPERABLE BECAUSE OF NOISY LUBE OIL PUMP	PUMP - MOTOR MISALIGNMENT
G FP1	023101	120578	GM25	G	A02	S	D	4	T	"A" EDG TRIPPED WHEN BEING PAHALLED	MISADJUSTMENT OF GOVERNOR
G M11	016499	020177	FM25	A	U12	R	T	4	U	DG DECLARED INOPER IN ORDER TO REPAIR FUEL OIL LK	SMALL CRK IN PIPE NIPPLE TO NO. 12 INJ
G M11	019089	092777	FM25	A	U12	R	T	1	U	DG DECLARED INOPER IN ORDER TO REPAIR FUEL OIL LK	SMALL CRK IN PIPE NIPPLE TO NO. 12 INJ
G M11	019820	121077	FM25	I	U10	U	B	N		DIESEL GENERATOR BECAME INOPERABLE	GOV SHUTDOWN SOLENOID MALFUNCTION
G M01	016166	101076	GM25	C	A09	T	U	T		#11 DG FAILED TO START ON #2 STARTING SYSTEM	#2 START SYS AIR CONT COMP FOULED W RUST
G DC1	014447	030376	GM25	K	A10	D	B	T		DG 2 STARTED BUT DID NOT DEV SUFF VLTG TO LOAD	WESTHSE FFCO RELAY FLD TO ENPG2 FLD FLASH

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

UNIT	CONTROL NO.	FAIL DATE	PK CM	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
G DC1	015042	060876	GM25 C	UNIT 1 DG #2 FAILED TO START DURING OPERABILITY TEST	CONTROL SW FAULT - HOWEVER, SW CORRECT	
G UC1	023119	113078	GM25 K	UNIT 1 DG #10G STARTED BUT GEN FAILED TO EXCITE--AUTO ACTIVES	UNUSED TARGET MECH LINKAGE IN RELAY BINON	
G PB2	013591	011176	FM30 C	UNIT 1 N E-3 DG UC FEED BKR FOUND OPEN - PREVENTS STARTING	OPER LEFT OPEN AFTER DC GRND 15CL PROCEED	
G PB2	018586	092677	FM30 D	UNIT 1 E1 DG FAILED TO START DUE TO HI JKT CLG WTR TEMP	OPER RESET TRIPPED PMP, BUT NOT DIESEL TRIP	
G PB2	018887	082677	FM30 I	UNIT 1 A06 S D 4 F 25 DG TRIPPED ON OVERSPEED	OVSPD TRIP SET BELOW DESIGN VALUE	
G PB2	019714	101877	FM30 D	UNIT 1 N E3 DG TRIPPED FOLLOWING MANUAL START	3 VALVES TO LOW PRESS SW LEFT SHUT	
G PB2	019260	110177	FM30 B	UNIT 1 B N E-4 DG DECLARED INOPERABLE	CLEANUP ACCUM OIL UNDER MACHINE--FIRE HZO	
G PB2	019530	112277	FM30 A	UNIT 1 4 N E2 DG DECLARED INOPERABLE	REPAIR FUEL OIL LEAK IN PLUG ON CUND FLTR	
G PB2	02059C	121977	FM30 L	UNIT 1 E1 DG TRIPPED ON W/M PHASE DIFF AFTER PARALLELING	CAUSE COULD NOT BE DETERMD AFTER EXTIV TST	
G PB2	020167	010378	FM30 B	UNIT 1 K U 4 N E-4 DG DECLARED INOPERABLE	LO LUBE OIL TEMP-REPLC LUBE OIL HTR ELEM	
G PB2	020161	011878	FM30 B	UNIT 1 K U 8 N E2 DG DECLARED INOPERABLE	LO LUBE OIL TEMP-REPLC 2 COILS IN HTR ELE	
G PB2	020565	022878	FM30 B	UNIT 1 C 0 B T E-2 DIESEL TRIPPED ON HIGH CRANKCASE PRESSURE	WATER IN OIL VAPORIZED - LEAKY OIL DRUMS	
G PB2	022462	083078	FM30 G	UNIT 1 T E-3 DG START TIME DID NOT MEET IS REQUIREMENT	LEAKY CHR VLV IN AIR BOOSTER RELAY HYD 37	
G PB2	02349A	122178	FM30 G	UNIT 1 T E3 DG START TIME 13 SEC. VS. REQUIRED 10 SEC.	E3 DG GOVERNOR REPLACED ON 12/28/78	
G PB2	023398	122178	FM30 G	UNIT 1 T E2 DG START TIME 11 SEC. VS. 10 SEC	POSSIBLE GOVERNOR PROBLEMS	
G PB3	019259*	061377	FM30 C	UNIT 1 N 3 OF 4 DIESEL GENERATORS INOPERABLE	START AIR COMPRESSORS TRPD - AIR TANKS HI	
G P11	015466	092676	AL25 H	UNIT 1 B 04 B T D T "M" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED	
G P11	016268	111776	AL25 H	UNIT 1 B 04 B T D T "M" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED	
G P11	022128	080278	AL25 K	UNIT 1 B 01 D B T DG BECAME INOPERABLE AFTER ONE HOUR R/M	OPERATOR CAUSED DIODE FAILURE IN VLT REG	
G UC1	019120	011276	GM25 C	UNIT 1 DG FAILED TO START WHEN MADE SW IN START MO	AIR START SOL VLV DIRTY-NOT OPEN FULLY	

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

UNIT	CONTROL NO.	FAIL DATE	PK G.M.	FAILURE MODE	FAILURE MECHANISM
G	QC1 014426	031776	GM25 M 002 C	1/2 DG 005 100 LONG FOR PREVENTATIVE MAINTENANCE	COMMUNICATIONS PROBLEM BETWEEN OPER-MAINT
G	QC1 015715	072776	GM25 M 006 D	1 M UNIT 1/2 DG 005 FOR LONGER THAN IS ALLOWANCE	MAINT MAN UNWARE OF TIME LIMIT-PROCEED ER
G	QC1 016904	120276	GM25 D 002 C	0 8 M CUCKLING MTR HDR FOR DG 1 CW PUMP - AIRBOUND	AIR LINE ATTACHED TO RHR PUMP-COMMON HEADR
G	QC1 018442	042577	GM25 K A10 D	G T WHILE TESTING THE DG, THE FIELD FAILED TO FLASH	CAPACITOR ACROSS VLTG SUP RELAY DEFECTIVE
G	QC1 019114	050677	GM25 A 012 F	B U LEAK D13VD IN TAP OFF FUEL LINE TO FUEL PRESS GAGE	FOR 1/2 DG - CRACKS ATTRIBD TO NRM L STRS
G	QC1 019100	062477	GM25 L A13 T	4 T UNIT 1 DG STARTED AND RAN, BUT NO VLTG, SYNCH, FREQ.	FREQ GEN TACH SET SCREWS VIBRATED LOOSE
G	QC1 019994	112877	GM25 K A10 D	4 M 1/2 DG WOULD NOT START SUCCESSFULLY, FIELD BKR DEFECT	FAILED DIODE IN FLD BKR INTLK CIRCUIT
G	QC1 022066	092878	GM25 A 004 D	0 M UNIT 1 FUEL AFER LINES REMOVED-IT DECLARES DG INOP	750 GAL DAY TANK FULL-DIESEL WOULD RUN
G	QC2 018745	081077	GM25 D 012 T	G M 4M DG REMVD FRM SERV DUE TO DECRS IN ENG MTR LVL	EAST CW HT EXCHGR HAD A TUBE LEAK
G	QC2 020595	012478	GM25 D 012 J	E D T UNIT 2 DG CW PUMP DRAINS FAILED TO SHUT	AIR SUPPLY SOLENOID VALVES FAILED
G	Y11 014740	050676	FM30 F A09 K	T 4 M 18M DIESEL GENERATOR TRIPPED ON HI CRNKSE PRESS	CLOGGED CRNKSE EJ SUP ORIFICE ON EJ BODY
G	Y11 015739	082576	FM30 A B13 T	1 T 18M DG 005 TO TIGHTEN FUEL HEADER FITTINGS	ENGINE VIBRATION LOOSENED MECHANICAL CONN
G	Y11 018323	062377	FM30 F B43 R	T 4 T 18M DG TRIPPED ON HIGH CRANKCASE PRESSURE	VIBRTN CAUSED HOSE CLMP ON AIR EJECT FAIL
G	Y11 014658	072677	FM30 C A09 T	4 T 17M DIESEL GENERATOR FAILED TO START	AIR START SOL VALVES BOUND CLSD BY DEBRIS
G	Y11 020194	121977	FM30 F B13 K	T 4 T 18M DG TRIPPED ON HIGH CRANKCASE PRESSURE	ENG VIB CAUSED AIR EJECT HOSE TO LOOSEN
G	Y11 020464	012478	FM30 D 809 F	4 T DIESEL GENERATOR MTR TRIPPED ON HI JACKET CLNG TEMP	3-WAY VLV BLOCED TO BYPASS CLNT ARND MK
M	BV1 014503	052076	GM25 C A09 R	T 4 M DG #1 FAILED TO START 3 TIMES DG #2 STARTED OK	WATER ACCUMULATION IN AIR START SYSTEM
M	BV1 015413	090376	GM25 J A00 G	I T #1 DG OUTPUT BREAKER FAILED TO CLOSE	NO APPARENT CAUSE
M	BV1 017383	022477	GM25 L 805 D	4 T DG OUTPUT BREAKER TRIPPED:INTERNAL LOSS OF FIELD	TRIP NOT DISCONNECTED DURING ACCEPT, TEST
M	BV1 017348	031477	GM25 J A04 B	D 4 T #2 DG OUTPUT BREAKER FAILED TO CLOSE	DIRTY CONTACTS ON BKR CCNT SWITCH

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	CONTROL	FAIL DATE	TIME	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
8V1	017621	041177	GR25	J A04 B U 4 T #1 DG OUTPUT BREAKER FAIL TO CLOSE	DESIGN REQUESTED DIRTY CONTACTS ON MFLD(AING FIELD) RELAY	DESIGN CHANGE REQUEST FOR SEALED RELAYS
8V1	017693	042677	GR25	J A04 B U 4 T #1 DG OUTPUT BKR. FAIL TO CLOSE	DESIGN REQUESTED DIRTY CONTACTS ON MFLD(AING FIELD) RELAY	DESIGN CHANGE REQUEST FOR SEALED RELAYS
8V1	017696	042977	GR25	C A09 K T 4 N DG #1 FAIL TO START	REPEITIVE	MOISTURE IN STARTING AIR
8V1	017827	050977	GR25	J A04 R D 4 T #2 DG OUTPUT BKR. FAIL TO CLOSE	REPEITIVE	STICKING RELAYS(MSRZ) IN MANUAL START CRT.
8V1	018068	060377	GR25	J A04 R D 1 T #2 DG OUTPUT BKR. FAIL TO CLOSE ON FIRST ATTEMPT	REPEITIVE	STICKING RELAYS(MSRZ) IN MANUAL START CRT.
8V1	018069	062277	GR25	M L01 U N MODE 3 (HCT SYNDBY) TO MODE 1 (PWR OPS) 1DG 005	REPEITIVE	REG GUIDE 1-10-C-2-8.(2) MISINTERPRETED
8V1	018628	071177	GR25	K A10 R T 8 T #2 DG STARTED AND CLOSED ONTO 8U3 OUTPUT VOLTS =0.	LOOSE CONNECTIONS IN AUTO FIELD FLASH CRT	LOOSE CONNECTIONS IN AUTO FIELD FLASH CRT
8V1	021437	011178	GR25	J A04 R D 4 T #2 DG OUTPUT BKR. FAIL TO CLOSE IN EXERCISE MODE	NO CAUSE COULD BE DETERMINED	NO CAUSE COULD BE DETERMINED
8V1	021325	041878	GR25	A B12 I D N #1 DG WAS S/D AND DECLARED IMPERABLE--OIL LEAKS	FLAW IN FUEL OIL PUMP DISCHARGE PIPE MIPL	FLAW IN FUEL OIL PUMP DISCHARGE PIPE MIPL
8V1	021647	060178	GR25	B B02 D I T #2 DG LUBE OIL LEAK AT ENGINE CONTROL PANEL GAUGE	GAUGE WAS CALIBRATED ON 9/21: LOOSE CONN.	GAUGE WAS CALIBRATED ON 9/21: LOOSE CONN.
8V1	022137	072678	GR25	K A10 R D 1 N #2 DG FAIL TO FLASH DURING SI AND LUSP EVENT	STICKY FIELD FLASH CUTOUT RELAY: AUTO CRT.	STICKY FIELD FLASH CUTOUT RELAY: AUTO CRT.
8V1	022395A	090578	GR25	M U03 K D U T 2 DG 005 FOR TESTN DIESEL AIR AND GIL RELIEFS	#1 DG BKR FAIL TO CLOSE AUTO DURN TEST	#1 DG BKR FAIL TO CLOSE AUTO DURN TEST
8V1	022395B	090578	GR25	J A00 R D 1 T #1 DG OUTPUT BKR. FAIL TO CLOSE; #2 DG 005	BKR CLOSED MANUALLY; 1 HOUR RUN AT FULL LO	BKR CLOSED MANUALLY; 1 HOUR RUN AT FULL LO
8V1	022395A	091278	GR25	M U03 K D U T #2 DG 005 FOR TESTN AIR AND RELIEFS; TESTD #1 DG	1 DG BKR FAIL TO CLOSE USIN CONTROL SW.	1 DG BKR FAIL TO CLOSE USIN CONTROL SW.
8V1	022395B	091278	GR25	J A00 R D 1 T #1 DG OUTPUT BKR. FAIL TO CLOSE USING CONT. SWITCH	CLOSED LATER NEGATING TROUBLESHOOTING	CLOSED LATER NEGATING TROUBLESHOOTING
0C1	014412A	040176	W030	M U12 R T G N 1CD DG KEAR BANK AIR AFTERCOOLER HAD TUBE LEAK	Cooler replaced on 4-6-76	Cooler replaced on 4-6-76
0C1	014412B	040176	W030	M U12 R T G N 1AB DG REAR BANK AIR AFTERCOOLER HAD TUBE LEAK	REPLACED ON 4-24-76	REPLACED ON 4-24-76
0C1	016047	120976	W030	K A10 D I T C-D DG TRIPPED ON OVERSPEED--BLOWN FUSE ON INVERTER	FAIL SILICONE RECTIFIER IN DG INVERTER	FAIL SILICONE RECTIFIER IN DG INVERTER
0C1	020520	120977	W030	M U11 C D B N WITHIN 3HRS. 3 PURIOUS GS TRIP SIGNALS ON LAB#1CD DG	OPERABLE CHECKD TRIP POINTS DG COLD	OPERABLE CHECKD TRIP POINTS DG COLD
0C1	022146	110778	W030	K UG4 D I N AB DG INOPERABLE DUE TO INADQ. REMOVAL OF CRT. BOARD	SNAGGO ON CLOTHING; DESIGN CHANG	SNAGGO ON CLOTHING; DESIGN CHANG

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

V E N T	P L A N I	CONTRL NL.	FAIL DATE	M F X G W	S U B S Y S	F A I L M E C H	F A I L T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
W	DC2	020981	031978	W030	C	B10	U	4	T	2CD DG GASKETS ON AIR LINE TO #5 CYL BLEW OUT	FRACTURED AIR START CHECK VALVE	
W	DC2	021217	041578	W030	M	U03	D	G	N	SURVEILLANCE TESTING OF CO DG NOT PERFORMED	OPERATOR THOUGHT TEST SCHEDULE IN ERGR	
W	DC2	022280	061378	W030	M	U01	D	G	N	MODEL #AB DG INOP. FROM 2100 HR. 6-13 TO 1030 HRS. 6-14 --- INVERTER BEING REPAIRED		
W	DC2	021834*	061578	W030	M	U02	C	U	4	N	BOTH EDG'S PLACED IN A COND. OF NOT AUTO STARTING	TAGGED OUT WRONG STARTING AIR PILOT VALVE
W	DC2	021675	061778	W030	D	U05	T	G	N	NORMAL OPNS. WELD CRACK ON ESW OUTLET ON 2AB L.O	COULDR. TOOK 2AB DG OOS TO REPAIR	
W	DC2	021681	061778	W030	A	B07	T	8	T	2CD DG WIDELY VARYING CYLNDR TEMP TAGGED OUT	FUEL INJECT. PUMP FAILD	
W	DC2	022026	072878	W030	G	B10	K	4	T	#2 AB DG OVERSPED. WHL UNLOADG PREVIOUS OCCURRENCE	WORN LINKAGE CAP SCREW BROKE IN GOVENDR	
W	DC2	022330	090178	W030	A	U12	D	8	T	#2CD DECLARED INOPERABLE DUE TO L.O. VISCOSITY VIOL	REPLACED 4 INJ. PMP'S E1 INJ AS THE ANSWER	
W	DC2	022503	091178	W030	C	A13	T	4	T	2AB STARTED FOR LOAD TEST WAS TRIPPED OFF MANUALLY	PISTON BELT FOR AIR CHECK VALV LOOSE	
W	DC2	022839	101978	W030	A	A00	U	1	T	2AB FAILED TO START DUE TO LACK OF FUEL TO INJECTRS	UNKNOWN BUT REPLACED FUEL FILTER ELEMENT	
W	HN1	014162	020376	GM25	A	A02	S	D	1	T	EDG-28 TRIPPED ON OVERSPEED WHILE STARTING	CALIB TOOL LEFT IN FUEL RACK-RACK HLD OPN
W	HN1	021376	050878	GM25	M	U04	C	U	R	IF ONE DG FAILS TO START DURING COINCOT LOCALUSP	LOADING EN RMNG DG MAY EXCEED SPECS	
W	IP2	016041	121278	AL18	B	U11	R	4	T	LUBE OIL TEMP FOR 22 EDG BELOW MINIMUM FOR OPERATN	CHROMALOX HTR MTO-330A FOUND SHORTED	
W	IP2	018913	022677	AL18	B	U14	S	D	4	N	23 EDG REMOVED FROM SERVICE - DEFECTIVE PRESS SWCH	PRESS SW SETTING WAS FOUND TO BE INCORRECT
W	IP2	018914	082977	AL18	D	U12	T	G	N	23 EDG REMOVD FROM SERV TO REPAIR JACKET WTR COOLER	AMER STD HA, MOD 1205-0CP, DEVLPD TUBE LKS	
W	IP2	019244	091677	AL18	H	U10	T	G	N	22 EDG DEVLPD PHASE-TO-PHASE SHORT IN EXH HOOD MTK	DEFCTIVE DSL EXH BLWR HTR, GE 5K49HG61A	
W	IP2	019598	101977	AL18	B	U11	R	T	1	N	22 EDG FOUND TO HAVE LOW LUBE OIL TEMPERATURE	DEF TERMINAL BLK SHORTED CHROMALOX HTRS
W	IP2	023579	121978	AL18	C	U10	T	4	N	21 EDG INOP DUE TO AIR START MOTOR PROBLEMS	MOTORS CLEANED, DG TESTED SAT	
W	IP3	015120	061576	AL18	M	U03	S	D	1	T	LOST AC AUX FOR EDG 31 FOR 19 MINUTES	MECHANIC CAUSED A SUCCESSION OF BKR TRIPS
W	IP3	015733	083076	AL18	G	B02	T	D	1	T	EDG 31 BEGAN CYCLING BETWEEN 56 AND 63 CPS	GOV OIL DRAIN VLV NOT SHUT TIGHTLY

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	UNIT	CONTROL NO.	FAIL DATE	FAIL TIME	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
M	IP3	616035	092476	AL18 G	BQ2 T D N T	EDG 31 OUTPUT FREQ INC TO 62 HZ, COULD NOT CONT ELE AIR IN GCV OIL LINES FROM PREVIOUS REPAIR	UNIT/PARA RELAY OPER INTRMIT-DEFECTV CUMM
M	IP3	616286	102176	AL18 L	B10 S D B T	UNABLE TO CONTROL SPEED OF NO 31 DG	AMONG THE 3 GEN TRNS-DG 33 LT PERMIT BY IS
M	IP3	622410	082978	AL18 A	U10 S T U N	VALVE FAILURE CAUSED AN UNBALANCED DIST OF FUEL	MAIN AIR VALVE FAILED TO SHUT-CAUSED OVRSP
M	JF1	619655	081777	FM40 C	A10 B D U T	DG 18 TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY	MAIN AIR START VALV FAILED TO FULLY SHUT
M	JF1	619662	082877	FM40 C	A10 B D U T	DG 18 TRIPPED ON OVSPO DURING MANUAL START	MAIN AIR START VALVE FAILED TO FULLY SHUT
M	JF1	619359	091377	FM40 C	H10 B D D N	D3L GEN 18 EVENTUALLY TRPPD ON OVSPO AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
M	JF1	619360	091677	FM40 C	H10 B D B N	D3L GEN 1-2A EVENTUALLY TRPPD ON OVSPO AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
M	JF1	619368	100277	FM40 G	A10 D B T	D3L GEN 1-2A FAILED TO START DURING TEST	SPEED SWITCH FAILED - 120V VS 130V RATING
M	JF1	620291	010378	FM40 C	U10 S D D N	DG 18 DECLARED INOPERABLE	BOTH AIR COMPRESSORS ASSOC W 18 WERE ODS
M	JF1	620992	030278	FM40 C	A09 C T D T	D3L GEN 18 FAILED TO ATTAIN RATED SPEED	CORROSION PRODUCTS CLOGGED AIR START VLVs
M	JF1	620996	030878	FM25 C	A09 C T B T	D3L GEN 1C FAILED TO START DURING TEST	CORROSION PRODUCTS CLOGGED AIR START VLVs
M	JF1	621185	032378	FM40 C	A02 U D N	D3L GEN 18 FAILED TO COME UP TO SPEED PER TECH SP	MAIN AIR START VALV PUSHER ASSY MISSING
M	JF1	622293	081278	FM40 J	A10 J U B N	OUTPUT BRK FOR DG 18 FAILED TO CLOSE AUTOMATICALLY	OPEN MECH FOR AUX SWITCHS OUT OF ALIGNMT
M	JF1	622374	082778	FM25 G	A10 K D B N	ZC DG WOULD NOT RESPOND TO AUTO OP MAN SPEED CHG	BLOWN FUSES FOR MOP AND MGI
M	JF1	622373	090578	FM40 G	A10 H D B M	1-2A DG WOULD NOT RESPOND TO AUTO VLTG UR SPD CHG	BLOWN FUSES FOR MOP-CAUSED BY FAIL DIODES
M	JF1	623152	091478	FM40 C	U10 U N B	DG DECLARED INOPERABLE	14E18 AIR RESVRS WERE BLEED DOWN-HALF VLV
M	JF1	622630	091778	FM40 G	A10 D N T	DG FREQ COULD NOT BE INCR ABOVE 58.5 HZ	CPENG BEL DC MTR AND 60V POS POT WAS LCCD
M	JF1	622987	100378	FM25 J	A02 J D I T	IC DG OUTPUT BRKR FAILED TO CLP'E ON START	JUMPER FOR UNIT/UNITZ SEPAR, INCRECTLY POS
M	K61	618941	082477	GM25 I	U10 S D U M	PUSH-BUTTON TIMER IN C-000A - FIRE PROT SYS FAILED	IN INTER POSIT-CONT S/O SIGNAL 10 DG 18
M	K61	619171	092077	GM25 E	H06 C D N T	D3L GEN 1A S/O WHEN SMOKE & FIRE CBSD IN TURBCHG	CARBON BUILDUP DUE TO SHORT DURATION OPER

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

UNIT	CONTROL	FAIL DATE	FAIL TIME	FAILURE MODE	FAILURE MECHANISM
W	KEL	019719	102577	GM25 M A00 U U F 0/6 1A STARTED & WAS AT 70 RPM WHEN IT STOPPED	COULD NOT DETERMINE CAUSE OF FAILURE
W	KEL	020095	122177	GM25 G 802 S D 4 T 0/6 1B WOULD NOT PICK UP MORE THAN 1500 KW LOAD	SYNCHRO MOTOR LIMIT SWITCHS ADJUSTED IMPROV
W	PR1	048342	061777	FM30 G 810 T 0 T D2 0G FAILED TO RESPOND TO LOAD CHANGE SIGNALS	LINK LEVER KEY MISSING, CAPSCREWS LOOSE
W	PR1	019919	120977	FM30 M 001 C 0 1 U BOTH 0G5 INOPER FOR APPROXIMATELY 10 MINUTES	OPERATOR ERROR IN RESETTING MCA RELAYS
W	PR1	021704	062278	FM30 A 002 C 0 G M FOOT NLY ON 10 DAL OEL DAY TK INST LVL COLUMN-SHUT	IMPROPER NLY LVL DURING TEST ON JUNE 9TH
W	PK4	047606	040276	FM30 M 002 C 0 1 M 01 DIESEL GENERATOR MOMENTARILY LOCKED OUT	DURING MAINT, TECH ACTUATED WRONG RELAY
W	PK2	015745	091076	FM30 F 802 D 4 T 01 0G TRIPPED ON HIGH CRANKCASE PRESSURE	HOSE CLAMPS ON PIPE NOT TIGHT AFTER MAINT
W	PK2	017618	041277	FM30 M 010 C 0 4 U LIGHT SOCKET FOR 0G D2 60V READY LITE SHORTED CAUS	ING 2 HOUR LOSS OF CONTROL POWER
W	PK2	021328	032978	FM30 D 002 C 0 1 M 00, 12 DIESEL CM PUMP LOCKED OUT APPROX 1 MINUTE	MAINT MAN PLACED JUMPER BEFORE SUPPLY TO
W	PI1	017146	020977	GM25 J A10 R 0 8 T 3D EDG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	DIRT IN LWR BRNG OF OVRCRT RELAY TMG DISC
W	PI1	018417	062977	GM25 I A14 S T 4 Y 3D DIESEL GENERATOR FAILED TO START - LOGIC FAILURE	SPEED SENSING ASSY SETPOINT DRIFTED
W	PI1	021445	051778	GM25 J A10 R 0 0 T 4D EDG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	WAST 0624142H01 LATCH-CHKMG 3M DEFECTIVE
W	KG1	015126	070976	AL18 J 010 D U T 18 0G OUTPUT BREAKER COULD NOT BE CLSD RMTELY AFTER TEST	SWITCH WEAR PREVENTED BRKR ELEC RST
W	KG1	021625	030478	AL18 A 010 T 4 N "A" 0G FUEL XFER PUMP LGST-0G STILL HAD 3HR FUEL	POOR ELEC CONN CAUSED TMRPL DEVICE TRIP
W	KG1	022450	081678	AL18 J A10 F 8 T B EDG OUTPUT BREAKER WOULD NOT CLOSE	BAD CONN AT CONT PWR FUSE BLOCK STUBS
W	KU2	044823	030176	FM25 A 807 R T 8 T "B" EMER DIESEL DID NOT REACH RATED CAPACITY	# 12 CYL INJ PLUNGER & BARREL GALLED
W	KU2	019354	091377	FM25 A 807 R T 8 T "A" DIESEL GEN FAILED TO ASSUME FULL LOAD	SEVERAL FUEL INJ RODS WERE STICKING
W	KU2	021313	041078	FM25 G 813 I 4 T EDG LOAD FAILED TO INCREASE ABOVE 900KW	COMM BRUSH VIBRATED OUT OF GOV SPD CHGR
W	S41	018799A	073077	AL25 A A10 C T 4 M 1A DIESEL INOP-FAILED TO REACH RATED SPEED ON START	BINDING FUEL RACK LNKG - LACK OF LUBRICAL
W	S41	018799B	073077	AL25 A A10 C T 4 M 1B DIESEL INOP-FAILED TO REACH RATED SPEED ON START	BINDING FUEL RACK LNKG - LACK OF LUBRICAL

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT CONTROL NO.	FAIL DATE	PK CM	FAILURE MODE	FAILURE MECHANISM
SAL 019920	111777	AL25	D 813 B 1 A T 1 C DIESEL DEVELOPED WATER JACKET LEAK	CRACK FOUND ON 3/8" PIPE NIPPLE
SAL 019924	120277	AL25	E 804 T 6 T 18 DIESEL DECLARED INOP-TURBOCHGR & EXH EXP JT FLO CAUSE DETERMINED TO BE IURB BLADE FAILURE	
SAL 022070	101178	AL25	B 012 U 6 N 18 DIESEL DECLARED IMPERABLE-PRE-LUBE MTR FAILED	WATER JKT CLR LKNG ONTO PRELUBE PUMP MTR
S01 017666*	051077	DL10	A 005 U 0 R 2 DIESELS HAD FUEL OIL BYPASS LINE SUPPORTS MISSING	IMADV OMITTED DURING ASSY OF BYPASS PIPNG
S01 021316	032878	DL16	A 006 R 1 T 1 T NO 1 DIESEL GENERATOR FAILED TO START	FUEL LKNG BINDING - BEARINGS IN LKNG DRY
S01 022160	071878	DL16	A 006 U 1 T NO 1 DIESEL GENERATOR FAILED TO START	FUEL RACK BINDING-INGRPP PROC TO EXERCISE
S01 014869	041676	GR25	F 001 K 0 G T 01 DIESEL GENERATOR DAMAGED ON START	017 CYL FLOODED - CAUSED BROKEN INTERNALS
S01 014840	050876	GR25	F 012 R 0 G N 01 CYLINDER IN 01 DG WAS FOUND FLOODED	CRACK IN 01 CYL HD THRU TO WATER JACKET
S01 015521	070276	GR25	F 012 K 0 G N 019 CYLINDER IN 01 DG WAS FOUND FLOODED	CRACK IN 019 CYL HD THRU TO WATER JACKET
S01 015523	072376	GR25	F 012 H 0 G N 07 CYLINDER IN 01 DG WAS FOUND FLOODED	CRACK IN 07 CYL HD THRU TO WATER JACKET
S01 022419*	103178	GR25	M 006 U 0 R PT TO INSPECT DGS DURING OUTAGE NOT PERF FOR 163	ADMINISTRATIVE SCHEDULING ERROR
F01 014668	042076	GR40	A 006 G 1 6 U 001H OBL FUEL OIL TANKS LT IS LIMIT OF 33000 GAL	PROCEDURE NOT REVISED TO INDIC CORRECT LIM
F01 014929	051276	GR40	A 006 U 0 R PERIOD SURVEIL TO SAMPLE & VER DSL FUEL NOT PERFORMED	PROC FOR PROPER SCHED & RECORDING INADLV
F01 014930	052176	GR40	A 006 U 1 M EMER DIESEL FD DAY TANK LVL WAS LESS THAN TS REUMT AUTO M/U SETPOINT WAS SET LOW	
F01 018007	042977	GR40	M 000 U 0 N EOG FAIL TO START UN LESP (PARTIAL) 1ME 2ND TIME	NO LER FOR DG FAILURE JUST THE LOSP
F01 018047	062277	GR40	G 810 F 0 N WEST DG FAILED TO ASSUME MEN REQUIRED LOAD	BRUSH FALLEN OUT OF DC GOV DRIVE MOTOR
F01 020462	021778	GR40	L 006 U 0 R DG PHASE DIFFERL TRIP NOT VERIFIED BYPASSED ON STA	DEFECTIVE PROCEDURES
F03 014879	030676	GR25	J 010 B 0 8 N DISCOVD THAT 3B EGG OUTPUT BRKR INDIC NOT CHARGED	CHG MTR DRIVE PAWL MISALGND W CHG SPRING
F03 045963	090976	GR25	J 016 B 0 8 U 3A DG OUTPUT BRKR WAS NOT IN CHARGED POSITION	WORN NYLON BUSHING-DRV MTR ECCENTRIC MHL
F03 046136	100276	GR25	D 001 U 1 M DG "A" COOLING MTR SURGE INK LG LVL ALARM	PARTIALLY OPEN SAMPLE VALVE-OPERTR ERROR

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	CONTROL NO.	FAIL DATE	FAIL TIME	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
103	0175V1	020377	GM25 A	1215	UT DG	PROBABLE-AIR IN FUEL SUPPLY LINES
103	018147	031777	GM25 A	1216	UT DG	PROBABLE-AIR IN FUEL LINE-CRACKS IN SUCTION TUBING
103	019423	061077	GM25 D	U08	UM	EXT ENVIRON COND - INCOMPLETE CHEM MIXING
103	021919	066178	GM25 A	B10	UB	LEVEL SWITCH MALFUNCTION--REPLACED SWITC
101	017316	030177	GM02 C	A10	D 4 T	ARMATURE SHAFT BROKEN--REPLACED * SPARE
101	018653	080277	GM02 C	F 1 T	B1	SLUDGE AND SCALE IN 67% OF RADIATOR TUBES
101	018654	080277	GM02 D	B09 C	T 1 T	72% OF RADIATOR TUBES BLOCKED SLUDGE SCALE
101	020476	012878	GM02 D	U01	D 8 M	HEAT COIL FAILURE--T.S. VIOLATED (12 DG*5)
111	015188	062176	C840 A	B13	I 4 M	VIB CAUSED CRACKED FING ON LINE TO INJ
111	016179	092476	C840 M	A00	U T	NO CAUSE COULD BE DETERMINED
111	020255	010378	C840 K	B10 R	T D T	VC BOARD FAILURE IN THE VOLTAGE REGULATOR
111	020348A	011678	C840 B	U12 B	O G T	OIL CLR TUBE LM CONTAMINATED OIL * WATER
111	020348B	011678	C840 G	B10	F 4 T	LD CONTROL AIR PRESS--TRIP YLV * OIL RING LN
111	023468	074778	C840 B	U12 B	O G T	OIL CLR TUBE LM CONTAMINATED OIL * WATER
111	022410	080178	C840 C	A10	F 1 T	AIR LEAK IN STARTING AIR PILOT VALVE
111	022515	090278	C840 C	A10	D 4 T	STARTING AIR DIST BUSHING ROTATED IMPROP
111	022640	091478	C840 B	A02 C	D 4 N	RAG IN OIL STRAINER CAUSED LU OIL PRESS I
111	023368	122078	C840 M	A00	U D M	EXTENSIVE TESTING REVEALED NO CAUSE
112	017808	042777	C840 G	B10 R	D 1 T	GOV SPD CONT GEAR JAMMED AGAIN HI SPD STO
112	017809	050677	C840 I	B13 C	T 4 T	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE

ONE-LINE DESCRIPTION OF DIESEL GENERATOR EVENTS

PLANT	CONTROL NO.	FAIL DATE	M F K G M	SUB SYSTEM	FAILURE MODE	FAILURE MECHANISM
212	019714	111077	C840 B	812 B D G T	"0" DIESEL GEN TRIPPED ON LOW LUBE OIL PRESSURE	CAVITATION OF LC PUMP - WATER IN LUBE OIL
212	019780	111777	C840 I	813 C T 4 T	"0" DIESEL GENERATOR TRIPPED OFF-LINE	LLAM IN AIR LINE TO MASTER SLOWDOWN VALVE
212	020258	010678	C840 K	810 R T B T	2A DC OUTPUT VOLTAGE INCREASED AND COULD NOT LOWER MANUALLY	BURNED CONTACT IN THE VOLTAGE REGULATOR
212	020260	010978	C840 G	810 R D I T	2B DG POWER OUTPUT DVL'D - COULD NOT LOWER MANUALLY	GOV SYNCH IND GR JAMMED ON HI SPD STOP
212	021544	051778	C840 K	814 T B T	2A DG OUTPUT VOLTAGE CYCLED - COULD NOT CONTROL	DRIFT OF VLTGE REGULATOR STABILITY CIRCUIT

APPENDIX F

DIESEL-GENERATOR EVENTS CLASSIFIED AS DOES NOT START FAILURES

CODES USED IN LER ONE-LINE DESCRIPTIONS

REPAIR TIME	
CODE	DESCRIPTION
1	0 TO 1 HOURS
4	1 TO 4 HOURS
8	4 TO 8 HOURS
24	8 TO 24 HOURS
U	GREATER THAN 24 HOURS
	UNKNOWN / NOT APPLICABLE

FAILURE MODE	
CODE	DESCRIPTION
A	DOES NOT START
B	DOES NOT CONTINUE TO RUN
U	UNAVAILABLE / NONFAILURE

FAILURE CLASSIFICATION	
CODE	DESCRIPTION
D	DEMAND
T	TIME
U	UNKNOWN

SUB-SYSTEM	
CODE	DESCRIPTION
A	FUEL OIL SYSTEM
B	LUBE OIL SYSTEM
C	STARTING SYSTEM
D	COOLING SYSTEM
E	SCAVENGING AIR SYSTEM
F	ENGINE FRAME / INTERNALS
G	GOVERNOR
H	EXHAUST SYSTEM
I	SHUTDOWN SYSTEM
J	OUTPUT BREAKER
K	EXCITERS / VOLTAGE REGULATOR
L	GENERATOR
M	OTHER / UNKNOWN

FAILURE MECHANISM	
CODE	DESCRIPTION
00	UNKNOWN
01	PERSONNEL OPERATION
02	PERSONNEL MAINTENANCE
03	PERSONNEL TESTING
04	DESIGN ERROR
05	FABRICATION / CONSTRUCTION / QUALITY CONTROL
06	PROCEDURAL DISCREPANCY
07	DEFECTIVE FUEL INJECTOR(S)
08	CORROSION / EROSION
09	FOREIGN MATERIAL CONTAMINATION
10	MECHANICAL / ELECTRICAL CONTROL
11	H1 / LOW AMBIENT TEMPERATURE
12	LUBE / FUEL / WATER / AIR LEAKAGE
13	VIBRATION
14	OUT OF ADJUSTMENT / CALIBRATION

METHOD OF DISCOVERY	
CODE	DESCRIPTION
M	DURING MAINTENANCE
N	DURING NORMAL OPERATIONS
R	DURING RECORDS REVIEW
T	DURING TESTING
U	UNKNOWN

TYPE OF EVENT	
CODE	DESCRIPTION
B	RECURRING COMMON CAUSE
C	COMMON CAUSE
R	RECURRING
T	COMMAND FAULTS
Y	RECURRING COMMAND FAULTS

NSSS VENDOR	
CODE	DESCRIPTION
B	BABCOCK & WILCOX
C	COMBUSTION ENGINEERING
G	GENERAL ELECTRIC
M	WESTINGHOUSE

DG MANUFACTURER

CODE	DESCRIPTION
AL	ALCO
CA	CATERPILLAR
CB	COOPER-BESSEMER
DL	DE LAVAL
FM	FAIRBANKS MORSE
GM	GENERAL MOTORS
NM	NORBERG MANUFACTURING
WD	WORTHINGTON

KW RATING

CODE	DESCRIPTION
02	200-400 KW
10	500-1000 KW
40	1750-1950 KW
25	2500-2850 KW
30	3000-3500 KW
40	4000-4418 KW

DOES NOT START

PLANT CONTROL NO.	FAIL DATE	MODE	FAILURE MODE	FAILURE MECHANISM
B 001 014838	051176	GM25 C	AI0 D B T DG #1 FAILED TO START ON SIMULATED 4.5. ACTUATION	FAILED DIODE IN AUTO START CIRCUIT
B 001 019978	102377	GM25 C	A14 T B T M1 DG FAILED TO START; DRIFT OF TD RELAY SETPOINT	ALSO DIODE CR-1 FOUND SHORTED
B 001 018231	060277	FM30 A	A13 T 4 I MAM DG FAILED TO START ON MONTHLY TEST	LOOSE INJECTOR HOLD-DOWN NUTS
B 001 018265	072677	FM30 I	A06 S D I T M38M DG FAILED TO START DISEL TRIPS WERE NOT RESET	REVISED PROCEDURES TO RESET TRIPS
B 001 019302	092877	FM30 B	A10 S D B T 38 DG FAILED TO START DUE TO START PERMISSIVE LOST	D START PERM. DUE TO LOW LUBE OIL PRESSUR
B 001 020221	122777	FM30 G	A09 R D R T 38 DG FAILED TO START DUE TO START PERMISSIVE LOST	SMALL PIECES OF INSULATION PREVENT GOVERNOR
B 001 020278	010378	FM30 G	A09 R D R T 38 DG FAILED TO START ---4TH OCCURRENCE	FOREIGN MATTER IN SERVO BOOSTER
B 001 023166	111778	FM30 M	A00 R U I T EDG-B FAILED TO FAST START ON TWO CONS. ATTEMPTS	STARTED SUCCESSFULLY TWICE AFTER ANOMALY
B 001 019816	122977	GM25 G	A14 S D G M DURIN LOSP DG 1-1 STARTED AND TRIPPED ON OVERSPEED	IMPROPER SETTINGS OF HT SPEED AND OVERSPD
B 001 020273	010978	GM25 F	A09 T 4 T DG 1-1 TRIPPED ON HI CRANKCASE PRESSURE	DIRTY CRANKCASE VENT OIL COLLECTOR
B 001 021852	060478	GM25 K	A10 D 4 T I-1 DG FAILED TO OPERATE WITH PROPER FREQ/VOLT	FAILED PRIMARY POTENTIAL FUSE / 4 DG 1-1
B 001 015329	071276	GM25 M	A00 U I T SEVERAL ATTEMPTS TO START M8M DG WERE UNSUCCESSFUL	NO DEFINITE CAUSE COULD BE DETERMINED
B 001 015262	080676	GM25 C	A10 D 4 T MAM DG FAILED TO START DURING SPECIAL TEST	IMPROPER GEAR ENGAGEMENT- AIR START MTR DOC
B 001 018053	082477	GM25 M	A00 R U I T DISEL GENERATOR M8M FAILED TO START	NO SPECIFIC CAUSE COULD BE DETERMINED
B 001 014298	022176	FM30 J	A06 S D I T M18M DG OUTPUT BREAKER FAILED TO CLOSE	PROCD ERROR-IMP GOV SETTING-FREQ TOO LOW
B 001 020294	011278	FM30 B	A14 S T 4 T EDG 1B FAILED TO START ON SIMULATED AUTOS TEST	OIL PRESS LIM SW PRESS SETTING DRIFTED
B 001 020299	031878	FM30 B	A10 T B T EDG FAILED TO START	DEFECTIVE OIL PRESSURE LIMIT SWITCH
B 001 021267	052078	FM30 F	A05 C D G T DG 8 FAILED TO START	VERT SHFT RTM UP & LWR CRANKS FLD-IMP MTL
B 001 023430	122878	FM30 A	A09 T B T DF-X-1B DID NOT START	PARTIALLY CLOGGED FUEL OIL FILTER
B 001 015567	072676	FM25 D	A02 S U 4 N #12 DG FAILED TO START AUTO FAILED ALSO FROM CONT RM	JACKET CCLLING H2O SYS AIRBOUND NOT VENTED

DOES NOT START

EVENT	PLANT	CONTROL NO.	FAIL DATE	H F K W	SUB/SYS	FAIL MODE	TYPE	CLASS	REPAIR	DISCOVERY	FAILURE MODE	FAILURE MECHANISM
C	CC1	015584	080776	FM25	J	A02	S	D	G	T	11 DG FAILED TO SENSE "AT VOLTAGE" COND.--OUTPUT BKR.	WILL NOT CLOSE--COLD SOLDER CONN TO ERA
C	CC1	017213	111876	FM25	M	A00	R	U	1	T	#12 DG S/D DUE TO ITS VENT FAN NOT STARTING	BLOWN FUSE--REPLACED CONTROLLER COIL T7
C	CC1	017822	051577	FM25	M	A09	R	T	6	T	#12 DG FAN FAILED TO START WHEN GEN RECEIVED SIGNAL	DIRT ON FAN MAIN BKR CONTACTS
C	CC1	019592	101077	FM25	K	A13	T	8	T	#12 DG FAILED TO REACH VOLTAGE WITHIN 10 SEC.	2 LOOSE FUSE HLDRS IN EXCITATION CIRCUIT	
C	CC1	021066	041078	FM25	L	A00	U	1	T	#12 DG OVERSPED & TRIPPED RESTARTED SUCCESSFULLY	CAUSE NOT DETERMINED TESTED SAT NEXT TIM	
C	CC1	021055	041378	FM25	M	A00	U	1	N	#11 DG FAILED TO START ON LOSS OF OFFSITE POWER	START/FAILURE ALARM DISPLAYD NO ABNORMALS	
C	CC2	016722	121576	FM25	C	A09	T	4	T	#21 DG FAILED TO START FROM CONTROL ROOM & LOCALLY	CLOGGED AIR STRT DISTRIBUTOR PILOT VALVES	
C	CC2	018422	022277	FM25	C	A0C	U	6	T	#21 FAILED TO START & ASSUME RATED SPEED IN 10 SEC	AIR START SYS DISASSEMBLD & INSPECTED	
C	CC2	017457	031777	FM25	M	A00	R	U	1	T	#12 DG VENT FAN FAILED TO START ON SIAS SIGNAL	OVERLOADS TRIPPED ON FAN; RESET OVERLOADS
C	CC2	017986	060177	FM25	D	A12	T	0	T	#21 DG FAILED TO MEET START TIME CRITERIA	SERVICE WATER INLET VALVE LEAKING EXCESSV	
C	FC1	014559	040776	GM25	M	A06	S	D	1	T	START ON SECONDRY AIR REQD 10.6 SECS.VS. 10SECS.	PROCEDURE WAS INADEQUATE
C	FC1	014590	042776	GM25	C	A02	T	0	8	U	DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE	IMPRPR SEING FOR MAG PKUP ON SWTCHG TALK
C	FC1	015722	081576	GM25	C	A14	T	0	8	U	DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE	SEING FOR MAG PKUP ON SWTCHG EACH DRIFTED
C	FC1	017662B	040677	GM25	C	A09	R	T	4	T	DG-1 FAILED TO STRT WITHN 10 SEC, STRTD OK ON PRI AIR	DEPOSITS FOUND ON SECONDARY AIR MOTORS
C	FC1	017662A	041477	GM25	C	A09	R	T	4	T	DG-2 FAILED TO START IN 10 SEC STRTD OK ON PRIMARY	DEPOSITS IN SECONDARY AIR MOTORS
C	FC1	021692	061978	GM25	K	A10	K	U	1	T	DG-1 FAILED TO REACH RATED TERM VLTG ON STARTUP	BLOWN FUSE IN GEN FIELD CIRCUIT
C	M12	014260A	021776	FM25	A	A09	B	T	1	N	DG 12U FAILED TO START - SIMILAR OCCUR, LER (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRKCS VENT
C	M12	015583A	081676	FM25	G	A10	B	T	4	T	DG 12U FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C	M12	015583B	081776	FM25	G	A10	B	T	4	T	DG 12U FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C	M12	016626	120176	FM25	D	A09	B	T	6	T	13U DG STARTED, NO CW FLOW, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS

DOES NOT START

PLANT	CONTROL	FAIL DATE	M K G	MODE	DESCRIPTION	FAILURE MECHANISM
C MLC	016923	081077	FM25	G	A01 S D I N DG 12V FAILED TO RESTART ON DEMAND	GOVERNOR STILL IN "NO FUEL" FROM PREV 3/0
C M12	019029	110977	FM25	K	A01 S D I T DG 13U TRIPPED WHILE PARALLELING WITH 4100V BUS	IMPROPER VOLTAGE SETTING PRIOR TO PARALL
C M11	020333	021878	GM25	G	A09 T B T DG-1A FAILED TO RESPOND DURING TEST RUN FOR TRAINING	DIRTY CONTACT ON SPEED CONTROL PC BOARD
C M11	022715	092578	GM25	A	A06 S D I T DG-1B COULD NOT BE LOADED DURING TEST AFTER MAINT	AIR WAS NOT PURGED FROM FUEL LINES
C S11	016881	110276	GM30	M	A01 S D I T 1A DG FAILED TO START	PERSONNEL ERROR - INCORRECT VALVE LINEUP
C S11	017135A	011977	GM30	A	A09 R T I T THE 1A DIESEL GENERATOR FAILED TO START	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C S11	017135B	011977	GM30	A	A09 R T I T THE 1A DG FAILED TO START AGAIN - LATER SAME DAY	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C S11	017441	030177	GM30	I	A01 S D I T 1A DIESEL GENERATOR FAILED TO START	OPER FAILED TO RESET OVERSPEED TRIP
C S11	022532	090578	GM30	J	A16 T B T "M" DG OUTPUT BREAKER WOULD NOT CLOSE REMOTELY	DIRTY CONTACTS ON ITS OPERATION RELAY
G 8F1	014102	011476	GM30	G	A12 T I T FAILED TO RESPOND TO ELEC. GOVNR SIGNALS DG #0	OIL DRAIN FROM HYDRAULIC ACTUATOR
G 8F3	014133	091977	GM30	K	A10 D I T 30 DG TRIPPO ON OVERSPEED ; GOVERNOR INOPERABLE	ID FUSE OPEN DISENABLING FIELD CIRCUIT
G 8P1	015448	080576	CA02	M	A03 R U U T DG FAILED TO START WITHIN 15 SEC NOT RETESTED	OPERATOR NOT AWARE OF SIGNIF OF START TIM
G 8P1	015449	080576	CA02	D	A00 R U R N DG FAILED TO START WITHIN 15 SECONDS DURING WEEKLY	POSSIBLE WATER JACKET HEATER FAILURE
G 8P1	015449	081276	CA02	C	A46 R T B T WEEKLY TEST FAILED TO START	STARTING BATTERY CABLE FAILED TO CONNECT
G 8P1	016072	090276	CA02	A	A00 R U U T FAILED TO MEET 15 SEC START TIME DURING WEEKLY TEST	POSSIBLE FUEL SYSTEM FAILURE
G 8P1	016304	102876	CA02	G	A00 R U U T DG FAILED TO START WITHIN 15 SEC	POSSIBLE FUEL GOVERNOR CONTROL PROBLEM
G 8P1	016460	110476	CA02	G	A00 R U U T START TIME 2.2 SEC SLOWER THAN REQUIRED	POSSIBLE FUEL GOVERNOR PROBLEM
G 8P1	016087	111876	CA02	C	A10 R D N T FAILED TO START IN AUTO TEST; STARTER MOTOR PROBLEM	BROKEN SPRING IN BENDIX MECHANISM
G 8P1	016597	120276	CA02	G	A00 R U U T FAILED TO MEET 12 SEC START TIME DURING AUTO TEST	FUEL GOVERNOR REPLACED ON 12/19/76
G 8P1	016913	122076	CA02	G	A04 R U U T START TIME EXCEEDED CRITERIA BY 4 SEC	GOVERNOR LUBE OIL FUEL SYS UNDER INVESTIGTN

DOES NOT START

VEN	CONTROL NO.	FAIL DATE	M F K G W S	START TIME	GT. CRITERIA	FAILURE MODE	FAILURE MECHANISM
G	BPI 016912	122776	CA02 A	004 R U U T	START TIME GT. CRITERIA 15 VS 12		FUEL GOV. LUBE OIL SUPPLY MODIFIED 1/10/77
G	BPI 016911	122876	CA02 C	A10 R D M	DEFECTIVE STARTER DRIVE, DG FAILED TO START		BROKEN SPRING DELCO PART #1945487
G	BPI 016916	010377	CA02 G	A00 R U U T	FAILED TO START IN AUTO TEST		CAUSE UNKNOWN LUBE OIL RETENTION IN GOV.?
G	BPI 020298	032477	CA02 G	A00 R U U T	EDG STARTING TIME EXCEEDED 12 SEC. BY .8 SEC.		GOVERNOR LUBE SYS MODIFIED ON 1/16/77
G	BPI 018102	051877	CA02 D	A00 R T N	H2O JACKET HEATER FAILURE--EDG TESTED; DID NOT MEE		FUEL CRITERIA EXCEEDED BY 12 SECONDS
G	BPI 018103	052677	CA02 A	A00 R U U T	START TIME 16.5 SEC, SHOULD BE LT 13.9 SEC		FUEL CONTROL VALVE MODIFIED
G	BPI 018742	080577	CA02 J	A04 S D G	TESTED EDG WITH 2A-28 BKR RACKD OUT; AUTO TRAN-PR		AND MAN TRANSFER FAILD TO CLCSE ULTPUT BKR
G	BPI 019241	102077	CA02 C	A00 R U U T	START TIME 21.8 SEC VS. 13.9 SEC		CHECKD VOLTAGE DRUP ON START CABLES
G	BPI 019993	112477	CA02 A	A00 R U U T	START TIME 33 SECS TESTED SAT WITHIN ONE HOUR		FUEL CHECKED OK PREM GRADE OF FUEL USED
G	BPI 020275	020278	CA02 M	A00 R U U T	START TIME 26.5 SECS VS 13.9 SECS		CAUSE UNKNOWN
G	BPI 018854	010477	NM30 B	A04 C D Y	DG TRIPPD R/X AT POWER LOW LUBE OIL TEMP		LOW SETPOINT FOR PRE-FILTER HEATER /JACKT
G	BPI 018854	010477	NM30 B	A04 C D Y	DG TRIPPD R/X AT POWER, TO SWITCH NOT RESET		L.G.PRESS SWITCH TIME DELAY INCORRECT
G	BPI 020068	120977	NM30 C	A09 T D T	DG START TIME 10.2 SEC VS 10		CARBON BUILDUP ON AIR VALVE STUCK SHUT
G	BPI 014136	010976	NM30 J	A10 D 4 N	DG STARTED BUT OUTPUT BKR FAILD TO CLOSE TO E-1		BROKEN LLG WIRE DUE TO STRESS
G	BPI 015461	061176	NM30 A	A02 C D T	DG STALLED & FAILD TO TIE INTO E-BUS R/X AT PR		40 GAL H2O IN SADDLE & 4 DAY TANK
G	BPI 016399	111176	NM30 C	A08 T U T	DG FAILD OPER TEST-12.2 ON #2 AIR RECIEVER		CHECK VALVE RUSTED SHUT
G	BPI 020612	021378	NM30 K	A01 S D N	FOLLOWING SCRAM ON UNIT 1, #1 DG LG RELAY WOULDN'T		RESET; LOSS OF EXCITATION RELAY NOT RESET
G	CUI 016712	111076	CB40 J	A03 S D B	T 00-1 OUTPUT BKR FAILD TO CLOSE--BLOWN FUSE		59RELAY DISCONNECTD ONLY ONE WIRE ON 11/8/76
G	CUI 023644	091278	CB40 F	A09 T G T	DG TRIPPD APPROX 1 MIN AFTR REACH RATED		SPEED MAIN BEARING FAILD DUE TO LOW LUBE OIL
G	DAI 015493	100776	FM25 F	A05 D D T	1621 BROKEN LOWER VERT DRIVE COUPLING HUB		HUB MADE OF WRONG MATERIAL

DOES NOT START

PLANE	CONTROL NO.	FAIL DATE	F K C W	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
G	DA1 01756	051077	FM25	J	10-21 DG OUTPUT BKR FAILED TO CLOSE	AUX CONTACTS OF STANBY TRANSFORMER OPEN
G	DA1 021171	040578	FM25	F	A06 DG M BEARING WIPED ON 4/13/77 NOT DUE TO MISALIGNMENT	LUBE OIL FILTER DRAIN VALVE WAS OPEN
G	DA1 0204088	012778	GM10	M	ALL C D I N U-1 B/U DG FAIL TO START 1ST 5 TIMES-LOW TEMPERAT	WINTER WEATHER
G	DA1 020408A	012978	GM10	M	ALL C D I N U-1 B/U DG FAIL TO START DUE TO COLD WEATHR 6 HEATRS	INSTALLED & ROOM WINTERIZED
G	DA1 020852	030478	GM10	C	A10 D G T D-1 B/U FAIL TO START R/X IN HOT S/D MODE	SYNCHRO START SWITCH FAIL
G	DA1 021517	050778	GM10	B	A10 F D N TEMPORARY DG FAIL TO START DUE TO LOW LUBE OIL PRS	L.G. PUMP COUPLING DAMAGED
G	DA1 021516	051178	GM10	A	A10 R D G T TEMP. DG FAIL TO START-BLOW FUSES IN CONT LOGIC	SHORTED DIODE ACROSS FUEL PRIMING PUMP
G	DA1 014913	052376	GM25	C	A00 U I T UNIT 2/3 DG FAIL TO START	CAUSE UNKNOWN BUT POSSIBLE AIR START SYST
G	DA1 016443	102976	GM25	I	A14 S T O T UNIT 2 DG FAIL TO START TWICE MALFUNCTION S/D SOLENOID	SOLENOID PLUNGER OUT OF ADJUSTMENT
G	DA1 017347	032277	GM25	C	A10 R D I T UNIT 2/3 FAILED TO START	AIR START MOTOR PINION GEAR JAMMED
G	DA1 018283	063077	GM25	G	A00 K D I T 2/3 DG TRIPPO ON OVERSPEED DURING 2 ATTEMPTS	POSSIBLE CUT-OF-ADJUST GOVERNOR COMPENSATION
G	DA1 018494	071277	GM25	G	A00 R D I T U 2/3 DG TRIPPO ON OVERSPEED--OCCURD ALSO 6/30/77	PROBABLE CUT-OF-ADJUST GOVERNOR COMPENSATION
G	DA1 019732	111677	GM25	I	A00 S D I T AUTOC-START SIGNAL SENT TO UNIT 2/3 DURING CORE SPRAY	RESET START FAILURE RELAY & DIESEL START
G	DA1 019723	120277	GM25	C	A13 R T I T UNIT 2 DG AIR RECEIVER L.P. PRESS TERMINATED START	LOOSE WIRE AT TERMINAL 25A5
G	DA1 019610	120377	GM25	C	A12 D A T 2/3 DG FAIL TO ROLL OVER--LOW START AIR PRESSURE	RUPTURED REGULATOR DIAPHRAM
G	DA1 019905	120477	GM25	J	A00 U I T 02 DG OUTPUT BKR FAIL TO CLOSE--NO APPARENT CAUSE	3 SUBJECT TESTS WERE SUCCESSFUL
G	DA1 020242	010378	GM25	C	A13 R T B T UNIT 2 DG FAIL TO START WEEKLY SURV TEST	LOOSE WIRE AT TERMINAL 25A5
G	DA1 021048	030778	GM25	C	A00 S D B T OPERATOR SHOOK AIR START SOLENOID 6 UNIT 2/3	STARTED POSSIBLE WIRE DAMAGED DUE TO FREQ INSPEC
G	DA1 020855	030878	GM25	G	A14 S D B T ENGINE OVERSHOOT AT 1010 RPM WHILE 05 SET AT 1020	HI OVERSHOOT BY CUT-OF-ADJUST GOVERNOR COMP
G	DA1 021338	052278	GM25	G	A02 D B T U-2 DG TRIPPO 4 TIMES ON OVERSPEED/RX IN S/D	MODE GOVERNOR SETTING FLUID SET TOO HIGH

DOES NOT START

PLANT	CONTROL NO.	FAIL DATE	M F K G W	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
G DR2	022462	082478	GM25	C A10 R U 4 T	2/3 UNIT 005 UNIT 2 FAIL TO START ON 1ST ATTEMP	PINION GEAR NOT ENGAGED ON AIR START MIR
G DR2	022389	092278	GM25	C A06 R U 8 T	UNIT 2/3 FAIL TO START; AIR START MTRS ENGAGED	AIR-START SYS WILL BE MODIFIED
G DR2	023337	121678	GM25	C A09 R D 4 T	2/3 DG AIR START MCTORS DISENGAGED AFTER FEW SECS.	T02 RELAY CLEANED; T02 AND AIR VALVE ?
G DR3	014439	036376	GM25	G A13 R Y 4 T	DG COULD NOT BE LOADED FROM CONTROL ROOM	GOVNR CONTROL WIRE VIBRATED FREE FROM LUG
G DR3	010487	100976	GM25	G A13 R E 4 T	LOSS OF CONTROL ROOM SPEED CONTROL	LOOSE WIRE ON GOVNR CONTROL CIRCUIT
G DR3	017509	032277	GM25	K A10 O G M	GEN FIELD FAIL TO FLASH	INTERMITTENT CAPACITOR SHORT IN FLASH CIRC
G DR3	017722	112277	GM25	G A10 R D 8 T	B DG STARTED/LOADED-OVERLOAD ALARM-DG TRIPPED	BAD CAPACITOR IN SPEED SENSING CNT. ?
G EN1	014778	031576	FM25	C A10 D D I	1A DG FAILED TO START DURING SURVEILLANCE	SOL OPER AIR VLV IN START SYS STUCK SHUT
G EN1	014796	051576	FM25	M A00 U D T	1B DG FAILED TO START ON FIRST ATTEMPT	UNKNOWN WILL DO WEEKLY START TO DETERMINE
G EN1	015268	080576	FM25	K A06 S D I	DG 1A TRIPPED DUE TO LOSS OF EXCITATION DRNG SYNCH	DEFECTIVE PROCEDURE - PARALLELED OUT OF SYN
G EN1	015947	081476	FM25	M A00 R D U	1C DG FAILED TO START - SURV TEST - OCCURRED PREV	LOW OIL LEVEL IN GOVERNOR
G EN1	016665	091176	FM25	G A10 R D I	1A DG FAILED TO START - SURV TEST - RECURRING	EXACT CAUSE OF START FAILURE NOT KNOWN
G EN1	016843	123176	FM25	M A00 R U I	MAN START OF 1A DG FAILED THIS HAS HAPPEND BEFORE	INSPECTED & RETESTED SATISFACTORILY
G EN1	018141	052877	FM25	M A00 U U I	1A DG FAILED TO COME UP TO RATED VOLT IN REQD. TIME	TUOK 16 SEC VS 12 SEC RETESTED SATISFAC
G EN1	020214	112577	FM25	G A08 T 8 T	1A DG FAILED TO START; STUCK GOVNR BOOSTER SERVO MOTOR	AIR PISTON WAS CORRODED
G EN2	022751A	102878	FM25	G A10 R D 8 T	"C" DIESEL FAILED TO REACH 250RPM IN 7 SEC.	STICKING GOVNR BOOSTER SERVO
G EN2	022751B	103178	FM25	G A10 K T 8 M	"C" DIESEL FAILED TO REACH 250RPM IN 7 SEC.	FAULTY ELECTRONIC SPEED SWITCH SIGNAL
G FPI	016496	111776	GM25	I A10 R D 8 T	"B" EDG FAILED TO START DURING SURVEILLANCE TEST	GEN TACH RELAY DID NOT OPERATE, DEF CNVTR
G FPI	016600	121576	GM25	B A10 R D I	DURING TESTING "A" EDG FAILED TO START	LOW LUBE OIL PRESS - RELIEF VLV LEAKAGE
G FPI	016471	011977	GM25	B A10 R D I	DURING SURV, EDG TRIPPED ON EMERGENCY START	LOW LUBE OIL PRESS, SECOND ATTEMPT SUCCESSFUL

DOES NOT START

UNIT	CONTROL NO.	FAIL DATE	FAILURE MODE	FAILURE MECHANISM
G	F01	012725	DURING ROUTINE SURV TEST, EDG FAILED TO START	TACHOMETER RELAY FAILED
G	F01	023161	"M" DG TRIPPED WHEN BEING PARALLELED	MISADJUSTMENT OF GOVERNOR
G	M01	010186	"T" DG FAILED TO START ON #2 STARTING SYSTEM	#2 START SYS AIR CONT COMP FOULED W RUST
G	O01	014447	"B" DG 2 STARTED BUT DID NOT DEV SUFF VLTG TO LOAD	WESTHSE FFCU RELAY FLD TO EMRGZ FLD FLASH
G	O01	015642	"J" DG #2 FAILED TO START DURING OPERABILITY TEST	CONTROL SEQ FAULT - HOWEVER, SEQ CORRECT
G	O01	023119	"B" DG STARTED BUT GEN FAILED TO EXCITE--AUTG ACT-IES	UNUSED TARGET MECH LINKAGE IN RELAY BINDM
G	P02	010886	"J" DG FAILED TO START DUE TO HI JKT CLG WTR TEMP	OPER RESET TRIPPED PMP, BUT NOT DIESEL TRP
G	P02	018887	"J" DG TRIPPED ON OVERSPEED	OVSPD TRIP SET BELOW DESIGN VALUE
G	P02	019414	"M" DG TRIPPED FOLLOWING MANUAL START	3 VALVES TO LOW PRESS SW LEFT SHUT
G	P02	020090	"M" DG TRIPPED ON "M" PHASE DIFF AFTER PARALLELING	CAUSE COULD NOT BE DETERMD AFTER EXTN YSI
G	P02	022462	"E-3" DG START TIME DID NOT MEET TS REQUIREMENT	LEAKY CHR VLV IN AIR BOOSTER RELAY HYD 0Y
G	P02	02349A	"E-3" DG START TIME 13 SEC. VS. REQUIRED 10 SEC.	E-3 DG GOVERNOR REPLACED ON 12/26/78
G	P02	02349B	"E-3" DG START TIME 11 SEC. VS. 10 SEC	POSSIBLE GOVERNOR PROBLEMS
G	Q01	014120	"I" DG FAILED TO START WHEN MODE SW IN START MD	AIR START SOL VLV DIRTY-NOT OPEN FULLY
G	Q01	018112	"I" DG WHILE TESTING THE DG, THE FIELD FAILED TO FLASH	CAPACITOR ACROSS VLTG SUP RELAY DEFECTIVE
G	Q01	019100	"I" DG STARTED AND RAN, BUT NO VLTG SYNC/FREQ	FREQ GEN TACH SET SCREWS VIBRATED LGUSE
G	Q01	019594	"I" DG WOULD NOT START SUCCESSFULLY/FIELD BRK DEFECT	FAILED D10E IN FLD BRK INLK CIRCUIT
G	Y01	014740	"M" DIESEL GENERATOR TRIPPED CP. HI CRNKSE PRESS	CLOGGED CRNKSE EJ SUP ORIFICE OR EJ BODY
G	Y01	014628	"M" DIESEL GENERATOR FAILED TO START	AIR START SOL VALVES BOUND CLSD BY DEBRIS
G	B01	014903	"I" DG #1 FAILED TO START 3 TIMES DG #2 STARTED OK	WATER ACCUMULATION IN AIR START SYSTEMS

DOES NOT START

P L N F	CONTROL NO.	FAIL DATE	M F K G W	F F JUB M S D O C E H E S I Y	A A I I L L M M T T C C P P V V A A R R K K E E A A R R K K E E S S I I Y Y	D I S C O V E R S I M U L A T I O N	FAILURE MODE -----	FAILURE MECHANISM -----
W	8V1 015913	090376	GM25 J	A00	U	I	#1 DG OUTPUT BREAKER FAIL TO CLOSE	NO APPARENT CAUSE
W	8V1 017348	031477	GM25 J	A04 B 0 4	I	#2 DG OUTPUT BREAKER FAIL TO CLOSE	DIRTY CONTACTS ON BKR CONT SWITCH	
W	8V1 017621	041177	GM25 J	A04 B 0 4	I	#1 DG OUTPUT BREAKER FAIL TO CLOSE	DESIGN CHANGE REQUEST FOR SEALED RELAYS	
W	8V1 017693	042677	GM25 J	A04 B 0 4	I	#1 DG OUTPUT BKR. FAIL TO CLOSE	DIRTY CONTACTS ON NFLDA(AND FIELD) RELAY	
W	8V1 017696	042977	GM25 C	A09 R T 4	N	DG #1 FAIL TO START REPETITIVE	MOISTURE IN STARTING AIR	
W	8V1 017627	050977	GM25 J	A04 R 0 4	I	#2 DG OUTPUT BKR. FAIL TO CLOSE	STICKING RELAY(MSR2) IN MANUAL START CRT.	
W	8V1 018008	060377	GM25 J	A04 R 0 1	I	#2 DG OUTPUT BKR. FAIL TO CLOSE	CLOSED ON NEXT ATTEMPT; STICKY NFLDA RELAY	
W	8V1 018828	071777	GM25 K	A10 R T 8	I	#2 DG STARTED AND CLOSED ONTO BUS; OUTPUT VOLTS =0.	LOOSE CONNECTIONS IN AUTO FIELD FLASH CRT	
W	8V1 020437	011178	GM25 J	A04 R 0 4	I	#2 DG OUTPUT BKR. FAIL TO CLOSE	IN EXERCISE MODE NO CAUSE COULD BE DETERMINED	
W	8V1 022437	072878	GM25 K	A10 R 0 1	N	#2 DG FAIL TO FLASH DURING SI AND LOSP EVENT	STICKY FIELD FLASH CUTOFF RELAY; AUTO CRT.	
W	8V1 022525B	090573	GM25 J	A00 R 0 1	I	#1 DG OUTPUT BKR. FAIL TO CLOSE; #2 DG DCS	BKR CLOSED MANUALLY; 1 HOUR RUN AT FULL LO	
W	8V1 022394B	091278	GM25 J	A00 R 0 1	I	#1 DG OUTPUT BKR. FAIL TO CLOSE USING CONT.	SWITCH CLOSED LATER NEGATING TROUBLESHOOTING	
W	DC1 016647	120976	W030 K	A10	D	I	T C-0 DG TRIPPED ON OVERSPEED--BLOWN FUSE ON INVERTER	FAILED SILICONE RECTIFIER IN DG INVERTER
W	DC2 022503	091178	W030 C	A13	T	4	T 2AB STARTED FOR LOAD TEST WAS TRIPPED OFF MANUALLY	PISTON BOLT FOR AIR CHECK VALVE LOOSE
W	DC4 022839	101978	W030 A	A00	U	I	T 2AB FAIL TO START DUE TO LACK OF FUEL TO INJECTRS	UNKNOWN BUT REPLACED FUEL FILTER ELEMENT
W	HN1 014162	020376	GM25 A	A02 J 0 1	E	DG-28 TRIPPED ON OVERSPEED WHILE STARTING		
W	JF1 014955	081777	FM40 C	A10 B 0 1	D	G 18 TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY	MAIN AIR VALVE FAIL TO SHUT/CAUSED OVRSP	
W	JF1 014962	082077	FM40 C	A10 B 0 1	D	G 18 TRIPPED ON OVRSP DURING MANUAL START	MAIN AIR START VLV FAILED TO FULLY SHUT	
W	JF1 019368	101877	FM40 G	A10	D	8	T OSL GEN 1-2A FAILED TO START DURING TEST	SPEED SWITCH FAILED - 120V VS 130V RATING
W	JF1 020992	030278	FM40 C	A09 C 1	D	I	DJL GEN 18 FAILED TO ATTAIN RATED SPEED	CORROSION PRODUCTS CLOGGED AIR START VLVs

DCES NOT START

PLANT	CONTROL NO.	FAIL DATE	MARKS	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
YRI	017176	030177	M02	C AIG	D 4 T #1 EDG FAILED TO START DUE TO FAILO STARTER MOTOR	ARMATURE SHAFT BROKEN--REPLACED * SPARE
W	Z11	012477	C840	M A00	U 1 T #04 DIESEL GENERATOR FAILED TO START	NO CAUSE COULD BE DETERMINED
W	Z11	010178	C840	C AIG	T 1 T 18 DIESEL GENERATOR FAILED TO START	AIR LEAK IN STARTING AIR PILOT VALVE
W	Z11	010278	C840	C AIG	U 4 T 18 DIESEL GENERATOR FAILED TO START	STARTING AIR DIST BUSHING ROTATED IMPROP
W	Z11	022846	C840	B A02	C 0 4 M 1A DG CAME UP TO SPEED AND THEN TRIPPED - 5 TIMES	RAG IN OIL STRAINER CAUSED LO OIL PRESS I
W	Z11	023308	C840	M A00	U 0 D N 18 DG FAILED TO START DURN AN INADVERTANT SAFETY INJEC	EXTENSIVE TESTING REVEALD NO CAUSE

APPENDIX G

DIESEL-GENERATOR EVENTS CLASSIFIED AS
DOES NOT CONTINUE TO RUN FAILURES

CODES USED IN LER ONE-LINE DESCRIPTIONS

REPAIR TIME
 CODE DESCRIPTION
 1 0-1 HOURS
 2 1-2 HOURS
 3 2-4 HOURS
 4 4-8 HOURS
 5 GREATER THAN 24 HOURS
 6 UNKNOWN / NOT APPLICABLE

FAILURE MODE
 CODE DESCRIPTION
 A DOES NOT START
 B DOES NOT CONTINUE TO RUN
 C UNAVAILABLE / NONFAILURE

FAILURE CLASSIFICATION
 CODE DESCRIPTION
 0 DEMAND
 1 TIME
 2 UNKNOWN

METHOD OF DISCOVERY

CODE DESCRIPTION
 K DURING MAINTENANCE OPERATIONS
 M DURING NORMAL OPERATIONS
 P DURING REPAIRS
 Q UNKNOWN

FAILURE MECHANISM

CODE DESCRIPTION
 01 UNKNOWN
 02 OPERATIONAL
 03 OPERATIONAL / TESTING
 04 OPERATIONAL / CONSTRUCTION / QUALITY CONTROL
 05 PRODUCTION / COMPANY (FACTORY)
 06 PRODUCTION / USER (CUSTOMER)
 07 DECOMMISSION / MAINTENANCE
 08 MECHANICAL / ELECTRICAL / CONTROL
 09 FUEL / WATER / AIR LEAKAGE
 10 TYPE OF ADJUSTMENT / CALIBRATION

SUB-SYSTEM

CODE DESCRIPTION
 A FUEL SYSTEM
 B OIL SYSTEM
 C FUEL SYSTEM
 D COOLING SYSTEM
 E ENGINE / INJECTION SYSTEMS
 F GOVERNOR SYSTEM
 G EXHAUST SYSTEM
 H STARTER / BRAKE
 I VOLTAGE REGULATOR
 J EXCITER
 K GENERATOR
 L UNKNOWN

TYPE OF EVENT

CODE DESCRIPTION
 0 RECURRING COMMON CAUSE
 1 RECURRING CAUSE
 2 RECURRING FAULTS
 3 RECURRING COMMAND FAULTS

OG MANUFACTURER

CODE DESCRIPTION
 AL ALCO
 CA CATERPILLAR
 CB CUMMINS
 CC CUMMINS
 CM CUMMINS
 DM DEERE
 MO MOTOROLA
 ND NORTHROP

KW RATING

CODE DESCRIPTION
 2 20-40 KW
 3 40-75 KW
 4 75-150 KW
 5 150-300 KW
 6 300-450 KW

DOES NOT CONTINUE TO RUN

164

V E N T	P L A N T	CONTROL NO.	FAIL DATE	M F G W	S E R V I C E	F A I L M O D E	F A I L M E C H E N I S M	C L A S S	R E P A I R	D I S C O V E R Y		FAILURE MODE	FAILURE MECHANISM
B	ARI	021063	032078	GM25	E	804	T G I	DG #2	ON FIRE DUE TO LUBE OIL GETTING INTO EXHAUST	TURBOCHGR BNG FAILED, CAUSNG SEAL FAILURE			
B	DB1	020706	020878	GM25	E	805	U G T	1-1	DG S/D DUE TO NOISY TURBOCHARGER	DESIGN/FABRICN OR COMPNT FAILURE, REPLACD			
J	061	021580	050978	GM25	E	800	U G T	GEN LOAD FLUCTUATING	AIR INTAKE LO PRESS ALARM	CAUSE UNKNOWN EXTENSIVE MAINT PERFORMED			
B	DB1	023007	103178	GM25	M	811	S U 4 T	1-2	DG S/D DUE TO ROOM TEMP RISE TO 110 DEG.	OUTSIDE AIR DAMPER WOULD NOT OPEN			
B	RJ1	010656	120676	GM25	G	810	D B T	DG "A"	TRIPPED OFF-LINE 25 MIN INTO TEST	SPEED CONT SW FLD CLOSED, SPD DECK TO TRIP			
B	RJ1	022613	100478	GM25	A	801	S D 1 N	"A"	DG S/D DUE TO SPRAY OF FUEL OIL; "B" DG OOS	FUEL LEAK-EXCSVLY LOOSEND STRK PKG GLND			
B	I12	021609	042578	FM36	F	806	R U 1 T	"B"	DG TRIPPED ON HI CRNKSE PRESS AFTER 32 MIN RUN	NO ABNORMAL PARAMETERS WERE FOUND			
B	I12	021605	052378	FM36	F	809	R T 8 M	DG B	TRIPPED ON HIGH CRANKCASE PRESS - 32 MIN RUN	PART PLUGD ORIFICE PLATE-TO-CRCKSE VAC EJC			
C	CC1	016405	102576	FM25	M	800	R U 1 T	#12	DG S/D DUE TO DG VENT FAN STOPPED-BLOWN FUSE	CAUSE FOR BLOWN FUSE NOT DETERMINED			
C	CC1	018306	061777	FM25	F	802	D 1 T	#11	DG STARTD; LATER DISCOVERD #6 CYLINDR RELIEF	VALVE VIBRATED LOOSE AND FELL OFF DG			
C	CC1	018488	071177	FM25	B	802	C D 4 M	#11	DG ON FIRE DUE TO L.O. HITTING HOT EXHAUST	G-RING SEAL ON STRNK NOT GLUED PROPERLY			
C	CC1	018487	071377	FM25	D	802	S D 1 T	#11	DG TRIPPED ON LOW JACKET COOLNT PRESS WHEN SIAS	SIGNAL REMOVED; DP SWITCH ISOLATED			
C	CC1	023386	121878	FM25	M	806	R D 1 T	#11	DG SHUTDOWN DUE TO ROOM VENT, FAN FAILD TO STRT	FAN FAILURE--RESET OVERLOADS			
C	CC2	020226	011078	FM25	J	810	I 1 T	#21	DG TRIPPED AFTR 29 MIN. DUE TO GEN FAULT	LOSS OF FIELD & REVERSE POWER RELAYS			
C	CC2	021491	080178	FM25	D	810	S D 4 T	#21	DG TRIPPED ON HI JACKET COOLNT TEMP	SERV H2O SUPPLY VALV FAILD TO OPEN			
C	FC1	015614	081576	GM25	G	816	T 8 N	SMOKE	COMING FROM DG-2 GOVENDR MOTOR ENCLOSURE	ARMATURE HAD OPEN WINDING			
C	FC1	021799	071278	GM25	K	816	R D 8 T	DG-1	FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN	3 EXCITER SUBCOMPONENT FAILURES (COINCIDT)			
C	FC1	022249	080978	GM25	K	810	R D 8 T	DG-1	FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN	REFER VOLTAGE ZENER DIODE OUTPUT DRIFTED			
C	M12	0142608	021876	FM25	A	809	B T 1 N	DG 12U	TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLIR, CARBON IN CRCKSE VENT			
C	M12	0142600	022076	FM25	A	809	B T 1 N	DG 12U	TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLIR, CARBON IN CRCKSE VENT			

----- DOES NOT CONTINUE TO RUN -----

UNIT	CONTROL NO.	FAIL DATE	M K G W	REASON	FAILURE MODE	FAILURE MECHANISM
C M12	0142600	022376	FM25 F	B04 B T G N	DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR. (75-23)	UPPER ROD BEARING FAILURE - LACK OF LUBRI
C M12	015166	066276	FM25 F	B09 B T 1 T	DG 13U TRIPPED ON HI CRANKCASE PRESS - 11 MIN RUN	CRKCASE AIR EDUCATOR FOUND DIRTY
C M12	015563C	082376	FM25 G	B10 B T 4 T	DG 12U TRIPPED OFF-LINE	DRYED LEATHER WASHER IN BOOSTER SERVMOTOR
C M12	015906	090176	FM25 B	B12 C T 1 N	DG 13U SHUTDOWN - FIRE ON EXHAUST MANIFOLD	LUBE & FUEL OIL ACCUM UNDER MANIF INSULAT
C M12	016636	091976	FM25 B	B12 B D 4 N	12U DG HAD TO BE SECURED AND DECLARED INOPERABLE	EXCSV LEAKAGE OF LUBE OIL FILTER GASKET
C M12	016631	092276	FM25 D	B09 B T G T	12U DG RECVD LOW CM FLO ALA-UNIT UNLOADED, SECURED	EXCSV MUSSEL FEULING OF DG HT EXCHANGERS
C M12	016755	121876	FM25 F	B06 D G I	DG 13U #3 UPPER PISTON COM ROD BRNG CAP SHEARED	CAPSCREWS FAILD - PROB DUE TO DRY STARTS
C M12	017020	011077	FM25 F	B13 S D G T	DG 13U SHUTDOWN DUE TO HIGH VIBRATION	>K10 MOUNT IN RESONANCE WITH ENG FREQUEN
C M12	018972	081777	FM25 D	B09 B T G T	12U DG LOW CM FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FEULING OF DG HT EXCHANGERS
C M12	018976B	092077	FM25 D	B09 B T G N	COOLING WTR LOW FLOW ALARM - 12U DIESEL GEN	INSUF CL INJECTION FOR ADJ MUSSEL CONTROL
C M12	019225	092477	FM25 I	B14 S T B T	12U DG APPEARED TO TRIP ON GEN OVERCURRENT	MICRO SW OUT OF ADJ DN DG DWSPD TRIP MECH
C M12	021386	050878	FM25 D	B09 B T G T	12U DG LOW CM FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FEULING OF DG HT EXCHANGERS
C M12	022131	080378	FM25 A	B07 T B T	DG 13U SHUTDOWN DUE TO LEAKING INJECTOR	CRACK IN INJ PUMP DISCH VALVE CAGE
C M12	023213	120578	FM25 D	B09 B T G T	12U DG S/D DUE TO LOW COOLING WATER FLOW	MUSSEL SHELLS IN THE HEAT EXCHANGER
C S11	027134	011877	GM30 E	B04 R T G T	18 DG RAN FOR 55 MIN THEN TRIPPED ON LOCKOUT	TURBOCHARGER SHAFT AND OIL SEAL DAMAGED
C S11	019511	092677	GM30 E	B04 R T G T	1A DG SHUTDOWN WHEN SMOKE ISSUED FROM TURBOCHARGER	FAILED TURBO CHARGER UNIT
G RPI	010201	110376	GM30 G	B09 C T 4 T	D DG ERRATIC SPEED BEHAVIOR UNDER LOAD	DIRTY OIL IN GOVERNOR
G RPI	014417	030476	CA02 U	B09 R T B T	DG TRIPD ON HI COOLING WATER TEMP	WATER PUMP SUCT SCREEN PLUGGD
G RPI	014894	051676	CA02 D	B09 R T G N	DG TRIPD ON HI COOLN WATER TEMP PUMP SHAFT SCORED	INLET SCREEN PARTIALLY PLUGGED
G RPI	020584	020978	CA02 D	B12 T 4 T	DG TRIPD ON HI WATER TEMP AFT 25 MIN OF OPS	AIR LEAKAGE ON PUMP COOLING WATER SHAFT

DOES NOT CONTINUE TO RUN

V E N	P L A N T	C O N T R O L N O.	F A I L D A T E	M F K G W	S U B S Y S T E M	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE		FAILURE MECHANISM
G BK1	019391	101177	NM30	G	805	D	B	T	#2 DG	UNABLE TO MAINTAIN LOAD CYCLING 500KW	SHORTED LEADS TO GOVERNOR; INCORRECT ASMB			
G BR1	019448	121077	NM30	J	800	D	D	T	SMOKE	COMING FROM 320 RELAY AND #608 RELAY	FLAMING REPLACED AND CALIBRATED RELAYS			
G BR1	022454	091178	NM30	A	807	T	4	T	#1 DG	CYLINDER #1 NOT FIRING--HEAVY LOADING ???	FAULTY FUEL PUMP REPLACED			
G BR2	014614	031476	NM30	A	812	T	D	T	AT 96% POWER	#2 DG STARTED TO CYCLE IN LOCAL-MANUL	FUELOIL SHIFT VALVE LEAKN GASKET RENEWD			
G BR2	016823	122976	NM30	G	810	T	8	T	#2 DG	FAILD OPERABILITY TEST --LOSS OF SPEED CONT.	CLUTCH ADJUSTED AND STATOR VOLTMR REPLAC			
G CO1	015872	082376	CB40	A	800	U	8	T	FUEL LINE	TO AN INJECTOR OF #1 DG BURST	CAUSE UNDETERMINED			
G CO1	016560	110776	CB40	K	808	T	D	T	DG-2	LOST ELECT GOVERNOR CONTROL AND VOLTAGE	POT. TRANSFRMR FUSE CONTACTS OXIDIZED			
G DAL	014334	022776	FM25	B	812	R	D	T	SMALL FIRE	ON EXHAUST MANIFOLD OF DG 1G21	OIL LEAK FROM FRONT COVER PLATE			
G DAL	014337	031776	FM25	H	812	K	D	T	SMALL FIRE	NEAR EXHAUST MAN-TURBOCHRG R FLANGE	1G21 LEAKY FLANGE GASKET			
G DAL	014953	062276	FM25	D	809	C	T	B	T	1G-31 DG TRIPPD ON HI JACKET TEMP-DECLARED INOPRBL	ESW LOW FLOW DUE TO MUD IN STRAINER ^R			
G DAL	016452	110476	FM25	A	804	D	D	T	DG 1G-21	S/D DUE TO FIRE -FUEL LINE FRACTURE	INADEQUATE DESIGN			
G DAL	017963	051277	FM25	G	806	S	D	I	T	1G-31 DG WOULD NOT REACH FULL LOADING ONLY 2500 KW	SPEED SETTING ADJUSTMNT NOT RESET			
G DR2	016168	093076	GM25	K	809	T	D	T	2/3 DG	OUTPUT ERRATIC AFTR CONTROL PLACED IN "STOP"	SHORTD SELENIUM RECTIFIER DUE TO DIRT			
G DR2	016554	121876	GM25	A	802	S	D	D	T	UNIT 2 DG FAILD TO CARRY REQD LOAD ;2600KW MAX	H2O IN FUEL SUPPLY FROM FLUSHING OPERATON			
G DR2	014651	103077	GM25	E	806	T	G	T	UNIT 2/3	UNLOADED TRIPPD ON LOW H2O PRESS RESTART	TURBO-CHARGR CLUTCHSHAFT BEARING			
G DR2	019728	112977	GM25	D	812	C	D	D	T	2/3 DG S/D DUE TO COOL H2O PUMP TRIP 10MIN. LOADED	WATER LEAKD GROUNDED PUMP STATOR			
G DR2	021682	063078	GM25	D	814	T	D	G	T	2/3 DG COOLING H2O PUMP TRIP ON HI AMPS; REPLACED	OVERLOAD TRIP SET CLOSE TO RUNNING AMPS			
G DR3	016015	092176	GM25	B	809	T	4	T	DIESEL 3	RECIEVD HI TEMP ALARM	PARTIALLY CLOGGD STRAINR IN L.O. CIRC PMP			
G DR3	016455	110576	GM25	G	810	R	T	B	T	LOST SPEED CONTROL FROM CONTROL ROOM	FAILD OVERTRAVL LIMIT SWITCH ON GOVNR			
G DR3	019727	112977	GM25	G	810	R	D	H	N	3 DG TRIPPD 30 MIN AFTER START AND LOADING	SHORTED CAPICITOR ON SPEED SENSING BOARD			

 DOES NOT CONTINUE TO RUN

V E N T	P L A N T	CONTROL NO.	FAIL DATE	M F K G W	S U B S Y S	F A I L M O D E	F A I L T Y P E	R E V I S I O N	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM	
G	EN1	014795	050176	FM25	M	B13	S	T	8	T	NORMAL SURV. TEST DG 1C TRIPPD; LOOSE WIRE	NOT VIBRATED OFF WIRE-PANEL R43-P. J1C
G	EN1	015557	062676	FM25	B	B02	S	D	8	T	DG 1C TRIPPD DUE TO LUBE OIL SWITCH NOT CALIBRATED	PERSONNEL DID NOT CALIBRATE SWITCH
G	EN1	016842	122576	FM25	M	B06	R	U	U	T	DG 1C TRIPPD APPROX 45 MIN. OF RUN TIME; REPETITIVE	CHECKING OLT LOGIC ON 1C DG
G	EN1	018644	061377	FM25	D	B14	T	D	4	T	1C DG TRIPPD RESTARTED SATISFACT LO JACKET CLNT	LOW COOLNT PRESS SWITCH TO BE CALIBRATED
G	EN1	018646	061877	FM25	D	B14	T	D	4	T	1C DG TRIPPD ON LO COOLNT JACKET PRESSURE	POSSIBLE INCORRECT PRESSURE SETPOINTS
G	EN1	018647	062377	FM25	D	B14	T	D	4	N	1C DG TRIPPD ON LO COOLNT JACKET PRESS	OPERT PRESSURE WAS ABOVE TRIP SETPOINT
G	EN1	018839	081277	FM25	K	B10		D	8	T	1A DG LOST MANUAL VOLTAGE CONTROL	MAN REG PTR OPER XFMR PWR SUP DIODES FAIL
G	EN1	020031	081877	FM25	F	B00	R	U	6	T	DURING SURV TESTING, DG 1B GEN INBOARD BRNG FAILED	BEARING OVERHEATED - EXACT CAUSE UNKNOWN
G	EN1	020013	111977	FM25	K	B02	S	D	4	T	1B DG OUTPUT VOLTAGE TOO HIGH - 1B DG SHUTDOWN	IMPROPER ADJUSTMENT OF AUTO REG SETPOINT
G	FP1	020518	021578	GM25	J	B10		T	1	T	"A" EDG TRIPPED DURING SURVEILLANCE TEST	BLOWN FUSE IN SYNCH CKT FOR OUTPUT BRKR
G	P82	020685	022878	FM30	B	B12	C	D	8	T	E-2 DIESEL TRIPPED ON HIGH CRANKCASE PRESSURE	WATER IN OIL VAPORIZED - LEAKY OIL DRUMS
G	P11	015966	092276	AL25	H	B04	B	T	D	T	"A" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
G	P11	016368	111776	AL25	H	B04	B	T	D	T	"B" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
G	P11	022128	080278	AL25	K	B01		D	8	T	B DG BECAME INOPERABLE AFTER ONE HOUR RUN	OPERATOR CAUSED DIODE FAILURES IN VLT REG
G	VT1	015739	082576	FM30	A	B13		T	1	T	"B" DG OOS TO TIGHTEN FUEL HEADER FITTINGS	ENGINE VIBRATION LOOSENED MECHANICAL CONN
G	VT1	018323	062377	FM30	F	B13	R	T	4	T	"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE	VIBRTN CAUSED HOSE CLMP ON AIR EJECT FAIL
G	VT1	020194	121977	FM30	F	B13	R	T	4	T	"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE	ENG VIB CAUSED AIR EJECT HOSE TO LOOSEN
G	VT1	020464	012478	FM30	D	B09		T	4	T	DIESEL GENERATOR "A" TRIPPED ON HI JAKET CLNG TEMP	3-WAY VLV BLOCKED TO BYPASS CLNT ARND HA
W	BV1	017883	022477	GM25	L	B05		D	4	T	DG OUTPUT BREAKER TRIPPED; INTERNAL LOSS OF FIELD	TRIP NOT DISCONNECTED DURING ACCEPT. TEST
W	BV1	021355	041878	GM25	A	B12		T	D	N	#1 DG WAS S/D AND DECLARED INOPERABLE--OIL LEAKS	FLAW IN FUEL OIL PUMP DISCHARGE PIPE NEPL

DOES NOT CONTINUE TO RUN

UNIT	CONTROL	FAIL DATE	M K G M	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
W 191	010653	080277	G02 D	B09 C T D Y #1 DG	OVERHEATED---RUNNING FOR APPROX 25 MINUTES	SLUDGE AND SCALE IN 67% OF RADIATOR TUBES
W 191	018654	080277	G02 D	B09 C T D Y #3 DG	OVERHEATED AFTER 30 MIN. OF OPERATION	72% OF RADIATOR TUBES BLOCKED SLUDGE SCALE
W 211	015188	062176	C840 A	B13 F 4 N 14 DG	HAD FU LEAKAGE AT THE 8L FUEL INJ PUMP	VIB CAUSED CRACKED FING ON LINE TO INJ
W 211	020255	010378	C840 K	B10 R T D F 18 DG	OUTPUT VOLTAGE PEGGED HIGH-COULD NOT LOWER	PC BOARD FAILURE IN THE VOLTAGE REGULATOR
W 211	0203408	011678	C840 G	B10 F 4 T DG	"0" STARTED & LOADED, BUT DECLARED INOPERABLE	LO CONTROL AIR PRESS-TRIP VLV "0" RING LK
W 212	017508	042777	C840 G	B10 R D I T	GOVERNOR SPEED CONTROL FAILED ON 28 DIESEL GEN	GOV JPD CONT GEAR JAMMED AGNST HI SPD STD
W 212	017809	050677	C840 I	B13 C T 4 T	DIESEL GENERATOR 2A TRIPPED FROM FULL LOAD	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
W 212	017714	111077	C840 B	B12 B D G T "0"	DIESEL GEN TRIPPED ON LOW LUBE OIL PRESSURE	CAVITATION OF LO PUMP - WATER IN LUBE OIL
W 212	017780	111777	C840 I	B13 C T 4 T "0"	DIESEL GENERATOR TRIPPED OFF-LINE	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
W 212	020258	010678	C840 K	B10 R T B T 2A DG	OUTPUT VOLTAGE INCREASED AND COULD NOT LOWER	BURNED CONTACT IN THE VOLTAGE REGULATOR
W 212	020266	010978	C840 G	B10 R D I T 28 DG	POWER OUTPUT OVLD - COULD NOT LOWER MANUALLY	GOV SYNCH IND GR JAMMED ON HI SPD STOP
W 212	021544	051778	C840 K	B14 T Y R T 2A DG	OUTPUT VOLTAGE CYCLED - COULD NOT CONTROL	DRIFT OF VLTGE REGULATOR STABILITY CIRCUIT

APPENDIX H

DIESEL-GENERATOR EVENTS CLASSIFIED AS UNAVAILABLE/NONFAILURE



CODES USED IN LER ONE-LINE DESCRIPTIONS

REPAIR TIME
 CODE DESCRIPTION
 1 0-1 HOURS
 2 1-2 HOURS
 3 2-4 HOURS
 4 4-8 HOURS
 5 8-24 HOURS
 6 GREATER THAN 24 HOURS
 7 UNKNOWN / NOT APPLICABLE

FAILURE MODE
 CODE DESCRIPTION
 A DOES NOT START
 B DOES NOT CONTINUE TO RUN
 U UNAVAILABLE / NO FAILURE

FAILURE CLASSIFICATION
 CODE DESCRIPTION
 0 DEMAND
 1 TIME
 2 UNKNOWN

SUB-SYSTEM
 CODE DESCRIPTION
 1 FUEL OIL SYSTEM
 2 STARTING SYSTEM
 3 COOLING SYSTEM
 4 EXHAUST SYSTEM
 5 GOVERNOR SYSTEM
 6 EXHAUST SYSTEM
 7 SUPERCHARGER SYSTEM
 8 VOLTAGE REGULATOR
 9 GENERATOR
 0 OTHER / UNKNOWN

FAILURE MECHANISM
 CODE DESCRIPTION
 01 UNKNOwn
 02 PERSONNEL
 03 DEFECTIVE PARTS
 04 DEFECTIVE WIRING
 05 DEFECTIVE CONNECTIONS / QUALITY CONTROL
 06 DEFECTIVE FUEL INJECTORS
 07 DEFECTIVE FUEL VALVES
 08 DEFECTIVE FUEL PIPING
 09 DEFECTIVE FUEL FILTERS
 10 DEFECTIVE FUEL TANKS
 11 DEFECTIVE FUEL TANKS / AIR LEAKAGE
 12 DEFECTIVE FUEL TANKS / AIR LEAKAGE
 13 DEFECTIVE FUEL TANKS / AIR LEAKAGE
 14 DEFECTIVE FUEL TANKS / AIR LEAKAGE

METHOD OF DISCOVERY
 CODE DESCRIPTION
 M DURING MAINTENANCE OPERATIONS
 N DURING NORMAL OPERATIONS
 P DURING REPAIRS
 U UNKNOWN

TYPE OF EVENT
 CODE DESCRIPTION
 B RECURRING COMMON CAUSE
 C RECURRING
 D COMMAND FAULTS
 E RECURRING COMMAND FAULTS

DC MANUFACTURER
 CODE DESCRIPTION
 AL ALCOHOL
 CA CATERPILLAR
 CB COOPER-BESSEMER
 DL DEERE
 FM FAYAT
 GM GENERAL MOTORS
 HW HONEYWELL
 MO MORTON

KW RATING
 CODE DESCRIPTION
 200-400 KW
 400-600 KW
 600-800 KW
 800-1000 KW
 1000-1500 KW
 1500-2000 KW
 2000-3000 KW
 3000-4000 KW

UNAVAILABLE / NONFAILURE

UNIT	CONTROL NO.	FAIL DATE	PK GW	FAILURE MODE	FAILURE MECHANISM
B	ARI 010405	112276	GM25 M	U04 C	INDIVIDUAL OPEN OF FIRE DELUGE SYSTEM
B	ARI 018847	080577	GM25 M	U03 K	THIS IS A REPETITIVE OCCURRENCE
B	DBI 022046	071978	GM25 M	U06	PROCEEDURES MODIFIED
B	DBI 022092	091478	GM25 M	U03	PERSONNEL ERROR
B	KS1 022827	110278	GM25 M	U10	BLOWN CONT. POWER FUSE IN VOLT. REGULATOR
B	III 017050	020377	FM30 B	U10	AN ES SIGNAL-FAULTY PRESSURE SWITCH
C	CCI 018041	060377	FM25 B	U13 R	FITTINGS VIBRATED LOOSE --TIGHTENED THEM
C	CCI 019095	111577	FM25 B	U13 R	LOOSE FITTINGS OLD GASKETS LOOSE FLANGES
C	CCI 019738	111677	FM25 B	U13 R	TIGHTENED FITTINGS+FLANGES
C	CC2 018428	062177	FM25 B	U13	FUEL OIL LEAKS FROM LOOSE FITTINGS
C	CC2 018489	071977	FM25 B	U12	REPLACED GLASS WITH PLEXIGLASS WINDOW
C	CC2 019481	110177	FM25 B	U13	1/4" FUEL OIL TURN TO INJ TIGHTENED
C	FC1 017661	040777	GM25 A	U01	DISCOVERD FOUR DAYS LATER+TANKS WERE FILLED
C	M12 014164*	012876	FM25 M	U03	OPER THUGHT SURV TEST UNNEC IF ODS - PMS
C	M12 014452	032476	FM25 M	U03	OPER UNAMWARE OF REPT TO TEST ALT DIESEL
C	M12 015116	061776	FM25 B	U11 S	NO CAUSE FOR TRIP+TEMP WOULD PREV DG SYM
C	M12 021371	020977	FM25 B	U14	REMOVE & RECALB LUBE OIL TEMP SWITCH
C	M12 017837*	051577	FM25 A	U02 S	REASON FOR SHUT VALVES WAS UNKNOWN
C	M12 018974	082377	FM25 M	U03	OPER DIDNT KNOW TEST REPRD AFTER PREV MTM
C	M12 018976A	082677	FM25 D	U09 B	INSUF CL INJECTION FOR ADD MUSSEL CONTROL

UNAVAILABLE / NONFAILURE

V E N T	P L A N T	C O N T R O L N O .	F A I L D A T E	M F K G M	S U B / S Y S	F A I L M O D E	T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
C	PA1	017219	021177	AL25	C	U12	C	T	4	T	DG 1-2 HAD 1 OF ITS AIR START MOTORS CYCLE	DEPLETED AIR SUPPLY, WATER LKG ONTO MOTOR
C	PA1	019409	082377	AL25	A	U06	C	T	4	N	LEVEL IN DIESEL FUEL OIL STG TANK DECRSD TO 53 PCT	SUPPLIER FAILED TO DELIVER PER SCHEDULE
C	SL1	015003	051876	GM30	C	U09	T	B	I	M	DG PLACED OUT OF SERVICE	AIR START SYS VALVES & LINES CLOGD W DIRT
G	BF1	016396	112276	GM30	C	U02	U	4	M	ONE START CIRCUIT ON B DG INOP; 2ND START CKT. OK	BROKEN STUD HOLDER ON BREAKER, REPLACED	
G	BF1	022084	070978	GM30	K	U11	S	D	4	T	1C DG FIELD BKR TRIPPD ;DG INOPERABLE	OVERHEATING OF BKR DUE TO INOPRBLE FAN
G	BF3	016817	112676	GM30	C	U02	U	B	M	START CKT. 1 OF DG 3D INOP DUE TO RELAY FAILURE	NOT ABLE TO SENSE SPEED IN START CKT.	
G	BF3	021780	070678	GM30	J	U10	U	B	N	4-KV STANDBY POWER CKT BKR DEFECTIVE; DG INOPERABL	SHORT IN WINDING OF A SPRING CHARGN MOTOR	
G	BP1	017622	011077	CA02	G	U04	R	U	B	N	REMOVED FROM SERVICE FOR CORRECTIVE MODIFICATION	LUBE OIL SUPPLY TO GOV. MODIFIED
G	BK1	019275A	091277	NM30	M	U01	R	D	U	N	R7X AT PWR #1 DG REMOVED FROM SERVICE FOR ANN. INSP	T.S.4.5.F NOT PERFORMED ON 9/15/77
G	BK1	019275B	092877	NM30	M	U01	R	D	U	N	#3 DG OUT FOR ANN. INSP. T.S.4.F NOT PERFORMD #4DG	OPERATOR ERROR
G	BK1	020246	010678	NM30	I	U01	S	D	4	N	#2 DG SECURED OPERATOR FAILED TO RESET LOCKOUT	#2 DG INOPRBLE FOR 1.5 HOURS
G	BK2	014609	032576	NM30	M	U01	D	G	N	REFUEL MODE, 3DG BEING PHD; FAILED TO TEST SBGT B	"B" TRAIN NOT TESTED TILL 3/29/76	
G	BK2	018177	060777	NM30	M	U03	D	U	T	WHILE SECURING DGI OPERATOR REDUCED LOAD TOO FAST	BKR TRIPPD ON REVERSE POWER AND DG LOCKED	
G	CO1	017064	121576	CB40	J	U10	B	U	T	COMPLETD DG TEST; BKR. IFS WOULD NOT CLOSE AUTO IF	BKR IAF LR IFA TRIPPD--AUX CONTACTS POOR	
G	CO1	019117	091277	CB40	A	U04	D	G	N	FUEL OIL RETURN LINE SHEARD AT INLET TO DAY STORAG	RIGID HANGER WORKED LOOSE CAUSN EX MOVEM	
G	CO1	020803	011778	CB40	J	U10	B	D	C	T	AUX SWITCHES FAILED TO CLOSE ON DG OUTPUT BKR THIS	WOULD PREVENT SHUTTING BKR, IFS AND 1GS
G	DA1	018449	110276	FM25	M	U06	D	G	R	1G-21 & 1G-31 ANNUAL INSPECT NOT PERFORM ON TIME	COMPLETED 10/21/76 VS 9/15/76	
G	DA1	019448	100677	FM25	A	U04	D	U	N	STNDRY DG FUEL STRGE TANK INDICATOR INCORRECTLY CAL	ACTUALLY 200G GAL LESS THAN INDICATED	
G	DA1	023063	122778	FM25	M	U01	D	G	N	CORE LOADING 1G-21 INOP; T.S.3.7.B VIOLATED	1G-31 NOT TESTD DAILY--12/25 TO 12/31	
G	DK1	016167	093076	GM10	A	U02	C	D	B	N	BACK-HDL SEVERED FUEL OIL TRANSFR LINE TO UNIT1 DG	AND FIRE PUMP; PROMPTLY REPAIRED

UNAVAILABLE / NONFAILURE

UNIT	CONTROL NO.	FAIL DATE	PK CM	FAILURE MODE	FAILURE MECHANISM					
G	DP1	050378	GM10	C	U02	S	D	D	N	LOW STARTN AIR PRESS DUE TO LEAKING PILOT AIR REG. IMPROPERLY POSITIONED O-RING
G	DR1	060678	GM10	A	U01	S	D	G	M	BACKUP DG DAY TANK EMPTY AND TRANSFER PUMP WAS OFF PUMP STARTER FAILD AND PERSONEL ERROR
G	DR2	010242	GM25	D	U11	D	U	M	U-2	DG COOLING H2O PUMP BKR FOUND TRIPPO
G	DM2	016018	GM25	M	U08	C	T	G	M	H2O LEAKAGE INTO U 2/3 DG ROOM; SMALL HOLE IN HPCI TEST RETURN LINE; CHLORIDE STRESS CORROJN
G	DR3	019449	GM25	K	U10	T	B	T	DAY TANK FOR DIESEL NOT AT NORMAL LEVEL	
G	DM3	015379	GM25	D	U09	B	D	B	M	U3 DG COOLING H2O PUMP CNT.BKR. FOUND TRIPPO;NESHET TRIPPO AGAIN--WORN PMP BEARINGS;REPLACED
G	DP3	018370	GM25	D	U11	B	D	U	M	DG COOLING WTR PMP BKR. FOUND TRIPPO PRESET OK
G	DP3	018986	GM25	D	U09	B	D	O	N	DG COOLN WTR PMP BKR. FOUND TRIPPO; WORN OUT BRKGS DUE TO DETEIRATION OF IN-LINE FILTER
G	DM3	019318	GM25	A	U01	R	D	4	N	U3 DIESEL OIL STORAGE LEVEL 8700 VS.10000 GALLONS
G	DR3	019025	GM25	M	U03	S	D	4	M	2/3 DG OUS--OPERATOR PULLED 3076 TO BUS 3A-1 SWITCH
G	DP3	021461	GM25	A	U09	R	D	1	M	U3 DIESEL STORAGE LEVEL 9000 GALS.--STUCK VALVE
G	EN1	020191	FM25	A	U01	S	D	U	N	1A DG FUEL OIL XFER PUMP DISCH VLV3 FOUND SHUT
G	EN1	021249	FM25	M	U04	C	D	U	T	BUS 2F FOR BREAKER CONT PWR DESIGN COULD CAUSE A
G	EN1	021250	FM25	M	U04	C	D	U	F	DSL LOAD SEQ TIMER DESIGN COULD RESULT IN OVLG OF
G	EN1	021476	FM25	M	U04	C	D	U	T	VLG LOGIC ON UGS 1A,1B,1C SUCH THAT WTRTN OF THE BKR DOOR WLD CAUSE BRKS TO CLOSE
G	EN1	021719	FM25	M	U02	C	U	U	1C DG BATTERY PLT CELL SURV NOT COMPLETED IN INTVL SPECIF IN TECH SPEC--PERSONNEL OVERSIGHT	
G	EN1	022476	FM25	M	U04	C	D	U	R	DG5 THAT FAIL TO START OR ARE S/D DURING LOCA OR
G	EN2	022213	FM25	M	U03	D	U	R	SURVEILL ON DG "B" NOT PERFORMED	
G	EN2	022493	FM25	M	U04	C	D	U	R	DG5 THAT FAIL TO START OR ARE S/D DURING A LOCA OR
G	EN2	023035	FM25	M	U03	D	B	N	POWER AT 1404 MW TESTING 2C DG, IS-4-B-1-1.1-A	

UNAVAILABLE / NONFAILURE

PLANT	CONTROL	FAIL DATE	FAIL TIME	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
G FPI	015250*	061676	0625	K U14	C D U T	A+B+C+D DGS WERE UNSTABLE DURING TESTING
G FPI	022115	073178	0625	B U03	U G T	L+O+ SAMPLES NOT TAKEN IN REQD TIME INTERVAL
G FPI	022278	082878	0625	B U05	D G N	EDG INOPERABLE BECAUSE OF NOISY LUBE OIL PUMP
G M11	016599	020177	0625	A U12	R T 4 U	DG DECLARED INOPER IN ORDER TO REPAIR FUEL OIL LK
G M11	019189	092777	0625	A U12	R T 1 U	DG DECLARED INOPER IN ORDER TO REPAIR FUEL OIL LK
G M11	019820	121077	0625	I U16	U B N	DIESEL GENERATOR BECAME INOPERABLE
G P82	013991	011176	0630	C U01	S U 1 N	E-3 DG DC FEED BKR FOUND OPEN - PREVENTS STARTING
G P82	019560	110177	0630	B U12	T B N	E-4 DG DECLARED INOPERABLE
G P82	019830	112277	0630	A U12	T 4 N	E2 DG DECLARED INOPERABLE
G P82	020167	010378	0630	B U11	R D 4 N	E-4 DG DECLARED INOPERABLE
G P82	020161	011878	0630	B U11	R D 8 N	E2 DG DECLARED INOPERABLE
G P83	018059*	061377	0630	C U10	C T U N	3 OF 4 DIESEL GENERATORS INOPERABLE
G GC1	014426	031776	0625	M U02	C D 4 M	1/2 DG COS TOO LONG FOR PREVENTATIVE MAINTENANCE
G GC1	019765	072776	0625	M U06	D 1 M	UNIT 1/2 DG COS FOR LONGER THAN IS ALLOWANCE
G GC1	016904	120276	0625	D U02	C D 8 M	COOLING WTR HDR FOR DG 1 CW PUMP - AIRBOUND
G GC1	018114	050677	0625	A U12	T B U	LEAK DISVD IN TAP OFF FUEL LINE TO FUEL PRESS GAGE
G GC1	022666	092878	0625	A U04	D O M	UNIT 1 FUEL XFER LINES REMOVED-TS DECLARES DG INCP
G GC2	010745	081077	0625	D U12	T G N	MAN DG REVWD FRM SERV DUE TO DEGRS IN ENG WTR LVL
G GC2	020395	012478	0625	D U12	S T D	UNIT 2 DG CW PUMP DRAINS FAILED TO SHUT
G B41	018669	062277	0625	M U01	D U N	MODE 3 (HOT STANDBY) TO MODE 1 (PWR OPS) LOG DGS

FAILURE MECHANISM

DRIFT IN DROCP CKT-NOT NECESSRY FOR ENERGY
 SAMPLE EQUIPMENT FAILURE
 PUMP - MOTOR MISALIGNMENT
 SMALL CRK IN PIPE NIPPLE TO NO. 12 INJ
 SMALL CRK IN PIPE NIPPLE TO NO. 12 INJ
 GUV SHUTDOWN SOLONOID MALFUNCTION
 OPER LEFT OPEN AFTER DC GRND ISOL PROCED
 CLEANUP ACCUM CIL UNDER MACHINE-FIRE H2O
 REPAIR FUEL OIL LEAK IN PLUG ON COND FLTR
 LU LUBE OIL TEMP-REPLC LUBE OIL HTR ELEM
 LD LUBE OIL TEMP-REPLC 2 COILS IN HTR ELE
 START AIR COMPRESSORS TRPD - AIR TANKS MT
 COMMUNICATIONS PROBLEM BETWEEN OPER-MAINT
 MAINT MAN UNAMWARE OF TIME LIMIT-PROCEED ER
 AIR LINE ATTACHU TO RHR PUMP-COMMON HEADR
 FUR 1/2 DG - CRACKS ATTRIBD TO NAML SIMJS
 75G GAL DAY TANK FULL-DIESEL WOULD RUN
 EAST CW HI EXCHGR HAD A TUBE LEAK
 AIR SUPPLY SOLONOID VALVES FAILED
 REG GUIDE 1.16-C-2.8.(12) MISINTERPRETED

UNAVAILABLE / NONFAILURE

V E N T	P L A N T	C O N T R O L N O.	F A I L D A T E	M F G K W	S U B S Y S	F A I L M O D E	F A I L M E C H	E T I P E	C L A S S	R E P A I R	O C C U R R E N C Y	D	FAILURE MODE	FAILURE MECHANISM
W	BV1	022395A	090578	GM25	M	U03	R	D	C	T	2	DG	DG DUS FOR TESTN DIESEL AIR AND OIL RELIEFS	#1 DG BRKR FAILED TO CLOSE AUTO DURN TEST
W	BV1	022394A	091278	GM25	M	U03	R	D	U	T	#2	DG	DG DUS FOR TESTN AIR AND RELIEFS, TESTD #1 DG	1 DG BRKR FAILED TO CLOSE USIN CONTROL SW.
W	DC1	014415A	040176	W030	M	U12	R	T	G	M	1CD	DG	REAR BANK AIR AFTERCOOLER HAD TUBE LEAK	COOLER REPLACED ON 4-6-76
W	DC1	014415B	040176	W030	M	U12	R	T	G	N	1AB	DG	REAR BANK AIR AFTERCOOLER HAD TUBE LEAK	REPLACED ON 4-24-76
W	DC1	020520	120977	W030	M	U11	C	D	B	N	WITHIN 3HRS. 3	SPURIOUS	OS TRIP SIGNALS ON 1AB, 1CD	DG OPERABLE CHECKD TRIP POINTS DG COLD
W	DC1	022946	110778	W030	K	U04	D	1	N	AB	DG	INOPERABLE DUE TO INADV. REMOVAL OF CKT. BOARD	CKT. BOARD SNAGGD ON CLOTHING; DESIGN CHANG	
W	DC2	021217	041578	W030	M	U03	D	G	N	SURVEILLANCE TESTING OF CD DG NOT PERFORMED			OPERATOR THOUGHT TEST SCHEDULE IN ERROR	
W	DC2	022280	061378	W030	M	U01	D	G	N	MODE1, AB DG INDP. FROM 2100 HR. 6-13 TO 1030 HRS. 6-14 --- INVE. YER BEING REPAIRED				
W	DC2	021634*	061578	W030	M	U02	C	D	4	N	BOTH EDG'S PLACED IN A JND. OF NOT AUTO STARTING			TAGGED OUT WRONG STARTING AIR PILOT VALVS
W	DC2	021675	061778	W030	D	U05	T	G	N	NORMAL OPNS. WELD CRACK ON ESW OUTLET ON ZAB L.O			COOLER, TOOK ZAB DG DUS TO REPAIR	
W	DC2	022330	090178	W030	A	U12	D	E	T	#2CD DECLARED INOPERABLE DUE TO L.O. VISCOSITY VIOL			REPLACD 4 INJ. PMPS & 1 INJ AS THE ANSWER	
W	HN1	021376	050878	GM25	M	U04	C	D	U	R	IF ONE DG FAILS TO START DURING CEINCOT LOCA/LESP			LOADING CN RMNG DG MAY EXCEED SPECS
W	IP2	016641	121276	AL18	B	U11	R	T	4	T	LUBE OIL TEMP FOR 22 EDG BELOW MINIMUM FOR OPERATN			CHROMALOX HTR MTO-330A FOUND SHORTED
W	IP2	018913	022677	AL18	B	U14	J	D	4	N	23 EDG REMOVED FROM SERVICE - DEFECTIVE PRESS SWCH			PRESS SW SETTING WAS FOUND TO BE INCORRECT
W	IP2	018914	082977	AL18	D	U12	T	G	N	23 EDG REMVD FROM SERV TO REPAIR JACKET WTR COOLER			AMER STD HX, MOD 1205-6CP, DEVLPD TUBE LKS	
W	IP2	019244	091477	AL18	M	U10	T	G	N	22 EDG DEVLPD PHASE-TO-PHASE SHORT IN EXH HOOD MTR			DEFCTVE DSL EXH BLWR MTR, GE 5K49HG61A	
W	IP2	019548	101977	AL18	B	U11	R	T	4	N	22 EDG FOUND TO HAVE LOW LUBE OIL TEMPERATURE			DEF TERMINAL BLK SHORTED CHROMALOX HTRS
W	IP2	023579	121978	AL18	C	U10	T	4	N	21 EDG INDP DUE TO AIR START MOTOR PROBLEMS			MOTORS CLEANED, DG TESTED SAT	
W	IP3	015120	061576	AL18	M	U03	S	D	1	T	LOST AC AUX FOR EDG 31 FOR 19 MINUTES			MECHANIC CAUSED A SUCCESSION OF BRK TRIPS
W	IP3	022410	082978	AL18	A	U10	S	I	D	N	VALVE FAILURE CAUSED AN INBALANCED DIST OF FUEL			AMONG THE 3 GEN TKS-DG 33 LT PERMIT BY TS

UNAVAILABLE / NONFAILURE

V E N	P L A N T	CONTROL NO.	FAIL DATE	M F K G W	S U B S Y S	F A I L M E C H	T Y P E	C L A S S	R E P A R Y	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
W	JF1	020291	010378	FM40	C	U10	S	D	U	H	DG 18 DECLARED INOPERABLE	BOTH AIR COMPRESSORS ASSOC W 18 WERE OOS
W	JF1	023152	091478	FM40	C	U10	D	4	N	18	DG DECLARED INOPERABLE	1A&1B AIR RESVRS WERE BLEW DOWN-RLF VLV
W	KL1	018941	082477	GM25	F	U10	S	D	U	M	PUSH-BUTTON TIMER IN CARDOX FIRE PROT SYS FAILED	IN INTER POSIT-COMT S/D SIGNAL TO DG 18
W	PH1	019919	120977	FM30	M	U01	C	D	1	U	BOTH DGS INOPER FOR APPROXIMATELY 10 MINUTES	OPERATOR ERROR IN RESETTING MCA RELAYS
W	PR1	021704	082278	FM30	A	U02	C	D	G	N	ROOT VLV ON DI DSL OIL DAY TK INST LVL COLMN-SHUT	IMPROPER VLV L/U DURING TEST ON JUNE 93H
W	PR2	014706	040276	FM30	M	U02	C	D	1	M	D2 DIESEL GENERATOR MOMENTARILY LOCKED OUT	DURING MAINT+TECH ACTUATED WRONG RELAY
W	PR2	017618	041277	FM30	M	U10	C	D	4	U	LIGHT SOCKET FOR DG D2 GOV READY LITE SHORTED CAUS	ING 2-HOUR LOSS OF CONTROL POWER
W	PR2	021358	032978	FM30	D	U02	C	D	1	M	NG. 12 DIESEL CW PUMP LOCKED OUT A PROX 1 MINUTE	MAINT MAN PLACED JUMPER BEFORE SUPPSD TO
W	RG1	019126	070976	AL18	J	U10	D	U	T	18	EG OUTPUT BREAKER COULD NOT BE CLSD RMTLY AFTER	TEST; SWITCH WEAR PREVENTED BRKR ELEC R/T
W	RG1	021025	030478	AL18	A	U10	T	4	N	"A" DG FUEL XFER PUMP LCST-DG STILL HAD 3HR FUEL	POOR ELEC CONN CAUSED THRLM DEVICE TRIP	
W	SA1	022870	101178	AL25	B	U12	D	G	N	18	DIESEL DECLARED INOPERABLE-PRE-LUBE MTR FAILED	WATER JKT CLR LKNG ONTO PRELUBE PUMP MTR
W	SO1	017760*	051077	DL10	A	U05	D	U	R	2	DIESELS HAD FUEL OIL BYPASS LINE SUPPORTS MISSING	INAOV OMITTED DURING ASSY OF BYPASS PIPNG
W	SO1	014840	050876	GM25	F	U12	R	D	G	N	#1 CYLINDER IN #1 DG WAS FOUND FLOODED	CRACK IN #1 CYL HD THRU TO WATER JACKET
W	SO1	019521	070276	GM25	F	U12	R	D	G	N	#19 CYLINDER IN #1 DG WAS FOUND FLOODED	CRACK IN #19 CYL HD THRU TO WATER JACKET
W	SO1	015523	072376	GM25	F	U12	R	D	G	N	#7 CYLINDER IN #1 DG WAS FOUND FLOODED	CRACK IN #7 CYL HD THRU TO WATER JACKET
W	SO1	022919*	103178	GM25	M	U06	U	U	R	P	T TO INSPECT DGS DURING OUTAGE NOT PERFF FOR 163	ADMINISTRATIVE SCHEDULING ERROR
W	TR1	014668	042076	GM40	A	U06	C	T	G	U	BOTH DSL FUEL OIL TANKS LT TS LIMIT OF 33000 GAL	PROCEDURE NOT REVISED TO INDIC CORRECT LIM
W	TR1	014929	051276	GM40	A	U06	D	U	R	P	ERIOD SURVEIL TO SAMPLE & VER DSL FUEL NOT PERFFD	PROC FOR PROPER SCHED & RECORDKPG INADEV
W	TR1	014930	052176	GM40	A	U06	D	1	M	EMER DIESEL FC DAY TANK LVL WAS LESS THAN TS REGM	AUTO M/U SETPOINT WAS SET LOW	
W	TR1	020902	021778	GM40	L	U06	D	U	R	DG PHASE DIFFNTL TRIP NOT VERIFIED BYPASSED ON STA	DEFECTIVE PROCEDURES	

UNAVAILABLE / NONFAILURE

VEH	PLANT	CONTROL NO.	FAIL DATE	MFG W	SUBSYS	F A I L M O D E	F A I L M E C H	I T E M	C L A S S	R E P A I R	O U T C O M E	FAILURE MODE	FAILURE MECHANISM
W	TU3	014879	030676	GM25	J	U10	B	D	B	N		DISCOVER THAT 3B EDG OUTPUT BRKR INDIC NOT CHARGED	CHG MTR DRIVE PAWL MISALGND W CHG SPRING
W	TU3	015963	090976	GM25	J	U10	B	D	B	U	3A	DG OUTPUT BRKR WAS NOT IN CHARGED POSITION	WORN NYLEN BUSHING-DRV MTR ECC/PATCHT WHL
W	TU3	016138	100276	GM25	D	U01		D	1	N	OG	"M" COOLING WTR SURGE TNK LO LVL ALARM	PARTIALLY OPEN SAMPLE VALVE-OPERTR ERROR
W	TU3	017423	061077	GM25	D	U08		T	U	M		FOUND PINHOLE LEAK IN "B" DG RADIATOR	EXT ENVIRON COND - INCOMPLETE CHEM MIXING
W	YR1	020476	012878	GM02	D	U01		D	B	N	MODE 3;#1CG	TAKEN OOS TO REPAIR WTR HEATER	HEATR COIL FAILURE--T.S.VIOLATED (3 DG'S)
W	Z11	020348A	011678	CB40	B	U12	B	D	G	T	1A	DG INOPERABLE - HI DELTA-P ACROSS LUBE OIL CLR	OIL CLR TUBE LN CONTAMINATED OIL W WATER
W	Z11	021968	071778	CB40	B	U12	B	D	G	T	1A	DG INOPERABLE - HI DELTA-P ACROSS LUBE OIL CLR	OIL CLR TUBE LN CONTAMINATED OIL W WATER

APPENDIX I

DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY FAILURE MECHANISM

CODES USED IN LER ONE-LINE DESCRIPTIONS

REPAIR TIME
 CODE DESCRIPTION
 1 - 0 TO 1 HOURS
 4 - 1 TO 4 HOURS
 8 - 4 TO 8 HOURS
 0 - 8 TO 24 HOURS
 C - GREATER THAN 24 HOURS
 U - UNKNOWN / NOT APPLICABLE

FAILURE MODE
 CODE DESCRIPTION
 A - DOES NOT START
 B - DOES NOT CONTINUE TO RUN
 U - UNAVAILABLE / NONFAILURE

FAILURE CLASSIFICATION
 CODE DESCRIPTION
 D - DEMAND
 T - TIME
 U - UNKNOWN

SUB-SYSTEM
 CODE DESCRIPTION
 A - FUEL OIL SYSTEM
 B - LUBE OIL SYSTEM
 C - STARTING SYSTEM
 D - COOLING SYSTEM
 E - SCAVENGING AIR SYSTEM
 F - ENGINE FRAME / INTERNALS
 G - GOVERNOR
 H - EXHAUST SYSTEM
 I - SHUTDOWN SYSTEM
 J - OUTPUT BREAKER
 K - EXCITER / VOLTAGE REGULATOR
 L - GENERATOR
 M - OTHER / UNKNOWN

FAILURE MECHANISM
 CODE DESCRIPTION
 00 - UNKNOWN
 01 - PERSONNEL OPERATION
 02 - PERSONNEL MAINTENANCE
 03 - PERSONNEL TESTING
 04 - DESIGN ERROR
 05 - FABRICATION / CONSTRUCTION / QUALITY CONTROL
 06 - PROCEDURAL DISCREPANCY
 07 - DEFECTIVE FUEL INJECTOR(S)
 08 - CORROSION / EROSION
 09 - FOREIGN MATERIAL CONTAMINATION
 10 - MECHANICAL / ELECTRICAL CONTROL
 11 - HI / LOW AMBIENT TEMPERATURE
 12 - LUBE / FUEL / WATER / AIR LEAKAGE
 13 - VIBRATION
 14 - OUT OF ADJUSTMENT / CALIBRATION

METHOD OF DISCOVERY
 CODE DESCRIPTION
 M - DURING MAINTENANCE
 N - DURING NORMAL OPERATIONS
 R - DURING RECORDS REVIEW
 T - DURING TESTING
 U - UNKNOWN

TYPE OF EVENT
 CODE DESCRIPTION
 B - RECURRING COMMON CAUSE
 C - COMMON CAUSE
 R - RECURRING
 S - COMMON FAULTS
 T - RECURRING COMMAND FAULTS

NSSS VENDOR
 CODE DESCRIPTION
 B - BABCOCK & WILCOX
 C - COMBUSTION ENGINEERING
 G - GENERAL ELECTRIC
 W - WESTINGHOUSE

183

MG MANUFACTURER

CODE DESCRIPTION
 AL - ALCO
 CA - CATERPILLAR
 CB - COOPER-BESSEMER
 DL - DE LAVAL
 FM - FAIRBANKS MORSE
 GM - GENERAL MOTORS
 NM - NORDBERG MANUFACTURING
 WD - WORTHINGTON

KW RATING

CODE DESCRIPTION
 02 - 200-400 KW
 10 - 500-1000 KW
 30 - 1750-1950 KW
 200 - 2500-2850 KW
 300 - 3000-3500 KW
 400 - 4000-4418 KW

UNKNOWN

PLANT	UNIT	CONTROL	FAIL DATE	TIME	FAILURE MODE	FAILURE MECHANISM
B	AR1	021603	032678	0825	E BUC	T G T DG #2 ON FIRE DUE TO LUBE OIL GETTING INTO EXHAUST TURBOCHGR BRNG FAILED CAUSING SEAL FAILURE
B	CK3	023166	111778	FM30	M A00	K U I T EDG-B FAILED TO FAST START ON TWO CONS. ATTEMPTS STARTED SUCCESSFULLY TWICE AFTER ANOMALY CAUSE UNKNOWN EXTENSIVE MAINT PERFORMED
B	DB1	021580	050978	GM25	E 800	U G T GEN LOAD FLUCTUATING AIR INTAKE LO PRESS ALARM CAUSE UNKNOWN EXTENSIVE MAINT PERFORMED
B	RS1	015359	071576	GM25	M A00	U O T SEVERAL ATTEMPTS TO START "B" DG WERE UNSUCCESSFUL NO DEFINITE CAUSE COULD BE FOUND
B	RS1	018853	082477	GM25	M A00	K U I T DIESEL GENERATOR "B" FAILED TO START NO SPECIFIC CAUSE COULD BE DETERMINED
B	II2	021609	042578	FM30	F 800	R U I T "B" DG TRIPPED ON HI CRKSE PRESS AFTER 32 MIN RUN NO ABNORMAL PARAMETERS WERE FOUND
C	CC1	018405	102576	FM25	M 800	K U I T #12 DG 570 DUE TO DG VENT FAN STOPPED-BLOWN FUSE CAUSE FOR BLOWN FUSE NOT DETERMINED
C	CC1	017213	111876	FM25	M A00	K U I T #12 DG 570 DUE TO ITS VENT FAN NOT STARTING BLOWN FUSE--REPLACED CONTROLLER COIL ??
C	CC1	021600	041078	FM25	L A00	U I T #12 DG OVERSPED & TRIPPED RESTARTED SUCCESSFULLY CAUSE NOT DETERMINED TESTED SAT NEAT FIM
C	CC1	021605	041378	FM25	M A00	U L M #11 DG FAILED TO START ON LOSS OF OFFSITE POWER START/FAILURE ALARM DISPLAY NO ABNORMALS
C	CC1	023380	121878	FM25	M 800	R D I T #11 DG SHUTDOWN DUE TO ROOM VENT/FAN FAIL TO STRT FAN FAILURE--RESET OVERLOADS
C	CC2	018422	022277	FM25	C A00	U B T #21 FAILED TO START & ASSUME RATED SPEED IN 10 SEC AIR START SYS DISASSEMBLD & INSPECTED
C	CC2	017457	031777	FM25	M A00	R U I T #12 DG VENT FAN FAILED TO START ON JIAS SIGNAL OVERLOADS TRIPPO ON FAN; RESET OVERLOADS
G	BP1	015449	080576	CA02	D A00	K U B N DG FAILED TO START WITHIN 15 SECONDS DURING WEEKLY POSSIBLE WATER JACKET HEATER FAILURE
G	BP1	016672	090276	CA02	A A00	R U U T FAILED TO MEET 15 SEC START TIME DURING WEEKLY TEST POSSIBLE FUEL SYSTEM FAILURE
G	BP1	016504	102876	CA02	G A00	R U U T DG FAILED TO START WITHIN 15 SEC POSSIBLE FUEL GOVERNOR CONTROL PROBLEM
G	BP1	016420	110476	CA02	G A00	R U U T START TIME 2+2 SEC SLOWER THAN REQUIRED POSSIBLE FUEL GOVERNOR PROBLEM
G	BP1	016597	120276	CA02	G A00	R U U T FAILED TO MEET 12 SEC START TIME DURING AUTO TEST FUEL GOVERNOR REPLACED ON 12/19/76
G	BP1	016410	010377	CA02	G A00	R U U T FAILED TO START IN AUTO TEST CAUSE UNKNOWN LUBE OIL RETENTION IN GOV-2
G	BP1	020298	032477	CA02	G A00	R U U T EDG STARTING TIME EXCEEDED 12 SEC. BY +8 SEC. GOVERNOR LUBE SYS MODIFIED ON 1/10/77

UNKNOWN

PLN	CONTROL	FAIL DATE	M F K	FAILURE MODE	FAILURE MECHANISM
G 8P1 018102	CA02	051877	CA02	D 400 R U T 4 T H2O JACKET HEATER FAILURE--EDG TESTED; DID NOT MEET TIME CRITERIA EXCEEDED BY 12 SECONDS	
G 8P1 018163	CA02	052677	CA02	A 400 R U T START TIME 16.5 SEC, SHOULD BE LT 13.9 SEC	FUEL CONTROL VALVE MODIFIED
G 8P1 019141	CA02	102077	CA02	C 400 R U T START TIME 21.6 SEC VS. 13.9 SEC	FUEL VOLTAGE DROP ON START CABLES
G 8P1 019993	CA02	112477	CA02	A 400 R U T START TIME 33 SECS TESTED SAT WITHIN ONE HOUR	FUEL CHECKED ON PREM GRADE OF FUEL USED
G 8P1 020575	CA02	020278	CA02	M 400 R U T START TIME 28.5 SECS VS 13.9 SECS	CAUSE UNKNOWN
G 8P1 019948	NR30	121077	NR30	J 800 D 0 T SMOKE COMING FROM 320 RELAY AND 800B RELAY FLAMING REPLACED AND CALIBRATED RELAYS	CAUSE UNDETERMINED
G CUI 020072	CB40	062376	CB40	A 800 U 8 T FUEL LINE TO AN INJECTOR OF #1 DG BURST	
G DR2 014913	GM25	052376	GM25	C 400 U 1 T UNIT 2/3 DG FAILED TO START	CAUSE UNKNOWN BUT POSSIBLE AIR START SYST
G DR2 018283	GM25	063077	GM25	G 400 R 0 1 T 2/3 DG TRIPPED ON OVERSPEED DURING 2 ATTEMPTS	POSSIBLE CUT-OFF-ADJUST GOVERNOR COMPENSATION
G DR2 018494	GM25	071277	GM25	G 400 R 0 1 T U 2/3 D/G TRIPPED ON OVERSPEED---OCCURD ALSO 6/30/77 PROBABLE CUT-OFF ADJUST GOVERNOR COMPENSATION	
G DR2 019732	GM25	111677	GM25	I 400 J 0 1 T AUTO-START SIGNAL SENT TO UNIT 2/3 DURING CORE SPRAY RESET START FAILURE RELAY 6 DIRECT STARTED	
G DR2 019905	GR25	120477	GR25	J 400 U 1 T L2 DG OUTPUT BKK FAILED TO CLOSE--NO APPARENT CAUSE 3 SUBSEQUENT TESTS WERE SUCCESSFUL	
G DR2 021848	GR25	030778	GR25	C 400 S 0 B T OPERATOR SHOOK AIR START SOLENOID UNIT 2/3 STARTED POSSIBLE WIRE DAMAGED DUE TO FREQ INSPEC	
G DR2 022589	GR25	092278	GR25	C 400 H 0 8 T UNIT 2/3 FAILED TO START; AIR START MINS ENGAGED	AIR-START SYS WILL BE MODIFIED
G DR2 023337	GR25	121678	GR25	C 400 R 0 4 T 2/3 DG AIR START MOTORS DISENGAGED AFTER FEW SECS. 102 RELAY CLEANED; 102 AND AIR VALVE ?	
G EN1 014746	FR25	051576	FR25	M 400 U 0 T 18 DG FAILED TO START ON FIRST ATTEMPT	UNKNOWN WILL DO WEEKLY START TO DETERMINE
G EN1 015947	FR25	081476	FR25	M 400 R 0 U T 1C DG FAILED TO START DURING SURV TEST - RECURRING EXACT CAUSE OF START FAILURE NOT KNOWN	
G EN1 016842	FR25	122576	FR25	M 800 R 0 U F DG 1C TRIPPED APPROX 45 MIN. OF RUN TIME; REPETITIVE CHECKING LOGIC ON 1C DG	
G EN1 016843	FR25	123176	FR25	M 400 R 0 U T MAN START OF 1A DG FAILED THIS HAS HAPPEND BEFORE INSPECTED & RETESTED SATISFACTORILY	
G EN1 018141	FR25	052077	FR25	M 400 U 0 T 1A DG FAILED TO COME UP TO RATED VOLT IN REED. TIME TOOK 16 SEC VS 12 SEC REJECTED SATISFAC	

UNKNOWN

UNIT	CONTROL NO.	FAIL DATE	M F K G	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
5 EN1	020031	021877	FM25 F	800 M U G T	DURING SURV TESTING, DG 18 GEN INBOARD BRNG FAILED BEARING OVERHEATED - EXACT CAUSE UNKNOWN	
5 DC1	015042	060876	GM25 C	A00 U I T	DG #2 FAILED TO START DURING OPERABILITY TEST	CONTROL SEQ FAULT - HOWEVER, SEQ CORRECT
5 PB2	020090	121977	FM30 L	A00 U U T	E1 DG TRIPPED ON "M" PHASE DIFF AFTER PARALLELING	CAUSE COULD NOT BE DETERMD AFTER EXTN TST
5 PB2	0233498	122178	FM30 G	A00 U I T	E2 DG START TIME 11 SEC. VS. 10 SEC	POSSIBLE GOVERNOR PROBLEMS
* BV1	015913	090376	GM25 J	A00 U I T	#1 DG OUTPUT BREAKER FAILED TO CLOSE	NO APPARENT CAUSE
* BV1	0223958	090578	GM25 J	A00 R D I T	#1 DG OUTPUT BKK. FAILED TO CLOSE; #2 DG DGS	BKK CLOSED MANUALLY, 1 HOUR RUN AT FULL LD
* BV1	0223948	091278	GM25 J	A00 R D I T	#1 DG OUTPUT BKK. FAILED TO CLOSE USING CONT. SWITCH	CLOSED LATER NEGATING TROUBLESHOOTING
* DC2	022039	101978	M030 A	A00 U I T	248 FAILED TO START DUE TO LACK OF FUEL TO INJECTMS	UNKNOWN BUT REPLACED FUEL FILTER ELEMENT
* KE1	019519	102577	GM25 M	A00 U U T	D/G 1A STARTED 6 WAS AT 70 RPM WHEN IT STOPPED	COULD NOT DETERMINE CAUSE OF FAILURE
* TR1	018007	042977	GM40 M	A00 U U M	EOG FAILED TO START ON LCSP (PARTIAL) THE 2ND TIME	NO LER FOR DG FAILURE JUST THE LCSP
* Z11	010179	092476	CB40 M	A00 U U T	"M" DIESEL GENERATOR FAILED TO START	NO CAUSE COULD BE DETERMINED
* Z11	023366	122078	CB40 M	A00 U U M	18 DG FAILED TO START DURN AN INADVRINT SAFETY IMVEC	EXTENSIVE TESTING REVEALD NO CAUSE

HUMAN ERROR

PLANT	CONTROL	FAIL DATE	PK	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM		
B	RS1	022613	GM25 A	B01	3 D 1 N	MAM DG S/D DUE TO SPRAY OF FUEL OIL; "B" DG 005	FUEL LEAK-EXCESSIVELY LOOSENEED STNR PKG GLMD	
C	CC1	015567	FM25 D	A02	5 D 4 N	#12 DG FAILED TO START AUTO FAILED ALSO FROM CONT RM	JACKET COOLING H2O SYS AIRBORING NOT VENTD	
C	CC1	015584	080776	FM25 J	A02	5 U 6 Y	#11 DG FAILED TO SENSE MAT VOLTAGE*COND.-OUTPUT BKR, WELL NUT CLOSE--COLD SOLDER CONN TO ERA	VALVE VIBRATED LOOSE AND FELL OFF DG
C	CC1	018366	061777	FM25 F	B02	D 1 Y	#11 DG START; LATER DISCOVERED #6 CYLINDER RELIEF	G-RING JEAL ON STNR NOT GLUED PROPERLY
C	CC1	018498	071177	FM25 B	B02	C D 4 M	#11 DG ON FIRE DUE TO L.O. HITTING HOT EXHAUST	SIGNAL REMOVED; OP SWITCH ISOLATED
C	CC1	018487	071377	FM25 D	B02	3 D 1 Y	#11 DG TRIPPED ON LOW JACKET COOLNT PRESS WHEN SIAS	IMPRPR SETING FCR MAG PKUP ON SWICNG TACH
C	FC1	014590	062776	GM25 C	A02	T D 6 U	DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE	GOVERNOR STILL IN "NO FUEL" FROM PREV S/D
C	M12	018923	083077	FM25 G	A01	3 D 1 N	DG 12U FAILED TO RESTART ON DEMAND	IMPROPER VOLTAGE SETTING PRIOR TO PARALL
C	M12	019929	116977	FM25 K	A01	3 D 1 Y	DG 13U TRIPPED WHILE PARALLELING WITH 4160V BUS	PERSONNEL ERROR - INCORRECT VALVE LINEUP
C	SL1	016881	110276	GM30 M	A01	3 D 4 T	1A DG FAILED TO START	OPER FAILED TO RESET OVERSPEED TRIP
C	SL1	017441	030177	GM30 I	A01	3 D 1 Y	1A DIESEL GENERATOR FAILED TO START	OPERATOR NOT AWARE OF SIGNIF OF START TIM
G	BPI	015448	080576	CA02 M	A03	R U U T	DG FAILED TO START WITHIN 15 SEC NOT RETESTED	PK 40 GAL H2O IN SADDLE 6 4 DAY TANK
G	BK2	015401	061176	MM36 A	A02	C D T	#1 DG STALLED & FAILED TO TIE INTO E-BUS RFX AT PK	RESET; LOSS OF EXCITATION RELAY NOT RESET
G	BK2	020612	021378	MM30 K	A01	3 D 1 M	FOLLOWING SCRAM ON UNIT 1 #1 DG LO RELAY WOULDNT	DISCONNECT ONLY ONE WIRE ON 11/8/76
G	CO1	016712	111076	CB40 J	A03	S D 8 T	EG-1 OUTPUT BKR FAILED TO CLOSE--BLOWN FUSE	H2O IN FUEL SUPPLY FROM FLUSHING OPERATLN
G	DK2	016054	121876	GM25 A	B02	3 D 0 T	UNIT 2 DG FAILED TO CARRY REED LOAD	GOVNR SETTING FOUND SET TOO HIGH
G	DK2	021538	052278	GM25 G	A02	0 8 T	U-2 DG TRIPPED 4 TIMES ON OVERSPEED; RFX IN S/D	PERSONNEL DID NOT CALIBRATE SWITCH
G	EN1	015557	062676	FM25 B	B02	3 D 8 T	DG 1C TRIPPED DUE TO LUBE OIL SWITCH NOT CALIBRATED	IMPROPER ADJUSTMENT OF AUTO RES JETPOINI
G	EN1	020613	111977	FM25 K	B02	J D 4 T	1B DG OUTPUT VOLTAGE TOO HIGH - 1B DG	MISADJUSTMENT OF GOVERNOR
G	FPI	021801	120578	GM25 G	A02	3 D 4 T	"A" DG TRIPPED WHEN BEING PARALLELED	

HUMAN ERROR

V E N I	P L A N C O N T R O L N U. N	F A I L D A T E	M F K G W	S U B S Y S	F A I L M O D E	M E C H T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
G	PB2 018886	082677	FM30	D	A01 S	D	1	T	E1	DG FAILED TO START DUE TO HI JKT CLG WTR TEMP	OPER RESET TRIPPED PMP,BUT NOT DIESEL TRP
G	PB2 019414	101877	FM30	D	A02 S	D	1	N	E3	DG TRIPPED FOLLOWING MANUAL START	3 VALVES TO LOW PRESS SW LEFT SHUT
G	PI1 022128	080278	AL25	K	B01	D	8	T	B	DG BECAME INOPERABLE AFTER ONE HOUR RUN	OPERATOR CAUSED DIODE FAILURES IN VLI REG
M	BV1 021647	060178	GM25	B	B02	D	1	T	#2	DG LUBE OIL LEAK AT ENGINE CONTROL PANEL GAUGE	GAUGE WAS CALIBRATED ON 5/21; LOOSE CONN.
M	HN1 014162	020376	GM25	A	A02 S	D	1	T	EDG-28	TRIPPED ON OVERSPEED WHILE STARTING	CALIB TOOL LEFT IN FUEL RACK-RACK HLD OPN
M	IP3 015733	083076	AL18	G	B02	D	1	T	EDG 31	BEGAN CYCLING BETWEEN 56 AND 63 CPS	GOV OIL DRAIN VLV NOT SHUT TIGHTLY
M	IP3 016035	092476	AL18	G	B02	D	4	T	EDG 31	OUTPUT FREQ INC TO 62 HZ; COULD NOT CONT ELE	AIR IN GOV OIL LINES FROM PREVIOUS REPAIR
M	JF1 021185	032378	FM40	C	A02	D	D	N	DSL	GEN 18 FAILED TO COME UP TO SPEED PER TECH SP	MAIN AIR START VLV PUSHER ASSY MISSING
M	JF1 022987	100378	FM25	J	A02 S	D	1	T	1C	DG OUTPUT BRKR FAILED TO CLOSE ON START	JUMPER FOR UNIT1/UNIT2 SEPAR, INCORCTLY POS
M	KE1 020095	122177	GM25	G	B02 S	D	4	T	D/G 18	WOULD NOT PICK UP MORE THAN 1500 KW LOAD	SYNCHRO MOTOR LIMIT SWCHS ADJUSTED IMPROP
M	PR2 015735	091076	FM30	F	B02	D	4	T	D1	DG TRIPPED ON HIGH CRANKCASE PRESSURE	HOSE CLAMP ON PIPE NOT CONN AFTER MAINT
M	SL1 014869	041676	GM25	F	A01 R	D	G	T	#1	DIESEL GENERATOR DAMAGED ON START	#17 CYL FLOODED - CAUSED BROKEN INTERNALS
M	Z11 022846	091478	CB40	B	A02 C	D	4	N	1A	DG CAME UP TO SPEED AND THEN TRIPPED - 5 TIMES	RAG IN OIL STRAINER CAUSED LO OIL PRESS T

DESIGN ERROR

Y E N T	P L A N	CONTROL NO.	FAIL DATE	W E K G M	S U B S Y S T E M	F A I L M O D E	C O N D I T I O N S	F A I L M E C H A N I S M
C M12	0142000	022376	FM25	F 804	B T G N	DG 12U	FR. PED OFF-LINE - SIMILAR OCCUR. 175-231	UPPER ROD BEARING FAILURE - LACK OF LUBRI
C 311	017134	011877	GM30	E 804	R T G T	18 DG	RAM FOR 95 MIN THEN TRIPPED ON LOCKOUT	TURBOCHARGER SHAFT AND OIL SEAL DAMAGED
C 311	019241	092677	GM30	E 804	R T G T	1A DG	SHUTDOWN WHEN SMOKE ISSUED FROM TURBOCHARGER	FAILED TURBO CHARGER UNIT
G 8P1	016913	122676	CA02	A 804	R U U T	START TIME	EXCEEDED CRITERIA BY 4 SEC	GOVERNOR LUBE FUEL SYS UNDER INVESTIGIN
G 8P1	016912	122776	CA02	A 804	R U U T	START TIME	VS 12	FUEL GOV. LUBE OIL SUPPLY MODIFIED 1/10/77
G 8P1	018742	080277	CA02	J 804	S D G T	TESTED EDG WITH 2A-2B	RKR RACKD OUT; AUTO TRANSF	AND MAN TRANSF
G 8P1	016694	010477	NM30	B 804	C D N T	03 DG	TRIPD N/A AT POWER	LOW LUBE OIL TEMP
G 8M1	0168548	010477	NM30	B 804	C D N T	04 DG	TRIPD N/A AT POWER	TO SWITCH NOT RESET
G 0A1	016452	110476	FM25	A 804	D D T DG	16-21	S/D DUE TO FIRE -FUEL LINE FRACTURE	INADEQUATE DESIGN
G P11	015966	092276	AL25	H 804	B T D T	MAN DG	EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
G P11	016368	111776	AL25	H 804	B T D T	MAN DG	EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
M 8V1	017346	031477	GR25	J 804	B D 4 T	02 DG	OUTPUT BREAKER FAILED TO CLOSE	DIRTY CONTACTS ON RKR CONT SWITCH
M 8V1	017621	041177	GR25	J 804	B D 4 T	01 DG	OUTPUT BREAKER FAILED TO CLOSE--DIRTY CONTACT	DESIGN CHANGE REQUEST FOR SEALED RELAYS
M 8V1	017693	042677	GR25	J 804	B D 4 T	01 DG	OUTPUT RKR. FAILED TO CLOSE--DESIGN REQUESTED	DIRTY CONTACTS ON NFLD(AND FIELD) RELAY
M 8V1	017827	050977	GR25	J 804	K D 4 T	02 DG	OUTPUT RKR. FAILED TO CLOSE--REPETITIVE	STICKING RELAYS(MSP2) IN MANUAL START CKT.
M 8V1	018068	060377	GR25	J 804	K D 1 T	02 DG	OUTPUT RKR. FAILED TO CLOSE ON FIRST ATTEMPT	CLOSED ON NEAT ATTEMPT; STICKY NFLD4 WELA
M 8V1	024437	011178	GR25	J 804	K D 4 T	02 DG	OUTPUT RKR. FAILED TO CLOSE IN EXERCISE MODE	NO CAUSE COULD BE DETERMINED
M 3A1	019424	120277	AL25	E 804	T G T	18	DIESEL DECLARED INDP-TURBOCHGR & EAM EXP JT	FLO CAUSE DETERMINED TO BE TURB BLADE FAILURE

FABRICATION / CONSTRUCTION / QUALITY CONTROL

V M N T	P L A N T	CONTROL NO.	FAIL DATE	M F G K W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	S E R I A L	S I D E	S I D E	FAILURE MODE		FAILURE MECHANISM	
														1-1 DG S/D DUE TO NOISY TURBOCHARGER	DESIGN/FABRICTN OR COMPNT FAILURE,REPLACD	VERT SHFT B/W LP & LWR CRANKS FLD-IMP MIL	SHORTED LEADS TO GOVERNOR; INCORRECT ASPB
B	DB1	020768	020878	GM25	E	B05			D	G	T			1-1 DG S/D DUE TO NOISY TURBOCHARGER	DESIGN/FABRICTN OR COMPNT FAILURE,REPLACD		
B	F12	021667	052078	FM30	F	A05		C	D	G	T			DG B FAILED TO START	VERT SHFT B/W LP & LWR CRANKS FLD-IMP MIL		
G	BR1	019391	101177	NM30	G	B05			D	B	T			#2 DG UNABLE TO MAINTAIN LOAD CYCLING 500KW	SHORTED LEADS TO GOVERNOR; INCORRECT ASPB		
G	DA1	015993	100776	FM25	F	A05			D	D	T			1G21 BROKEN LOWER VERT DRIVE COUPLNG HUB	HUB MADE OF WRONG MATERIAL		
M	BV1	017883	022477	GM25	L	B05			D	4	T			DG OUTPUT BREAKER TRIPPED;INTERNAL LOSS OF FIELD	TRIP NOT DISCONNECTED DURING ACCEPT.TEST		

PROCEDURAL DISCREPANCY

V E N I	P L A N I	CONTR OL NU.	FAIL DATE	M F G W	S Y S T E M	F A I L M O D E	F A I L M E C H	E T Y P E	C L A S S	R E P A R A B I L I T Y	D I S C R E P A N C Y	FAILURE MODE		FAILURE MECHANISM	
												DESCRIPTION	REASON	DESCRIPTION	REASON
B	CR3	018565	072677	FM30	I	A06	S	D	1	T	"30" DG FAILED TO START DIESEL TRIPS WERE NOT RESET	REVISED PROCEDURES TO RESET TRIPS			
B	T11	014298	022176	FM30	J	A06	S	D	1	T	"18" DG OUTPUT BREAKER FAILED TO CLOSE	PROCED ERROR-IMP GOV SETTING-FREQ TOO LOW			
C	FC1	014559	040776	GM25	M	A06	S	D	1	T	START ON SECONDRY AIR REQUD 10.6 SECS.VS. 10SECS.	PROCEDURE WAS INADEQUATE			
C	M12	016755	121876	FM25	F	B06		D	6	T	DG 130 #3 UPPER PISTON CON ROD BRNG CAP SHEARED	CAPSCREWS FAILED - PROB DUE TO DRY STARTS			
C	MY1	022715	092578	GM25	A	A06	S	U	1	T	DG-18 COULD NOT BE LOADED DURING TEST AFTER MAINI	AIR WAS NOT PURGED FROM FUEL LINES			
G	DA1	017963	051277	FM25	G	B06	S	D	1	T	1G-31 DG WOULD NOT REACH FULL LOADING ONLY 2500 KW	SPEED SETTING ADJUSTMNT NOT RESET			
G	DA1	021171	040578	FM25	F	A06		D	6	M	BEARING WIPED ON 4/13/77 NOT DUE TO MISALIGNMENT	LUBE OIL FILTER DRAIN VALVE WAS OPEN			
G	DR2	019651	103077	GM25	E	B06		T	6	I	UNIT 2/3 UNLOADED TRIPPD ON LOW H2O PRESS RESTART	TURBO-CHARGR CLUTCHSHAFT BEARING			
G	EN1	015568	080576	FM25	K	A06	S	D	1	T	DG 1A TRIPPED DUE TO LOSS OF EXCITATION DRNG SYNCH	DEFECTIVE PROCEDURE - PARALLED OUT OF SYN			
G	PB2	018887	082677	FM30	I	A06	S	U	4	T	E4 DG TRIPPED ON OVERSPEED	OVSPD TRIP SET BELOW DESIGN VALUE			
W	KE1	019471	092077	GM25	E	B06	C	D	4	T	DSL GEN 1A S/D WHEN SMOKE & FIRE OBSVD IN TURBOCHG	CARBON BUILDUP DUE TO SHORT DURATION OPER			
W	SO1	022190	071878	DL10	A	A06		D	1	T	NO 1 DIESEL GENERATOR FAILED TO START	FUEL RACK BINDING-INCORP PROC TO EXERCISE			

-----DEFECTIVE FUEL INJECTORS-----

P	CONTR	FAIL	PK	MODE	FAILURE MODE	
N	NO.	DATE	GM	TYPE		
C	M12	022131	080378	FM25 A	807	OG 130 SHUTDOWN DUE TO LEAKING INJECTOR
G	BRI	022454	091178	MH30 A	807	#1 NOT FIRING---HEAVY LOADING ???
H	UC2	021681	061778	W030 A	807	#10 DG 200 DG WIDELY VARYING CYLNR TEMP TAGGED OUT
W	R02	014623	036176	FM25 A	807	R #8 T #8 EMER DIESEL DID NOT REACH RATED CAPACITY
*	R02	019354	091377	FM25 A	807	K #8 T #8 "A" DIESEL GEN FAILED TO ASSUME FULL LOAD

FAILURE MECHANISM
CRACK IN INJ PUMP DISCH VALVE CAUSE
FAULTY FUEL PUMP REPLACED
FUEL INJECT. PUMP FAILD
12 CYL INJ PLUNGER & BARREL GALLED
SEVERAL FUEL INJ RODS WERE STICKING

-----CORROSION / EROSION-----

PISTON CONTROL NUMBER	FAIL DATE	EXAMINER	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
G 882	010359	111176	MM30 C A08	1 D T DG FAILED OPER TEST-12+2 ON #2 AIR RECEIVER	CHECK VALVE RUSTED SHUT
G C01	010560	110776	CB40 K B08	1 D T DG-2 LOST ELECT GOVERNOR CONTROL AND VOLTAGE	POT. TRANSFER FUSE CONTACTS OXIDIZED
G EN1	020214	112577	FR25 G A08	1 B T 1A DG FAILED TO START; STUCK GOVNR BOOSTER SERVOACTOR AIR PISTON WAS CORRODED	

FOREIGN MATERIAL CONTAMINATION

V E N T	P L A N T	CONTROL NO.	FAIL DATE	M F K G W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I R T I N V O L V E M E N T	FAILURE MODE	FAILURE MECHANISM	
B	CR3	020221	122777	FM30	G	A09	R	D	8	7	38	DG FAILED TO START--3RD OCCURANCE	SMALL PIECES OF INSULATION PREVENT GOVERNOR	
B	CR3	020278	010378	FM30	G	A09	R	D	8	7	38	DG FAILED TO START --4TH OCCURANCE	FOREIGN MATTER IN SERVO BOOSTER	
B	DB1	020273	010978	GM25	F	A09	T	4	T	DG	1-1	TRIPPED ON HI CRANKCASE PRESSURE	DIRTY CRANKCASE VENT OIL COLLECTOR	
B	T12	021605	052378	FM30	F	B09	R	T	8	M	DG	B	TRIPPED ON HIGH CRANKCASE PRESS - 32 MIN RUN	PART PLUGD ORIFICE PLATE-TO-CRCKSE VAC EJC
B	T12	023430	122878	FM30	A	A09	T	8	T	DF-X-1B		DID NOT START	PARTIALLY CLOGGED FUEL OIL FILTER	
C	CC1	017822	051577	FM25	M	A09	R	T	8	T	#12	DG FAN FAILED TO START WHEN GEN RECEIVED SIGNAL	DIRT ON FAN MAIN BRK CONTACTS	
C	CC2	016722	121576	FM25	C	A09	T	4	T	#21	DG	FAILED TO START FROM CONTROL ROOM & LOCALLY	CLOGGED AIR STRT DISTRIBUTOR PILOT VALVES	
C	FC1	017662B	040677	GM25	C	A09	R	T	4	T	DG-1	FAILED TO STRT WITHN 10 SEC, STRTD OK ON PRI AIR	DEPOSITS FOUND ON SECONDARY AIR MOTORS	
C	FC1	017662A	041477	GM25	C	A09	R	T	4	T	DG-2	FAILED TO START IN 10 SEC STRTD OK ON PRIMARY	DEPOSITS IN SECONDARY AIR MOTORS	
C	M12	014260A	021776	FM25	A	B09	B	T	1	N	DG	12U	FAILED TO START - SIMILAR OCCUR, LER (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRCKSE VENT
C	M12	014260B	021876	FM25	A	B09	B	T	1	N	DG	12U	TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRCKSE VENT
C	M12	014260C	022076	FM25	A	B09	B	T	1	N	DG	12U	TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRCKSE VENT
C	M12	015166	060276	FM25	F	B09	B	T	1	T	DG	13U	TRIPPED ON HI CRANKCASE PRESS - 11 MIN RUN	CRCKSE AIR EDUCTOR FOUND DIRTY
C	M12	016031	092276	FM25	D	B09	B	T	6	T	12U	DG RECVD LOW CW FLD ALA-UNIT UNLOADED, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS	
C	M12	016626	120176	FM25	D	A09	B	T	6	T	13U	DG STARTED, NO CW FLOW, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS	
C	M12	018972	061777	FM25	D	B09	B	T	6	T	12U	DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS	
C	M12	018976B	092077	FM25	D	B09	B	T	6	N	COOLING WTR	LOW FLOW ALARM - 12U DIESEL GEN	INSUF CL INJECTION FOR A09 MUSSEL CONTROL	
C	M12	021386	050878	FM25	D	B09	B	T	6	T	12U	DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS	
C	M12	023213	120578	FM25	D	B09	B	T	6	T	12U	DG S/D DUE TO LOW COOLING WATER FLOW	MUSSEL SHELLS IN THE HEAT EXCHANGER	
C	MY1	020733	021878	GM25	G	A09	T	8	T	DG-1A		FAILED TO RESPOND DURING TEST RUN FOR TRAING	DIRTY CONTACT ON SPEED CONTROL PC BOARD	

FOREIGN MATERIAL CONTAMINATION

PLANT	CONTROL NO.	FAIL DATE	M C N	FAILURE MODE	FAILURE MECHANISM
C 311	017135A	011977	GM30 A	THE 1A DIESEL GENERATOR FAILED TO START	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C 311	017135B	011977	GM30 A	THE 1A DG FAILED TO START AGAIN - LATER SAME DAY	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
G 8F1	016201	110376	GM30 G	ERRATIC SPEED BEHAVIOR UNDER LOAD	DIRTY OIL IN GOVERNOR
G 8P1	014417	032476	CA02 D	TRIPPO ON HI COOLING WATER TEMP	WATER PUMP SUCT SCREEN PLUGGED
G 8P1	014894	051676	CA02 U	TRIPPO ON HI COOLN WATER TEMP PUMP SHAFT SCORED	INLET SCREEN PARTIALLY PLUGGED
G 8P1	020068	120977	MM36 C	START TIME 16.2 SEC VS 10	CARBON BUILDUP ON AIR VALVE STUCK SHUT
G C01	023644	091278	CB40 F	TRIPPO APPROX 1 MIN AFR REACH RATED SPEED	MAIN BEARING FAILED DUE TO LOW LUBE OIL
G DAL	014493	082276	FM25 D	TRIPPO ON HI JACKET TEMP-DECLARED INOPRBL	ESW LOW FLOW DUE TO MUD IN STRAINER
G UR2	016168	093076	GM25 K	DG OUTPUT ERNATIC AFR CONTROL PLACED IN "STOP"	SHORT JERANIUM RECIFIER DUE TO DIRT
G UR3	016615	092176	GM25 B	DIESEL 3 RECEIVED HI TEMP ALARM	PARTIALLY CLOGGED STRAINER IN L.C. CIRC PMP
G M01	016186	161676	GM25 C	DG FAILED TO START ON #2 STARTING SYSTEM	#2 START SYS AIR CONT COMP FOULED W RUST
G Y11	014740	050676	FM30 F	DIESEL GENERATOR TRIPPED ON HI CRNKSE PRESS	CLOGGED CRNKSE EJ SUP ORIFICE DR EJ BODY
G Y11	019658	072677	FM30 C	DIESEL GENERATOR FAILED TO START	AIR START SOL VALVES BOUND CLSD BY DEBRIS
G Y11	020464	012478	FM36 D	DIESEL GENERATOR "AM" TRIPPED ON HI JACKET CLNG TEMP	3-WAY VLV BLOCCKED TO BYPASS CLNE ARND HR
M 8V1	014963	052076	GM25 C	DG #1 FAILED TO START 3 TIMES DG #2 STARTED OK	WATER ACCUMULATION IN AIR START SYSTEMS
M 8V1	017656	042477	GM25 C	DG #1 FAILED TO START REPETITIVE	MOISTURE IN STARTING AIR
M JF1	020992	030278	FM40 C	DG #1 FAILED TO ATTAIN RATED SPEED	CORROSION PRODUCTS CLOGGED AIR START VLVs
M JF1	020996	030878	FM25 C	DG #1 FAILED TO START DURING TEST	CORROSION PRODUCTS CLOGGED AIR START VLVs
M Y11	019653	080277	GM02 D	DG #1 DG OVERHEATED--RUNNING FOR APPROX 25 MINUTES	SLUDGE AND SCALE IN 67% OF RADIATOR TUBES
M Y11	019654	080277	GM02 D	DG #3 DG OVERHEATED AFR 30 MIN. OF OPERATION	72% OF RADIATOR TUBES BLOCKED SLUGG. SCALE

MECHANICAL / ELECTRICAL CONTROL

P	C	CONTROL	FAIL	DATE	M	K	F	D	FAILURE MODE	FAILURE MECHANISM		
N	T	NO.	DATE	NO.	NO.	NO.	NO.	NO.				
B	AR1	014638	021176	GM25	C	A10	D	B	T	DG #1 FAILED TO START ON SIMULATED E-S. ACTUATION	FAILED DIODE IN AUTO START CIRCUIT	
B	CR3	019302	092877	FM30	B	A10	D	B	T	3B DG FAILED TO START DUE TO START PERMISSIVE LOST	D START PERM. DUE TO LOW LUBE OIL PRESSUR	
B	DB1	021822	060478	GM25	K	A10	D	N	T	1-1 DG FAILED TO OPERATE WITH PROPER FREQ/VOLT	FAILED PRIMARY POTENTIAL FUSE FGR DG 1-1	
B	RS1	015622	080676	GM25	C	A10	D	N	T	"M" DG FAILED TO START DURING SPECIAL TEST	IMPROPER GEAR ENGAGEMENT-AIR STRY MTR UCC	
B	RS1	016656	120676	GM25	G	B10	D	B	T	DG "M" TRIPPED OFF-LINE 25 MIN INTO TEST	SPEED CONT SW FLD CLOSED, SPD DECK TO TRIP	
B	T11	020997	031878	FM30	B	A10	T	B	T	EDG FAILED TO START	DEFECTIVE OIL PRESSURE LIMIT SWITCH	
C	CC2	020226	081078	FM25	J	B16	T	I	T	#21 DG TRIPPED AFTER 29 MIN. DUE TO GEN FAULT	LOSS OF FIELD E REVERSE POWER RELAYS	
C	CC2	021991	080178	FM25	D	B10	D	N	T	#21 DG TRIPPED ON HI JACKET COOLANT TEMP	SERV H2D SUPPLY VALV FAILED TO OPEN	
C	FC1	015614	081576	GM25	G	B10	T	B	N	SMOKE COMING FROM DG-2 GOVERNOR MOTOR ENCLOSURE	ARMATURE HAD OPEN WINDING	
C	FC1	021692	081978	GM25	K	A10	R	D	I	DG-1 FAILED TO REACH RATED TERM VLTG ON STARTUP	BLWLN FUSE IN GEN FIELD CIRCUIT	
C	FC1	041749	071278	GM25	K	B10	M	D	B	T	DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN	3 EXCITER SUBCOMPONENT FAILURES(COINCIDENT)
C	FC1	022249	080978	GM25	K	B10	M	D	B	T	DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN	REFER VOLTAGE ZENER DIODE OUTPUT DRIFTED
C	M12	015283A	081676	FM25	G	A10	B	T	N	T	DG 12U FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVMOTOR
C	M12	015283B	081776	FM25	G	A10	B	T	N	T	DG 12U FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVMOTOR
C	M12	015283C	082376	FM25	G	B10	B	T	N	T	DG 12U TRIPPED OFF-LINE	DRIED LEATHER WASHER IN BOOSTR SERVMOTOR
C	SL1	022532	090578	GM30	J	A10	T	B	T	"M" DG OUTPUT BREAKER WOULD NOT CLOSE REMOTELY	DIRTY CONTACTS ON ITS OPERATION RELAY	
G	BF3	019133	091977	GM30	K	A10	D	I	T	3D DG TRIPPED ON OVERSPEED ; GOVERNOR INOPERABLE	TO FUSE OPEN DISENABLING FIELD CIRCUIT	
G	BPL	015444	081276	CA02	C	A10	R	T	B	T	WEEKLY TEST FAILED TO START	STARTING BATTERY CABLE FAILED LOOSE CONNEX
G	BPL	016287	111876	CA02	C	A10	M	D	N	T	FAILED TO START IN AUTO TEST; STARTER MOTOR PROBLEM	BROKEN SPRING IN BENDIX MECHANISM
G	BPL	016911	122876	CA02	C	A10	R	D	N	T	DEFECTIVE STARTER DRIVE DG FAILED TO START	BROKEN SPRING DELCO PART #1945407

MECHANICAL / ELECTRICAL CONTROL

V E N T	P L A N T	C O N T R O L N O .	F A I L D A T E	M F K G W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
G BR2	G14136	010976	NM30	J	A10	D	4	N	#1 DG STARTED BUT OUTPUT BKR FAILED TO CLOSE TO E-1	BROKEN LUG WIRE DUE TO STRESS			
G BR2	C16623	122976	NM30	G	B1G	T	B	T	#2 DG FAILED OPERABILITY TEST --LOSS OF SPEED CONT.	CLUTCH ADJUSTED AND STATOR VOLTMR REPLAC			
G DA1	Q17756	051077	FM25	J	A10	S	D	B	T	16-21 DG OUTPUT BKR FAILED TO CLOSE	AVA CONTACTS OF STDBY TRANSFORMER OPEN		
G DM1	Q20852	030478	GM10	C	A10	D	G	T	D-1 B/U FAILED TO START R/X IN HOT S/D MODE	SYNCHRO START SWITCH FAILED			
G DR1	Q21517	050778	GM10	B	A10	T	D	N	TEMPORARY DG FAILED TO START DUE TO LOW LUBE OIL PRS	L.O. PUMP COUPLING DAMAGED			
G DR1	Q21516	051178	GM10	A	A1G	R	D	G	T	TEMP. DG FAILED TO START-BLOW FUSES IN CONT LOGIC	SHORTED DIODE ACROSS FUEL PRIMING PUMP		
G DR2	Q17397	032277	GM25	C	A10	R	D	I	T	UNIT 2/3 FAILED TO START	AIR START MOTOR PINION GEAR JAMMED		
G DR2	Q22262	062478	GM25	C	A10	R	U	4	T	2/3 UNIT DCS UNIT 2 FAILED TO START ON 1ST ATTEMP	PINION GEAR NOT ENGAGED ON AIR START MTR		
G DR3	Q16455	110576	GM25	G	B1G	R	T	B	T	LOST SPEED CONTROL FROM CONTROL ROOM	FAILED OVERTRAVL LIMIT SWITCH ON GOVNR		
G DR3	Q17509	032277	GM25	K	A10	D	G	M	GEN FIELD FAILED TO FLASH	INTERMITINT CAPACITOR SHORT IN FLASH CIRC			
G DR3	Q19722	112277	GM25	G	A10	R	D	B	T	3 DG STARTD/LOADED-OVERLOAD ALARM-DG TRIPPO	BAD CAPACITOR IN SPEED SENSING Ckt.7		
G DR3	Q19727	112977	GM25	G	B1G	R	D	B	N	3 DG TRIPPO 30 MIN AFTER START AND LOADING	SHORTED CAPICITOR ON SPEED SENSING BOARD		
G EN1	Q14778	031576	FM25	C	A10	D	D	T	1A DG FAILED TO START DURING SURVEILLANCE	SOL OPER AIR VLV IN START SYS STUCK SHUT			
G EN1	Q16665	091176	FM25	G	A10	R	D	I	T	1A DG FAILED TO START - SURV TEST - OCCURRED PREV	LOW OIL LEVEL IN GOVERNOR		
G EN1	Q18839	081277	FM25	K	B1G	D	B	T	1A DG LOST MANUAL VOLTAGE CONTROL	MAN REG MTR OPER XFM: PWR SUP DIODES FAIL			
G EN2	Q227514	102878	FM25	G	A10	R	D	B	T	"CM DIESEL FAILED TO REACH 250RPM IN 7 SEC.	STICKING GOVNR BOOSTR SERVO		
G EN2	Q227518	103178	FM25	G	A10	R	T	B	N	"CM DIESEL FAILED TO REACH 250RPM IN 7 SEC.	FAULTY ELECTRONIC SPEED SWITCH SIGNAL		
G FP1	Q16446	111776	GM25	I	A10	R	D	B	T	"BM EDG FAILED TO START DURING SURVEILLANCE TEST	GEN TACH RELAY DID NOT OPERATE, DEF CNVTR		
G FP1	Q16600	121576	GM25	B	A10	R	D	I	T	DURING TESTING "AM EDG FAILED TO START	LOW LUBE OIL PRESS - RELIEF VLV LEAKAGE		
G FP1	Q16971	011977	GM25	B	A10	R	D	I	T	DURING SURV, EDG TRIPPED ON EMERGENCY START	LOW LUBE OIL PRESS, SECOND ATMPY SUCCESSFL		

MECHANICAL / ELECTRICAL CONTROL

PLANT	CONTROL NO.	FAIL DATE	FK G W	DESCRIPTION	FAILURE CODE	FAILURE MECHANISM
G	FPI	017725	GM25 I	ALOR DBT	DURING KULTINE JURY TEST, EDG FAILED TO START	TACHOMETER RELAY FAILED
G	FPI	020518	GM25 J	810	1 Y PAM EDG TRIPPED DURING SURVEILLANCE TEST	BLOWN FUSE IN SYNCH CRT FOR OUTPUT BRKR
G	DC1	014447	GM25 K	ATG	DBT DG 2 STARTED BUT DID NOT DEV SUFF VLTG TO LOAD	WESTHSE PFCO RELAY FLD TO EMRGZ FLD FLASH
G	DC1	023119	GM25 K	ALO	DBT #1 DG STARTED BUT GEN FAILED TO EXCITE--AUTO ACT. YES	UNUSED TARGET MECH LINKAGE IN RELAY BINON
G	PR2	022462	FM30 G	ALO	1 Y E-3 DG START TIME DID NOT MEET TS REQUIREMENT	LEAKY CRK VLV IN AIR BOOSTER RELAY HYD SY
G	PR2	023549A	FM30 G	ALO	0 1 E3 DG START TIME 13 SEC. VS. REQUIRED 10 SEC.	E3 DG GOVERNOR REPLACED ON 12/28/78
G	QC1	014120	GM25 C	ALO	DBT UNIT 1 DG FAILED TO START WHEN MODE SW IN START MD	AIR START SOL VLV DIRTY--NOT OPEN FULLY
G	QC1	018112	GM25 K	ALO	0 G 1 WHILE TESTING THE DG, THE FIELD FAILED TO FLASH	CAPACITOR ACROSS VLTG SUP RELAY DEFECTIVE
G	QC1	019994	GM25 K	ALO	0 4 M 172 DG WOULD NOT START SUCCESSFULLY, FIELD BRK DEFECT	FAILED DIODE IN FLD BRK INTLK CIRCUIT
*	8V1	018828	GM25 K	ALO R	1 Y T #2 DG STARTED AND CLOSED ONTO BUS; OUTPUT VOLTS = 0.	LOOSE CONNECTIONS IN AUTO FIELD FLASH CRT
*	8V1	022137	GM25 K	ALO R	0 1 N #2 DG FAILED TO FLASH DURING SI AND LOSP EVENT	STICKY FIELD FLASH CUTOUT RELAY; AUTO CRT.
*	DC1	010647	W030 K	ALO	0 1 T C-D DG TRIPPED ON OVERSPEED--BLOWN FUSE ON INVERTER	FAILED SILICONE RECTIFIER IN DG INVERTER
*	DC2	020481	W030 C	810	0 4 T 2C0 DG GASKETS ON AIR LINE TO #5 CYL BLEW OUT	FRACTURED AIR START CHECK VALVE
*	DC2	022045	W030 G	810 R	1 4 T #2 AB DG OVERSPEED WHL UNLOADG PREVIOUS OCCURRENCE	WORN LINKAGE CAP SCREW BROKE IN GOVERNOR
*	1P3	016486	AL18 L	810 S	0 8 T 1 UNABLE TO CONTROL SPEED OF NO 31 DG	UNIT/PARA RELAY OPER INTRMIT-DEFECTV COMM
*	1	019055	FM40 C	ALO B	0 0 U I DG 18 TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY	MAIN AIR VALVE FAILED TO SHUT; CAUSED OVERSP
*	FL	019662	FM40 C	ALO B	0 0 U T DG 18 TRIPPED ON OVERSPEED DURING MANUAL START	MAIN AIR START VLV FAILED TO FULLY SHUT
*	JF1	019359	FM40 C	810 B	0 0 N DSL GEN 18 EVENTUALLY TRPPD ON OVERSPEED AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
*	JF1	019360	FM40 C	810 B	0 0 N DSL GEN 1-2A EVENTUALLY TRPPD ON OVERSPEED AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
*	JF1	019368	FM40 G	ALO	0 8 T DSL GEN 1-2A FAILED TO START DURING TEST	SPEED SWITCH FAILED - 120V VS 136V RATING

MECHANICAL / ELECTRICAL CONTROL

V E N	P L A N T	C O N T R O L N U .	F A I L D A T E	M F K G W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I S P O S I T I O N	FAILURE MODE		FAILURE MECHANISM	
												FAILURE MODE	FAILURE MECHANISM		
W	JF1	022235	081278	FM40	J	A10	S	D	8	N	OUTPUT BRK FOR DG 1B FAILED TO CLSE AUTOMATICALLY	OPER MECH FOR AUX SWCHS OUT OF ALIGNMT			
W	JF1	022374	082778	FM25	G	A10	R	D	8	N	2C DG WOULD NOT RESPOND TO AUTO DR MAN SPEED CHG	BLOWN FUSES FOR MOP AND MOT			
W	JF1	022373	090578	FM40	G	A10	R	U	8	M	1-2A DG WOULD NOT RESPOND TO AUTO VLTG DR SPD CHGS	BLOWN FUSES FOR MOP, CAUSED BY FAIL DIODES			
W	JF1	022630	091778	FM40	G	A10	D	4	T	18	DG	FREQ COULD NOT BE INCR ABOVE 58.5 HZ	CPLNG BET DC MTR AND GOV POS PDT WAS LOOS		
W	PK1	018342	061777	FM30	G	B10	T	8	T	D2	DG	FAILED TO RESPOND TO LOAD CHANGE SIGNALS	LINK LEVER KEY MISSING, CAPSCREWS LOOSE		
W	PT1	017146	020977	GM25	J	A10	R	D	8	T	3D	EDG	OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	DIRT IN LWR BRNG OF OVCRT RELAY TMG DISC	
W	PT1	021445	051778	GM25	J	A10	R	D	D	T	4D	EDG	OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	WEST 602A143H01 LATCH-CHKNG SW DEFECTIVE	
W	RG1	022450	081678	AL18	J	A10	T	8	T	B	EDG	OUTPUT BREAKER WOULD NOT CLSE	BAD CONN AT CONT PWD FUSE BLOCK STUBS		
W	SA1	018799A	073077	AL25	A	A10	C	T	4	N	1A	DIESEL	INOP-FAILED TO REACH RATED SPEED ON STRT	BINDING FUEL RACK LNKG - LACK OF LUBRICAT	
W	SA1	018799B	073077	AL25	A	A10	C	T	4	N	1B	DIESEL	INOP-FAILED TO REACH RATED SPEED ON STRT	BINDING FUEL RACK LNKG - LACK OF LUBRICA	
W	SO1	021310	032878	DL10	A	A10	K	F	1	T	NO	1	DIESEL	GENERATOR FAILED TO START	FUEL LNKG BINDING - BEARINGS IN LNKG DRY
W	TR1	018447	062277	GM40	G	B10	T	4	N	WEST	DG	FAILED TO ASSUME MIN REQUIRED LOAD	BRUSH FALLEN OUT OF DC GOV DRIVE MOTOR		
W	TU3	021419	060178	GM25	A	B10	T	4	T	B	DG	HI LEVEL IN FUEL TANK (ENG. MOUNTD) DG S/D	LEVEL SWITCH MALFUNCTION--REPLACED SWITC		
W	YR1	017316	030177	GM02	C	A10	D	4	T	#1	EDG	FAILED TO START DUE TO FAILD STARTER MOTOR	ARMATURE SHAFT BROKEN--REPLACED W SPARE		
W	Z11	020255	010378	CB40	K	B10	R	T	D	T	18	DG	OUTPUT VOLTAGE PEGGED HIGH-COULD NOT LOWER	PC BOARD FAILURE IN THE VOLTAGE REGULATOR	
W	Z11	023348B	011678	CB40	G	B10	T	4	T	DG	MOD	STARTED & LOADED, BUT DECLARED INOPERABLE	LD CONTROL AIR PRESS-TRIP VLV / JM RING LK		
W	Z11	022110	080178	CB40	C	A10	T	1	T	18	DIESEL	GENERATOR FAILED TO START	AIR LEAK IN STARTING AIR PILOT VALVE		
W	Z11	022515	090278	CB40	C	A10	D	4	T	18	DIESEL	GENERATOR FAILED TO START	STARTING AIR DIST BUSHING ROTATED IMPROP		
W	Z12	017006	042777	CB40	G	B10	R	D	1	T	GOVERNOR	SPEED CONTROL FAILED ON 2B DIESEL GEN	GOV SPD CONT GEAR JAMMED AGNST HI SPD SET		
W	Z12	020058	010678	CB40	K	B10	R	T	8	T	2A	DG	OUTPUT VOLTAGE INCREASED AND COULD NOT LOWER	BURNED CONTACT IN THE VOLTAGE REGULATOR	
W	Z12	020260	010978	CB40	G	B10	R	D	1	T	2B	DG	POWER OUTPUT OVLD - COULD NOT LOWER MANUALLY	GOV SYNCH IND GR JAMMED ON HI SPD STOP	

HI / LOW AMBIENT TEMPERATURE

PLANT	CONTROL	FAIL DATE	PK	MODE	TYPE	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
081	0204088	012778	GM10	M	ALL	C D I M U-1 B/U DG FAILED TO START 1ST 5 TIMES-LOW TEMPERAT WINTER WEATHER	1-2 DG S/D DUE TO ROOM TEMP RISE TO 110 DEG.	OUTSIDE AIR DAMPER WOULD NOT OPEN
081	0204088	012978	GM10	M	ALL	C D G N U-1 FAILED TO START DUE TO COLD WEATHR 6 HEATRS INSTALLED & ROOM WINTERIZED		

LUBE / FUEL / WATER / AIR LEAKAGE

PLANT	CONTROL NO.	FAIL DATE	M K C M	FAILURE MECHANISM	FAILURE MECHANISM
C CC2	017986	060177	FM25	D 0 A12	DIAGNOSTIC
C M12	015400	090176	FM25	B 012	DIAGNOSTIC
C M12	016636	091976	FM25	B 012	DIAGNOSTIC
G 8F1	014162	011476	GM30	G A12	DIAGNOSTIC
G 8P1	020580	020978	CA02	D 012	DIAGNOSTIC
G 8K2	014614	031476	MM30	A 012	DIAGNOSTIC
G 0A1	014334	022776	FM25	B 012	DIAGNOSTIC
G 0A1	014337	031776	FM25	H 012	DIAGNOSTIC
G 0R2	019728	112977	GM25	D 012	DIAGNOSTIC
G 0R2	019810	120377	GM25	C A12	DIAGNOSTIC
G 0P2	020685	022878	FM30	B 012	DIAGNOSTIC
A 0V1	021355	041878	GM25	A 012	DIAGNOSTIC
A 1U3	017591	020377	GM25	A 012	DIAGNOSTIC
A 1U3	018447	033177	GM25	A 012	DIAGNOSTIC
A 1Z1	049714	111077	C040	B 012	DIAGNOSTIC

VIBRATION

V E N T	P L A N T	C O N T R O L N O .	F A I L D A T E	F K G W	S U B / S Y S	F A I L M O D E	M E C H	T Y P E	C L A S S	R E P A I R	D I S C O N T	FAILURE MODE	FAILURE MECHANISM
B	CR3	018231	060277	FM30	A	A13						"A" DG FAILED TO START ON MONTHLY TEST	LOOSE INJECTOR HOLD-DOWN NUTS
C	CC1	019192	101077	FM25	K	A13						#12 DG FAILED TO REACH VOLTAGE WITHIN 10 SEC.	2 LOOSE FUSE HOLDERS IN EXCITATION CIRCUIT
C	M12	017020	011077	FM25	F	B13	S	D	G	T		DG 130 SHUTDOWN DUE TO HIGH VIBRATION	SKID MOUNT IN RESONANCE WITH ENG FREQU
G	DR2	019723	120277	GM25	C	A13	R	T	1	T		UNIT 2 DG AIR RECEIVER LOW PRESS TERMINATED START	LOOSE WIRE AT TERMINAL 25A5
G	DR2	020242	010378	GM25	C	A13	R	T	8	T		UNIT 2 DG FAILED TO START WEEKLY SURV TEST	LOOSE WIRE AT TERMINAL 25A5
G	DR3	014439	030376	GM25	G	A13	R	T	4	T		DG COULD NOT BE LOADED FROM CONTROL ROOM	GOVNR CONTROL WIRE VIBRATED FREE FROM LUG
G	DR3	016187	100976	GM25	G	A13	R	T	4	T		LOSS OF CONTROL ROOM SPEED CONTROL	LOOSE WIRE ON GOVNR CONTROL CIRCUIT
G	EN1	014795	050176	FM25	M	B13	S	T	8	T		NORMAL SURV. TEST DG IC TRIPPED; LOOSE WIRE	NUT VIBRATED OFF WIRE-PANEL P43-P001C
G	QC1	019100	082477	GM25	L	A13						UNIT 1 DG STARTED AND RAN, BUT NO VLTG, SYNCH, FREQ	FREQ GEN TACH SET SCREWS VIBRATED LOOSE
G	Y11	015739	082576	FM30	A	B13						"B" DG OUS TO TIGHTEN FUEL HEADER FITTINGS	ENGINE VIBRATION LOOSENED MECHANICAL CONN
G	Y11	018323	062377	FM30	F	B13	R	T	4	T		"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE	VIBRTN CAUSED HOSE CLMP ON AIR EJECT FAIL
G	Y11	020194	121977	FM30	F	B13	R	T	4	T		"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE	ENG VIB CAUSED AIR EJECT HOSE TO LOOSEN
M	DC2	022503	091178	MO30	C	A13						2A8 STARTED FOR LOAD TEST WAS TRIPPED OFF MANUALLY	PISTON BOLT FOR AIR CHECK VALV LOOSE
M	RD2	021313	041078	FM25	G	B13						EDG LOAD FAILED TO INCREASE ABOVE 900KW	COMM BRUSH VIBRATED OUT OF GOV SPD CHGR
M	SA1	019420	111777	AL25	D	B13	B	1	4	T		1C DIESEL DEVELOPED WATER JACKET LEAK	CRACK FOUND ON 3/8" PIPE NIPPLE
M	Z11	015188	062176	CB40	A	B13						N 14 DG HAD FUEL LEAKAGE AT THE 6L FUEL INJ PUMP	VIB CAUSED CRACKED FTNG ON LINE TO INJ
M	Z12	017869	051677	CB40	I	B13	C	T	4	T		DIESEL GENERATOR 2A TRIPPED FROM FULL LOAD	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
M	Z12	019780	111777	CB40	I	B13	C	T	4	T		"M" DIESEL GENERATOR TRIPPED OFF-LINE	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE

OUT OF ADJUSTMENT / CALIBRATION

PLANT	CONTROL NO.	FAIL DATE	FK CM	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM	
B	01	019578	02577	02577	12-29-77	01 DG FAILED TO START; DRIFT OF TO RELAY SETPOINT	ALSO DIODE CR-1 FOUND SHORTED
B	06	019816	02577	02577	12-29-77	OURIN L0SP DG 1-1 STARTD AND TRIPD ON OVERSPEED	IMPROPER SETTINGS OF HI SPEED AND OVERSPD
B	11	020295	01278	01278	01-12-78	EDG 18 FAILED TO START ON SIMULATED AUTO ES TEST	OIL PRESS LIM SW PRESS SETTING DRIFTED
C	01	015722	02576	02576	08-15-76	DU-2 PRIMARY AIR START MTR FAILED TO DISENGAGE	SETTING FOR MAG PRUP ON SWTCHG EACH DRIFTED
C	12	019255	02477	02477	09-24-77	12U DG APPEARED TO TRIP ON GEN OVERCURRENT	MICRO SW OUT OF ADJ ON DG OVERSPD TRIP MECH
G	02	010443	02976	02976	10-29-76	UNIT 2 DG FAILED TO START TWICE MALFUNCTION 57D SOLENOID	SOLENOID PLUNGER OUT OF ADJUSTMENT
G	02	020025	03078	03078	03-08-78	ENGINE OVERSHOT AT 1010 RPM WHILE OS SET AT 1020	HI OVERSHOOT BY OUT-OF-ADJUST GOVNR COMP
G	02	021882	063078	063078	06-30-78	DG COOLING H2O PUMP TRIP ON HI AMPS; REPLACED	OVERLOAD TRIP SET CLOSE TO RUNNING AMPS
G	01	018044	06377	06377	06-13-77	DG TRIPD RESTARTED SATISFACT LO JACKET CLM	LUN COOLNT PRESS SWITCH TO BE CALIBRATED
G	01	018046	061877	061877	06-18-77	DG TRIPD ON LO COOLNT JACKET PRESSURE	POSSIBLE INCORRECT PRESSURE SETPOINTS
G	01	010047	062577	062577	06-25-77	DG TRIPD ON LU COOLNT JACKET PRESS	OPERNT PRESSURE WAS ABOVE TRIP SETPOINT
M	01	018417	062977	062977	06-29-77	DIESEL GENERATOR FAILED TO START - LOGIC FAILURE	SPEED SENSING ASSY SETPOINT DRIFTED
M	12	021544	03178	03178	03-17-78	DG OUTPUT VOLTAGE CYCLED - COULD NOT CONTROL	DRIFT OF VLTGE REGULATOR STABILITY CIRCUIT

APPENDIX J

DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY SUBSYSTEM

CODES USED IN LSR ONE-LINE DESCRIPTIONS

REPAIR TIME
CODE DESCRIPTION
1 - 0 TO 1 HOURS
4 - 1 TO 4 HOURS
8 - 4 TO 8 HOURS
D - 8 TO 24 HOURS
G - GREATER THAN 24 HOURS
U - UNKNOWN / NOT APPLICABLE

FAILURE MODE
CODE DESCRIPTION
A - DOES NOT START
B - DOES NOT CONTINUE TO RUN
U - UNAVAILABLE / NONFAILURE

FAILURE CLASSIFICATION
CODE DESCRIPTION
D - DEMAND
T - TIME
U - UNKNOWN

SUB-SYSTEM
CODE DESCRIPTION
A - FUEL OIL SYSTEM
B - LUBE OIL SYSTEM
C - STARTING SYSTEM
D - COOLING SYSTEM
E - SCVENGING AIR SYSTEM
F - ENGINE FRAME / INTERNALS
G - GOVERNOR
H - EXHAUST SYSTEM
I - SHUTDOWN SYSTEM
J - OUTPUT BREAKER
K - EXCITER / VOLTAGE REGULATOR
L - GENERATOR
M - OTHER / UNKNOWN

FAILURE MECHANISM
CODE DESCRIPTION
00 - UNKNOWN
01 - PERSONNEL OPERATION
02 - PERSONNEL MAINTENANCE
03 - PERSONNEL TESTING
04 - DESIGN ERROR
05 - FABRICATION / CONSTRUCTION / QUALITY CONTROL
06 - PROCEDURAL DISCREPANCY
07 - DEFECTIVE FUEL INJECTORS
08 - CORROSION / EROSION
09 - FOREIGN MATERIAL CONTAMINATION
10 - MECHANICAL / ELECTRICAL CONTROL
11 - HI / LOW AMBIENT TEMPERATURE
12 - LUBE / FUEL / WATER / AIR LEAKAGE
13 - VIBRATION
14 - OUT OF ADJUSTMENT / CALIBRATION

METHOD OF DISCOVERY
CODE DESCRIPTION
M - DURING MAINTENANCE
N - DURING NORMAL OPERATIONS
R - DURING RECORDS REVIEW
T - DURING TESTING
U - UNKNOWN

TYPE OF EVENT
CODE DESCRIPTION
B - RECURRING COMMON CAUSE
C - COMMON CAUSE
R - RECURRING
V - COMMAND FAULTS
F - RECURRING COMMAND FAULTS

NSSS VENDOR
CODE DESCRIPTION
B - BABCOCK & WILCOX
C - COMBUSTION ENGINEERING
G - GENERAL ELECTRIC
W - WESTINGHOUSE

DG MANUFACTURER
CODE DESCRIPTION
AL - ALCO
CA - CATERPILLAR
CB - COOPER-BESSEMER
DL - DE LAVAL
FM - FAIRBANKS MORSE
GM - GENERAL MOTORS
NM - NORDBERG MANUFACTURING
WD - WORTHINGTON

HP RATING
CODE DESCRIPTION
02 - 200-400 KW
10 - 500-1000 KW
18 - 1750-1910 KW
25 - 2500-2850 KW
30 - 3000-3500 KW
40 - 4000-4418 KW

FUEL OIL SYSTEM

V E N	P L A N I	C O N T R O L N L.	F A I L D A T E	M F G M	S U B S Y S	F A I L M O D E	F A I L M E C H E	E T Y P E	C L A S S	R E P A I R	S E R I A L	S U C C E S S	FAILURE MODE	FAILURE MECHANISM	
G	DR2	G16654	121876	GM25	A	B02	S	D	D	T			UNIT 2 DG FAILED TO CARRY REQD LOAD ;2000KW MAX	H2O IN FUEL SUPPLY FROM FLUSHING OPERATION	
G	VT1	G15739	082576	FM30	A	B13	T	1	T	"B" DG OOS TO TIGHTEN FUEL HEADER FITTINGS			ENGINE VIBRATION LOOSENEED MECHANICAL CONN		
W	Bv1	G21355	041878	GM25	A	B12	T	D	N	#1 DG WAS S/D AND DECLARED INOPERABLE--OIL LEAKS			FLAW IN FUEL OIL PUMP DISCHARGE PIPE NIPL		
W	DC2	021681	061778	W030	A	B07	T	8	T	2CD DG WIDELY VARYING CYLNR TEMP TAGGED OUT			FUEL INJECT. PUMP FAILD		
W	DC2	G22839	101978	W030	A	A00	U	1	T	2AB FAILED TO START DUE TO LACK OF FUEL TO INJECTRS			UNKNOWN WHY REPLACED FUEL FILTER ELEMENT		
W	HN1	014162	020376	GM25	A	A02	S	D	1	T	EUG-2B TRIPPED ON OVERSPEED WHILE STARTING			CALIP TOLL LEFT IN FUEL RACK--RACK HLD GPN	
W	RU2	014823	030176	FM25	A	B07	R	T	8	T	"B" EMER DIESEL DID NOT REACH RATED CAPACITY			# 12 CYL INJ PLUNGER & BARREL GALLED	
W	RU2	014354	091377	FM25	A	B07	R	T	8	T	"A" DIESEL GEN FAILED TO ASSUME FULL LOAD			SEVERAL FUEL INJ RODS WERE STICKING	
W	S41	018799A	073077	AL25	A	A10	C	I	4	N	1A DIESEL INOP--FAILED TO REACH RATED SPEED ON STRT			BINDING FUEL RACK LNKG - LACK OF LUBRICAT	
W	S41	018799B	073077	AL25	A	A10	C	I	4	N	1B DIESEL INOP--FAILED TO REACH RATED SPEED ON STRT			BINDING FUEL RACK LNKG - LACK OF LUBRICA	
W	S01	021510	032878	DL10	A	A10	R	T	1	T	NO 1 DIESEL GENERATOR FAILED TO START			FUEL LNKG BINDING - BEARINGS IN LNKG DRY	
W	S01	022100	071878	DL10	A	A06	D	1	T	NO 1 DIESEL GENERATOR FAILED TO START			FUEL RACK BINDING--INCRP PROC TO EXERCISE		
W	TU3	017591	020377	GM25	A	A12	R	I	U	T	DG "B" FAILED TO START			PROBABLE-AIR IN FUEL SUPPLY LINES	
W	TU3	G16147	C33177	GM25	A	A12	R	I	4	T	DG "B" DID NOT REACH SPEED & VLTG WITHIN SPEC TIME			AIR IN FUEL LINE--CRACKS IN SUCTION TUBING	
W	TU3	021914	060178	GM25	A	B10	T	4	T	B DG HI LEVEL IN FUEL TANK (ENG.MOUNTD) DG S/D			LEVEL SWITCH MALFUNCTION--REPLACED SWITC		
W	Z11	019188	062176	CB40	A	B13	T	4	N	14 DG HAD FO LEAKAGE AT THE 8L FUEL INJ PUMP			VIB CAUSED CRACKED FTNG ON LINE TO INJ		

LUBE OIL SYSTEM

UNIT	CONTROL NO.	FAIL DATE	FAIL NO.	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
B	CR3	019302	FM30	B ALO 5 0 6 T	38 DG FAILED TO START DUE TO START PERMISSIVE LOST	0 START PEMP, DUE TO LOW LUBE OIL PRESSUR
B	F11	020295	FM30	B ALO 5 1 4 T	EDG 18 FAILED TO START ON SIMULATED AUTO ES TEST	OIL PRESS LIM SW PRESS SETTING DRIFTED
B	F11	020947	FM30	B ALO 5 1 6 T	EDG FAILED TO START	DEFECTIVE OIL PRESSURE LIMIT SWITCH
C	CC1	018408	FM25	B 802 C 0 4 M	811 DG ON FIRE DUE TO L.O. HITTING HOT EXHAUST	O-RING SEAL ON STRNK NOT GLUED PROPERLY
C	M12	015906	FM25	B 812 C 1 1 N	DG 130 SHUTDOWN - FIRE ON EXHAUST MANIFOLD	LUBE & FUEL OIL ACCUM UNDER MANIF INSULAT
C	M12	016036	FM25	B 812 B 0 4 N	12U DG HAD TO BE SECURED AND DECLARED IMPERABLE	EXCSV LEAKAGE OF LUBE OIL FILTER GASKET
G	BM1	010054	MM30	B 404 C 0 4 T	83 DG TRIPPD R/X AT POWER, LOW LUBE OIL TEMP	LOW SETPOINT FOR PRE-FILTER HEATER, JACKET
G	BM1	010054	MM30	B 404 C 0 4 T	84 DG TRIPPD R/X AT POWER, TO SWITCH NUT RESET	L.O. PRESS SWITCH TIME DELAY INCORRECT
G	DA1	014334	FM25	B 812 R 1 0 T	SMALL FIRE ON EXHAUST MANIFOLD OF DG 1G21	OIL LEAK FROM FRONT COVER PLATE
G	DR1	021517	GM10	B ALO 1 0 N	TEMPORARY DG FAILED TO START DUE TO LOW LUBE OIL PR	L.O. PUMP COUPLING DAMAGED
G	DR3	016015	GM25	B 809 1 4 T	DIESEL 3 RECEIVED HI TEMP ALARM	PARTIALLY CLOGGD STRAINER IN L.O. CIRC PMP
G	EM1	015557	FM25	B 802 S 0 8 T	DG 1C TRIPPD DUE TO LUBE OIL SWITCH NOT CALIBRATED	PERSONNEL DID NOT CALIBRATE SWITCH
G	FPI	016006	GM25	B ALO 8 0 1 T	DURING TESTING "M" EDG FAILED TO START	LOW LUBE OIL PRESS - RELIEF VLV LEAKAGE
G	FPI	016071	GM25	B ALO 8 0 1 T	DURING SURV, EDG TRIPPED ON EMERGENCY START	LOW LUBE OIL PRESS, SECND ATTEMPT SUCCESSFL
G	PR2	020005	FM30	B 812 C 0 8 T	E-2 DIESEL TRIPPED ON HIGH CRANKCASE PRESSURE	WATER IN OIL VAPORIZED - LEAKY OIL UMUMS
M	8V1	020047	GM25	B 802 0 1 T	82 DG LUBE OIL LEAK AT ENGINE CONTROL PANEL GAUGE	GAUGE WAS CALIBRATED ON 521110DUSE CONN.
M	Z11	022846	CB40	B A02 C 0 4 N	1A DG CAME UP TO SPEED AND THEN TRIPPED - 3 TIMES	RAG IN OIL STRAINER CAUSED LO OIL PRESS I
M	Z12	019714	CB40	B 812 B 0 6 T	"C" DIESEL GEN TRIPPED ON LOW LUBE OIL PRESSURE	CAVITATION OF LO PUMP - WATER IN LUBE OIL

STARTING SYSTEM

VEH	PLANT	CONTROL NO.	FAIL DATE	MFG	K	W	SUBSYS	FAIL MODE	TYPE	CLASS	RECOVERY	DISCOVERY	FAILURE MODE	FAILURE MECHANISM
B	AR1	014838	051176	GM25	C		A10	D 8 T	DG #1	FAILED TO START ON SIMULATED E+S ACTUATION			FAILED DIODE IN AUTO START CIRCUIT	
B	AR1	014978	102377	GM25	C		A14	T 8 T	#1 DG	FAILED TO START; DRIFT OF TO RELAY SETPOINT			ALSO DIODE CR-1 FOUND SHORTED	
B	AR1	015622	080676	GM25	C		A10	D 4 T	#1 DG	FAILED TO START DURING SPECIAL TEST			IMPROPER GEAR ENGAGEMENT-AIR START MTR GDC	
C	CC2	016722	121576	FM25	C		A09	T 4 T	#21 DG	FAILED TO START FROM CONTROL ROOM & LOCALLY			CLOGGED AIR STRI DISTRIBUTOR PILOT VALVES	
C	CC2	018422	022277	FM25	C		A00	U 8 T	#21 DG	FAILED TO START & ASSUME RATED SPEED IN 10 SEC			AIR START SYS DISASSEMBLED & INSPECTED	
C	FC1	014590	042776	GM25	C		A02	T D B	DG-2	PRIMARY AIR START MTR FAILED TO DISENGAGE			IMPRPR SETNG FOR MAG PKUP ON SWTCHG TACH	
C	FC1	015722	081576	GM25	C		A14	T D B	DG-2	PRIMARY AIR START MTR FAILED TO DISENGAGE			SETNG FOR MAG PKUP ON SWTCHG TACH DRIFTED	
C	FC1	017662B	040677	GM25	C		A09	R T 4	DG-1	FAILED TO START WITHN 10 SEC, STRTD OK ON PRI AIR			DEPOSITS FOUND ON SECONDARY AIR MOTORS	
C	FC1	017662A	041477	GM25	C		A09	R I 4	DG-2	FAILED TO START IN 10 SEC, STRTD OK ON PRIMARY			DEPOSITS IN SECONDARY AIR MOTORS	
G	BP1	015444	081276	CA02	C		A10	R T B	F	WEEKLY TEST FAILED TO START			STARTING BATTERY CABLE FAILED LOOSE CONNEX	
G	BP1	016587	111876	CA02	C		A10	R D 4	T	FAILED TO START IN AUTO TEST; STARTER MOTOR PROBLEM			BROKEN SPRING IN BENDIX MECHANISM	
G	BP1	016911	122876	CA02	C		A10	R D 4	M	DEFECTIVE STARTER DRIVE, DG FAILED TO START			BROKEN SPRING DELCO PART #1945467	
G	BP1	017541	102077	CA02	C		A00	R U	U	T START TIME 21.8 SEC VS. 13.9 SEC			CHECKD VOLTAGE DROP ON START CABLES	
G	BR1	026668	126977	NM30	C		A09	F D T	#3 DG	START TIME 10.2 SEC VS 10			CARBON BUILDUP ON AIR VALVE STUCK SHUT	
G	BR2	016399	111176	NM30	C		A08	F U I	DG	FAILED OPER TEST-12.2 ON #2 AIR RECIEVER			CHECK VALVE RUSTED SHUT	
G	DR1	024652	030478	GM10	C		A10	D G T	D-1 B/O	FAILED TO START R/X IN HOT S/D MODE			SYNCHRO START SWITCH FAILED	
G	DR2	014913	052376	GM25	C		A00	U 1 T	UNIT 2/3	DG FAILED TO START			CAUSE UNKNOWN BUT POSSIBLE AIR START SYS	
G	DR2	017357	032277	GM25	C		A10	R D 1	I	UNIT 2/3 FAILED TO START			AIR START MOTOR PINION GEAR JAMMED	
G	DR2	017723	120277	GM25	C		A13	R I 1	T	UNIT 2 DG AIR RECIEVR LOW PRESS TERMINATED START			LOOSE WIRE AT TERMINAL 25A5	
G	DR2	017610	126377	GM25	C		A12	D 4 T	2/3 DG	FAILED TO ROLL OVER--LOW START AIR PRESSURE			RUPTURED REGULATOR DIAPHRAM	

STARTING SYSTEM

P	N	A	CONTROL	FAIL	DATE	F K	M	S	U	D	C	S	E	R	T	UNIT	DESCRIPTION	FAILURE MECHANISM
G	DR2	020242	010378	GM25	C	A13	R	F	I	UNIT 2	DG	FAILED TO START WEEKLY SURV TEST	LOOSE WIRE AT TERMINAL 25A5					
G	DR2	021048	030778	GM25	C	A00	S	D	B	T	OPERATR	SHOOK AIR START SOLENOID	UNIT 2/3 STARTED POSSIBLE WIRE DAMAGED DUE TO FREQ INSPEC					
G	DR2	022462	082478	GM25	C	A1C	R	U	4	T	2/3	UNIT	005 UNIT 2	FAILED TO START UN 1ST ATTEMP	PINION GEAR NOT ENGAGED ON AIR START MTR			
G	DR2	022569	092270	GM25	C	A00	R	U	B	I	UNIT	2/3	FAILED TO START; AIR	STR1 MTR5 ENGAGED	AIR-START SYS WILL BE MODIFIED			
G	DR2	023337	121678	GM25	C	A00	R	D	4	T	2/3	DG	AIR START	MOTORS DISENGAGED AFTER FEW SECS.	TD2 RELAY CLEANED; TD2 AND AIR VALVE 7			
G	EN1	044778	031976	FM25	C	A10	D	U	T	1A	DG	FAILED TO START DURING SURVEILLANCE	SOL OPER AIR VLV IN START SYS STUCK SHUT					
G	M01	016186	101076	GM25	C	A09	T	D	T	011	DG	FAILED TO START ON #2 STARTING SYSTEM	#2 START SYS AIR COMT COMP FOULED W MUST					
G	OC1	045042	060876	GM25	C	A00	U	2	T	DG	#2	FAILED TO START DURING OPERABILITY TEST	CONTROL SEQ FAULT - HOWEVER, SEQ CORRECT					
G	OC1	014120	011276	GM25	C	A10	D	B	T	UNIT	1	DG	FAILED TO START WHEN MODE 3M IN START MD	AIR START SOL VLV DIRTY-NOT OPEN FULLY				
G	VF1	019858	072677	FM30	C	A09	T	4	T	MAM	DIESEL	GENERATOR FAILED TO START	AIR START SOL VALVES BOUND CLSD BY DEBRIS					
*	BVA	044963	052076	GM25	C	A09	R	T	4	N	DG	01	FAILED TO START 3 TIMES	DG #2 STARTED OK	WATER ACCUMULATION IN AIR START SYSTEMS			
*	BV1	017666	042977	GM25	C	A09	K	T	4	N	DG	01	FAILED TO START REPETITIVE	MOISTURE IN STARTING AIR				
*	DC2	020981	031978	WD30	C	H10	U	4	T	2C0	DG	GASKETS	ON AIR LINE TO #5 CYL BLEW OUT	FRACURED AIR START CHECK VALVE				
*	DC2	022503	091178	WD30	C	A13	T	4	T	2A8	STARTED	FOR LOAD TEST	WAS TRIPPED OFF MANUALLY	PISTON BELT FOR AIR CHECK VALV LOOSE				
*	JF1	019055	081777	FM40	C	A10	B	D	U	T	DG	18	TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY	MAIN AIR VALVE FAILED TO SHUT; CAUSED OVR,P				
*	JF1	019062	082877	FM40	C	A1C	B	D	U	T	DG	18	TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY	MAIN AIR START VLV FAILED TO FULLY SHUT				
*	JF1	019359	091377	FM40	C	B10	B	D	D	N	D5L	GEN	18	EVENTUALLY TRPD ON OVSPO DURING MANUL START	MAIN AIR START VALVE FAILED TO FULLY SHUT			
*	JF1	019360	091677	FM40	C	B10	B	D	B	N	D5L	GEN	1-2A	EVENTUALLY TRPD ON OVSPO AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT			
*	JF1	020492	030278	FM40	C	A09	C	T	U	T	D5L	GEN	18	FAILED TO ATTAIN RATED SPEED	CORROSION PRODUCTS CLOGGED AIR START VLVs			
*	JF1	0	030878	FM25	C	A09	C	T	B	T	D5L	GEN	1C	FAILED TO START DURING TEST	CORROSION PRODUCTS CLOGGED AIR START VLVs			

STARTING SYSTEM

PLANT	CONTROL NO.	FAIL DATE	MFK C M	MODE	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
W JFL	021185	032378	FM40	C A02	DUN DSL GEN 1B FAILED TO COME UP TO SPEED PER TECH SP	TO COME UP TO SPEED PER TECH SP	FAILURE MECHANISM
4 YRI	617316	036177	GM02	C A10	D 4 T #1 EDG FAILED TO START DUE TO FAILED STARTER MOTOR	FAILED STARTER MOTOR	ARMATURE SHAFT BROKEN--REPLACED W SPARE
W ZIL	022116	080178	CB40	C A10	T 1 T 1B DIESEL GENERATOR FAILED TO START	GENERATOR FAILED TO START	AIR LEAK IN STARTING AIR PILOT VALVE
W ZIL	022115	090278	CB40	C A10	D 4 T 1B DIESEL GENERATOR FAILED TO START	GENERATOR FAILED TO START	STARTING AIR DIST BUSHING ROTATED IMPRUP

COOLING SYSTEM

EVENT	PLANT	CONTROL NO.	FAIL DATE	MFG	K W	SUBSYSTEM	FAILURE MODE	FAILURE MECHANISM	DISCOVERY	
										FAIL
C CC1	015587	072976	FM25	D	A02	S	D	4	N	#12 DG FAILED TO START AUTO FAILED ALSO FROM CONT RM JACKET COOLING H2O SYS AIRBOUND NOT VENTD
C CC1	018487	071377	FM25	C	B02	S	D	1	T	#11 DG TRIPPD ON LOW JACKET COOLNT PRESS WHEN SIAS SIGNAL REMOVED;OP SWITCH ISOLATED
C CC2	017985	060177	FM25	D	A12		D	1	T	#21 DG FAILED TO MEET START TIME CRITERIA SERVICE WATER INLET VALVE LEAKING EXCEJVL
C CC2	021491	080178	FM25	D	B10	S	D	4	T	#21 DG TRIPPD ON HI JACKET COOLNT TEMP SERV H2O SUPPLY VALV FAILD TO OPEN
C M12	016031	092276	FM25	D	B09	B	T	6	T	12U DG RECVD LOW CW FLD ALA-UNIT UNLOADED, SECURED EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	016626	120176	FM25	D	A09	B	T	6	T	13U DG STARTED, NO CW FLOW, SECURED EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	018972	081777	FM25	D	B09	B	T	6	T	12U DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	0189768	092077	FM25	D	B09	B	T	6	N	COOLING WTR LOW FLOW ALARM - 12U DIESEL GEN INSUF CL INJECTION FOR ADD MUSSEL CONTROL
C M12	021386	050878	FM25	D	B09	B	T	6	T	12U DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	023213	120578	FM25	D	B09	B	T	6	T	12U DG S/D DUE TO LOW COOLING WATER FLOW MUSSEL SHELLS IN THE HEAT EXCHANGER
G BP1	014417	032476	CA02	D	B09	R	T	8	T	DG TRIPPD ON HI COOLING WATER TEMP WATER PUMP SUCT SCREEN PLUGGD
G BP1	014894	051676	CA02	D	B09	R	T	6	N	DG TRIPPD ON HI COOLN WATER TEMP PUMP SHAFT SCORED INLET SCREEN PARTIALLY PLUGGED
G BP1	015449	080576	CA02	D	ACC	R	U	8	N	DG FAILED TO START WITHIN 15 SECONDS DURN WEEKLY POSSIBLE WATER JACKET HEATER FAILURE
G BP1	018102	051677	CA02	D	A00	R	T	4	T	H2O JACKET HEATER FAILURE--EDG TESTED; DID NOT MEE T TIME CRITERIA:EXCEEDED BY 12 SECONDS
G BP1	020580	020978	CA02	D	B12		T	4	T	DG TRIPPD ON HI WATER TEMP AFTR 25 MIN OF OPS AIR LEAKAGE ON PUMP COOLING WATER SHAFT
G DA1	014453	062276	FM25	D	B09	C	T	8	T	1G-31 DG TRIPPD ON HI JACKET TEMP-DECLARED INOPRSL ESW LOW FLOW DUE TO MUD IN STRAINER
G DR2	019728	112977	GM25	D	B12	C	D	D	T	2/3 DG S/D DUE TO COOL H2O PUMP TRIP 10MIN, LOADED WATER LEAKD GROUNDED PUMP STATOR
G DR2	021882	063078	GM25	D	B14	F	D	G	T	2/3 DG COOLING H2O PUMP TRIP ON HI AMPS; REPLACED OVERLOAD TRIP SET CLOSE TO RUNNING AMPS
G EN1	013644	061377	FM25	D	B14	I	D	4	T	1C DG TRIPPD RESTARTED SATISFACT LO JACKET CLNT LOW COOLNT PRESS SWITCH TO BE CALIBRATED
G EN1	018646	061877	FM25	D	B14	I	D	4	T	1C DG TRIPPD ON LO COOLNT JACKET PRESSURE POSSIBLE INCORRECT PRESSURE SETPOINTS

COOLING SYSTEM

PLANT CONTROL NO.	FAIL DATE	M K G M	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
081 018647	062577	FM25	D 14 T 0 4 N 1 C 0 G	TRIPPO ON LO COOLNT JACKET PRESS	OPER PRESSURE WAS ABOVE IMIP SETPOINT
082 018806	082677	FM30	U A01 S 0 1 T E1 0 G	FAILED TO START DUE TO HI JKT CLG MTR TEMP	OPER RESET TRIPPED PMP BUT NOT DIESEL TRIP
082 014414	101877	FM30	D A02 S 0 1 N E3 0 G	TRIPPED FOLLOWING MANUAL START	3 VALVES TO LGM PRESS 3M LEFT SHUT
081 020464	012478	FM30	D 809 T 4 T	DIESEL GENERATOR "A" TRIPPED ON HI JACKET CLNG TEMP	3-WAY VLV BLOCKED TO BYPASS CLNT ARND HX
081 019420	111777	AL25	D 813 B T 4 T 1 C	DIESEL DEVELOPED WATER JACKET LEAK	CRACK FOUND ON 3/8" PIPE NIPPLE
081 018053	080277	GM02	D 809 C T 0 T #1 0 G	OVERHEATED--PUNNING FOR APPROX 25 MINUTES	SLUDGE AND SCALE IN 67% OF RADIATOR TUBES
081 018054	080277	GM02	D 809 C T 0 T #3 0 G	OVERHEATED AFR 30 MIN. OF OPERATION	72% OF RADIATOR TUBES BLOCKED SLUDGE SCALE

SCAVENGING AIR SYSTEM

VEHICLE	CONTROL NO.	FAIL DATE	M K C W	FAILURE MODE	FAILURE MECHANISM
BARI	021003	032078	GM25	E 800	ENGINE FIRE DUE TO LUBE OIL GETTING INTO EXHAUST TURBOCHARGER BEING FAILED, CAUSING SEAL FAILURE
BARI	020768	052878	GM25	E 805	1-1 DG S/D DUE TO NOISY TURBOCHARGER DESIGN/FABRICN OR COMPNT FAILURE, REPLAC
BARI	021580	050978	GM25	E 806	GEN LOAD FLUCTUATING AIR INTAKE LD PRESS ALARM CAUSE UNKNOWN EXTENSIVE MAINT PERFORMED
SLI	017134	011877	GM30	E 804	R 76 T 1B DG MAN FOR 55 MIN THEM TRIPPED ON LOCKOUT TURBOCHARGER SHAFT AND OIL SEAL DAMAGED
SLI	019211	092677	GM30	E 804	R 76 T 1A DG SHUTDOWN WHEN SMOKE ISSUED FROM TURBOCHARGER FAILED TURBO CHARGER UNIT
ORE	019851	103077	GM25	E 806	Y 6 Y UNIT 2/3 UNLOADED TRIPPED ON LOW H2O PRESS RESTART TURBO-CHARGER CLUTCH/SHAFT BEARING
WEL	019471	092077	GM25	E 806	C 0 4 Y USL GEN 1A S/D WHEN SMOKE & FIRE OBSVD IN TURBOCHG C RBN BUILDUP DUE TO SHORT DURATION OPER
SAL	019924	122277	AL25	E 804	T 6 Y 1B DIESEL DECLARED IMP-TURBOCHGR & EXH EMP JT FLD CAUSE DETERMINED TO BE TURB BLADE FAILURE

ENGINE FRAME / INTERNALS

V E N	P L A N T	CONTROL NO.	FAIL DATE	M F K G W	S U B S Y S	F A I L M O D E	F A I L T Y P E	C L A S S	R E P A R Y	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
B	DB1	020273	010978	GM25	F	A09	T	4	T	DG	1-1 TRIPPED ON HI CRANKCASE PRESSURE	DIRTY CRANKCASE VENT OIL COLLECTOR
B	T12	021609	042578	FM30	F	B06	R	U	1	T	#8" DG TRIPPED ON HI CRNKSE PRESS AFTER 32 MIN RUN	NO ABNORMAL PARAMETERS WERE FOUND
B	T12	021607	052078	FM30	F	A05	C	D	G	T	DG B FAILED TO START	VERT SHFT BTW LP & LWR CRANKS FLD-IMP MTL
B	T12	021605	052378	FM30	F	B09	R	T	B	M	DG B TRIPPED UN HIGH CRANKCASE PRESS - 32 MIN RUN	PART PLUGD ORIFICE PLATE-TO-CRCKSE VAC EJC
C	CC1	018306	061777	FM25	F	B02	D	1	T	#11 DG STARTED; LATER DISCOVERD #6 CYLINDR RELIEF	VALVE VIBRATED LOOSE AND FELL OFF DG	
C	M12	014260D	022376	FM25	F	B04	B	T	G	N	DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR, (175-23)	UPPER RCG BEARING FAILURE - LACK OF LUBRI
C	M12	015106	060276	FM25	F	B09	B	T	1	T	DG 13U TRIPPED ON HI CRANKCASE PRESS - 11 MIN RUN	CRKCE AIR EDUCTOR FOUND DIRTY
C	M12	016755	121876	FM25	F	B06	D	G	T	DG 13U #3 UPPER PISTON CON ROD BRNG CAP SHEARED	CAPSCREWS FAILED - PROB DUE TO DRY STARTS	
C	M12	017020	011077	FM25	F	B13	S	D	G	T	DG 13U SHUTDOWN DUE TO HIGH VIBRATION	SKID MOUNT IN RESONANCE WITH ENG FREQUEN
G	GD1	023044	091278	CB40	F	A09	T	G	T	#2 DG TRIPPED APPROX 1 MIN AFTR REACH RATED SPEED	MAIN BEARING FAILD DUE TO LOW LUBE OIL	
G	DA1	013493	100776	FM25	F	A05	D	D	T	1G21 BROKEN LOWER VERT DRIVE COUPLNG HUB	HUB MADE OF WRONG MATERIAL	
G	DA1	021171	040578	FM25	F	A06	D	G	M	BEARING WIPED ON 4/13/77 NOT DUE TO MISALIGNMENT	LUBE OIL FILTER DRAIN VALVE WAS OPEN	
G	EN1	020031	081877	FM25	F	B00	H	U	G	T	DURING SURV TESTING, DG 1B GEN INBOARD BRNG FAILED	BEARING OVERHEATED - EXACT CAUSE UNKNOWN
G	VT1	014740	050876	FM30	F	A09	R	T	4	N	#8" DIESEL GENERATOR TRIPPED ON HI CRNKSE PRESS	CLOGGED CRNKSE EJ SUP ORIFICE OR EJ BODY
G	VT1	018323	062377	FM30	F	B13	R	T	4	T	#8" DG TRIPPED ON HIGH CRANKCASE PRESSURE	VIBRTN CAUSED HOSE CLMP ON AIR EJECT FAIL
G	VT1	020194	121977	FM30	F	B13	R	T	4	T	#8" DG TRIPPED ON HIGH CRANKCASE PRESSURE	ENG VIB CAUSED AIR EJECT HOSE TO LOOSEN
W	PR2	015735	091076	FM30	F	B02	D	4	T	D1 DG TRIPPED ON HIGH CRANKCASE PRESSURE	HOSE CLAPPS ON PIPE NOE CONN AFTER MAINT	
W	SU1	014669	041676	GM25	F	A01	R	U	G	T	#1 DIESEL GENERATOR DAMAGED ON START	#17 CYL FLOGGED - CAUSED BROKEN INTERNALS

GOVERNOR

W L N	P L A N T	C O N T R O L N O.	F A I L D A T E	M F G W	S U B S T S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	C O D E	D E S C R I P T I O N	FAILURE MODE	FAILURE MECHANISM
B	CR3	020221	122777	FM30	G	A09	R	D	B	T	3B DG	FAILED TO START--3RD OCCURANCE	SMALL PIECES OF INSULATION PREVNI GOVENOR
B	CR3	020278	010378	FM30	G	A09	R	D	B	T	3B DG	FAILED TO START --4TH OCCURANCE	FOREIGN MATTER IN SERVO BOOSTR
B	DB1	019816	122977	GM25	G	A14	D	G	N	D	DURIN	LOSP DG 1-1 STARTD AND TRIPPD CN OVERSPEED	IMPROPER SETTINGS OF HI SPEED AND OVERSPD
B	RS1	016056	120676	GM25	G	B10	D	B	T	DG	"M" TRIPPED OFF-LINE 25 MIN INTO TEST	SPEED CONT SW FLD CLOSED, SPD DECR TO TRIP	
C	FC4	015014	081576	GM25	G	B10	T	B	N	S	SMOKE COMING FROM DG-2 GOVENOR MOTOR ENCLOSURE	ARMATURE HAD OPEN WINDING	
C	M12	015583A	081676	FM25	G	A10	B	T	4	T	DG 12U	FAILED TO START	DRIED LEATHER WASHER IN BOOSTP SERVMOTOR
C	M12	015583B	081776	FM25	G	A10	B	T	4	T	DG 12U	FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVMOTOR
C	M12	015583C	082376	FM25	G	B10	B	T	4	T	DG 12U	TRIPPED OFF-LINE	DRIED LEATHER WASHER IN BOOSTR SERVMOTOR
C	M12	018423	081077	FM25	G	A01	D	N	DG	12U	FAILED TO RESTART CN DEMAND	GOVERNOR STILL IN "NO FUEL" FROM PREV S/D	
C	MY1	020733	021878	GM25	G	A09	T	B	T	DG-1A	FAILED TO RESPOND DURING TEST RUN FOR TRAIING	DIRTY CONTACT CN SPEED CONTROL PC BC-20	
G	BF1	014162	011476	GM30	G	A12	T	I	F	FAILED TO RESPOND TO ELEC. GOVNR SIGNALS	DG #D	OIL DRAIND FROM HYDRAULIC ACTUATOR	
G	BF1	016261	110376	GM30	G	B09	C	T	4	T	DG	ERRATIC SPEED BEHAVIOR UNDER LOAD	DIRTY OIL IN GOVERNOR
G	BP1	016364	102876	CA02	G	A00	R	U	U	T	DG	FAILED TO START WITHIN 15 SEC	POSSIBLE FUEL GOVERNOR CONTROL PROBLEM
G	BP1	016400	110476	CA02	G	A00	R	U	U	T	START TIME 2.2 SEC SLOWER THAN REQUIRED	POSSIBLE FUEL GOVERNOR PROBLEM	
G	BP1	016547	120276	CA02	G	A00	R	U	U	T	FAILED TO MEET 12 SEC START TIME DURING AUTO TEST	FUEL GOVERNOR REPLACED ON 12/19/76	
G	BP1	016913	122076	CA02	G	A04	R	U	U	T	START TIME EXCEEDED CRITERIA BY 4 SEC	GOVERNOR LUBE & FUEL SYS UNDER INVESTIGYN	
G	BP1	016910	010377	CA02	G	A00	R	U	U	T	FAILED TO START IN AUTO TEST	CAUSE UNKNOWN LUBE OIL RETENTION IN GOV. 2	
G	BP1	020298	032477	CA02	G	A00	R	U	U	T	EDG STARTING TIME EXCEEDED 12 SEC. BY +8 SEC.	GOVERNOR LUBE SYS MODIFIED CN 1/10/77	
G	BK1	019391	101177	NM30	G	B05	D	B	T	#2 DG	UNABLE TO MAINTAIN LOAD CYCLING 500KW	SHORTED LEADS TO GOVERNOR; INCORRECT ASMB	
G	BR2	016023	122976	NM30	G	B10	T	B	T	#2 DG	FAILD OPERABILITY TEST --LOSS OF SPEED CONT.	CLUTCH ADJUSTED AND STATOL. VOLTMTR REPLAC	

GOVERNOR

PLANT	CONTROL NO.	FAIL DATE	MFK DATE	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
G DAL	017963	051277	FM25	G 806	S D I T	16-31 DG WOULD NOT REACH FULL LOADING ONLY 2500 KW SPEED SETTING ADJUSTMENT NOT RESET
G DR2	018263	063077	GM25	G A00	R D I T	2/3 DG TRIPPO ON OVERSPEED DURING 2 ATTEMPTS
G DR2	018444	071277	GM25	G A01	R D I T	U 2/3 D/G TRIPPO ON OVERSPEED---OCCURD ALSO 6/30/77
G DR2	020855	030878	GM25	G A14	S U B T	ENGINE OVERSHOOT AT 1010 RPM WHILE DS SET AT 1020
G DR2	021538	052278	GM25	G A02	D H T U-2	DG TRIPPO 4 TIMES ON OVERSPEED; P/X IN S/D MODE
G DR3	014439	030376	GM25	G A13	R T 4 T	DG COULD NOT BE LOADED FROM CONTROL ROOM
G DR3	016487	100976	GM25	G A13	R T 4 T	LOSS OF CONTROL ROOM SPEED CONTROL
G DR3	018455	110576	GM25	G B10	R T 8 T	LOST SPEED CONTROL FROM CONTROL ROOM
G DR3	019722	112277	GM25	G A16	R D B T	3 DG STARTED/LOADED-OVERLOAD ALARM-DG TRIPPO
G DR3	019727	112977	GM25	G B10	R O B N	3 DG TRIPPO 30 MIN AFTER START AND LOADING
G EN1	016665	091176	FM25	G A10	R D I T	1A DG FAILED TO START - SURV TEST - OCCURRED PREV
G EN1	020214	112577	FM25	G A08	T 8 T 1A	DG FAILED TO START; STUCK GOVNR BOOSTER SERVO MOTOR AIR PISTON WAS CORRUDED
G EN2	022751A	102878	FM25	G A16	R D B T	"CM" DIESEL FAILED TO REACH 250RPM IN 7 SEC.
G EN2	022751B	103178	FM25	G A10	R T 8 M	"CM" DIESEL FAILED TO REACH 250RPM IN 7 SEC.
G FP1	023104	120578	GM25	G A02	S D 4 T	"MADG" TRIPPO WHEN BEING PARALLELED
G P82	022964	083078	FM30	G A10	T 1 T E-3	DG START TIME DID NOT MEET TS REQUIREMENT
G P82	023349A	122178	FM30	G A10	D 1 T E3	DG START TIME 13 SEC. VS. REQUIRED 16 SEC.
G P82	023349B	122178	FM30	G A00	U 1 T E2	DG START TIME 11 SEC. VS. 10 SEC
* DC2	022026	072878	MO30	G B10	K T 4 T	#2 AB DG OVERSPEED WHL UNLOADG PREVIOUS OCCURRENCE
W IP3	015733	083076	AL18	G P02	T D 1 T	EDG 31 BEGAN CYCLING BETWEEN 96 AND 63 CPS

POSSIBLE OUT-OF-ADJUST GOVERNOR COMPENSATION
 PROBABLE OUT-OF-ADJUST GOVERNOR COMPENSATION
 HI OVERSHOOT BY OUT-OF-ADJUST GOVERNOR COMP
 GOVERNOR SETTING FOUND SET TOO HIGH
 GOVERNOR CONTROL WIRE VIBRATED FREE FROM LOG
 LOG WIRE ON GOVERNOR CONTROL CIRCUIT
 FAILED OVERTRAVEL LIMIT SWITCH ON GOVERNOR
 BAD CAPACITOR IN SPEED SENSING CIRCUIT
 SHORTED CAPACITOR ON SPEED SENSING BOARD
 LOW OIL LEVEL IN GOVERNOR
 STICKING GOVERNOR BOOSTER SERVO
 FAULTY ELECTRONIC SPEED SWITCH SIGNAL
 MISADJUSTMENT OF GOVERNOR
 LEAKY CHECK VALVE IN AIR BOOSTER RELAY HYD ST
 E3 DG GOVERNOR REPLACED ON 12/28/78
 POSSIBLE GOVERNOR PROBLEMS
 MOPN LINKAGE CAP SCREW BROKE IN GOVERNOR
 GOV OIL DRAIN VALVE NOT SHUT TIGHTLY

GOVERNOR

PLANT	CONTROL NO.	FAIL DATE	FK GW	SUBSYSTEM	FAILURE MODE	FAILURE MECHANISM
IP3	016135	092476	AL18	G 802	T 0 4 T EDG 31 OUTPUT FREQ INC TO 62 HZ, COULD NOT CONT ELE AIR IN GOV OIL LINES FROM PREVIOUS REPAIR	SPEED SWITCH FAILED - 120V VS 130V RATING
JF1	019308	100277	FM40	G A10	D 8 T DSL GEN 1-2A FAILED TO START DURING TEST	BLOWN FUSES FOR MOP AND MOT
JF1	022374	082778	FM25	G A10	R 8 N 2C DG WOULD NOT RESPOND TO AUTO OR MAN SPEED CHG	BLOWN FUSES FOR MOP, CAUSED BY FAIL DIODES
JF1	022373	090278	FM40	G A10	R 8 M 1-2A DG WOULD NOT RESPOND TO AUTO VLTG OR SPD CHGS	BLOWN FUSES FOR MOP, CAUSED BY FAIL DIODES
JF1	022630	091778	FM40	G A10	U 4 T 1B DG FREQ COULD NOT BE INCR ABOVE 58.5 HZ	CPLNG BET DC MTR AND GOV POS POT WAS LOOS
K11	020095	122177	GM25	G 802	S 0 4 T D/G 1B WOULD NOT PICK UP MORE THAN 1500 KW LOAD	SYNCHRO MOTOR LIMIT SWCHS ADJUSTED IMPROP
PH1	018342	061777	FM30	G 810	T 8 T D2 DG FAILED TO RESPOND TO LOAD CHANGE SIGNALS	LINK LEVER KEY MISSING, CAPSCREWS LOOSE
RU2	021313	041678	FM25	G 813	T 4 T EDG LOAD FAILED TO INCREASE ABOVE 900KW	CUMM BRUSH VIBRATED OUT OF GOV SPD CHGR
IM1	018447	062277	GM40	G 810	T 4 N WEST DG FAILED TO ASSUME MIN REQUIRED LOAD	BRUSH FALLEN OUT OF DC GOV DRIVE MOTOR
Z11	0203408	011678	C840	G 810	T 4 T DG "GM" STARTED & LOADED, BUT DECLARED IMPERABLE	LO CONTROL AIR PRESS-TRIP VLV "CM" RING LK
Z12	017808	042777	C810	G 810	M 0 1 T GOVERNOR SPEED CONTROL FAILED ON 28 DIESEL GEN	GOV SPD CCNT GEAR JAMMED AGAINST HI SPD STU
Z12	020260	010978	C840	G 810	R 0 1 T 28 DG POWER OUTPUT OVLD - COULD NOT LOWER MANUALLY	GOV SYNCH IND GR JAMMED ON HI SPD STOP

EXHAUST SYSTEM

PLANT	CONTROL NO.	FAIL DATE	MFR	DESCRIPTION	FAILURE MODE
G P11	015960	092276	AL25 H 804 B T D T	SMALL FIRE NEAR EXHAUST MAN-TURBOCHGR FLANGE	FAILURE MECHANISM 1621 LEAKY FLANGE GASKET
G P11	016308	111776	AL25 H 804 B T D T	"M" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLONS CONNECTOR SEPARATED
G P11	016308	111776	AL25 H 804 B T D T	"M" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLONS CONNECTOR SEPARATED

SHUTDOWN SYSTEM

PLANT CONTROL UNIT	CONTROL NO.	FAIL DATE	M K G W S E	DESCRIPTION	FAILURE MECHANISM
B	CR3	018565	072677	FM30	1 A06 S D I T M38M DG FAILED TO START DIESEL TRIPS WERE NOT RESET REVISED PROCEDURES TO RESET TRIPS
C	M12	019255	092477	FM25	1 B14 S T B I 12U DG APPEARED TO TRIP ON GEN OVERCURRENT MICRO SW GUT OF ADJ ON DG OVSPO TRIP MECH
C	S14	017441	030377	GM30	1 A01 S D I T 1A DIESEL GENERATOR FAILED TO START OPER FAILED TO RESET OVERSPEED TRIP
G	0R2	010443	102076	GM25	1 A14 S F D T UNIT 2 DG FAILED TO START TWICE MALFUNCT S/D SOLENOID PLUNGER OUT OF ADJUSTMENT
G	0R2	019732	111677	GM25	1 A00 S D I T AUTO-START SIGNAL SENT TO UNIT 2/3 DURING CORE SPRY RESET START FAILURE RELAY & DIESEL STARTD
G	FPI	010496	111776	GM25	1 A10 R D B T M8M EDG FAILED TO START DURING SURVEILLANCE TEST GEN TACH RELAY DID NOT OPERATE, DEF CNVTR
G	FPI	017725	042077	GM25	1 A10 R D B T DURING ROUTINE SURV TEST, EDG FAILED TO START TACHMETER RELAY FAILED
G	P42	018887	082677	FM30	1 A06 S D 4 T E4 DG TRIPPED ON OVERSPEED OVSPO TRIP SET BELOW DESIGN VALUE
M	P11	018417	062077	GM25	1 A14 S F 4 T 30 DIESEL GENERATOR FAILED TO START - LOGIC FAILURE SPEED SENSING ASSY SETPOINT DRIFTED
M	Z12	017609	050677	CR40	1 B13 C T 4 T DIESEL GENERATOR 2A TRIPPED FROM FULL LOAD LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
M	Z12	019780	111777	CR40	1 B13 C T 4 T M0M DIESEL GENERATOR TRIPPED OFF-LINE LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE

OUTPUT BREAKER

UNIT	CONTROL NO.	FAIL DATE	FAIL G.W.	FAILURE MODE	FAILURE MECHANISM
B	014296	022176	FR30	J A06 S D I T	"18" DG OUTPUT BREAKER FAILED TO CLOSE
C	015284	080776	FR25	J A02 S D G T	11 DG FAIL TO SENSE "AT VOLTAGE" COND.--OUTPUT BRK. WILL NOT CLOSE--COLD SOLDER CONN TO CRA
C	020426	011078	FR25	J B10	I T T #21 DG TRIPPED AFR 29 MIN. DUE TO GEN FAULT
C	022532	090478	GM30	J A10	I B T "M" DG OUTPUT BREAKER WOULD NOT CLOSE REMOTELY
G	018742	030577	CA02	J A04 S D G T	TESTED EDG WITH 2A-28 BRK RACK OUT; AUTO TRANSR AND MAN TRANSR FAILED TO CLOSE OUTPUT BRK
G	019448	121677	NM30	J B00	D D T SMOKE COMING FROM 320 RELAY AND 860B RELAY FLAMING REPLACED AND CALIBRATED RELAYS
G	014136	010276	NM30	J A10	D 4 N #1 DG STARTED BUT OUTPUT BRK FAILED TO CLOSE TO E-1 BROKEN LUG WIRE DUE TO STRESS
G	016742	111076	CR40	J A03 S D B T	EG-1 OUTPUT BRK FAILED TO CLOSE--BLOWN FUSE 59RELAY DISCONNECTED ONLY ONE WIRE ON 11/8/76
G	017756	051077	FM25	J A10 S D B T	1G-21 DG OUTPUT BRK FAILED TO CLOSE
G	014461	120477	GM25	J A00	U T U2 DG OUTPUT BRK FAILED TO CLOSE--NO APPARENT CAUSE 3 SUBSEGT TESTS WERE SUCCESSFUL
G	020516	021578	GM25	J B10	I T T "M" EDG TRIPPED DURING SURVEILLANCE TEST
G	015413	090376	GM25	J A00	U I T #1 DG OUTPUT BREAKER FAILED TO CLOSE
G	017348	031477	GM25	J A04 B D 4 T	#2 DG OUTPUT BREAKER FAILED TO CLOSE
G	017021	041177	GM25	J A04 B D 4 T	#1 DG OUTPUT BREAKER FAILED TO CLOSE--DIRTY CONTACT DESIGN CHANGE REQUEST FOR SEALED RELAYS
G	017693	042677	GM25	J A04 B D 4 T	#1 DG OUTPUT BRK. FAILED TO CLOSE--DESIGN REQUESTED DIRTY CONTACTS ON NFD(AND FELD) RELAY
G	017827	050977	GM25	J A04 R D 4 T	#2 DG OUTPUT BRK. FAILED TO CLOSE--REPETITIVE STICKING RELAY(MSR2) IN MANUAL START CRT.
G	016468	060377	GM25	J A04 R D 1 T	#2 DG OUTPUT BRK. FAILED TO CLOSE ON FIRST ATTEMPT CLOSED ON NEXT ATTEMPT; SLICKY NELD4 RELAY
G	020437	011178	GM25	J A04 R D 4 T	#2 DG OUTPUT BRK. FAILED TO CLOSE IN EXERCISE MODE NO CAUSE COULD BE DETERMINED
G	0223928	090578	GM25	J A00 R D 1 T	#1 DG OUTPUT BRK. FAILED TO CLOSE TO CLOSE: #2 DG DGS
G	0223948	092278	GM25	J A00 R D 1 T	#1 DG OUTPUT BRK. FAILED TO CLOSE USING CONT. SWITCH CLOSED MANUALLY 1 HOUR RUN AT FULL LO
G	022235	082278	FM40	J A10 S D B N	OUTPUT BRK FOR DG 18 FAILED TO CLOSE AUTOMATICALLY OPER MECH FOR AUX SWITCHS OUT OF ALIGNMT
G	022987	100378	FM25	J A04 S D 1 T	1C DG OUTPUT BRK FAILED TO CLOSE ON START JUMPER FCP UNIT1/UNIT2 SEPAR. INCRCTLY POS
G	017446	020977	GM25	J A10 R D B T	3D EDG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST DIRTY IN LWR BRNG OF DVCRT RELAY IMG D13C
G	021445	051778	GM25	J A10 R D D T	4D EDG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST WEST 062A143MO1 LATCH-CHKNG SW DEFECTIVE
G	022450	081678	AL18	J A10	I B T B EDG OUTPUT BREAKER WOULD NOT CLOSE BAD CONN AT CONT PWR FUSE BLOCK SLUGS

EXCITER / VOLTAGE REGULATOR

V E N	P L A N N O.	J/NIRGL NO.	FAIL DATE	M F K G W	S U B S Y S	F A I L M O D E	D I S C O V E R Y	C L A S S	R E P A R Y	FAILURE MODE	FAILURE MECHANISM
B DB1	021852	060478	GM25	K	A10	D 4 T	1-1 DG	FAILED TO OPERATE WITH PROPER FREQ/VOLT		FAILED PRIMARY POTENTIAL FUSE FOR DG 1-1	
C CC1	019592	101077	FM25	K	A13	F 8 T	#12 DG	FAILED TO REACH VOLTAGE WITHIN 10 SEC.		2 LOOSE FUSE HLDS IN EXCITATION CIRCUIT	
C FC1	021642	061978	GM25	K	A10	R D 1 T	DG-1	FAILED TO REACH RATED TERM VLTG ON STARTUP		BLOWN FUSE IN GEN FIELD CIRCUIT	
C FC1	021799	071278	GM25	K	B10	R D 8 T	DG-1	FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN		3 EXCITER SUBCOMPONENT FAILURES (COINCIDENT)	
C FC1	022249	080978	GM25	K	B10	K D 8 T	DG-1	FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN		REFER VOLTAGE ZENER DIODE OUTPUT DRIFTED	
C M12	019929	110977	FM25	K	A01	S D 1 T	DG 130	TRIPPED WHILE PARALLELING WITH 4160V BUS		IMPROPER VOLTAGE SETTING PRIOR TO PARALL	
G BF3	019133	091977	GM30	K	A10	D 1 T	30 DG	TRIPPED ON OVERSPEED ; GOVERNOR INOPERABLE		10 FUSE OPEN DISENABLING FIELD CIRCUIT	
G BR2	020612	021378	NM30	K	A01	S D 1 N	FOLLOWING SCRAM ON UNIT 1 ; #1 DG LO RELAY WOULDNT		RESET ; LOSS OF EXCITATION RELAY NOT RESET		
G CD1	016560	110776	CB40	K	B08	F D T	DG-2	LOST ELECT GOVERNOR CONTROL AND VOLTAGE		POT. TRANSFORMER FUSE CONTACTS OXIDIZED	
G DM2	016166	093076	GM25	K	B09	T D T	2/3 DG	OUTPUT ERRATIC AFTR CONTROL PLACED IN "STOP"		SHORTED SELENIUM RECTIFIER DUE TO DIRT	
G DR3	017509	032277	GM25	K	A10	D G M	GEN FIELD	FAILED TO FLASH		INTERMITTENT CAPACITOR SHORT IN FLASH CIRC	
G EN1	015568	080576	FM25	K	A06	S D 1 T	DG 1A	TRIPPED DUE TO LOSS OF EXCITATION DRNG SYNCH		DEFECTIVE PROCEDURE - PARALLELED OUT OF SYN	
G EN1	018839	091277	FM25	K	B10	D 8 T	1A DG	LOST MANUAL VOLTAGE CONTROL		MAN REG MTR OPER AFMR PWR SUP DIODES FAIL	
G EN1	020113	111977	FM25	K	B02	S D 4 T	1B DG	OUTPUT VOLTAGE TOO HIGH - 1B DG SHUTDOWN		IMPROPER ADJUSTMENT OF AUTO REG SETPOINT	
G OC1	014447	030376	GM25	K	A10	D 8 T	DG 2	STARTED BUT DID NOT DEV SUFF VLTG TO LOAD		WESTINGHOUSE FFCD RELAY FLD TO ENRGZ FLD FLASH	
G OC1	023119	113078	GM25	K	A10	D 8 T	#10G	STARTED BUT GEN FAILED TO EXCITE--AUTO ACT.TES		UNUSED TARGET MECH LINKAGE IN RELAY BINDN	
G P11	022125	080278	AL25	K	B01	D 8 T	8 DG	BECAME INOPERABLE AFTER ONE HOUR RUN		OPERATOR CAUSED DIODE FAILURES IN VLT REG	
G QC1	018112	042577	GM25	K	A10	D 6 T	WHILE TESTING THE DG, THE FIELD FAILED TO FLASH		CAPACITOR ACROSS VLTG SLP RELAY DEFECTIVE		
G QC1	019494	112877	GM25	K	A10	D 4 M	1/2 DG	WOULD NOT START SUCCESSFULLY, FIELD BKR DEFECT		FAILED DIODE IN FLD BKR INTLK CIRCUIT	
# BV1	018628	071777	GM25	K	A10	R F 8 T	#2 DG	STARTED AND CLOSED ONTO BUS; OUTPUT VOLTS =0.		LOOSE CONNECTIONS IN AUTO FIELD FLASH CKT	
# BV1	022137	072878	GM25	K	A10	R D 1 N	#2 DG	FAILED TO FLASH DURING SI AND LOSEP EVENT		STICKY FIELD FLASH CUTOFF RELAY; AUTO CKT.	
# DC1	016647	120976	W030	K	A10	D 1 T	C-0 DG	TRIPPED ON OVERSPEED--BLOWN FUSE ON INVERTER		FAILED SILICONE RECTIFIER IN DG INVERTER	
# Z11	020255	010378	CB40	K	B10	R T U T	1B DG	OUTPUT VOLTAGE PEGGED HIGH--COULD NOT LOWER		PC BOARD FAILURE IN THE VOLTAGE REGULATOR	
# Z12	020258	010678	CB40	K	B10	M T 8 T	2A DG	OUTPUT VOLTAGE INCREASED AND COULD NOT LOWER		BURNED CONTACT IN THE VOLTAGE REGULATOR	
# Z12	021544	051778	CB40	K	B14	T T 8 T	2A DG	OUTPUT VOLTAGE CYCLED - COULD NOT CONTROL		DRIFT OF VLTGE REGULATOR STABILITY CIRCUIT	

GENERATOR

PLANT CONTROL UNIT	FAIL DATE	EXPLANATION	FAILURE MODE	FAILURE MECHANISM
CC1 021060	041076	FR25 L AGC	UNIT #12 DG OVERSPED & TRIPPED	CAUSE NOT DETERMINED
PH2 020690	121977	FR30 L 400	UNIT #11 DG TRIPPED ON "A" PHASE DIFF AFTER PARALLELING	CAUSE COULD NOT BE DETERMD AFTER EATV T-1
9C1 019100	082477	GR29 L A13	T 4 T UNIT 1 DG STARTED AND RAN, BUT NO VLTG, SYNCH, FREQ	FREQ GEN TACH SET SCREWS VIBRATED LOOSE
8V1 017683	022477	GR29 L 805	D 4 T DG OUTPUT BREAKER TRIPPED; INTERNAL LOSS OF FIELD	TRIP NOT DISCONNECTED DURING ACCEPT. TEST
IP3 016286	102176	AL18 L 810 S D 6 T	UNABLE TO CONTROL SPEED OF MO 31 D6	UNIT/PARA RELAY OPER INTERMITT-DEFECTV CONN

APPENDIX K

DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY TYPE OF EVENT

CODES USED IN LER ONE-LINE DESCRIPTIONS

REPAIR TIME
 CODE DESCRIPTION
 1 0-4 HOURS
 2 4-8 HOURS
 3 8-24 HOURS
 4 GREATER THAN 24 HOURS
 5 UNKNOWN / NOT APPLICABLE

FAILURE MODE
 CODE DESCRIPTION
 A DOES NOT START
 B DOES NOT CONTINUE TO RUN
 U UNAVAILABLE / NONFAILURE

FAILURE CLASSIFICATION
 CODE DESCRIPTION
 B DEMAND
 V TIME
 U UNKNOWN

METHOD OF DISCOVERY

CODE DESCRIPTION
 KN DURING MAINTENANCE OPERATIONS
 P DURING NORMAL OPERATIONS
 U DURING TESTING
 UNKNOWN

FAILURE MECHANISM

CODE DESCRIPTION
 01 UNKNOWN
 02 PERSONNEL OPERATION
 03 PERSONNEL MAINTENANCE
 04 PERSONNEL TESTING
 05 PERSONNEL WORK / CONSTRUCTION / QUALITY CONTROL
 06 PERSONNEL CONNECTIONS
 07 PERSONNEL CONNECTIONS (ELECTRICAL)
 08 PERSONNEL CONNECTIONS (MECHANICAL)
 09 PERSONNEL CONNECTIONS (THERMAL)
 10 PERSONNEL CONNECTIONS (FLUID)
 11 PERSONNEL CONNECTIONS (TEMPERATURE)
 12 PERSONNEL CONNECTIONS (AIR LEAKAGE)
 13 PERSONNEL CONNECTIONS (WATER / AIR LEAKAGE)
 14 PERSONNEL CONNECTIONS (CALIBRATION)

SUB-SYSTEM

CODE DESCRIPTION
 A FUEL SYSTEM
 B OIL SYSTEM
 C AIR SYSTEM
 D ELECTRICAL SYSTEM
 E INSTRUMENTS
 F EXHAUST SYSTEM
 G SUPERCHARGER SYSTEM
 H TURBOCHARGER SYSTEM
 I VOLTAGE REGULATOR
 J GENERATOR
 K UNKNOWN

TYPE OF EVENT

CODE DESCRIPTION
 B RECURRING COMMON CAUSE
 C COMMON CAUSE
 D RECURRING FAULTS
 E RECURRING COMMAND FAULTS

OG MANUFACTURER

CODE DESCRIPTION
 AL ALCO
 CA CATERPILLAR
 CB CUMMINS
 CC CUMMINS-DESSNER
 CD DEERE
 CE DEERE-VALVE
 CF FORD
 CG GENERAL MOTORS
 CH GENERAL MOTORS
 CI INTERNATIONAL
 CJ INTERNATIONAL

KW RATING

CODE DESCRIPTION
 02 200-400 KW
 03 400-1000 KW
 04 1000-1500 KW
 05 1500-2000 KW
 06 2000-3000 KW
 07 3000-4000 KW

RECURRING COMMON CAUSE

V E N I	P L A N I	CONTROL NO.	FAIL DATE	M F K G W	S U B / S Y S	F A I L M U D C P P E	F A I L M U D C P P E	C L A S S I F I C A T I O N	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
C M12	014260A	021776	FM25	A	A09	B	T	1	N	DG 12U FAILED TO START - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRKCSV VENT
C M12	014260B	021876	FM25	A	B09	B	T	1	N	DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRKCSV VENT
C M12	014260C	022076	FM25	A	B09	B	T	1	N	DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRKCSV VENT
C M12	014260D	022376	FM25	F	B04	B	F	G	N	DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	UPPER ROD BEARING FAILURE - LACK OF LUBRI
C M12	015106	060276	FM25	F	B09	B	T	1	F	DG 13U TRIPPED ON HI CRANKCASE PRESS - 11 MIN RUN	CRKCSV AIR EDUCTOR FOUND DIRTY
C M12	015583A	081676	FM25	G	A10	B	F	4	T	DG 12U FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C M12	015583B	081776	FM25	G	A10	B	F	4	T	DG 12U FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C M12	015583C	082376	FM25	G	B10	B	F	4	T	DG 12U TRIPPED OFF-LINE	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C M12	016036	091976	FM25	B	B12	B	D	4	N	12U DG HAD TO BE SECURED AND DECLARED INOPERABLE	EXCSV LEAKAGE OF LUBE OIL FILTER GASKET
C M12	016031	092276	FM25	D	B09	B	F	G	T	12U DG RECVD LOW CW FLOW ALARM, UNLOADED, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	016626	120176	FM25	D	A09	B	F	G	T	13U DG STARTED, NO CW FLOW, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	018472	081777	FM25	D	B09	B	F	G	T	12U DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	018476B	092077	FM25	D	B09	B	F	G	N	COOLING WTR LOW FLOW ALARM - 12U DIESEL GEN	INSUF CL INJECTION FOR ADD MUSSEL CONTROL
C M12	021186	050878	FM25	U	B09	B	F	G	T	12U DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	023213	120578	FM25	D	B09	B	F	G	T	12U DG S/D DUE TO LOW COOLING WATER FLOW	MUSSEL SHELLS IN THE HEAT EXCHANGER
G P11	015966	092276	AL25	H	B04	B	F	D	T	"A" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
G P11	016368	111776	AL25	H	B04	B	F	D	T	"B" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
W BV1	017348	031477	GM25	J	A04	B	D	4	T	#2 DG OUTPUT BREAKER FAILED TO CLOSE	DIRTY CONTACTS ON BKR CONT SWITCH
W BV1	017621	041177	GM25	J	A04	B	D	4	T	#1 DG OUTPUT BREAKER FAILED TO CLOSE--DIRTY CONTACT	DESIGN CHANGE REQUEST FOR SEALED RELAY
W BV1	017693	042677	GM25	J	A04	B	D	4	T	#1 DG OUTPUT BKR. FAILED TO CLOSE--DESIGN REQUESTED	DIRTY CONTACTS ON NFLOAING FIELD1 RELAY
W JF1	019055	081777	FM40	C	A10	B	D	U	F	DG 1B TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY	MAIN AIR VALVE FAILED TO SHUT, CAUSED OVRSP
W JF1	019062	082877	FM40	C	A10	B	D	U	F	DG 1B TRIPPED ON OVRSPD DURING MANUAL START	MAIN AIR START VLV FAILED TO FULLY SHUT
W JF1	019359	091377	FM40	C	B10	B	D	D	N	DSL GEN 1B EVENTUALLY TRPD ON OVRSPD AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
W JF1	019360	091677	FM40	C	B10	B	D	D	N	DSL GEN 1-2A EVENTUALLY TRPD ON OVRSPD AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
W SA1	019920	111777	AL25	D	B13	B	F	4	T	1C DIESEL DEVELOPED WATER JACKET LEAK	CRACK FOUND ON 3/8" PIPE NIPPLE
W Z12	019714	111077	CB40	B	B12	B	D	G	T	"U" DIESEL GEN TRIPPED ON LOW LUBE OIL PRESSURE	CAVITATION OF LD PUMP - WATER IN LUBE OIL

COMMON CAUSE

VEN	UNIT	CONTROL NO.	FAIL DATE	FK G M	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM	
B	112	021607	052678	FM30	F	05	08	VERT SHFT BTM UP & LWR CRANKS FLO-IMP MTL
C	001	018468	071177	FM25	B	02	04	0-RING SEAL ON STRNR NOT GLUED PROPERLY
C	012	015906	090176	FM25	B	01	02	LUBE & FUEL OIL ACCUM UNDER MANIF INSULAT
G	014	040261	110376	GM30	G	00	01	DIRTY OIL IN GOVERNOR
G	015	016054	010477	NM30	B	04	05	LOW SETPOINT FOR PRE-FILTER HEATER, JACKET
G	016	016054	010477	NM30	B	04	05	L.G.PRESS SWITCH TIME DELAY INCORRECT
G	017	015461	061176	NM30	A	02	03	LOW FLOW DUE TO MUD IN STRAINER
G	018	014953	062276	FM25	D	00	01	WINTER WEATHER
G	019	020408	012776	GM10	M	01	02	INSTALLED & ROOM WINTERIZED
G	021	024468	012978	GM10	M	01	02	WATER LEAKED GROUND PUMP STATOR
G	042	019728	112977	GM25	D	01	02	WATER IN OIL VAPORIZED - LEAKY OIL DRUMS
G	082	020685	022878	FM30	B	01	02	CORROSION PRODUCTS CLOGGED AIR START VLV
M	J11	020992	030278	FM40	C	00	01	CORROSION PRODUCTS CLOGGED AIR START VLV
M	J11	020996	030878	FM25	C	00	01	CARBON BLEEDUP DUE TO SHORT DURATION OPER
M	K11	019171	092077	GM25	E	00	01	FUEL BINDING FUEL RACK LNKG - LACK OF LUBRICAT
M	S41	018799A	073677	AL25	A	01	02	FUEL BINDING FUEL RACK LNKG - LACK OF LUBRICAT
M	S41	048799B	073677	AL25	A	01	02	FUEL BINDING FUEL RACK LNKG - LACK OF LUBRICAT
M	Y01	016653	080277	GM02	D	00	01	SLUDGE AND SCALE IN 67% OF RADIATOR TUBES
M	Y01	018224	080277	GM02	D	00	01	72% OF RADIATOR TUBES BLOCKED SLUDGE
M	Z11	022646	091478	CR40	B	00	01	RAG IN OIL STRAINER CAUSED LO OIL PRESS T
M	Z12	017809	050677	CR40	I	01	02	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
M	Z12	019780	111777	CR40	I	01	02	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE

RECURRING

VENUE	CONTROL NO.	FAIL DATE	F.K. G.M.	FAILURE MODE	FAILURE MECHANISM
B CW3	624221	122777	FM30	G 409 R 08 T 38	DG FAILED TO START--3RD OCCURRENCE
B CW3	020278	010378	FM30	G 409 R 08 T 38	DG FAILED TO START --4TH OCCURRENCE
B CW3	023166	111778	FM30	M 400 R 01 T 06	DG FAILED TO FAST START ON TWO CONSEC. ATTEMPTS
B CW3	023166	082477	GM25	M 400 R 01 T 06	DIESEL GENERATOR "B" FAILED TO START
B CW3	021609	042578	FM30	F 800 R 01 T 08	DG TRIPPED ON HI CRNKSE PRESS AFTER 32 MIN RUN
B CW3	021605	052378	FM30	F 800 R 01 T 08	DG TRIPPED ON HIGH CRANKCASE PRESS - 32 MIN RUN
C CC1	016405	102576	FM25	M 800 R 01 T 06	DG DUE TO DG VENT FAN STOPPED-BLOWN FUSE
C CC1	017213	111876	FM25	M 800 R 01 T 06	DG DUE TO ITS VENT FAN NOT STARTING
C CC1	017822	051577	FM25	M 800 R 01 T 06	DG FAN FAILED TO START WHEN GEN RECEIVED SIGNAL
C CC1	023380	121878	FM25	M 800 R 01 T 06	DG SHUTDOWN DUE TO ROOM VENT-FAN FAIL TO START
C CC1	017457	031777	FM25	M 800 R 01 T 06	DG VENT FAN FAIL TO START ON SIAS SIGNAL
C FC1	017628	040677	GM25	C 409 R 04 T 06	DG-1 FAILED TO START WITHIN 10 SEC. AIR DEPOSITS FOUND ON SECONDARY AIR MOTORS
C FC1	017628	041477	GM25	C 409 R 04 T 06	DG-2 FAILED TO START IN 10 SEC. AIR DEPOSITS FOUND ON SECONDARY AIR MOTORS
C FC1	021682	061978	GM25	K 810 R 01 T 06	DG-1 FAILED TO REACH RATED TERM VLTG ON STARTUP
C FC1	021799	071278	GM25	K 810 R 01 T 06	DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN
C FC1	022249	080978	GM25	K 810 R 01 T 06	DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN
C SL1	017434	011877	GM30	E 804 R 01 T 18	DG HAN FOR 55 MIN THEN TRIPPED ON LOCKOUT
C SL1	017384	011977	GM30	A 409 R 01 T 18	DIESEL GENERATOR FAILED TO START
C SL1	017398	011977	GM30	A 409 R 01 T 18	DG FAILED TO START AGAIN - LATER SAME DAY
C SL1	019111	092677	GM30	E 804 R 01 T 18	DG SHUTDOWN WHEN SMOKE ISSUED FROM TURBOCHARGER

RECURRING

PLANT	CONTROL NO.	FAIL DATE	M F K G W	FAILURE MODE	FAILURE MECHANISM
G BPI	014417	032476	CA02 D 809 R T 8 T	DG TRIPPD ON HI COOLING WATER TEMP	WATER PUMP SUCT SCREEN PLUGGED
G BPI	014894	051876	CA02 D 809 R T 6 N DG	DG TRIPPD ON HI COOLM WATER TEMP PUMP SHAFT SCORED	INLET SCREEN PARTIALLY PLUGGED
G BPI	015448	080576	CA02 M A03 K U U Y DG	FAIL TO START WITHIN 15 SEC NCT REQUESTED	OPERATOR NOT AWARE OF SIGNIF OF START TIM
G BPI	015449	080976	CA02 D A00 R U 8 N DG	FAIL TO START WITHIN 15 SECONDS DURN WEEKLY	POSSIBLE WATER JACKET HEATER FAILURE
G BPI	015444	081276	CA02 C A10 R T 8 I	WEEKLY TEST FAIL TO START	STARTING BATTERY CABLE FAILD LOOSE CONNCT
G BPI	016672	090276	CA02 A A00 K U U T	FAIL TO MEET 15 SEC START TIME DURING WEEKLY TEST	POSSIBLE FUEL SYSTEM FAILURE
G BPI	016304	102876	CA02 G A00 R U U T	DG FAIL TO START WITHIN 15 SEC	POSSIBLE FUEL GOVERNOR CONTROL PROBLEM
G BPI	01649C	110476	CA02 G A00 K U U T	START TIME 2.2 SEC SLOWER THAN REQUIRED	POSSIBLE FUEL GOVERNOR PROBLEM
G BPI	016587	111876	CA02 C A10 R D 4 T	FAIL TO START IN AUTO TEST; STARTER MOTOR PROBLEM	BROKEN SPRING IN BENDIX MECHANISM
G BPI	016547	120276	CA02 G A00 R U U T	FAIL TO MEET 12 SEC START TIME DURING AUTO TEST	FUEL GOVERNOR REPLACED ON 12/19/76
G BPI	016943	122076	CA02 G A04 R U U T	START TIME EXCEEDED CRITERIA BY 4 SEC	GOVERNOR LUBE SFUEL SYS UNDER INVESTIGTN
G BPI	016912	122776	CA02 A A04 R U U T	START TIME 6T. CRITERIA 15 VS 12	FUEL GOV. LUBE OIL SUPPLY MODIFID 1/10/77
G BPI	016511	122876	CA02 C A10 R D 4 M	DEFECTIVE STARTER DRIVE DG FAILED TO START	BROKEN SPRING DELCO PART #1945487
G BPI	016940	010377	CA02 G A00 K U U T	FAIL TO START IN AUTO TEST	CAUSE UNKNOWN LUBE OIL RETENTION IN GOV.7
G BPI	020298	032477	CA02 G A00 R U U T	EDG STARTING TIME EXCEEDED 12 SEC. BY +6 SEC.	GOVERNOR LUBE SYS MODIFIED ON 1/10/77
S BPA	018102	051877	CA02 D A00 R T 4 T	H2O JACKET HEATER FAILURE--EDG TESTED; DID NOT MEET	TIME CRITERIA; EXCEEDED BY 12 SECONDS
G BPI	048103	052677	CA02 A A00 R U U T	START TIME 16.5 SEC, SHOULD BE LT 13.9 SEC	FULL CONTROL VALVE MODIFIED
G BPI	019241	102077	CA02 C A00 R U U T	START TIME 21.8 SEC VS. 13.9 SEC	CHECKD VOLTAGE DROP ON START CABLES
G BPI	019093	112477	CA02 A A00 H U I T	START TIME 33 SECS TESTED SAT WITHIN ONE HOUR	FUEL CHECKED ON PREM GRADE OF FUEL USED
G BPI	020375	020278	CA02 M A00 R U U T	START TIME 26.5 SECS VS 13.9 SECS	CAUSE UNKNOWN

RECURRING

V	L	CONTROL NO.	FAIL DATE	M F K G W	FAILURE MODE	FAILURE MECHANISM	
G	DA1	014334	022776	FM25	B	SMALL FIRE ON EXHAUST MANIFOLD OF DG 1G21	ORL LEAK FROM FRONT COVER PLATE
G	DA1	014337	031776	FM25	H	B12 R T D T	1G21 LEAKY FLANGE GASKET
G	DR1	021516	051178	GM10	A	ALW R D G T	SHORTED DIODE ACROSS FUEL PRIMING PUMP
G	DR2	017397	032277	GM25	C	AL0 R O I T	AIR START MOTOR PINION GEAR JAMMED
G	DR2	016263	063077	GM25	G	A00 R O I T	POSSIBLE OUT-OF-ADJUST GOVERNOR COMPENSTIN
G	DR2	018494	071277	GM25	G	A00 R O I T	PROBABLE OUT-OF ADJUST GOVERNOR COMPENSTIN
G	DR2	019723	120277	GM25	C	AL3 R T I T	LOOSE WIRE AT TERMINAL 25A5
G	DR2	020442	010378	GM25	C	AL3 R T I T	LOOSE WIRE AT TERMINAL 25A5
G	DR2	022262	092478	GM25	C	AL0 R U 4 T	PINION GEAR NOT ENGAGED ON AIR START NTK
G	DR2	022389	092278	GM25	C	A00 R U 8 T	AIR-START SYS WILL BE MODIFIED
G	DR2	023337	121678	GM25	C	A00 R U 4 T	1G2 RELAY CLEANED; D2 AND AIR VALVE T
G	DR3	014439	030376	GM25	G	AL3 R T 4 T	GOVNR CONTROL WIRE VIBRATED FREE FROM LUG
G	DR3	016187	100976	GM25	G	AL3 R T 4 T	LOOSE WIRE ON GOVNR CONTROL CIRCUIT
G	DR3	016455	110576	GM25	G	B10 R T 8 T	FAILD OVERTRAVL LIMIT SWITCH ON GOVNR
G	DR3	019722	112277	GM25	G	AL0 R O 8 T	RAD CAPACITOR IN SPEED SENSING CNT. T
G	DR3	019727	112977	GM25	G	B10 R D 8 M	SHORTED CAPACITOR ON SPEED SENSING BOARD
G	EN1	015947	081476	FM25	M	A00 R D U T	EXACT CAUSE OF START FAILURE NOT KNOWN
G	EN1	016005	091176	FM25	G	AL0 R D I T	LOW OIL LEVEL IN GOVERNOR
G	EN1	016842	122576	FM25	M	B00 R U U T	CHECKING OUT LOGIC ON IC DG
G	EN1	016843	123176	FM25	M	A00 R U I T	INSPECTED & RETESTED SATISFACTORILY

RECURRING

VEH	PLANT	CONTROL NO.	FAIL DATE	MFG	W	SUBSYS	FAIL MODE	REPAIR	DISCOVERY	FAILURE MECHANISM
G EN1	G20C31	081877	FM25	F	800	R U G T	DURING SURV TESTING, DG 18 GEN INBOARD BRNG FAILED			BEARING OVERHEATED - EXACT CAUSE UNKNOWN
G EN2	022751A	102878	FM25	G	A10	R D B T	"C" DIESEL FAILED TO REACH 250RPM IN 7 SEC.			STICKING GOVNR BOOSTR SERVO
G EN2	022751B	103178	FM25	G	A10	R F B N	"C" DIESEL FAILED TO REACH 250RPM IN 7 SEC.			FAULTY ELECTRONIC SPEED SWITCH SIGNAL
G FP1	016496	111776	GM25	I	A10	R D B T	"B" EDG FAILED TO START DURING SURVEILLANCE TEST			GEN TACH RELAY DID NOT OPERATE, DEF CNVR
G FP1	016600	121576	GM25	B	A10	R D 1 T	DURING TESTING "A" EDG FAILED TO START			LOW LUBE OIL PRESS - RELIEF VLV LEAKAGE
G FP1	016971	011977	GM25	B	A10	R D 1 T	DURING SURV, EDG TRIPPED ON EMERGENCY START			LOW LUBE OIL PRESS, SECND ATTMPT SUCCESSFL
G FP1	017725	042077	GM25	I	A10	R D B T	DURING ROUTINE SURV TEST, EDG FAILED TO START			TACHOMETER RELAY FAILED
G VY1	014740	050876	FM30	F	A09	R T 4 N	"B" DIESEL GENERATOR TRIPPED ON HI CRNKSE PRESS			CLOGGED CRNKSE EJ SUP ORIFICE OR EJ BODY
G VY1	019323	062377	FM30	F	B13	R T 4 T	"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE			VIBRTN CAUSED HOSE CLMP ON AIR EJECT FAIL
G VY1	020194	121977	FM30	F	B13	R T 4 T	"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE			ENG VIB CAUSED AIR EJECT HOSE TO LOUSEN
W BV1	014903	092076	GM25	C	A09	R T 4 N	DG #1 FAILED TO START 3 TIMES DG #2 STARTED OK			WATER ACCUMULATION IN AIR START SYSTEMS
W BV1	017696	042977	GM25	C	A09	R T 4 N	DG #1 FAILED TO START REPETITIVE			MOISTURE IN STARTING AIR
W BV1	017827	050977	GM25	J	A04	R D 4 T	#2 DG OUTPUT BKR. FAILED TO CLOSE--REPETITIVE			STICKING RELAY(MSR2) IN MANUAL START CKT.
W BV1	018068	060377	GM25	J	A04	R D 1 T	#2 DG OUTPUT BKR. FAILED TO CLOSE ON FIRST ATTEMPT			CLOSED ON NEXT ATTEMPT; STICKY NFLOA RELAY
W BV1	018828	071777	GM25	K	A10	R T B F	#2 DG STARTED AND CLOSED UNTO BUS; OUTPUT VOLTS =0.			LOOSE CONNECTIONS IN AUTO FIELD FLASH CKT
W BV1	020437	011178	GM25	J	A04	R D 4 T	#2 DG OUTPUT BKR. FAILED TO CLOSE IN EXERCISE MODE			NO CAUSE COULD BE DETERMINED
W BV1	022137	072878	GM25	K	A10	R D 1 N	#2 DG FAILED TO FLASH DURING SI AND LOSP EVENT			STICKY FIELD FLASH CUTOFF RELAY; AUTO CKT.
W BV1	022395B	090578	GM25	J	A00	R D 1 T	#1 DG OUTPUT BKR. FAILED TO CLOSE; #2 DG OOS			BKR CLOSED MANUALLY; 1 HOUR RUN AT FULL LD
W BV1	022394B	091278	GM25	J	A00	R D 1 T	#1 DG OUTPUT BKR. FAILED TO CLOSE USING CONT. SWITCH			CLOSED LATER NEGATING TROUBLESHOOTING
W DC2	022C26	072878	W030	G	B10	R T 4 T	#2 AB DG OVERSPED WHL UNLOADG PREVIOUS OCCURRENCE?			WORN LINKAGE CAP SCREW BROKE IN GOVERNOR

RECURRING

PLANT	CONTROL NO.	FAIL DATE	FK GW	FAILURE MODE	FAILURE MECHANISM
JFI	022374	082778	FM25	2C DG WOULD NOT RESPOND TO AUTO OR MAN SPEED CHG	BLOWN FUSES FOR POP AND MOT
JFI	022373	090578	FM40	1-2A DG WOULD NOT RESPOND TO AUTO VLTG OR SPD CHGS	BLOWN FUSES FOR POP CAUSED BY FAIL DIODES
PTI	017146	020977	GM25	3D EDG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	DIRT IN LMR BRNG OF OVRCRY RELAY TNG DISC
PTI	021445	051778	GM25	4D EDG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	WESS 002A13H01 LATCH-CHKNG SW DEFECTIVE
RU2	014823	030176	FM25	EMER DIESEL DID NOT REACH RATED CAPACITY	12 CYL INJ PLUNGER & BARREL GALLED
RU2	019354	041377	FM25	DIESEL GEN FAILED TO ASSUME FULL LOAD	SEVERAL FUEL INJ RUDS WERE STICKING
SUI	021316	032878	DL10	DIESEL GENERATOR FAILED TO START	FUEL LNRG BINDING - BEARINGS IN LNRG URY
SUI	014809	041676	GM25	DIESEL GENERATOR DAMAGED ON START	17 CYL FLOODED - CAUSED BROKEN INTERNALS
I03	017591	026377	GM25	DIESEL GEN FAILED TO START	PROBABLE-AIR IN FUEL SUPPLY LINES
I03	018147	033177	GM25	DIESEL GEN DID NOT REACH SPEED & VLTG WITHIN SPEC TIME	AIR IN FUEL LINE-CRACKS IN SUCTION TUBING
Z11	020255	010378	CB40	OUTPUT VOLTAGE PEGGED HIGH-COULD NOT LOWER	PC BOARD FAILURE IN THE VOLTAGE REGULATOR
Z12	017808	042777	CB40	GVERNOR SPEED CONTROL FAILED ON 28 DIESEL GEN	GOV SPD CCNT GEAR JAMMED AGAINST HI SPD SIO
Z12	020258	010678	CB40	OUTPUT VOLTAGE INCREASED AND COULD NOT LOWER	BURNED CONTACT IN THE VOLTAGE REGULATOR
Z12	020260	010978	CB40	POWER OUTPUT OVLD - COULD NOT LOWER MANUALLY	GOV SYNCH IND GR JAMMED ON HI SPD STOP

COMMAND FAULTS


UNIT	CONTROL NO.	FAIL DATE	M C M	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
B	018505	072677	FM30	I	A06	S 0 1 T "18" DG FAILED TO START DUE TO DIESEL TRIPS WERE NOT RESET REVISED PROCEDURES TO RESET TRIPS
B	019302	092877	FM30	B	A10	S 0 8 T "38" DG FAILED TO START DUE TO START PERMISSIVE LOST D START PERM. DUE TO LOW LUBE OIL PRESSOR
B	019816	122977	GM25	G	A14	S 0 6 N DURIN LOSP DG 1-1 STARTD AND TRIPPD ON OVERSPEED IMPROPER SETTING'S CF HI SPEED AND OVERSPD
B	023007	103178	GM25	M	B11	S 0 4 T 1-2 DG S/D DUE TO ROOM TEMP RCSE TO 110 DEG. OUTSIDE AIR DAMPER WOULD NOT OPEN
B	022613	100478	GM25	A	B01	S 0 1 N "18" DG S/D DUE TO SPRAY OF FUEL OIL; "18" DG DCS FUEL LEAK-EXCESSIVELY LOOJENED STNR PKG GLND
B	019298	022176	FM30	J	A06	S 0 1 T "18" DG OUTPUT BREAKER FAILED TO CLOSE PROCED ERROR-IMP GOV SETTING-FAEQ TOO LGM
B	020295	011278	FM30	B	A14	S 0 4 T "18" DG FAILED TO START ON SIMULATED AUTO ES TEST GIL PRESS LIM SW PRESS SETTING DRIFED
C	015587	072976	FM25	D	A02	S 0 4 N "12" DG FAILED TO START AUTO FAILD ALSO FROM CONT RM JACKET COOLING H2O SYS AIRBOURD MCE VENTD
C	015584	080776	FM25	J	A02	S 0 6 T "11" DG FAILED TO SENSE "AY VOLTAGE" COND.-OUTPUT BKR. WILL NOT CLOSE--CLLD SOLDER CONN TO ERA
C	018487	071377	FM25	D	B02	S 0 1 T "11" DG TRIPPD ON LCM JACKET COOLNT PRESS WHEN SIAS SIGNAL REMOVED;DP SWITCH ISOLATED
C	021991	080178	FM25	D	B10	S 0 4 T "21" DG TRIPPD ON HI JACKET COOLNT TEMP SERV H2O SUPPLY VALV FAILD TO OPEN
C	014559	040776	GM25	M	A06	S 0 1 T START ON SECONDARY AIR REUD 10.6 SECS. VS. 10SECS. PROCEDURE WAS INADEQUATE
C	017020	011077	FM25	F	B13	S 0 6 T DG 13U SHUTDOWN DUE TO HIGH VIBRATION SKID MOUNT IN RESONANCE WITH ENG FREQUEN
C	018923	081077	FM25	G	A01	S 0 1 N DG 12U FAILED TO RESTART ON DEMAND GOVERNOR STILL IN "NO FUEL" FROM PREV S/D
C	019255	092477	FM25	I	B14	S 0 8 T 12U DG APPEARED TO TRIP ON GEN OVERCURRENT MICRO SW CUT OF ADJ ON DG OVERSPD TRIP MECH
C	019929	110977	FM25	K	A01	S 0 1 T DG 13U TRIPPED WHILE PARALLELING WITH 4160V BUS IMPROPER VOLTAGE SETTING PRIOR TO PARALL
C	022745	092578	GM25	A	A06	S 0 1 T DG-18 COULD NOT BE LOADED DURING TEST AFTER MAINT AIR WAS NOT PURGED FROM FUEL LINES
C	016681	110276	GM30	M	A01	S 0 4 T 1A DG FAILED TO START PERSONNEL ERROR - INCORRECT VALVE LINEUP
C	017441	030177	GM30	I	A01	S 0 1 T 1A DIESEL GENERATOR FAILED TO START OPER FAILED TO WESET OVERSPEED TRIP
G	018742	080577	CA02	J	A04	S 0 6 T TESTED EDG WITH 2A-2B BKR RACKD OUT; AUTO TRANSFER AND MAN TRANSFER FAILD TO CLOSE OUTPUT BKR

RECURRING COMMAND FAULTS

V E N T	P L A N T	CONTROL NO.	FAIL DATE	M F G	K W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R N E E D E D	D E T E R M I N E D	FAILURE MODE		FAILURE MECHANISM	
													FAILURE MODE	FAILURE MECHANISM		
B	ARI	019578	102377	GM25	C	A14	T	D	U	8	T	#1 DG FAILED TO START; DRIFT OF TD RELAY SETPOINT	ALSO DIODE CR-1 FOUND SHORTED			
C	FC1	014590	042776	GM25	C	A02	T	D	U	8	U	DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE	IMPRPR SETNG FOR MAG PKUP ON SWTCHG TACH			
C	FC1	015722	081576	GM25	C	A14	T	D	U	8	U	DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE	SETNG FOR MAG PKUP ON SWTCHG TACH DRIFTED			
G	DK2	021882	063078	GM25	D	B14	T	D	G	T	2/3 DG COOLING H2O PUMP TRIP ON HI AMPS; REPLACED	OVERLOAD TRIP SET CLOSE TO RUNNING AMPS				
G	EN1	018644	061377	FM25	D	B14	T	D	4	T	1C DG TRIPPD RESTARTED SATISFACT LO JACKET CLNT	LOW COOLNT PRESS SWITCH TO BE CALIBRATED				
G	EN1	018646	061877	FM25	D	B14	T	D	4	T	1C DG TRIPPD ON LO COOLNT JACKET PRESSURE	POSSIBLE INCORRECT PRESSURE SETPOINTS				
G	EN1	018647	062577	FM25	D	B14	T	D	4	M	1C DG TRIPPD ON LO COOLNT JACKET PRESS	OPERT PRESSURE WAS ABOVE TRIP SETPOINT				
M	IP3	015733	083076	AL18	G	B02	T	D	1	T	EDG 31 BEGAN CYCLING BETWEEN 56 AND 63 CPS	GOV OIL DRAIN VLV NOT SHUT TIGHTLY				
M	IP3	016035	092476	AL18	G	B02	T	D	4	T	EDG 31 OUTPUT FREQ INC TO 62 HZ; COULD NLT CONT EIE	AIR IN GOV OIL LINES FROM PREVIOUS REPAIR				
M	ZI2	021544	051778	CB40	K	B14	T	I	8	T	2A LG OUTPUT VOLTAGE CYCLED - COULD NOT CONTROL	DRIFT OF VLTGE REGULATOR STABILITY CIRCUIT				

APPENDIX L

DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY FAILURE CLASSIFICATION



CODES USED IN LEP ONE-LINE DESCRIPTIONS

REPAIR TIME	
CODE	DESCRIPTION
1	0 TO 1 HOURS
4	1 TO 4 HOURS
8	4 TO 8 HOURS
00	8 TO 24 HOURS
6	GREATER THAN 24 HOURS
U	UNKNOWN / NOT APPLICABLE

FAILURE MODE	
CODE	DESCRIPTION
A	DOES NOT START
B	DOES NOT CONTINUE TO RUN
U	UNAVAILABLE / NONFAILURE

FAILURE CLASSIFICATION	
CODE	DESCRIPTION
D	DEMAND
T	TIME
U	UNKNOWN

SUB-SYSTEM	
CODE	DESCRIPTION
A	FUEL OIL SYSTEM
B	LUBE OIL SYSTEM
C	STARTING SYSTEM
D	COOLING SYSTEM
E	SCAVENGING AIR SYSTEM
F	ENGINE FRAME / INTERNALS
G	GOVERNOR
H	EXHAUST SYSTEM
I	SHUTDOWN SYSTEM
J	OUTPUT BREAKER
K	EXCITER / VOLTAGE REGULATOR
L	GENERATOR
M	OTHER / UNKNOWN

FAILURE MECHANISM	
CODE	DESCRIPTION
00	UNKNOWN
01	PERSONNEL OPERATION
02	PERSONNEL MAINTENANCE
03	PERSONNEL TESTING
04	DESIGN ERROR
05	FABRICATION / CONSTRUCTION / QUALITY CONTROL
06	PROCEDURAL DISCREPANCY
07	DEFECTIVE FUEL INJECTOR(S)
08	CORROSION / EROSION
09	FOREIGN MATERIAL CONTAMINATION
10	MECHANICAL / ELECTRICAL CONTROL
11	HI / LOW AMBIENT TEMPERATURE
12	LUBE / FUEL / WATER / AIR LEAKAGE
13	VIBRATION
14	OUT OF ADJUSTMENT / CALIBRATION

METHOD OF DISCOVERY	
CODE	DESCRIPTION
M	DURING MAINTENANCE
N	DURING NORMAL OPERATIONS
R	DURING RECORDS REVIEW
T	DURING TESTING
U	UNKNOWN

TYPE OF EVENT	
CODE	DESCRIPTION
B	RECURRING COMMON CAUSE
C	COMMON CAUSE
R	RECURRING
W	COMMAND FAULTS
T	RECURRING COMMAND FAULTS

NSSS VENDOR	
CODE	DESCRIPTION
B	BABCOCK & WILCOX
C	COMBUSTION ENGINEERING
G	GENERAL ELECTRIC
W	WESTINGHOUSE

DG MANUFACTURER

KW RATING

CODE	DESCRIPTION
AL	ALCO
CA	CATERPILLAR
CB	COOPER-BESSEMER
DL	DE LAVAL
FM	FAIRBANKS MORSE
GM	GENERAL MOTORS
NM	NORDBERG MANUFACTURING
WG	WORTHINGTON

CODE	DESCRIPTION
02	200-400 KW
10	500-1000 KW
18	1750-1950 KW
25	2500-2650 KW
30	3000-3500 KW
40	4000-4418 KW

DEMAND

VEN	CONTROL NO.	DATE	TIME	FAILURE MODE	FAILURE MECHANISM
B	AV1 014838	051176	GM25 C	AL0 D 8 T DG #1 FAILED TO START ON SIMULTED E-S. ACTUATION	FAILED DIODE IN AUTO START CIRCUIT
B	CR3 018265	072677	FM30 I	A06 S 0 1 T "38" DG FAILED TO START DIESEL TRIPS WERE NOT RESET	RE-ADVISED PROCEDURES TO RESET TRIPS
B	CR3 019302	092877	FM30 B	AL0 S 0 8 T 38 DG FAILED TO START DUE TO START PERMISSIVE LOST	D START PERM. DUE TO LOW LUBE OIL PRESSUR
B	CR3 020221	122777	FM36 G	A09 K 0 8 T 38 DG FAILED TO START--3RD OCCURANCE	SMALL PIECES OF INSULATION PREVENT GOVERNOR
B	CR3 020278	010378	FM30 G	A09 K 0 8 T 38 DG FAILED TO START ---4TH OCCURANCE	FOREIGN MATTER IN SERVO BOOSTER
B	DB1 019816	122977	GM25 G	AL4 J 0 6 M DURIN LUSP DG 1-1 STARTD AND TRIPPD ON OVERSPEED	IMPROPER SETTINGS OF HI SPEED AND OVERSPO
B	DB1 020708	020678	GM25 E	B05 0 6 T 1-1 DG 5/0 DUE TO NOISY TURBOCHARGER	DESIGN/FABRICATION OR COMPONENT FAILURE, REPLACD
B	DB1 021852	060478	GM25 K	AL0 0 4 T 1-1 DG FAILED TO OPERATE WITH PROPER FREQ/VOLT	FAILED PRIMARY POTENTIAL FUSE FOR DG 1-1
B	DB1 023607	103178	GM25 M	B11 S 0 4 T 1-2 DG 5/0 DUE TO ROOM TEMP ROSE TO 180 DEG.	OUTSIDE AIR DAMPER WOULD NOT OPEN
B	R31 015622	080676	GM25 C	AL0 0 4 T "M" DG FAILED TO START DURING SPECIAL TEST	IMPROPER GEAR ENGAGEMENT-AIR START MTR DCC
B	R31 016626	120676	GM25 G	B10 0 8 T DG "M" TRIPPED OFF-LINE 25 MIN INTO TEST	SPEED CONT SW FLD CLOSED, SPD DECR TO TRIP
B	R31 022613	100478	GM25 A	B01 S 0 1 M "M" DG 5/0 DUE TO SPRAY OF FUEL OIL; "B" DG DCS	FUEL LEAK-EXCESSIVELY LOOSENEED STNR PKG GLEND
B	R11 014698	022176	FM30 J	A06 S 0 1 T "18" DG OUTPUT BREAKER FAILED TO CLCSE	PROCED ERROR--IMP GOV SETTING--FREQ TOO LOW
B	T12 021607	052078	FM30 F	A05 C 0 6 T DG 8 FAILED TO START	VERT SHFT BTM UP & LMR CRANKS FLD-IMP MTL
C	CC1 015587	072976	FM25 D	A02 S 0 4 M B12 DG FAILED TO START AUTO FAILD ALSO FROM CONT RM	JACKET COOLING H2O SYS AIRROUND NOT MENTD
C	CC1 015904	776	FM25 J	A02 S 0 6 T 11 DG FAILED TO SENSE "AT VOLTAGE" COND.--OUTPUT BKR.	WILL NOT CLOSE--COLD SOLDER CONN TO ERA
C	CC1 018306	777	FM25 F	B02 D 1 T B11 DG START-LATER DISCOVERED #6 CYLINDER RELIEF	VALVE VIBRATED LOUSE AND FELL OFF DG
C	CC1 018446	1177	FM25 B	B02 C 0 4 M B11 DG ON FIRE DUE TO L.O. HITTING HOT EXHAUST	O-RING SEAL ON STNR NOT GLUED PROPERLY
C	CC1 018487	11377	FM25 D	B02 S 0 1 T B11 DG TRIPPD ON LOW JACKET COOLNT PRESS WHEN STAS	SIGNAL REMOVED/OP SWITCH ISOLATED
C	CC1 023380	121878	FM25 M	B00 R 0 1 T B11 DG SHUTDOWN DUE TO ROOM VENT/FAN FAILD TO STRT	FAN FAILURE--RESET OVERLOADS

DEMAND

PLANT CONTROL UNIT	FAIL DATE	M/K G/W	FAILURE MODE	FAILURE MECHANISM
C CC2 021991	080178	FM25 D 810 S D 4 T	#21 DG TRIPPD ON HI JACKET COCLNT TEMP	SERV H2O SUPPLY VALV FAILED TO OPEN
C FC1 014559	040776	GM25 M A06 S D 1 T	STARI ON SECONDRY AIR REQUD 10.6 SECS.VS. 10SECS.	PROCEDURE WAS INADEQUATE
C FC1 014590	042776	GM25 C A02 T D 8 U	06-2 PRIMARY AIR START MTR FAILED TO DISENGAGE	IMPRPR SETNG FOR MAG PKUP ON SWTCHG EACH
C FC1 015722	081576	GM25 C A14 T D 8 U	06-2 PRIMARY AIR START MTR FAILED TO DISENGAGE	SETNG FOR MAG PKUP ON SWTCHG YACH DRIFTED
C FC1 021692	061978	GM25 K A10 R D 1 T	06-1 FAILED TO REACH RATED TERM VLTG ON STARTUP	BLOWN FUSE IN GEN FIELD CIRCUIT
C FC1 021799	071278	GM25 K B10 R D 0 T	06-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN	3 EXCITER SUBCOMPONENT FAILURE(S) COINCIDENT
C FC1 022259	080978	GM25 K B10 R D 0 T	06-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN	REFER VOLTAGE ZENER DIODE OUTPUT DRIFTED
C M12 016036	091976	FM25 B 812 B D 4 N	12U DG HAD TO BE SECURED AND DECLARED INOPERABLE	EXCSV LEAKAGE CF LUBE OIL FILTER GASKET
C M12 016755	121876	FM25 F 806 D 6 T	UG 13U #3 UPPER PISTON CON ROD BRNG CAP SHEARED	CAPSCREWS FAILED - PROB DUE TO DRY STARTS
C M12 017020	011077	FM25 F 813 S 0 6 T	06 13U SHUTDOWN DUE TO HIGH VIBRATION	SKID MOUNT IN RESONANCE WITH ENG FREQUEN
C M12 018923	081077	FM25 G A01 S D 1 N	DG 12U FAILED TO RESTART ON DEMAND	GOVERNOR STILL IN "NO FUEL" FROM PREV S/D
C M12 019429	110977	FM25 K A01 S D 3 T	06 13U TRIPPED WHILE PARALLELING WITH 4160V BUS	IMPROPER VOLTAGE SETTING PRIOR TO PARALL
C M12 022719	092578	GM25 A A06 S D 1 T	06-18 COULD NOT BE LOADED DURING TEST AFTER MAINT	AIR WAS NOT PURGED FROM FUEL LINES
C S11 010681	110276	GM30 M A01 S D 4 T	1A UG FAILED TO START	PERSONNEL ERROR - INCORRECT VALVE LINEUP
C S11 017444	030177	GM30 I A01 S D 1 T	1A DIESEL GENERATOR FAILED TO START	OPER FAILED TO RESET OVERSPEED TRIP
G 0F3 019153	091977	GM30 K A10 C D 1 T	30 DG TRIPPD ON OVERSPEED ; GOVERNOR INOPERABLE	TO FUSE CFEN DISENABLING FIELD CIRCUIT
G 0P1 016287	111876	CA02 C A10 R D 4 T	FAILED TO START IN AUTO TEST; STARTER MOTOR PROBLEM	BROKEN SPRING IN BENDIX MECHANISM
G 0P1 016911	122876	CA02 C A10 R D 4 M	DEFECTIVE STARTER DRIVE; DG FAILED TO START	BROKEN SPRING DELCO PART #1945487
G 0P1 018742	080577	CA02 J A04 S 0 6 T	TESTED EDG WITH 2A-2B BKR RACKD OUT; AUTO TRANSFM	AND MAN TRANSFR FAILED TO CLOSE OUTPUT BKR
G 0M1 016654	010477	GM30 B A04 C D 4 T	#3 DG TRIPPD K/X AT POWER LOW LUBE OIL TEMP	LOW SETPOINT FOR PRE-FILTER HEATER + JACK

DEMAND

V E N T	P L A N I	C O N T R O L N O.	F A I L D A T E	M F K G W	S U B S Y S	F A I L M O D E	F A I L M E C H	C L A S S	R E P A I R	C O M M E N T	F A I L M O D E	F A I L M E C H
G BR1	0168548	010477	NM30	B	A04	C	D	4	T	#4 DG TRIPPD R/X AT POWER TO SWITCH NOT RESET	L.C.PRESS SWITCH TIME DELAY INCORRECT	
G BR1	019391	101177	NM30	G	B05	D	6	T	#2 DG UNABLE TO MAINTAIN LOAD CYCLING 50KW	SHORTED LEADS TO GOVERNOR; INCORRECT ASMB		
G BR1	019948	121077	NM30	J	B06	D	0	T	SMOKE COMING FROM 320 RELAY AND 860B RELAY FLAMING	REPLACED AND CALIBRATED RELAYS		
G BR2	014136	010976	NM30	J	A10	D	4	N	#1 DG STARTED BUT OUTPUT BKR FAILED TO CLOSE TO E-1	BROKEN LUG WIRE DUE TO STRESS		
G BR2	015461	061176	NM30	A	A02	G	0	T	#1 DG STALLED & FAILED TO TIE INTO E-BUS R/X AT PR	40 GAL H2O IN SADDLE & 4 DAY TANK		
G BR2	020612	021378	NM30	K	A01	S	0	1	N	FOLLOWING SCRAM ON UNIT 1 #01 DG LD RELAY WOULDN'T RESET	LOSS OF EXCITATION RELAY NOT RESET	
G C01	016712	111076	CR40	J	A03	S	0	8	I	EG-1 OUTPUT BKR FAILED TO CLOSE--BLOWN FUSE 59RELAY	DISCONNECTO ONLY ONE WIRE ON 11/8/76	
G DA1	015993	100776	FM25	F	A05	D	0	T	1G21 BROKEN LOWER VERT DRIVE COUPLNG HUB	HUB MADE OF WRONG MATERIAL		
G DA1	016452	110476	FM25	A	B04	D	0	T	DG 1G-21 S/D DUE TO FIRE -FUEL LINE FRACTURE	INADEQUATE DESIGN		
G DA1	017756	051077	FM25	J	A10	S	0	8	I	1G-21 DG OUTPUT BKR FAILED TO CLOSE	AUX CONTACTS OF STROBY TRANSFORMER OPEN	
G DA1	017963	051277	FM25	G	B06	S	0	1	T	1G-31 DG WOULD NOT REACH FULL LOADING ONLY 250G KW	SPEED SETTING ADJUSTMNT NOT RESET	
G DA1	021171	040578	FM25	F	A06	D	0	G	M	BEARING WIPED ON 4/13/77 NOT DUE TO MISALIGNMENT	LUBE OIL FILTER DRAIN VALVE WAS OPEN	
G DR1	0204088	012778	GM10	M	A11	C	0	1	N	U-1 870 DG FAILED TO START 1ST 5 TIMES-LOW TEMPERAT	WINTER WEATHER	
G DR1	020408A	012978	GM10	M	A11	C	0	G	N	U-1 FAILED TO START DUE TO COLD WEATHR 6 HEATRS	INSTALLED & ROOM WINTERIZED	
G DR1	020852	030478	GM10	C	A10	D	0	G	T	D-1 870 FAILED TO START R/X IN HOT S/D MODE	SYNCHRO START SWITCH FAILED	
G DR1	021516	051178	GM10	A	A10	R	0	G	T	TEMP. DG FAILED TO START-BLOW FUSES IN CONT LOGIC	SHORTED DIODE ACROSS FUEL PRIMING PUMP	
G DR2	016654	121876	GM25	A	B02	S	0	0	T	UNIT 2 DG FAILED TO CARRY REQD LOAD ;2600KW MAX	H2O IN FUEL SUPPLY FROM FLUSHING OPERATON	
G DR2	017397	032277	GM25	C	A10	R	0	1	T	UNIT 2/3 FAILED TO START	AIR START MOTOR PINION GEAR JAMMED	
G DR2	018283	063077	GM25	G	A00	R	0	1	T	2/3 DG TRIPPD ON OVERSPEED DURING 2 ATTEMPTS	POSSIBLE OUT-OF-ADJUST GOVERN COMPENSAIIN	
G DR2	018494	071277	GM25	G	A00	R	0	1	T	U 2/3 D/G TRIPPD ON OVERSPEED--OCCLRD ALSO 6/30/77	PROBABLE OUT-OF ADJUST GOVENOR COMPENSTIN	

DEMAND

V E N I	P L A	CONTROL NO.	FAIL DATE	M K G W	SUB SYS	FAILURE MODE	FAILURE MECHANISM
G DR2	619732	111677	GM25	I	A00	S O I F	AUTO-START SIGNAL SENT TO UNIT 2/3 DURING CORE SPRAY RESET START FAILURE RELAY & DIESEL START
G DR2	019728	112977	GM25	D	B12	C O D T	2/3 DG 3/0 DUE TO COOL H2O PUMP TRIP 10MIN. LOADED WATER LEAK GROUND PUMP STATOR
G DR2	019610	120377	GM25	C	A12	O 4 T	2/3 DG FAIL TO ROLL OVER--LOW START AIR PRESSURE RUPTURED REGULATOR DIAPHRAM
G DR2	021648	030778	GM25	C	A00	S O R T	OPERATE SHOOK AIR START SOLENOID UNIT 2/3 STARTED POSSIBLE WIRE DAMAGED DUE TO FREQ INSPEC
G DR2	020655	030878	GM25	G	A14	O 8 T	ENGINE OVERSHOT AT 1010 RPM WHILE OS SET AT 1020 HI OVERSHOOT BY UUF-OF-ADJUST GOVNR COMP
G DR2	021738	052278	GM25	G	A02	O 8 T	U-2 DG TRIPPO 4 TIMES ON OVERSPED/RX IN S/D MODE GOVNR SETTING FOUND SET TOO HIGH
G DR2	021882	063078	GM25	D	B14	I D G T	2/3 DG COOLING H2O PUMP TRIP ON HI AMPS; REPLACED OVERLOAD TRIP SET CLOSE TO RUNNING AMPS
G DR2	023337	121678	GM25	C	A00	R D 4 T	2/3 DG AIR START MOTORS DISENGAGED AFTER FEW SECS. T02 RELAY CLEANED; T02 AND AIR VALVE 2
G DR3	017509	032277	GM25	K	A10	O 6 M	GEN FIELD FAIL TO FLASH
G DR3	019722	112277	GM25	G	A10	R D 8 T	3 DG START/LOADED-OVERLOAD ALARM-DG TRIPPO
G DR3	019727	112977	GM25	G	B10	R D 8 M	3 DG TRIPPO 30 MIN AFTER START AND LOADING
G EN1	014778	031576	FM25	C	A10	D D T	1A DG FAILED TO START DURING SURVEILLANCE
G EN1	012557	062676	FM25	B	B02	S D B T	DG 1C TRIPPO DUE TO LUBE OIL SWITCH NOT CALIBRATED PERSONNEL DID NOT CALIBRATE SWITCH
G EN1	012568	080576	FM25	K	A08	S D I T	DG 1A TRIPPO DUE TO LOSS OF EXCITATION DURING SYNC DEFECTIVE PROCEDURE - PARALLELED OLI OF SYN
G EN1	012947	081476	FM25	M	A00	R D U T	1C DG FAILED TO START DURING SURV TEST - RECURRING EXACT CAUSE OF START FAILURE NOT KNOWN
G EN1	010605	091176	FM25	G	A10	R D I T	1A DG FAILED TO START - SURV TEST - OCCURRED PREVIOUS
G EN1	010604	061377	FM25	D	B14	F D 4 T	1C DG TRIPPO RESTARTED SATISFACT LO JACKET CLNT
G EN1	018046	061877	FM25	D	B14	I D 4 T	1C DG TRIPPO ON LO COOLNT JACKET PRESSURE
G EN1	018047	062577	FM25	D	B14	I D 4 N	1C DG TRIPPO ON LO COOLNT JACKET PRESS
G EN1	018039	081277	FM25	K	B10	D B T	1A DG LOST MANUAL VOLTAGE CONTROL

DEMAND

PLANT	CONTROL NO.	FAIL DATE	FK CM	SUBSYSTEM	FAILURE MECHANISM	FAILURE MODE	FAILURE MECHANISM
M	BV1 017021	041177	GM25	J A04 B 0 4 T #1 DG	OUTPUT BREAKER FAIL TO CLOSE--DIRTY CONTACT DESIGN CHANGE REQUEST FOR SEALED RELAYS		
M	BV1 017093	042677	GM25	J A04 B 0 4 T #1 DG	OUTPUT BKR. FAIL TO CLOSE--DESIGN REQUESTED DIRTY CONTACTS ON NFLDA(ND FIELD) RELAY		
M	BV1 017027	050977	GM25	J A04 R 0 4 T #2 DG	OUTPUT BKR. FAIL TO CLOSE--REPETITIVE STICKING RELAY(MSR2) IN MANUAL START CRT.		
M	BV1 016068	060377	GM25	J A04 R 0 1 T #2 DG	OUTPUT BKR. FAIL TO CLOSE ON FIRST ATTEMPT CLOSED ON NEXT ATTEMPT STICKY NFLDA RELAY		
M	BV1 020437	011178	GM25	J A04 R 0 4 T #2 DG	OUTPUT BKR. FAIL TO CLOSE IN EXERCISE MODE NO CAUSE COULD BE DETERMINED		
M	BV1 021647	060178	GM25	B 802 0 1 T #2 DG	LUBE OIL LEAK AT ENGINE CONTROL PANEL GAUGE GAUGE WAS CALIBRATED ON 5/21; LOOSE CONN.		
M	BV1 022437	072878	GM25	X A10 R 0 1 N #2 DG	FAIL TO FLASH DURING SI AND LOSP EVENT STICKY FIELD FLASH CUTOFF RELAY; AUDIO CRT.		
M	BV1 0223958	090578	GM25	J A00 R 0 1 T #1 DG	OUTPUT BKR. FAIL TO CLOSE; #2 DG OCS BKR CLOSED MANUALLY; 1 HOUR RUN AT FULL LD		
M	BV1 0223948	091278	GM25	J A00 R 0 1 T #1 DG	OUTPUT BKR. FAIL TO CLOSE USING CONT. SWITCH CLOSED LATER NEGATING TROUBLESHOOTING		
M	0416647	120976	M030	K A10 0 1 T C-D DG	TRIPPED ON OVERSPEED--BLOWN FUSE ON INVERTER FAIL SILICONE RECTIFIER IN DG INVERTER		
M	014162	020376	GM25	A A02 3 0 1 T EOG-2B	TRIPPED ON OVERSPEED WHILE STARTING CALIB TOOL LEFT IN FUEL RACK--RACK HLD UPN		
M	013733	083076	AL18	G 802 T 0 4 T EOG 31	BEGAN CYCLING BETWEEN 56 AND 63 CPS GOV OIL DRAIN VLV NOT SHUT TIGHTLY		
M	016035	092476	AL18	G 802 T 0 4 T EOG 31	OUTPUT FREQ INC TO 62 HZ; COULD NOT COME ELE AIR IN GCV OIL LINES FROM PREVIOUS REPAIR		
M	016286	102176	AL18	L 810 3 0 1 T	UNABLE TO CONTROL SPEED OF NO 31 DG UNIT/PARA RELAY OPER INTRMIT-DEFECTV CONN		
M	017055	081777	FM40	C A10 B 0 0 T DG 18	TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY MAIN AIR VALVE FAIL TO SHUT; CAUSED OVRSP		
M	019062	082877	FM40	C A10 B 0 0 U T DG 18	TRIPPED ON OVSPO DURING MANAL START MAIN AIR START VLV FAILED TO FULLY SHUT		
M	019359	091377	FM40	C B10 B 0 0 N DSL GEN 18	EVENUALLY TRPD ON OVSPO AFTER START MAIN AIR START VALVE FAILED TO FULLY SHUT		
M	019360	091677	FM40	C B10 B 0 0 B N DSL GEN 1-2A	EVENUALLY TRPD ON OVSPO AFTER START MAIN AIR START VALVE FAILED TO FULLY SHUT		
M	019368	100277	FM40	G A16 0 0 T DSL GEN 1-2A	FAILED TO START DURING TEST SPEED SWITCH FAILED - 120V VS 130V RATING		
M	021185	082378	FM40	C A02 0 0 N DSL GEN 18	FAILED TO COME UP TO SPEED PER TECH SP MAIN AIR START VLV PUSHER ASSY MISSING		

DEMAND

P	LN	CONTROL	FAIL	DATE	CM	SY	DESCRIPTION	FAILURE MECHANISM
							OUTPUT BRK FOR DG 18 FAILED TO CLOSE AUTOMATICALLY OPER MECH FOR AUX SWITCHS OUT OF ALIGNM	
							BLOWN FUSES FOR MOP AND MOT	
							BLOWN FUSES FOR MOP CAUSED BY FAIL DIODES	
							CPLNG BET DC MTR AND GOV POS POT WAS LOOS	
							JURPER FOR UNIT1/UNIT2 SEPAR INCRCCTLY POS	
							CARBON BILLOUP DUE TO SHORT DURATION OPER	
							SYNCRD MOTOR LIMIT SWCHS ADJUSTED IMPROP	
							HOSE CLAMPS ON PIPE NOT CONN AFTER MAINT	
							DIRT IN LWR BRNG UF OVRCRT RELAY IMG DISC	
							WEST 662A143H01 LATCH-CHKNG SW DEFECTIVE	
							FUEL RACK BINDING-INCORP PROC TO EXERCISE	
							#17 CYL FLOODED - CAUSED BROKEN INTERNALS	
							ARMATURE SHAFT BROKEN--REPLACED W SPARE	
							STARTING AIR DIST BUSHING ROTATED IMPROP	
							RAG IN LIL STRAINER CAUSED LU CIL PRESS T	
							GOV SPD CONT GEAR JAMMED AGNST HI SPD J10	
							CAVITATION OF LO PUMP - WATER IN LUBE LIL	
							GOV SYNCH IND GR JAMMED ON HI SPD STOP	

TIME

UNIT	CONTROL	FAIL DATE	M K G M	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
B A01	G19578	102377	GM25 C A14	#1 DG FAILED TO START; DRIFT OF TO RELAY SETPOINT	ALSO DIODE CR-1 FOUND SHORTED	
B A01	G24663	032078	GM25 E 800	T G T DG #2 ON FIRE DUE TO LUBE OIL GETTING INTO EXHAUST	TURBOCHARGER BRNG FAILED, CAUSING SEAL FAILURE	
B CR3	018231	060277	FM30 A A13	T 4 T MAM DG FAILED TO START ON MONTHLY TEST	LOOSE INJECTOR HOLD-DOWN NUTS	
B DB1	020273	010978	GM25 F A09	T 4 T DG 1-1 TRIPPED ON HI CRANKCASE PRESSURE	DIRTY CRANKCASE VENT OIL COLLECTOR	
B T11	G20295	011278	FM30 B A14	T 4 T EUG 1B FAILED TO START ON SIMULATED AUTOCES TEST	OIL PRESS LIM SW PRESS SETTING DRIFTED	
B T11	020997	031878	FM30 B A10	T 8 T EUG FAILED TO START	DEFECTIVE OIL PRESSURE LIMIT SWITCH	
B T12	G21605	052378	FM30 F B09	R T B M DG B TRIPPED ON HIGH CRANKCASE PRESS - 32 MIN RUN	PART PLUGD DRIFICE PLATE-TO-CRCKSE VAC EJC	
B T12	G23430	122878	FM30 A A09	T 8 T DF-X-18 DID NOT START	PARTIALLY CLOGGED FUEL OIL FILTER	
C CC1	017822	051577	FM25 M A09	R T B T #12 DG FAN FAILED TO START WHEN GEN RECEIVED SIGNAL	DIRT ON FAN MAIN BRK CONTACTS	
C CC1	019592	101077	FM25 K A13	T 8 T #12 DG FAILED TO REACH VOLTAGE WITHIN 10 SEC.	2 LOOSE FUSE HOLDERS IN EXCITATION CIRCUIT	
C CC2	016722	121576	FM25 C A09	T 4 T #21 DG FAILED TO START FROM CONTROL ROOM & LOCALLY	CLOGGED AIR START DISTRIBUTOR PILOT VALVES	
C CC2	017986	060177	FM25 D A12	T D T #21 DG FAILED TO MEET START TIME CRITERIA	SERVICE WATER INLET VALVE LEAKING EXCESSV	
C CC2	G20226	011078	FM25 J B10	T 1 T #21 DG TRIPPED AFTER 29 MIN. DUE TO GEN FAULT	LOSS OF FIELD & REVERSE POWER RELAYS	
C FC1	G45614	081576	GM25 G B10	I B N SMOKE CURING FROM DG-2 GOVERNOR MOTOR ENCLOSURE	ARMATURE HAD OPEN WINDING	
C FC1	G176628	040677	GM25 C A09	R T 4 T DG-1 FAILED TO START WITHIN 10 SEC; START OK ON PH1 AIR	DEPOSITS FOUND ON SECONDARY AIR MOTORS	
C FC1	G17662A	041477	GM25 C A09	R T 4 T DG-2 FAILED TO START IN 10 SEC. START OK ON PRIMARY	DEPOSITS IN SECONDARY AIR MOTORS	
C M12	G14200A	021776	FM25 A A09	B T 1 N DG 12U FAILED TO START - SIMILAR OCCUR#175-23	DIRTY FUEL OIL FLTR; CARBON IN CRKCE VENT	
C M12	G14200B	021876	FM25 A B09	B T 1 N DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR#175-23	DIRTY FUEL OIL FLTR; CARBON IN CRKCE VENT	
C M12	G14200C	022076	FM25 A B09	B T 1 N DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR#175-23	DIRTY FUEL OIL FLTR; CARBON IN CRKCE VENT	
C M12	G142600	022476	FM25 F B04	B T G N DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR#175-23	UPPER ROD BEARING FAILURE - LACK OF LUBRI	

TIME

UNIT	CONTROL NO.	FAIL DATE	PK CM	FAILURE MODE	FAILURE MECHANISM
C	M12 015106	080276	FM25 F	OG 13U TRIPPED ON HI CRANKCASE PRESS - 11 MIN RUN	CRKCS AIR EJECTOR FOUND DIRTY
C	M12 015583A	081676	FM25 G	A16 B T 4 T DG 12U FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C	M12 015583B	081776	FM25 G	A10 B T 4 T DG 12U FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C	M12 015583C	082376	FM25 G	B10 B T 4 T DG 12U TRIPPED OFF-LINE	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C	M12 015906	090176	FM25 B	C 11 N DG 13U SHUTDOWN - FIRE ON EXHAUST MANIFOLD	LJBE C FUEL CIL ACCUM UNDER MANIF INSULAT
C	M12 016031	092276	FM25 D	B09 B T 6 T 12U DG RECD LOW CM FLD ALA-UNIT UNLOADED, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12 016626	120176	FM25 D	A09 B T 6 T 13U DG STARTED, NO CM FLOW, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12 016972	081777	FM25 D	B09 B T 6 T 12U DG LOW CM FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12 018976B	092077	FM25 D	B09 B T 6 N COOLING MTR LOW FLOW ALARM - 12U DIESEL GEN	INSUL CL INJECTION FOR ADD MUSSEL CONTRCL
C	M12 019255	092477	FM25 J	B14 S I 8 Y 12U DG APPEARED TO TRIP ON GEN OVERCURRENT	MICRO SW CUT OF ADJ ON DG OVSPD TRIP MECH
C	M12 021386	090678	FM25 D	B09 B T 6 T 12U DG LOP CM FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12 022431	080378	FM25 A	B07 I 8 T DG 13U SHUTDOWN DUE TO LEAKING INJECTOR	CRACK IN INJ PUMP DISCH VALVE CAGE
C	M12 023213	120576	FM25 D	B09 B T 6 T 12U DG S/D DUE TO LOW COOLING WATER FLOW	MUSSEL SHELLS IN THE HEAT EXCHANGER
C	M11 020733	021878	GM25 G	A09 I M T DG-1A FAILED TO RESPOND DURING TEST RUN FOR TRAINING	DIRTY CONTACT ON SPEED CONTROL PC BOARD
C	511 017134	011877	GM30 E	B04 R T 6 T 18 DG RAM FOR 55 MIN THEN TRIPPED ON LOCKOUT	TURBOCHARGER SHAFT AND OIL SEAL DAMAGED
C	511 017135A	011977	GM30 A	A09 R I 1 T THE 1A DIESEL GENERATOR FAILED TO START	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C	511 017135B	011977	GM30 A	A09 R T 1 T THE 1A DG FAILED TO START AGAIN - LATER SAME DAY	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C	511 019211	092677	GM30 E	B04 R T 6 T 1A DG SHUTDOWN WHEN SMOKE ISSUED FROM TURBOCHARGER	FAILED TURBO CHARGER UNIT
C	511 022432	090576	GM30 J	A10 T 8 T "A" DG OUTPUT BREAKER WOULD NOT CLOSE REMOTELY	DIRTY CONTACTS ON ITS OPERATION RELAY
C	811 014102	011476	GM30 G	A12 I 1 T FAILED TO RESPOND TO ELEC. GOVNR SIGNALS DG #0	OIL DRAIN FROM HYDRAULIC ACTUATOR

TIME

PLANT	CONTROL NO.	FAIL DATE	M K DATE	MODE	FAILURE MODE	FAILURE MECHANISM
G	BP1 016261	116376	GM30	G	D DG ERRATIC SPEED BEHAVIOR UNDER LOAD	DIRTY OIL IN GOVERNOR
G	BP1 014417	032476	CA02	D	BP1 DG TRIPPD ON HI COOLING WATER TEMP	WATER PUMP SUCTION SCREEN PLUGGED
G	BP1 014894	051676	CA02	D	BP1 DG TRIPPD ON HI COOLIN WATER TEMP PUMP SHAFT SCORED	INLET SCREEN PARTIALLY PLUGGED
G	BP1 015444	081276	CAC2	C	BP1 WEEKLY TEST FAILED TO START	STARTING BATTERY CABLE FAILED LOOSE CONNEX
G	BP1 018102	051877	CA02	D	BP1 H2O JACKET HEATER FAILURE--EDG TESTED; DID NOT MEE T TIME CRITERIA; EXCEEDED BY 12 SECONDS	AIR LEAKAGE ON PUMP COOLING WATER SHAFT
G	BP1 020580	020978	CA02	D	BP1 DG TRIPPD ON HI WATER TEMP AFTR 25 MIN OF OPS	CARBON BUILDUP ON AIR VALVE STUCK SHUT
G	BP1 020008	120977	NM30	C	BP1 DG START TIME 10.2 SEC VS 10	FAULTY FUEL PUMP REPLACED
G	BP1 022454	091178	NM30	A	BP1 DG CYLINDER #1 NOT FIRING--HEAVY LOADING ???	FUELOIL SHIFT VALVE LEAKN GASKET RENEWED
G	BP2 014614	031476	NM30	A	BP2 AT 96: POWER #2 DG STARTED TO CYCLE IN LOCAL-MANUL	CHECK VALVE RUSTED SHUT
G	BP2 016399	111176	NM30	C	BP2 DG FAILD OPER TEST--12.2 ON #2 AIR RECEIVER	CLUTCH ADJUSTED AND STATOR VOLTMR REPLAC
G	BP2 016823	122976	NM30	G	BP2 DG FAILD OPERABILITY TEST --LOSS OF SPEED CONT.	POT. TRANSFORMER FUSE CONTACTS OXIDIZED
G	CO1 016560	110776	CB40	K	CO1 DG-2 LOST ELECT GOVERNOR CONTROL AND VOLTAGE	MAIN BEARING FAILED DUE TO LOW LUBE OIL
G	CO1 023044	091278	CB40	F	CO1 DG TRIPPD APPROX 1 MIN AFTER REACH RATED SPEED	OIL LEAK FROM FRONT COVER PLATE
G	DA1 014334	022776	FM25	B	DA1 SMALL FIRE ON EXHAUST MANIFOLD OF DG 1021	1021 LEAKY FLANGE GASKET
G	DA1 014337	031776	FM25	H	DA1 SMALL FIRE NEAR EXHAUST MAN-TURBOCHRG R FLANGE	1021 LEAKY FLANGE GASKET
G	DA1 014953	062276	FM25	D	DA1 DG TRIPPD ON HI JACKET TEMP--DECLARED INOPRBL	EGW LOW FLOW DUE TO MUD IN STRAINER
G	DM1 021517	050776	GM16	B	DM1 TEMPORARY DG FAILD TO START DUE TO LOW LUBE OIL PPS	L.G. PUMP COUPLING DAMAGED
G	DR2 016168	093076	GM25	K	DR2 DG OUTPUT ERRATIC AFTR CONTROL PLACED IN "STOP"	SHORTD SELENIUM RECTIFIER DUE TO DIRTY
G	DR2 016443	102976	GM25	I	DR2 UNIT 2 DG FAILD TO START TWICE MALFUNCI S/D SCLEND	SOLENOID PLUNGER OUT OF ADJUSTMENT
G	DR2 014951	103477	GM25	E	DR2 UNIT 2/3 UNLOADED TRIPPD ON LOW H2O PRESS	RESTART TURBO-CHARGE CLUTCHESHAFT BEARING

TIME

PLANT CONTROL NO.	FAIL DATE	FAIL TIME	FAILURE MODE	FAILURE MECHANISM
G DRZ 019723	10277	GM25 C	UNIT 2 DG AIR RECEIVER LOW PRESS	LOOSE WIRE AT TERMINAL 25A5
G DRZ 020242	010378	GM25 C	UNIT 2 DG FAILED TO START WEEKLY SURV TEST	LOOSE WIRE AT TERMINAL 25A5
G DR3 C44439	030376	GM25 G	UNIT 4 DG COULD NOT BE LOADED FROM CONTROL ROOM	GOVNR CONTROL WIRE VIBRATED FREE FROM LUG
G DR3 016015	021176	GM25 B	UNIT 4 DIESEL 3 RECEIVED HI TEMP ALARM	PARTIALLY CLOGGED STRAINER IN L.O. CIRC PMP
G DR3 016107	100976	GM25 G	LOSS OF CONTROL ROOM SPEED CONTROL	LOOSE WIRE ON GOVNR CONTROL CIRCUIT
G DR3 016425	110576	GM25 G	UNIT 8 T LOST SPEED CONTROL FROM CONTROL ROOM	FAILED OVERTRAVEL LIMIT SWITCH ON GOVNR
G EN1 014705	050176	FM25 M	UNIT 8 T NORMAL SURV. TEST DG IC TRIPPED; LOOSE WIRE	NUT VIBRATED OFF WIRE-PANEL R43-P001C
G EN1 020214	112577	FM25 G	UNIT 1A DG FAILED TO START; STUCK GOVNR BOOSTER SERVO MOTOR	AIR PISTON WAS CORRODED
G EN2 022721B	103178	FM25 G	UNIT 1B MCM DIESEL FAILED TO REACH 250RPM IN 7 SEC.	FAULTY ELECTRONIC SPEED SWITCH SIGNAL
G FPI 020510	021578	GM25 J	UNIT 1E MCM EDG TRIPPED DURING SURVEILLANCE TEST	BLOWN FUSE IN SYNCH CKT FOR OUTPUT BRKR
G M01 016100	101076	GM25 C	UNIT 1D T DIESEL FAILED TO START ON #2 STARTING SYSTEM	#2 START SYS AIR CONT COMP FOULED W MUST
G P82 022402	083078	FM30 G	UNIT 1E-3 DG START TIME DID NOT MEET TS REQUIREMENT	LEAKY CRK VLV IN AIR BOOSTER RELAY HYD 3Y
G P11 015905	022276	AL25 H	UNIT 1E MCM DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
G P11 016300	111776	AL25 H	UNIT 1E MCM DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
G Q01 019100	082477	GM25 L	UNIT 1 DG STARTED AND RAN BUT NO VLTG/SYNCH/FREQ	FREQ GEN TACH SET SCREWS VIBRATED LOOSE
G W11 014740	050676	FM30 F	UNIT 4 M DIESEL GENERATOR TRIPPED ON HI CRANKCASE PRESS	CLOGGED CRANKSE EJ SUP ORIFICE ON EJ BODY
G W11 015739	082576	FM30 A	UNIT 1 T DIESEL GENERATOR TRIPPED ON HI CRANKCASE PRESS	ENGINE VIBRATION LOOSE/OLD MECHANICAL CONN
G W11 016323	062377	FM30 F	UNIT 4 T DIESEL GENERATOR TRIPPED ON HIGH CRANKCASE PRESSURE	VIBRIN CALDED HOSE CLMP ON AIR EJECT FAIL
G W11 019620	072677	FM30 G	UNIT 4 T DIESEL GENERATOR FAILED TO START	AIR START SOL VALVES BOUND CLSD BY DEBRIS
G W11 020104	121977	FM30 F	UNIT 4 T DIESEL GENERATOR TRIPPED ON HIGH CRANKCASE PRESSURE	ENG VIB CAUSED AIR EJECT HOSE TO LOOSEN

TIME

UNIT	CONTROL NO.	FAIL DATE	PK G M	SUB	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
G	W1	020464	FM30	D	009	T 4 T DIESEL GENERATOR MAN TRIPPED ON HI JACKET CLNG TEMP 3-WAY VLV BLOCKED TO BYPASS CLNT ARMD HA	WATER ACCUMULATION IN AIR START SYSTEMS
M	BV1	014903	GM25	C	A09	R 4 N DG #1 FAILED TO START 3 TIMES DG #2 STARTED OK	MOISTURE IN STARTING AIR
M	BV1	017696	GM25	C	A09	R 4 N DG #1 FAILED TO START REPETITIVE	
M	BV1	018828	GM25	K	A10	R 4 T #2 DG STARTED AND CLOSED ONTO BUS:OUTPUT VOLTS =0, LOOSE CONNECTIONS IN AUTO FIELD FLASH CRT	
M	BV1	021355	GM25	A	B12	T D N #1 DG WAS S/D AND DECLARED IMPERABLE... L LEAKS	FLAM IN FUEL OIL PUMP DISCHARGE PIPE NIPL
M	DC2	021681	W030	A	B07	T 6 T 2CD DG WIDELY VARYING CYLNDR TEMP TAGGED OUT	FUEL INJECT. PUMP FAIL
M	DC2	022026	W030	G	B10	R 4 T #2 AB DG OVERSPED WHL UNLOADG PREVIOUS OCCURRENCE	WORM LINKAGE CAP SCREW BROKE IN GOVERNOR
M	DC2	022563	W030	C	A13	T 4 T 2AB STARTED FOR LOAD TEST WAS TRIPPED OFF MANUALLY PISTON BELT FOR AIR CHECK Y Y W LOOSE	
M	JF1	026492	FM40	C	A09	C I D T D5L GEN 1B FAILED TO ATTAIN RATED SPEED	CORROSION PRODUCTS CLOGGED START VLVs
M	JF1	020996	FM25	C	A09	C I B T D5L GEN 1C FAILED TO START DURING TEST	CORROSION PRODUCTS CLOGGED AIR START VLVs
M	PH1	018342	FM30	G	B10	T 8 T D2 DG FAILED TO RESPOND TO LOAD CHANGE SIGNALS	LINK LEVER KEY MISSING CAPSCREWS LOOSE
M	PH1	018417	GM25	I	A14	J 4 T 30 DIESEL GENERATOR FAILED TO START - LOGIC FAILURE SPEED SENSING ASSY SETPOINT DRIFTED	BAD CONN AT CONT PWR FUSE BLOCK STUBS
M	RG1	022450	AL18	J	A10	T 8 T B EDG OUTPUT BREAKER WOULD NOT CLOSE	# 12 CYL INJ PLUNGER & BARREL GALLED
M	R02	014823	FM25	A	B07	R 4 T #8 EMER DIESEL DID NOT REACH RATED CAPACITY	SEVERAL FUEL INJ RODS WERE STICKING
M	R02	019354	FM25	A	B07	R 4 T #8 EMER DIESEL GEN FAILED TO ASSUME FULL LOAD	CONN BRUSH VIBRATED OUT OF GOV SPD CHGR
M	R02	021313	FM25	G	B13	T 4 T EDG LOAD FAILED TO INCREASE ABOVE 900KW	SEVERAL FUEL INJ RODS WERE STICKING
M	S41	018799A	AL25	A	A10	C I N 1A DIESEL INOP-FAILED TO REACH RATED SPEED ON STRT	CRACK FOUND ON 3/8" PIPE NIPLLE
M	S41	018799B	AL25	A	A10	C I N 1B DIESEL INOP-FAILED TO REACH RATED SPEED ON STRT	CRACK FOUND ON 3/8" PIPE NIPLLE
M	S41	019420	AL25	D	B13	B 4 T 1C DIESEL DEVELOPED WATER JACKET LEAK	
M	S41	019424	AL25	E	B04	T 6 T 1B DIESEL DECLARED INOP-TURBOCHGR & EAM EXP JT FLD CAUSE DETERMINED TO BE TURB BLADE FAILURE	

TIME

PL	CONTROL NO.	FAIL DATE	PK CM	FAILURE MODE	FAILURE MECHANISM	
W	501	021310	032576	DL10 A	NO 1 DIESEL GENERATOR FAILED TO START	FUEL LNKG BINDING -- BEARINGS IN LNKG DRY
W	TR1	018447	062277	GM40 G	BL0 F 4 N WEST DG FAILED TO ASSURE MIN REQUIRED LOAD	BRUSH FALLEN OUT OF DC GOV DRIVE MOTOR
W	TU3	017591	020377	GM25 A	A12 R Y U T DG "B" FAILED TO START	PROBABLE-AIR IN FUEL SUPPLY LINES
W	TU3	018147	033177	GM25 A	A12 R T 4 T DG "B" DID NOT REACH SPEED 6 VLTG WITHIN SPEC TIME	AIR IN FUEL LINE-CRACKS IN SUCTION TUBING
W	TU3	021919	060178	GM25 A	BL0 T 4 B DG HI LEVEL IN FUEL TANK (ENG.MOUNTD) DG S/D	LEVEL SWITCH MALFUNCTION--REPLACED SWITC
W	YR1	010653	080277	GM02 D	BU9 C T D T B1 DG OVERHEATED--RUNNING FOR APPROX 25 MINUTES	SLUDGE AND SCALE IN 672 OF RADIATOR TUBES
W	YR1	018654	080277	GM02 D	BU9 C T D T B3 DG OVERHEATD AFR 30 MIN. OF OPERATION	727 OF RADIATOR TUBES BLOCKED SLUDGE SCAL
W	Z11	015469	062176	CB40 A	BL3 T 4 N 14 DG HAD FD LEAKAGE AT THE 8L FUEL INJ PUMP	WIB CAUSED CRACKED FENG DN LINE TO INJ
W	Z11	020255	010378	CB40 K	BL0 K T D T 18 DG OUTPUT VOLTAGE PEGGED HIGH-COULD NOT LOWER	PC BOARD FAILURE IN THE VOLTAGE REGULATOR
W	Z11	0203488	011678	CB40 G	BL0 F 4 T DG "M" STARTED 6 LOADED* BUT DECLARED INOPERABLE	LD CONTRLL AIR PRESS-TRIP VLV "M" RING LR
W	Z11	022110	080178	CB40 C	AL0 T 1 T 18 DIESEL GENERATOR FAILED TO START	AIR LEAK IN STARTING AIR PILOT VALVE
W	Z12	017809	050677	CB40 I	BL3 C T 4 T DIESEL GENERATOR 2A TRIPPED FROM FULL LOAD	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
W	Z12	019780	111777	CB40 I	BL3 C T 4 T "U" DIESEL GENERATOR TRIPPED OFF-LINE	LEAK IN 402 LINE TO MASTER SHUTDOWN VALVE
W	Z12	020258	010678	CB40 K	BL0 K T 8 T 2A DG OUTPUT VOLTAGE INCREASED AND COULD NOT LOWER	BURNED CONTACT IN THE VOLTAGE REGULATOR
W	Z12	021544	051778	CB40 K	BL4 T 8 T 2A DG OUTPUT VOLTAGE CYCLED - COULD NOT CONTROL	DRIFT OF VLTGE REGULATOR STABILITY CIRCUIT

UNKNOWN

V L N Y	CONTROL	FAIL DATE	PK G M	RECOVERY	FAILURE MODE	FAILURE MECHANISM
B CK3	023106	111778	FM30	M	EDG-B FAILED TO FAST START ON TWO CONS. ATTEMPTS	STARTED SUCCESSFULLY TWICE AFTER ANOMALY
B 081	021580	050978	GM25	E	U G T GEN LOAD FLUCTUATING AIR INTAKE LO PRESS ALARM	CAUSE UNKNOWN EXTENSIVE MAINT PERFORMED
B 051	015359	071576	GM25	M	U D T SEVERAL ATTEMPTS TO START "B" DG WERE UNSUCCESSFUL	NO DEFINITE CAUSE COULD BE FOUND
B 051	010853	082477	GM25	M	U I T DIESEL GENERATOR "B" FAILED TO START	NO SPECIFIC CAUSE COULD BE DETERMINED
B 112	021069	042978	FM30	F	U I T "B" DG TRIPPED ON HI CRANKSE PRESS AFTER 32 MIN RUN	NO ABNORMAL PARAMETERS WERE FOUND
C C01	016405	102576	FM25	M	U I T #12 DG S/D DUE TO DG VENT FAN STOPPED-BLOWN FUSE	CAUSE FOR BLOWN FUSE NOT DETERMINED
C C01	017113	111876	FM25	M	U I T #12 DG S/D DUE TO ITS VENT FAN NOT STARTING	BLOWN FUSE--REPLACED CONTROLLER COIL ??
C C01	021060	041678	FM25	L	U I T #12 DG OVERSPEED & TRIPPED RESTARTED SUCCESSFULLY	CAUSE NOT DETERMINED TESTED SAT NEXT TIM
C C01	021055	041378	FM25	M	U I T #11 DG FAILED TO START ON LOSS OF OFFSITE POWER	START/FAILURE ALARM DISPLAYED NO ABNORMALS
C C02	018422	022277	FM25	C	U B T #21 FAILED TO START & ASSUME RATED SPEED IN 10 SEC	AIR START SYS DISASSEMBLED & INSPECTED
C C02	017457	031777	FM25	M	U I T #12 DG VENT FAN FAILED TO START ON STAS SIGNAL	OVERLOADS TRIPPED ON FAN; RESET OVERLOADS
G 8P1	015448	080576	CA02	M	U U T DG FAILED TO START WITHIN 15 SEC NLT RETESTED	OPERATOR NOT AWARE OF SIGNIF OF START TIM
G 8P1	015449	080576	CA02	U	U B N DG FAILED TO START WITHIN 15 SECONDS DURING WEEKLY	POSSIBLE WATER JACKET HEATER FAILURE
G 8P1	016074	090276	CA02	A	U U T FAILED TO MEET 15 SEC START TIME DURING WEEKLY TEST	POSSIBLE FUEL SYSTEM FAILURE
G 8P1	016304	102876	CA02	G	U U T DG FAILED TO START WITHIN 15 SEC	POSSIBLE FUEL GOVERNOR CONTROL PROBLEM
G 8P1	016460	110476	CA02	G	U U T START TIME 2.2 SEC SLOWER THAN REQUIRED	POSSIBLE FUEL GOVERNOR PROBLEM
G 8P1	016597	120276	CA02	G	U U T FAILED TO MEET 12 SEC START TIME DURING AUTO TEST	FUEL GOVERNOR REPLACED ON 12/19/76
G 8P1	016913	122076	CA02	G	U U T START TIME EXCEEDED CRITERIA BY 4 SEC	GOVERNOR LUBE & FUEL SYS UNDER INVESTIGATION
G 8P1	016912	122776	CA02	A	U U T START TIME GT. CRITERIA 15 VS 12	FUEL GOV. LUBE OIL SUPPLY MODIFIED 1/10/77
G 8P1	016910	010377	CA02	G	U U T FAILED TO START IN AUTO TEST	CAUSE UNKNOWN LUBE OIL RETENTION IN GOV.?

UNKNOWN

PLANT	CONTROL NO.	FAIL DATE	FEK	UNIT	FAILURE MODE	FAILURE MECHANISM
G BPI	024298	032477	CA02	G	EDG STARTING TIME EXCEEDED 12 SEC. BY .8 SEC.	GOVERNOR LUBE SYS MODIFIED ON 1/10/77
G BPI	018103	052677	CA02	A	U T START TIME 16.5 SEC, SHOULD BE LT 13.9 SEC	FUEL CONTROL VALVE MODIFIED
G BPI	019541	102677	CA02	C	U T START TIME 21.8 SEC VS. 13.9 SEC	CHECKD VOLTAGE DROP ON START CABLES
G BPI	019993	112477	CA02	A	U T START TIME 33 SECS TESTED SAT WITHIN ONE HOUR	FUEL CHECKED ON PREM GRADE OF FUEL USED CAUSE UNKNOWN
G BPI	020575	020278	CA02	M	U T START TIME 28.5 SECS VS 13.9 SECS	CAUSE UNDETERMINED
G C01	015872	082376	CB40	A	U T FUEL LINE TO AN INJECTOR OF #1 DG BURST	CAUSE UNKNOWN BUT POSSIBLE AIR START SYS
G DR2	014913	052376	GM25	C	U T UNIT 2/3 DG FAILED TO START	CAUSE UNKNOWN BUT POSSIBLE AIR START SYS
G DR2	019905	120477	GM25	J	U T U2 DG OUTPUT BRK FAILED TO CLOSE--NO APPARENT CAUSE	3 SUBSEQUENT TESTS WERE SUCCESSFUL
G DR2	022262	082478	GM25	C	U T UNIT 005 UNIT 2 FAILED TO START ON 1ST ATTEMPT	PINION GEAR NOT ENGAGED ON AIR START MTR
G DR2	022589	092278	GM25	C	U T UNIT 2/3 FAILED TO START; AIR STRT MTRS ENGAGED	AIR-START SYS WILL BE MODIFIED
G EN1	014796	051576	FM25	M	U T U2 DG FAILED TO START ON FIRST ATTEMPT	UNKNOWN WILL DG WEEKLY START TO DETERMINE
G EN1	016842	122576	FM25	M	U T U2 DG TRIPPED APPROX 45 MIN. OF RUN TIME; REPETITIVE CHECKING OUT LOGIC ON 1C DG	INSPECTED & RETESTED SATISFACTORILY
G EN1	016843	123176	FM25	M	U T MAN START OF 1A DG FAILED THIS HAS HAPPND BEFORE	TIME TOOK 18 SEC VS 12 SEC RETESTED SATISFAC
G EN1	018141	052877	FM25	M	U T 1A DG FAILED TO COME UP TO RATED VOLT IN REQD. TIME	BEARING OVERHEATED - EXACT CAUSE UNKNOWN
G EN1	020031	081877	FM25	F	U T DURING SURV TESTING, DG 18 GEN INBOARD BRNG FAILED	CONTROL SEQ FAULT - HOWEVER, SEQ CORRECT
G UC1	015042	060876	GM25	C	U T DG #2 FAILED TO START DURING OPERABILITY TEST	CAUSE COULD NOT BE DETERMD AFTER ENTV TST
G P82	020040	121977	FM30	L	U T E1 DG TRIPPED ON "M" PHASE DIFF AFTER PARALLELING	POSSIBLE GOVERNOR PROBLEMS
G P82	023349B	122178	FM30	G	U T E2 DG START TIME 11 SEC. VS. 10 SEC	NO APPARENT CAUSE
M RV1	015913	090376	GM25	J	U T #1 DG OUTPUT BREAKER FAILED TO CLOSE	FRACTURED AIR START CHECK VALVE
N DC2	020984	031978	MD30	C	U T 2CD DG GASKETS ON AIR LINE TO #5 CYL BLEW OUT	

UNKNOWN

PLANT	CONTROL NO.	FAIL DATE	ENGINE	FAILURE MODE	FAILURE MECHANISM
DC2	022839	101978	M030 A	U I T 2AB FAILED TO START DUE TO LACK OF FUEL TO INJECTORS UNKNOWN BUT REPLACED FUEL FILTER ELEMENT	
KEL	039519	102577	G425 M	U U T 0/G 1A STARTED & WAS AT 70 RPM WHEN IT STOPPED	COULD NOT DETERMINE CAUSE OF FAILURE
TR1	018667	042577	G440 M	U U M EDG FAILED TO START ON LCSP (PARTIAL) THE 2ND TIME	NO LER FOR DG FAILURE JUST THE LCSP
Z11	016174	092476	CR40 M	U U I "CM" DIESEL GENERATOR FAILED TO START	NO CAUSE COULD BE DETERMINED
Z11	023308	122078	CR40 M	U D M 1B DG FAILED TO START DURN AN INADVERTNI SAFETY INJEC EXTENSIVE TESTING REVEALD NO CAUSE	

APPENDIX M

DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY REPAIR-TIME INTERVAL

CODES USED IN LER ONE-LINE DESCRIPTIONS

REPAIR TIME

CODE	DESCRIPTION
1	U TO 1 HOURS
4	1 TO 4 HOURS
8	4 TO 8 HOURS
0	8 TO 24 HOURS
G	GREATER THAN 24 HOURS
U	UNKNOWN / NOT APPLICABLE

FAILURE MODE

CODE	DESCRIPTION
A	DOES NOT START
B	DOES NOT CONTINUE TO RUN
U	UNAVAILABLE / NONFAILURE

FAILURE CLASSIFICATION

CODE	DESCRIPTION
D	DEMAND
T	TIME
U	UNKNOWN

SUB-SYSTEM

CODE	DESCRIPTION
A	FUEL OIL SYSTEM
B	LUBE OIL SYSTEM
C	STARTING SYSTEM
D	COOLING SYSTEM
E	SCAVENGING AIR SYSTEM
F	ENGINE FRAME / INTERNALS
G	GOVERNOR
H	EXHAUST SYSTEM
I	SHUTDOWN SYSTEM
J	OUTPUT BREAKER
K	EXCITER / VOLTAGE REGULATOR
L	GENERATOR
M	OTHER / UNKNOWN

FAILURE MECHANISM

CODE	DESCRIPTION
00	UNKNOWN
01	PERSONNEL OPERATION
02	PERSONNEL MAINTENANCE
03	PERSONNEL TESTING
04	DESIGN ERROR
05	FABRICATION / CONSTRUCTION / QUALITY CONTROL
06	PROCEDURAL DISCREPANCY
07	DEFECTIVE FUEL INJECTOR(S)
08	CORROSION / EROSION
09	FOREIGN MATERIAL CONTAMINATION
10	MECHANICAL / ELECTRICAL CONTROL
11	HI / LOW AMBIENT TEMPERATURE
12	LUBE / FUEL / WATER / AIR LEAKAGE
13	VIBRATION
14	OUT OF ADJUSTMENT / CALIBRATION

METHOD OF DISCOVERY

CODE	DESCRIPTION
M	DURING MAINTENANCE
N	DURING NORMAL OPERATION
R	DURING RECORDS REVIEW
T	DURING TESTING
U	UNKNOWN

TYPE OF EVENT

CODE	DESCRIPTION
B	RECURRING COMMON CAUSE
C	COMMON CAUSE
R	RECURRING
T	COMMAND FAULTS
Y	RECURRING COMMAND FAULTS

NSSS VENDOR

CODE	DESCRIPTION
B	BABCOCK & WILCOX
C	COMBUSTION ENGINEERING
E	GENERAL ELECTRIC
W	WESTINGHOUSE

UG MANUFACTURER

CODE	DESCRIPTION
AL	ALCO
CA	CATERPILLAR
CB	COOPER-BESSEMER
DL	DE LAVAL
FM	FAIRBANKS MORSE
GM	GENERAL MOTORS
NM	NORDBERG MANUFACTURING
WO	WORTHINGTON

KW RATING

CODE	DESCRIPTION
C2	200-400 KW
10	500-1000 KW
18	1750-1450 KW
25	2500-2850 KW
30	3000-3900 KW
40	4000-4410 KW

C TO 1 HOURS

P	N	L	A	C	CONTROL	FAIL	M	F	Q	DI			
					NO.	DATE	K	L		S			
B	CM3	018265	072677	FM30	I	A06	S	0	I	"B38	DG	FAILED TO START DIESEL TRIPS WERE NOT RESET REVISED PROCEDURES TO RESET TRIPS	
B	CM3	023108	111778	FM30	M	AUG	K	U	I	"E06-B	FAILED TO FAST START ON TWO CONS. ATTEMPTS	STARTED SUCCESSFULLY TWICE AFTER ANOMALY	
B	RJ1	018653	082477	GM25	M	A08	R	U	I	"DIESEL	GENERATOR "B" FAILED TO START	NO SPECIFIC CAUSE COULD BE DETERMINED	
B	RJ1	022213	100478	GM25	A	B01	S	U	I	"M	DG	370 DUE TO SPRAY OF FUEL OIL; "B" DG 005	FUEL LEAK-EXCESSIVELY LOOSENEED STINK PKG GEND
B	RI1	014298	022176	FM30	J	A06	S	0	I	"18"	DG	OUTPUT BREAKER FAILED TO CLOSE	PROCD ERROR--IMP COM SETTING-FREQ TOO LOW
B	RI2	021609	042578	FM30	F	B00	K	U	I	"B3"	DG	TRIPPED ON HI CRKCKSE PRESS AFTER 32 MIN RUN NO ABNORMAL PARAMETERS WERE FOUND	CAUSE FOR BLOWN FUSE NOT DETERMINED
C	CC1	016405	102576	FM25	M	B00	R	U	I	"12	DG	370 DUE TO DG VENT FAN STOPPED-BLOWN FUSE	BLOWN FUSE--REPLACED CONTROLLER COIL BY
C	CC1	017413	111076	FM25	M	A00	R	U	I	"12	DG	370 DUE TO ITS VENT FAN NOT STARTING	VALVE VIBRATED LOOSE AND FELL OFF DG
C	CC1	018300	061777	FM25	F	B02	D	I	"11	DG	STARTD:LATER DISCOVERED #6 CYLINDER RELIEF	SIGNAL REMOVED:TOP SWITCH ISOLATED	
C	CC1	018467	071377	FM25	D	B02	S	0	I	"11	DG	TRIPPED ON LOW JACKET COOLMT PRESS WHEN STIAS	CAUSE NOT DETERMINED TESTED SAT NEAT LIM
C	CC1	021060	041078	FM25	L	A00	U	I	"12	DG	OVERSPED & TRIPPED RESTARTED SUCCESSFULLY	START/FAIL: E ALARM DISPLAYD NO ABNORMAL	
C	CC1	021055	041378	FM25	M	A00	M	I	"11	DG	FAILED TO START ON LOSS OF OFFSITE POWER	FAN FAILURE--RESET OVERLOADS	
C	CC1	023380	121078	FM25	M	B00	R	U	I	"11	DG	SHUTDOWN DUE TO ROOM VENT/FAN FAIL TO STRT	OVERLOADS TRIPPED ON FAN; RESET OVERLOADS
C	CC2	017457	031777	FM25	M	A00	K	U	I	"12	DG	VENT FAN FAIL TO START ON STIAS SIGNAL	LOSS OF FIELD & REVERSE POWER RELAYS
C	CC2	020226	011078	FM25	J	B10	I	"11	DG	TRIPPED AFIR 29 MIN. DUE TO GEN FAULT	PROCEDURE WAS INADEQUATE		
C	FC1	014559	040776	GM25	M	A06	S	0	I	"T	START	ON SECONDARY AIR REUD 16.6 SECS+VS. 10SECS.	BLOWN FUSE IN GEN FIELD CIRCUIT
C	FC1	021692	061978	GM25	K	A10	R	U	I	"DG-1	FAILED TO REACH RATED TERM VLTG ON STARTUP	DIRTY FUEL GIL FLTR+CARBON IN CRKCKSE VENT	
C	M12	014260A	021776	FM25	A	A09	B	I	"N	DG	12U FAILED TO START - SIMILAR OCCUR:175-23)	DIRTY FUEL GIL FLTR+CARBON IN CRKCKSE VENT	
C	M12	014260B	021876	FM25	A	B09	B	I	"N	DG	12U TRIPPED OFF-LINE - SIMILAR OCCUR:175-23)	DIRTY FUEL GIL FLTR+CARBON IN CRKCKSE VENT	
C	M12	014260C	022076	FM25	A	B09	B	I	"N	DG	12U TRIPPED OFF-LINE - SIMILAR OCCUR:175-23)	DIRTY FUEL GIL FLTR+CARBON IN CRKCKSE VENT	

0 TO 1 HOURS

V	L	C	N	T	CONTROL	FAIL	PK	DATE	TIME	DESCRIPTION	FAILURE MECHANISM	
C	M12	015106	FR25	F	809	B	T	I	T	DG 13U TRIPPED ON HI CRANKCASE PRESS - 11 MIN RUN	CRACK AIR EDUCTOR FOUND DIRTY	
C	M12	015406	FR25	B	842	C	T	I	N	DG 13U SHUTDOWN - FIRE ON EXHAUST MANIFOLD	LUBE & FUEL OIL ACCUM UNDER MANIF INSULAT	
C	M12	018923	GM1077	FR25	G	A01	S	O	I	DG 12U FAILED TO RESTART ON DEMAND	GOVERNOR STILL IN "NO FUEL" FROM PREV STD	
C	M12	019929	FR25	K	A01	S	O	I	T	DG 13U TRIPPED WHILE PARALLELING WITH 4160V BUS	IMPRPER VOLTAGE SETTING PRIOR TO PARALL	
C	M12	022715	GM25	A	A06	S	O	I	T	DG-48 COULD NOT BE LOADED DURING TEST AFTER MAINI	AIR WAS NOT PURGED FROM FUEL LINES	
C	SU1	017135A	GM1077	GM30	A	A09	R	T	I	T	THE 1A DIESEL GENERATOR FAILED TO START	DIRTY FUEL RACK LINKAGE--RACK STUCK OPEN
C	SU1	017135R	GM1077	GM30	A	A09	R	T	I	T	THE 1A DG FAILED TO START AGAIN - LATER SAME DAY	DIRTY FUEL RACK LINKAGE--RACK STUCK OPEN
C	SU1	017441	GM1077	GM30	I	A01	S	O	I	T	1A DIESEL GENERATOR FAILED TO START	OPER FAILED TO RESET OVERSPEED TRIP
G	RF1	014102	GM1077	GM30	G	A12	T	I	T	FAILED TO RESPOND TO ELEC. GOVNR SIGNALS DG #G	OIL DRAIN FROM HYDRAULIC ACTUATOR	
G	RF3	019133	GM1077	GM30	K	A10	D	I	T	30 DG TRIPPO ON OVERSPEED GOVERNOR INOPERABLE	TO FUJE OPEN DISENABLING FIELD CIRCUIT	
G	RF1	014993	GM1077	GM30	A	A00	R	O	U	I	START TIME 33 SECS TESTED SAT WITHIN ONE HOUR	FUEL CHECKED OK PREM GRADE OF FUEL USED
G	RF2	020612	GM1077	GM30	K	A01	S	O	I	N	FOLLOWING SCRAM ON UNIT 1 #B1 DG LD RELAY WOULDNT	RESET; LOSS OF EXCITATION RELAY NOT RESEI
G	DA1	017963	GM1077	GM25	G	B06	S	O	I	T	16-31 DG WOULD NOT REACH FULL LOADING ONLY 2500 KW	SPEED SETTING ADJUSTMNT NOT RESEI
G	UR1	020408B	GM1077	GM10	M	A11	C	O	I	N	U-1 8/U DG FAILED TO START 1ST 5 TIMES--LOW TEMPERAT	WINTER WEATHER
G	DR2	014913	GM25	C	A00	U	I	T	UNIT	2/3	DG FAILED TO START	CAUSE UNKNOWN BUT POSSIBLE AIR START STJA
G	DR2	017397	GM25	C	A16	R	O	I	T	UNIT	2/3 FAILED TO START	AIR START MOTOR PINION GEAR JAMMED
G	DR2	018483	GM25	G	A00	R	O	I	T	U	2/3 DG TRIPPO ON OVERSPEED DURING 2 ATTEMPTS	POSSIBLE CUT-OF-ADJUST GOVERNOR COMPENSATIN
G	DR2	018494	GM25	G	A00	R	O	I	T	U	2/3 D/G TRIPPO ON OVERSPEED--OCCURD ALSO 5/30/77	PROBABE CUT-OF ADJUST GOVERNOR COMPENSATIN
G	DR2	019732	GM25	I	A00	S	O	I	T	AUTO-START SIGNAL SENT TO UNIT 2/3 DRAIN COME SPRY	RESET START FAILURE RELAY & DIESEL STARTD	
G	DR2	019723	GM25	C	A13	R	I	T	UNIT	2	UG AIR RECEIVR LOW PRESS TERMINATO START	LOOSE NIME AT TERMINAL 25A5

0 TO 1 HOURS

V E N	P L A N T	C O N T R O L N U .	F A I L D A T E	M F G W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	I R I R	Y R M K C V H D	FA I L U R E M O D E	FA I L U R E M E C H A N I S M
G	EN1	015568	080976	FM25	K	A06	S	D	1	T	DG 1A	TRIPPED DUE TO LOSS OF EXCITATION DRNG SYNCH	DEFECTIVE PROCEDURE - PARALLED OUT OF SYN
G	EN1	016665	091176	FM25	G	A10	R	D	1	T	1A	DG FAILED TO START - SURV TEST - OCCURRED PREV	LOW OIL LEVEL IN GOVERNOR
G	EN1	016643	123176	FM25	M	A00	R	U	1	F	MAN	START OF 1A DG FAILED THIS HAS HAPPND BEFORE	INSPECTED & RETESTED SATISFACTORILY
G	FP1	016600	121576	GM25	B	A10	R	D	1	T	DURING	TESTING "AM" EDG FAILED TO START	LOW LUBE OIL PRESS - RELIEF VLV LEAKAGE
G	FP1	016974	011977	GM25	B	A10	R	D	1	F	DURING	SURV, EDG TRIPPED ON EMERGENCY START	LOW LUBE OIL PRESS, SECOND ATTMPT SUCCESSFL
G	FP1	020518	021578	GM25	J	B10			1	T	"AM"	EDG TRIPPED DURING SURVEILLANCE TEST	BLOWN FUSE IN SYNCH CKT FOR OUTPUT BRKR
G	DC1	015042	060876	GM25	C	A00			U	1	DG #2	FAILED TO START DURING OPERABILITY TEST	CONTROL SEQ FAULT - HOWEVER, SEQ CORRECT
G	P82	018686	082677	FM30	D	A01	S	D	1	T	E1	DG FAILED TO START DUE TO HI JKT CLG WTR TEMP	OPER RESET TRIPPED PMP, BUT NOT DIESEL INP
G	P82	019414	101877	FM30	U	A02	J	D	1	N	E3	DG TRIPPED FOLLOWING MANUAL START	3 VALVES TO LOW PRESS SW LEFT SHUT
G	P82	022462	083078	FM30	G	A10			1	T	E-3	DG START TIME DID NOT MEET TS REQUIREMENT	LEAKY CHK VLV IN AIR BOOSTER RELAY HYD ST
G	P82	023349A	122178	FM30	G	A10			U	1	E3	DG START TIME 13 SEC. VS. REQUIRED 10 SEC.	E3 DG GOVERNOR REPLACED ON 12/28/78
G	P82	023349B	122178	FM30	G	A00			U	1	E2	DG START TIME 11 SEC. VS. 10 SEC	POSSIBLE GOVERNOR PROBLEMS
G	VY1	015739	082576	FM30	A	B13			1	T	"B"	DG OOS TO TIGHTEN FUEL HEADER FITTINGS	ENGINE VIBRATION LOOSENED MECHANICAL CONN
N	BV1	015913	090376	GM25	J	A00			U	1	#1	DG OUTPUT BREAKER FAILED TO CLOSE	NO APPARENT CAUSE
N	BV1	018068	060377	GM25	J	A04	R	D	1	T	#2	DG OUTPUT BRK. FAILED TO CLOSE ON FIRST ATTEMPT	CLOSED ON NEXT ATTEMPT; STICKY NPLDA RELAY
N	BV1	021647	060178	GM25	B	B02			U	1	#2	DG LUBE OIL LEAK AT ENGINE CONTROL PANEL GAUGE	GAUGE WAS CALIBRATED ON 5/21; LOOSE CONN.
N	BV1	022137	072878	GM25	K	A10	R	D	1	N	#2	DG FAILED TO FLASH DURING SI AND LOSP EVENT	STICKY FIELD FLASH CUTOFF RELAY; AUTO CKT.
N	BV1	022345B	090578	GM25	J	A00	R	D	1	T	#1	DG OUTPUT BRK. FAILED TO CLOSE; #2 DG OOS	BRK CLOSED MANUALLY; 1 HOUR RUN AT FULL LD
N	BV1	022344B	091278	GM25	J	A00	R	D	1	T	#1	DG OUTPUT BRK. FAILED TO CLOSE USING CONT. SWTCH	CLOSED LATER NEGATING TROUBLESHOOTING
N	DC1	016647	120976	W030	K	A10			D	1	C-0	DG TRIPPED ON OVERSPEED--BLOWN FUSE ON INVERTER	FAILED SILICONE RECTIFIER IN DG INVERTER

G TO 1 HOURS

V E N I	P L A N I	C O N T R O L N U .	F A I L D A T E	M F K G W	S U B S Y	F A I L M M S U C C E H	S Y S T E M	C L A S S	R E P E R T	D I S C O V E R Y	FA I L U R E M O D E	FA I L U R E M E C H A N I S M
W	DC2	022839	101978	W030	A	A00	U	1	T	ZAB	FAILED TO START DUE TO LACK OF FUEL TO INJECTRS	UNKNOWN BUT REPLACED FUEL FILTER ELEMENT
W	HN1	014162	020376	GM25	A	A02	J	D	1	EDG-28	TRIPPED ON OVERSPEED WHILE STARTING	CALIB TOOL LEFT IN FUEL RACK-RACK HLD OPN
W	IP3	015733	063076	AL18	G	B02	I	D	1	EDG 31	BEGAN CYCLING BETWEEN 56 AND 63 CPS	GOV OIL DRAIN VLV NOT SHUT TIGHTLY
W	JF1	022987	100378	FM25	J	A02	J	D	1	10 DG	OUTPUT BRKR FAILED TO CLOSE ON START	JUMPER FOR UNIT1/UNIT2 SEPARATE INCORRECTLY POS
W	S01	021310	032878	DL10	A	A10	R	1	T	NO 1	DIESEL GENERATOR FAILED TO START	FUEL LNKG BINDING - BEARINGS IN LNKG DRY
W	S01	022100	071878	DL10	A	A06	D	1	T	NO 1	DIESEL GENERATOR FAILED TO START	FUEL RACK BINDING-INCRP PROC TO EXERCISE
W	Z11	022110	080178	CB40	C	A10	I	1	T	18	DIESEL GENERATOR FAILED TO START	AIR LEAK IN STARTING AIR PILOT VALVE
W	Z12	017808	042777	CB40	G	B10	R	D	1	T	GOVERNOR SPEED CONTROL FAILED ON 28 DIESEL GEN	GOV SPD CONE GEAR JAMMED AGAINST HI SPD STD
W	Z12	020260	010978	CB40	G	B10	R	D	1	T	28 DG POWER OUTPUT OVLD - COULD NOT LOWER MANUALLY	GOV SYNCH IND GR JAMMED ON HI SPD STOP

1 TO 4 HOURS

V E N	P L A N I	CONTRCL NO.	FAIL DATE	M F G	K W	S U B J	F A I L M E C H	F A I L T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE		FAILURE MECHANISM	
G BP1	018102	051877	CA02	D	A00	R	T	4	T	H2O JACKET HEATER FAILURE--EDG TESTED; DID NOT MEE T TIME CRITERIA; EXCEEDED BY 12 SECONDS					
G BP1	020580	020978	CA02	D	B12	T	4	T	DG TRIPPD ON HI WATER TEMP AFTR 25 MIN OF OPS				AIR LEAKAGE ON PUMP COOLING WATER SHAFT		
G BR1	016854A	010477	NM30	B	A04	C	D	4	T	#3 DG TRIPPD R/X AT POWER LOW LUBE OIL TEMP				LOW SETPOINT FOR PRE-FILTER HEATER #JACKET	
G BR1	016854B	010477	NM30	B	A04	C	D	4	T	#4 DG TRIPPD R/X AT POWER, TD SWITCH NOT RESET				L.O.PRES SWITCH TIME DELAY INCORRECT	
G BR1	022454	091178	NM30	A	B07	T	4	T	#1 DG CYLINDER #1 NOT FIRING--HEAVY LOADING ???				FAULTY FUEL PUMP REPLACED		
G BR2	014136	010978	NM30	J	A10	D	4	N	#1 DG STARTED BUT OUTPUT BKR FAILED TO CLOSE TO E-1				BROKEN LUG WIRE DUE TO STRESS		
G DR2	019810	120377	GM25	C	A12	D	4	T	2/3 DG FAILED TO ROLL OVER--LOW START AIR PRESSURE				RUPTURED REGULATOR DIAPHRAM		
G DR2	022262	082478	GM25	C	A10	R	U	4	T	2/3 UNIT DUS UNIT 2 FAILED TO START ON 1ST ATTEMP				PINION GEAR NOT ENGAGED ON AIR START MTR	
G DR2	023337	121678	GM25	C	A00	K	D	4	T	2/3 DG AIR START MOTORS DISENGAGED AFTER FEW SECS.				TD2 RELAY CLEANED; TD2 AND AIR VALVE ?	
G DR3	014439	030376	GM25	G	A13	K	T	4	T	DG COULD NOT BE LOADED FROM CONTROL ROOM				GOVNR CONTROL WIRE VIBRATED FREE FROM LUG	
G DR3	016015	092176	GM25	B	B09	T	4	T	DIESEL 3 RECIEVD HI TEMP ALARM				PARTIALLY CLOGGD STRAINER IN L.O. CIRC PMP		
G DR3	016187	160976	GM25	G	A13	R	T	4	T	LOSS OF CONTROL ROOM SPEED CONTROL				LOOSE WIRE ON GOVNR CONTROL CIRCUIT	
G EN1	018644	061377	FM25	D	B14	F	D	4	T	1C DG TRIPPD RESTARTED SATISFACT LO JACKET CLNT				LOW COOLNT PRESS SWITCH TO BE CALIBRATED	
G EN1	018646	061877	FM25	D	B14	F	D	4	T	1C DG TRIPPD ON LO COOLNT JACKET PRESSURE				POSSIBLE INCORRECT PRESSURE SETPOINTS	
G EN1	018647	062577	FM25	D	B14	T	D	4	N	1C DG TRIPPD ON LO COOLNT JACKET PRESS				OPERT PRESSURE WAS ABOVE TRIP SETPOINT	
G EN1	020113	111977	FM25	K	B02	S	D	4	T	1B DG OUTPUT VOLTAGE TOO HIGH - 1B DG SHUTDOWN				IMPROPER ADJUSTMENT OF AUTO REG SETPOINT	
G FP1	023101	120578	GM25	G	A02	S	D	4	T	"A" DG TRIPPD WHEN BEING PARALLED				MISADJUSTMENT OF GOVNR	
G PB2	019087	082677	FM30	I	A06	S	D	4	T	E4 DG TRIPPD ON OVERSPEED				OWSPD TRIP SET BELOW DESIGN VALUE	
G QC1	019100	082477	GM25	L	A13	T	4	T	UNIT 1 DG STARTED AND RAN, BUT NO VLTG, SYNCH, FREQ				FREQ GEN EACH SET SCREWS VIBRATED LOOSE		
G QC1	019444	112677	GM25	K	A10	D	4	M	1/2 DG WOULD NOT START SUCCESSFULLY, FIELD BKR DEFECT				FAILED DIODE IN FLD BKR INTLK CIRCUIT		

1 TO 4 HOURS

V E N	P L A N T	CONTROL NO.	FAIL DATE	H P G	K M	S U B S Y S	F A I L M O D E	F A I L M E C H	E T Y P E	C L A S S	R E P A I R	D I S C R I M I N A T O R Y	FAILURE MODE	FAILURE MECHANISM
G	VY1	014740	050676	FM30	F	A09	R	T	4	N	"B" DIESEL GENERATOR TRIPPED ON HI CRNKSE PRESS	CLOGGED CRNKSE EJ SUP URIFICE OR EJ BUDT		
G	VY1	018323	062377	FM30	F	B13	R	I	4	T	"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE	VIBRN CALSED HOSE CLMP ON AIR EJECT FAIL		
G	VY1	019658	072677	FM30	C	A09		T	4	T	"A" DIESEL GENERATOR FAILED TO START	AIR START SOL VALVES BOUND CLSD BY DEBRIS		
G	VY1	020194	121977	FM30	F	B13	R	T	4	T	"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE	ENG VIB CAUSED AIR EJECT HOSE TO LOOSEN		
G	VY1	020464	012478	FM30	D	B09		T	4	T	DIESEL GENERATOR "A" TRIPPED ON HI JAKEI CLNG TEMP	3-WAY VLV BLOCKED TO BYPASS CLNT ARND HX		
W	BV1	014903	052076	GM25	C	A09	K	T	4	N	DG #1 FAILED TO START 3 TIMES DG #2 STARTED OK	WATER ACCUMULATION IN AIR START SYSTEMS		
W	BV1	017883	022477	GM25	L	B05		D	4	T	DG OUTPUT BREAKER TRIPPED; INTERNAL LOSS OF FIELD	TRIP NOT DISCONNECTED DURING ACCEPT. TEST		
W	BV1	017346	031477	GM25	J	A04	B	D	4	T	#2 DG OUTPUT BREAKER FAILED TO CLOSE	DIRTY CONTACTS ON BKR CONT SWITCH		
W	BV1	017621	041177	GM25	J	A04	B	D	4	T	#1 DG OUTPUT BREAKER FAILED TO CLOSE--DIRTY CONTACT	DESIGN CHANGE REQUEST FOR SEALED RELAYS		
W	BV1	017643	042677	GM25	J	A04	B	D	4	T	#1 DG OUTPUT BKR. FAILED TO CLOSE--DESIGN REQUESTED	DIRTY CONTACTS ON NPLD(AND FIELD) RELAY		
W	BV1	017696	042977	GM25	C	A09	R	T	4	N	DG #1 FAILED TO START REPETITIVE	MOISTURE IN STARTING AIR		
W	BV1	017827	050977	GM25	J	A04	R	D	4	T	#2 DG OUTPUT BKR. FAILED TO CLOSE--REPETITIVE	STICKING RELAY(MSR2) IN MANUAL START CKT.		
W	BV1	020437	011178	GM25	J	A04	R	D	4	T	#2 DG OUTPUT BKR. FAILED TO CLOSE IN EXERCISE MODE	NO CAUSE COULD BE DETERMINED		
W	DC2	020981	031978	WD30	C	B10		U	4	T	2CD DG GASKETS ON AIR LINE TO #5 CYL BLEW OUT	FRACTURED AIR START CHECK VALVE		
W	DC2	022026	072878	WD30	G	B10	R	T	4	T	#2 AB DG OVERSPED WHL UNLOADG PREVIOUS OCCURRENCE	WORN LINKAGE CAP SCREW BROKE IN GOVENOR		
W	DC2	022503	091178	WD30	C	A13		T	4	T	2AB STARTED FOR LOAD TEST WAS TRIPPED OFF MANUALLY	PISTON BOLT FOR AIR CHECK VALV LOOSE		
W	IP3	016035	092476	AL18	G	B02	T	D	4	T	EDG 31 OUTPUT FREQ INC TO 62 HZ; COULD NOT CONT ELE	AIR IN GOV OIL LINES FROM PREVIOUS REPAIR		
W	JF1	022630	091778	FM40	G	A10		D	4	T	1R DG FREQ COULD NOT BE INCR ABOVE 56.5 HZ	CPLNG BET DC MTR AND GOV POS POT WAS LOOS		
W	KE1	019171	092077	GM25	E	B06	C	D	4	T	DGL GEN 1A S/D WHEN SMOKE & FIRE OBSVD IN TURBOCHG	CARBON BUILDUP DUE TO SHORT DURATION OPER		
W	KE1	020095	122177	GM25	G	B02	S	D	4	T	D/G 1B WOULD NOT PICK UP MORE THAN 1500 KW LOAD	SYNCHRO MOTOR LIMIT SWCHS ADJUSTED IMPRUP		

1 TO 4 HOURS

PLANT	CONTROL NO.	FAIL DATE	M F K G W	UNIT	FAILURE MODE	FAILURE MECHANISM
PK2	C15735	091076	FM30	F 802	01 DG TRIPPED ON HIGH CRANKCASE PRESSURE	HOSE CLAMPS ON PIPE NOT TIGHT AFTER MAINT
PK1	018417	062977	SM25	I A14	3 T 4 T 30 DIESEL GENERATOR FAILED TO START - LOGIC FAILURE	SPEED SENSING ASSY SETPOINT DRIFTED
PK2	021313	041078	FM25	G B13	4 T 4 T EDG LOAD FAILED TO INCREASE ABOVE 900KW	COMP BRUSH VIBRATED OUT OF GOV SPD CHGR
SA1	018799A	073077	AL25	A A10	C T 4 N 1A DIESEL INOP-FAILED TO REACH MAINT SPEED ON STRT	BINDING FUEL RACK LNKG - LACK OF LUBRICAT
SA1	018799B	073077	AL25	A A10	C T 4 N 1B DIESEL INOP-FAILED TO REACH MAINT SPEED ON STRT	BINDING FUEL RACK LNKG - LACK OF LUBRICAT
SA1	019020	111777	AL25	D B13	B T 4 T 1C DIESEL DEVELOPED WATER JACKET LEAK	CRACK FOUND ON 3/8" PIPE NIPPLE
PA1	018447	062277	GM40	G B10	I 4 N WEST DG FAILED TO ASSUME MIN REQUIRED LOAD	BRUSH FALLEN OUT OF DC GOV DRIVE MOTOR
PA3	018147	033177	GM25	A A12	R T 4 T DG "0" DID NOT REACH SPEED & VLTG WITHIN SPEC TIME	AIR IN FUEL LINE-CRACKS IN SUCTION TUBING
PA3	025419	060178	GM25	A B10	T 4 T B DG HI LEVEL IN FUEL TANK (ENG.MOUNTED) DG S/D	LEVEL SWITCH MALFUNCTION--REPLACED SWTCH
PA1	017310	030177	GM02	C A10	D 4 T #1 EDG FAIL TO START DUE TO FAIL STARTER MOTOR	ARMATURE SHAFT BROKEN--REPLACED W SPARE
PA1	015108	062176	LB40	A B13	F 4 N 14 DG HAD FO LEAKAGE AT THE HL FUEL INJ PUMP	VIB CAUSED CRACKED FTNG ON LINE TO INJ
PA1	013408	011678	CB40	G B10	T 4 T "0" STARTED & LOADED, BUT DECLARED INOPERABLE	LD CONTROL AIR PRESS--TRIP VLV "0" RING LK
PA1	022545	090278	CB40	C A10	D 4 T "0" DIESEL GENERATOR FAILED TO START	STARTING AIR DIST BUSHING ROTATED IMPROP
PA1	022640	091478	CB40	B A02	C U 4 N 1A DG CARE UP TO SPEED AND THEN TRIPPED - 5 TIMES	RAG IN OIL STRAINER CAUSED LO OIL PRESS F
PA1	017809	050677	CB40	I B13	C T 4 T DIESEL GENERATOR 2A TRIPPED FROM FULL LOAD	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
PA1	019780	111777	CB40	I B13	C T 4 T "0" DIESEL GENERATOR TRIPPED OFF-LINE	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE

A TO B HOURS

UNIT	CONTROL NO.	FAIL DATE	M K G W	FAILURE MODE	FAILURE MECHANISM
B	ARI 014830	051176	GM25 C	ALC	U B T DG #1 FAILED TO START ON SIMULATED E.S. ACTUATION F A I L L
B	ARI 049578	122377	GM25 C	AL4	F I R T #1 DG FAILED TO START; DRIFT OF TO RELAY SETPOINT U B T DG #1 FAILED TO START ON SIMULATED E.S. ACTUATION
B	CR3 019302	092677	FM30 B	AL0	J D B T 38 DG FAILED TO START; DRIFT OF TO RELAY SETPOINT U B T 38 DG FAILED TO START; DRIFT OF TO RELAY SETPOINT
B	CR3 020221	122777	FM30 G	A09	R D B T 38 DG FAILED TO START DUE TO START PERMISSIVE LCST U B T 38 DG FAILED TO START DUE TO START PERMISSIVE LCST
B	CR3 020278	010378	FM30 G	A09	R D B T 38 DG FAILED TO START --3RD OCCURRENCE U B T 38 DG FAILED TO START --3RD OCCURRENCE
B	MS1 016056	120676	GM25 G	B10	D B T DG "AM" TRIPPED OFF-LINE 25 MIN INTO TEST U B T DG "AM" TRIPPED OFF-LINE 25 MIN INTO TEST
B	111 020997	031878	FM30 B	AL0	F B T EDG FAILED TO START U B T EDG FAILED TO START
B	112 021605	052378	FM30 F	B09	R F B M DG B TRIPPED ON HIGH CRANKCASE PRESS - 32 MIN RUN U B M DG B TRIPPED ON HIGH CRANKCASE PRESS - 32 MIN RUN
B	112 023430	122878	FM30 A	A09	F B T DF-A-18 DID NOT START U B T DF-A-18 DID NOT START
C	CL1 017842	051577	FM25 M	A09	R F B T #12 DG FAN FAILED TO START WHEN GEN RECEIVED SIGNAL U B T #12 DG FAN FAILED TO START WHEN GEN RECEIVED SIGNAL
C	CL1 019592	103077	FM25 K	AL4	F B T #12 DG FAILED TO REACH VOLTAGE WITHIN 10 SEC. U B T #12 DG FAILED TO REACH VOLTAGE WITHIN 10 SEC.
C	CL2 018422	022277	FM25 C	A00	U B T #21 FAILED TO START & ASSUME RATED SPEED IN 10 SEC U B T #21 FAILED TO START & ASSUME RATED SPEED IN 10 SEC
C	FC1 014590	042776	GM25 C	A02	T D B U DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE U D B U DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE
C	FC1 015614	081576	GM25 G	B10	T B M SMOKE COMING FROM DG-2 GOVERNOR MOTOR ENCLOSURE U B M SMOKE COMING FROM DG-2 GOVERNOR MOTOR ENCLOSURE
C	FC1 015722	081576	GM25 C	AL4	T D B U DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE U D B U DG-2 PRIMARY AIR START MTR FAILED TO DISENGAGE
C	FC1 021799	071278	GM25 K	B10	R D B T DG-2 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN U D B T DG-2 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN
C	FC1 022249	080978	GM25 K	B10	R D B T DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN U D B T DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUTDOWN
C	M12 019455	092477	FM25 I	B14	S T B T 12U DG APPEARED TO TRIP ON GEN OVERCURRENT U B T 12U DG APPEARED TO TRIP ON GEN OVERCURRENT
C	M12 022131	080378	FM25 A	B07	F B T DG 13U SHUTDOWN DUE TO LEAKING INJECTOR U B T DG 13U SHUTDOWN DUE TO LEAKING INJECTOR
C	MY1 020733	021878	GM25 G	A09	T B T DG-1A FAILED TO RESPOND DURING TEST RUN FOR TRAINING CONTROL PC BOARD U B T DG-1A FAILED TO RESPOND DURING TEST RUN FOR TRAINING CONTROL PC BOARD

4 TO 6 HOURS

PLANT	CONTROL NO.	FAIL DATE	M F K G W	SYMBOL	FAILURE MODE	FAILURE MECHANISM
C 511	22532	090578	GM30	J A1C	"A" DG OUTPUT BREAKER WOULD NOT CLOSE REMOTELY	DIRTY CONTACTS ON ITS OPERATION RELAY
G BP1	015417	032476	CA02	D B09	M T B T B T "A" DG TRIPPO ON HI COOLING WATER TEMP	WATER PUMP SUCT SCREEN PLUGGED
G BP1	015449	080576	CA02	D A00	R U B N DG FAILED TO START WITHIN 15 SECONDS	POSSIBLE WATER JACKET HEATER FAILURE
G BP4	015444	081276	CA02	C A10	R T B T WEEKLY TEST FAILED TO START	STARTING BATTERY CABLE FAILD LOOSE CONNED
G BP1	015391	101177	NM30	G B05	D B T #2 DG UNABLE TO MAINTAIN LOAD CYCLING 500KW	SHORTED LEADS TO GOVERNOR; INCORRECT ASMB
G BP2	010823	122976	NM30	G B10	T B T #2 DG FAILED OPERABILITY TEST --LOSS OF SPEED CONT.	CLUTCH ADJUSTED AND STATOR VULTAIR REPLAC
G C01	012872	062376	CB40	A B00	U B T FUEL LINE TO AN INJECTOR OF #1 DG BURST	CAUSE UNDETERMINED
G C01	015714	111076	CB40	J A03	J U B T EG-1 OUTPUT BKR FAILED TO CLOSE--BLOWN FUSE	DISCONNECTED ONLY ONE WIRE ON 11/8/76
G D01	015453	062276	FM25	D B09	C T B T 16-31 DG TRIPPO ON HI JACKET TEMP--DECLARED INCPRBL	LOW FLOW DUE TO MUD IN STRAINER
G D01	017756	051077	FM25	J A10	J D B T 16-21 DG OUTPUT BKR FAILED TO CLOSE	AUX CONTACTS OF STNDBY TRANSFORMER OPEN
G D02	020242	010378	GM25	C A13	R T B T UNIT 2 DG FAILED TO START WEEKLY SURV TEST	LOOSE WIRE AT TERMINAL 25A3
G D02	021048	030778	GM25	C A00	S D B T OPERATR SHOOK AIR START SOLENOID UNIT 2/3 STARTED	POSSIBLE WIRE DAMAGED DUE TO FREQ INSPEC
G D02	020855	030678	GM25	G A14	J D B T ENGINE OVERSHOT AT 1010 RPM WHILE GS SET AT 1020	HI OVERSHOOT BY OUT-OF-ADJUST GOVNR COMP
G D02	021538	052278	GM25	G A02	D B T U-2 DG TRIPPO 4 TIMES ON OVERSPEED;RVA IN S/D MODE	GOVNR SETTING FOUND SET TOO HIGH
G D02	022589	092278	GM25	C A00	K U B T UNIT 2/3 FAILED TO START; AIR SERV MIRS ENGAGED	AIR-START SVS WILL BE MODIFIED
G D03	010455	110576	GM25	G B10	R T B T LGST SPED CONTROL FROM CONTROL ROOM	FAILED OVERTRAVL LIMIT SWITCH ON GOVNR
G D03	019722	112277	GM25	G A10	R D B T 3 DG STARTD/LOADED-OVERLOAD ALARM-DG TRIPPO	BAD CAPACITOR IN SPEED SENSING CRT-2
G D03	019727	112977	GM25	G B10	R D B N 3 DG TRIPPO 30 MIN AFTER START AND LOADING	SHORTED CAPACITOR ON SPEED SENSING BOARD
G EN1	0154795	050176	FM25	M B13	S T B T NORMAL SURV. TEST DG 1C TRIPPO; LOOSE WIRE	NOT VIBRATED OFF WIRE-PANEL R43-POOLC
G EN1	0155257	062676	FM25	B B02	S D B T DG 1C TRIPPO DUE TO LUBE CIL SWITCH NOT CALIBRATED	PERSONNEL DID NOT CALIBRATE SWITCH

8 TO 24 HOURS

V E N	P L A N T	C O N T R O L N O.	F A I L D A T E	M F G N	S U B S Y S	F A I L M E C H	F A I L T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	F A I L U R E	
											M O D E	M E C H A N I S M
B RS1	015359	071576	GM25	M	A00	U	U	T	SEVERAL ATTEMPTS TO START "B" DG WERE UNSUCCESSFUL	NO DEFINITE CAUSE COULD BE FOUND		
C CC2	017986	060177	FM25	D	A12	F	D	T	#21 DG FAILED TO MEET START TIME CRITERIA	SERVICE WATER INLET VALVE LEAKING EXCESSIVE		
G BR1	020008	120977	NM30	C	A09	T	D	T	#3 DG START TIME 10.2 SEC VS 10	CARBON BUILDUP ON AIR VALVE STUCK SHUT		
G BR1	019948	121077	NM30	J	B00	D	D	T	SMOKE COMING FROM 32G RELAY AND 860B RELAY FLAMING	REPLACED AND CALIBRATED RELAYS		
G BR2	014614	031476	NM30	A	B12	T	D	T	AT 96% POWER #2 DG STARTED TO CYCLE IN LOCAL-MANUL	FUELOIL SHIFT VALVE LEAKN GASKET RENEWED		
G BR2	015461	061176	NM30	A	A02	C	D	T	#1 DG STALLED & FAILED TO TIE INTO E-BUS R/X AT PR	40 GAL H2O IN SADDLE & 4 DAY TANK		
G BR2	016399	111176	NM30	C	A08	T	D	T	DG FAILED OPER TEST-12.2 ON #2 AIR RECEIVER	CHECK VALVE RUSTED SHUT		
G CU1	016560	110776	CB40	K	B08	T	D	T	DG-2 LOST ELECT GOVERNOR CONTROL AND VOLTAGE	POT. TRANSFORMER FUSE CONTACTS OXIDIZED		
G DA1	014334	022776	FM25	B	B12	K	D	T	SMALL FIRE ON EXHAUST MANIFOLD OF DG 1G21	OIL LEAK FROM FRONT COVER PLATE		
G DA1	014337	031776	FM25	H	B12	R	D	T	SMALL FIRE NEAR EXHAUST MAN-TURBOCHRGFR FLANGE	1G21 LEAKY FLANGE GASKET		
G DA1	015493	100776	FM25	F	A05	D	D	T	1G21 BROKEN LOWER VERT DRIVE COUPLING HUB	HUB MADE OF WRONG MATERIAL		
G DA1	016452	110476	FM25	A	B04	D	D	T	DG 1G-21 S/D DUE TO FIRE -FUEL LINE FRACTURE	INADEQUATE DESIGN		
G DR1	021517	050778	GM10	B	A10	F	D	N	DEMCRANTY DG FAILED TO START DUE TO LOW LUBE OIL PHS	L.O. PUMP COUPLING DAMAGED		
G DR2	016168	093076	GM25	K	B09	T	D	T	2/3 DG OUTPUT ERRATIC AFTR CONTRD PLACED IN "STOP"	SHORTED SELENIUM RECTIFIER DUE TO DIRT		
G DR2	016443	102976	GM25	I	A14	S	D	T	UNIT 1 DG FAILED TO START TWICE MALFUNCT S/D BLEND	SOLENOID PLUNGER OUT OF ADJUSTMENT		
G DR2	016654	121876	GM25	A	B02	S	D	T	UNIT 2 DG FAILED TO CARRY REGD LOAD 12000KW MAX	H2O IN FUEL SUPPLY FROM FLUSHING OPERATOR		
G DR2	014728	112977	GM25	D	B12	C	D	T	2/3 DG S/D DUE TO COOL H2O PUMP TRIP 10MIN. LOADED	WATER LEAKD GROUNDED PUMP STATOR		
G EN1	014778	031576	FM25	C	A10	D	D	T	1A DG FAILED TO START DURING SURVEILLANCE	SOLENOID OPER AIR VLV IN START SYS STUCK SHUT		
G MD1	016186	101076	GM25	C	A09	T	D	T	#11 DG FAILED TO START ON #2 STARTING SYSTEM	#2 START SYS AIR CONT COMP FOULED W RUST		
G PI1	015906	092276	AL25	H	B04	B	T	D	T	"A" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED	

B TO 24 HOURS

PLANT	CONTROL NO.	FAIL DATE	MFG DATE	UNIT	FAILURE MODE	FAILURE MECHANISM
AVI	021355	041878	GM25	A 812	"B" DG EXHAUST MANIF LEAKING BLACK SMOKE	EXPANSION BELLOWS CONNECTOR SEPARATED
JF1	019359	091377	FM40	C 810	GEN 18 WAS 570 AND DECLARED IMPERABLE--CIL LEAKS	FLAM IN FUEL OIL PUMP DUE TO LARGE PIPE NIPL
JFA	020992	030278	FM40	C 409	GEN 18 EVENTUALLY TRPD ON OMSPD AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
JF1	021185	032378	FM40	C 402	D 18 D5L GEN 18 FAILED TO ATTAIN RATED SPEED	CORROSION PRODUCTS CLOGGED AIR START VLV
PF1	021445	051778	GM25	J 410	R D 1 40 EDG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	MAIN AIR START VLV PUSHER ASSY MISSING
YR1	018693	080277	GM02	D 809	C 1 01 DG OVERHEATED--RUNNING FOR APPROX 25 MINUTES	WEST 562143H01 LATCH--CHRG 3M DEFECTIVE
YK1	018654	080277	GM02	D 809	C 1 01 DG OVERHEATED AFTR 30 MIN. OF OPERATION	SLUDGE AND SCALE IN 67% OF RADIATOR TUBES
Z11	020255	010378	CR40	K 810	H 1 01 DG OUTPUT VOLTAGE PEGGED HIGH--COULD NOT LUBE	72% OF RADIATOR TUBES BLOCKED SLUDGE SCALE
Z11	023308	122078	CR40	M 400	U D N 18 DG FAILED TO START DURN AN INADVRNT SAFTY INJEC	PC BOARD FAILURE IN THE VOLTAGE REGULATOR EXTENSIVE TESTING REVEALD NO CAUSE

GREATER THAN 24 HOURS

PLANT	CONTROL	FAIL DATE	MODE	MECHANISM
B 081	019816	122977	GM25 G A14 J U B N	DURIN LUSP DG 1-1 STARTO AND TRIPPO DN OVSPEED
B 081	020708	020878	GM25 E 805 D G T 1-1	DG 370 DUE TO NOISY TURBOCHARGER
B 081	021060	050978	GM25 E 860 U G T	GEN LOAD FLUCTUATING AIR INTAKE LC PRESS ALARM
B 112	021607	052078	FM30 F A01 C D G T	DG B FAILED TO START
C 001	015584	080776	FM25 J A02 S D G T	11 DG FAILED TO SENSE MAT VOLTAGE COND.--OUTPUT BKR. WILL NOT CLUSE--COLD SOLDER CONN TO ERA
C M12	014060	022376	FM25 F 804 B F G M	DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR 175-231
C M12	016631	092276	FM25 D 809 B T G T	12U DG K5CVU LOW CW FLO ALA-UNIT UNLOADED, SECURED EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	046626	120176	FM25 D A09 B T G T	13U DG STARTED, NO CW FLOW, SECURED EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	046755	121876	FM25 F 806 D G T	DG 13U #3 UPPER PISTON CON ROD BRNG CAP SHEARED CAPSCREWS FAILED - PROB DUE TO DRY STARTU
C M12	017620	011077	FM25 F 813 S U G T	DG 13U SHUTDOWN DUE TO HIGH VIBRATION SKID MOUNT IN RESONANCE WITH ENG FREQUEN
C M12	018472	081777	FM25 D 809 B T G T	12U DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	0184768	092077	FM25 D 804 R T G N	COOLING WTR LOW FLOW ALARM - 12U DIESEL GEN INSUF CL INJECTION FOR ADQ MUSSEL CONTROL
C M12	021380	050878	FM25 D 809 B T G T	12U DG LOW CW FLOW ALARM, DG UNLOADED AND SECURED EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C M12	023213	120578	FM25 D 809 B T G T	12U DG 370 DUE TO LOW COOLING WATER FLOW MUSSEL SHELLS IN THE HEAT EXCHANGER
C S11	017134	011877	GM30 E 804 R T G T	18 DG RAN FOR 95 MIN THEN TRIPPED ON LOCKOUT TURBOCHARGER SHAFT AND OIL SEAL DAMAGED
C 411	047544	092677	GM30 E 804 K T G T	1A DG SHUTDOWN WHEN SMOKE ISSUED FROM TURBOCHARGER FAILED TURBO CHARGER UNIT
G BPT	014694	051676	CA02 D 804 R T G N	DG TRIPPED ON HI COOLIN WATER TEMP PUMP SHAFT SCORED INLET SCREEN PARTIALLY PLUGGED
G BPT	046742	080577	CA02 J A04 D G T	TESTED EDG WITH 24-28 BKR RACKD OUT; AUTO TRANSR AND MAN TRANSR FAILD TO CLOSE OUTPUT BKR
G C01	023044	041278	CR40 F A04 T G T	DG 02 TRIPPED APPROX 1 MIN AFTR REACH RATED SPEED MAIN BEARING FAILD DUE TO LOW LUBE OIL

GREATER THAN 24 HOURS

UNIT	CONTROL NO.	FAIL DATE	M K G M	FAILURE MODE	FAILURE MECHANISM
G	DR1 021171	040578	FM25 F	ACB BEARING WIPED ON 4/13/77 NOT DUE TO MISALIGNMENT	LUBE OIL FILTER DRAIN VALVE WAS OPEN
G	DR1 020484	012978	GM10 M	ALL C D G M U-1 FAILED TO START DUE TO COLD WEATHR 6 HEATRS	INSTALLED 6 ROCH WINTERIZED
G	DR1 020852	030478	GM10 C	A10 D G T D-1 R/U FAILED TO START R/X IN HOT S/D MODE	SYNCHRO START SWITCH FAILED
G	DR1 021516	031178	GM16 A	ALC R D G T TEMP. DG FAILED TO START-BLOW FUSES IN CONT LOGIC	SHORTED DIODE ACROSS FUEL PRIMING PUMP
G	DR2 019051	103077	GM25 E	806 T G T UNIT 273 UNLOADED TRIPPED ON LOW H2O PRESS RESTART	TURBO-CHARGER CLUCTING/SHAFT BEARING
G	DR2 021682	063078	GM25 D	B14 T D G T 273 OG COOLING H2O PUMP TRIP ON HI AMPS; REPLACED	OVERLOAD TRIP SET CLOSE TO RUNNING AMPS
G	DR3 017509	032277	GM25 K	A10 D G M GEN FIELD FAILED TO FLASH	INTERMITT CAPACITOR SHORT IN FLASH CIRC
G	EN1 020031	081877	FM25 F	800 R U G T DURING SURV TESTING, DG 18 GEN IMBQARD BRNG FAILED	BEARING OVERHEATED - EXACT CAUSE UNKNOWN
G	QCL 018112	042577	GM25 K	A10 D G T WHILE TESTING THE DG, THE FIELD FAILED TO FLASH	CAPACITOR ACROSS VLTG SUP RELAY DEFECTIVE
W	SAL 019924	120277	AL25 E	804 T G T 18 DIESEL DECLARED INOP-TURBOCHGR 6 EXH EXP JT FLD	CAUSE DETERMINED TO BE TURB BLADE FAILURE
W	JUL 014069	041676	GM25 F	A01 R D G T #1 DIESEL GENERATOR DAMAGED ON START	#17 CYL FLOODED - CAUSED BROKEN INTERNALS
W	Z12 019714	111077	CB40 B	812 B D G T #04 DIESEL GEN TRAPPED ON LOW LUBE OIL PRESSURE	CAVITATION OF LO PUMP - WATER IN LUBE OIL

UNKNOWN / NOT APPLICABLE

V C N	P L A N I	CONTROL NO.	FAIL DATE	M F K G M	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
G	BP1	010448	080576	CA02	M	A03	R	U	U	I	DG	FAIL TO START WITHIN 15 SEC NOT RETESTED	OPERATOR NOT AWARE OF SIGNIF OF START TIM
G	BP1	016072	090276	CA02	A	A00	R	U	U	T	DG	FAILED TO MEET 15 SEC START TIME DURING WEEKLY TEST	POSSIBLE FUEL SYSTEM FAILURE
G	BP1	016304	102876	CA02	G	A00	R	U	U	T	DG	FAIL TO START WITHIN 15 SEC	POSSIBLE FUEL GOVERNOR CONTROL PROBLEM
G	BP1	016460	110476	CA02	G	A00	R	U	U	T	DG	START TIME 2.2 SEC SLOWER THAN REQUIRED	POSSIBLE FUEL GOVERNOR PROBLEM
G	BP1	016597	120276	CA02	G	A00	R	U	U	T	DG	FAILED TO MEET 12 SEC START TIME DURING AUTO TEST	FUEL GOVERNOR REPLACED ON 12/19/76
G	BP1	016913	122076	CA02	G	A04	R	U	U	T	DG	START TIME EXCEEDED CRITERIA BY 4 SEC	GOVERNOR LUBE & FUEL SYS UNDER INVESTIGTN
G	BP1	016912	122776	CA02	A	A04	R	U	U	T	DG	START TIME GT. CRITERIA 15 VS 12	FUEL GOV. LUBE OIL SUPPLY MODIFIED 1/10/77
G	BP1	016910	010377	CA02	G	A00	R	U	U	T	DG	FAILED TO START IN AUTO TEST	CAUSE UNKNOWN LUBE OIL RETENTION IN GOV.?
G	BP1	020298	032477	CA02	G	A00	R	U	U	T	DG	STARTING TIME EXCEEDED 12 SEC. BY .6 SEC.	GOVERNOR LUBE SYS MODIFIED ON 1/10/77
G	BP1	018103	052677	CA02	A	A00	R	U	U	T	DG	START TIME 16.5 SEC. SHOULD BE LT 13.9 SEC	FUEL CONTROL VALVE MODIFIED
G	BP1	019541	102077	CA02	C	A00	R	U	U	T	DG	START TIME 21.8 SEC VS. 13.9 SEC	CHECKD VOLTAGE DROP ON START CABLES
G	BP1	020575	020276	CA02	M	A00	R	U	U	T	DG	START TIME 28.5 SECS VS 13.9 SECS	CAUSE UNKNOWN
G	DR2	019905	120477	GM25	J	A00	U	U	U	T	DG	OUTPUT BKR FAILD TO CLOSE--NO APPARENT CAUSE	3 SUBSEQNT TESTS WERE SUCCESSFUL
G	EN1	014796	051576	FM25	M	A00	U	U	U	T	DG	FAILED TO START ON FIRST ATTEMPT	UNKNOWN WILL DO WEEKLY START TO DETERMINE
G	EN1	015947	081476	FM25	M	A00	R	U	U	T	DG	FAILED TO START DURING SURV TEST - RECURRING	EXACT CAUSE OF START FAILURE NOT KNOWN
G	EN1	016642	122576	FM25	M	B00	R	U	U	T	DG	IC TRIPPED APPROX 45 MIN. OF RUN TIME; REPETITIVE	CHECKNG OUT LOGIC ON IC DG
G	EN1	016141	052877	FM25	M	A00	U	U	U	T	DG	FAILED TO COME UP TO RATED VOLT IN RECD. TIME	TOOK 16 SEC VS 12 SEC RETESTED SATISFAC
G	PB2	020190	121977	FM30	L	A00	U	U	U	T	DG	TRIPPED ON "M" PHASE DIFF AFTER PARALLELING	CAUSE COULD NOT BE DETERMD AFTER EXTV TST
W	JF1	019055	081777	FM40	C	A10	B	U	U	T	DG	TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY	MAIN AIR VALVE FAILD TO SHUT, CAUSED OVRSP
W	JF1	019062	082877	FM40	C	A10	B	U	U	T	DG	TRIPPED ON OVSPD DURING MANUAL START	MAIN AIR START VLV FAILD TO FULLY SHUT

UNKNOWN / NOT APPLICABLE

UNIT	CONTROL NO.	FAIL DATE	MFG	MODEL	U	F	FAILURE MODE	FAILURE MECHANISM
M	KE1 017519	102377	GM25	M 400	U	U	D/G 1A STARTED & WAS AT 70 RPM WHEN IT STOPPED	COULD NOT DETERMINE CAUSE OF FAILURE
M	TR1 018007	042977	GM40	M 400	U	U	M EDC FAILED TO START ON LOSP (PARTIAL) THE 2ND TIME	NO LER FOR DG FAILURE JUST THE LOSP
M	FU3 017591	020377	GM25	A 412	R	U	T DG "B" FAILED TO START	PROBABLE-AIR IN FUEL SUPPLY LINES
M	Z11 016179	092476	CR40	M 400	U	U	T "C" DIESEL GENERATOR FAILED TO START	NO CAUSE COULD BE DETERMINED

APPENDIX N

DIESEL-GENERATOR EVENTS (FAILURES) SORTED BY MANUFACTURER/kW RATING

CODES USED IN LER ONE-LINE DESCRIPTIONS

<u>REPAIR TIME</u>	
<u>CODE</u>	<u>DESCRIPTION</u>
1	0 TO 1 HOURS
4	1 TO 4 HOURS
8	4 TO 8 HOURS
0	8 TO 24 HOURS
G	GREATER THAN 24 HOURS
U	UNKNOWN / NOT APPLICABLE

<u>FAILURE MODE</u>	
<u>CODE</u>	<u>DESCRIPTION</u>
A	DOES NOT START
B	DOES NOT CONTINUE TO RUN
U	UNAVAILABLE / NONFAILURE

<u>FAILURE CLASSIFICATION</u>	
<u>CODE</u>	<u>DESCRIPTION</u>
D	DEMAND
T	TIME
U	UNKNOWN

<u>SUB-SYSTEM</u>	
<u>CODE</u>	<u>DESCRIPTION</u>
A	FUEL OIL SYSTEM
B	LUBE OIL SYSTEM
C	STARTING SYSTEM
D	COOLING SYSTEM
E	SCAVENGING AIR SYSTEM
F	ENGINE FRAME / INTERNALS
G	GOVERNOR
H	EXHAUST SYSTEM
I	SHUTDOWN SYSTEM
J	OUTPUT BREAKER
K	EXCITER / VOLTAGE REGULATOR
L	GENERATOR
M	OTHER / UNKNOWN

<u>FAILURE MECHANISM</u>	
<u>CODE</u>	<u>DESCRIPTION</u>
00	UNKNOWN
01	PERSONNEL OPERATION
02	PERSONNEL MAINTENANCE
03	PERSONNEL TESTING
04	DESIGN ERROR
05	FABRICATION / CONSTRUCTION / QUALITY CONTROL
06	PROCEDURAL DISCREPANCY
07	DEFECTIVE FUEL INJECTOR(S)
08	CORROSION / EROSION
09	FOREIGN MATERIAL CONTAMINATION
10	MECHANICAL / ELECTRICAL CONTROL
11	H1 / LOW AMBIENT TEMPERATURE
12	LUBE / FUEL / WATER / AIR LEAKAGE
13	VIBRATION
14	OUT OF ADJUSTMENT / CALIBRATION

<u>METHOD OF DISCOVERY</u>	
<u>CODE</u>	<u>DESCRIPTION</u>
M	DURING MAINTENANCE
N	DURING NORMAL OPERATIONS
R	DURING RECORDS REVIEW
T	DURING TESTING
U	UNKNOWN

<u>TYPE OF EVENT</u>	
<u>CODE</u>	<u>DESCRIPTION</u>
B	RECURRING COMMON CAUSE
C	COMMON CAUSE
K	RECURRING
M	COMMAND FAULTS
N	RECURRING COMMAND FAULTS

<u>NSSS VENDOR</u>	
<u>CODE</u>	<u>DESCRIPTION</u>
B	BABCOCK & WILCOX
C	COMBUSTION ENGINEERING
G	GENERAL ELECTRIC
W	WESTINGHOUSE

DG MANUFACTURER

<u>CODE</u>	<u>DESCRIPTION</u>
AL	ALCO
CA	CATERPILLAR
CB	CLCPEK-BESSEMER
DL	DE LAVAL
FM	FAIRBANKS MORSE
GM	GENERAL MOTORS
NM	NORDBERG MANUFACTURING
WD	WORTHINGTON

KW RATING

<u>CODE</u>	<u>DESCRIPTION</u>
02	200-400 KW
10	500-1000 KW
18	1750-1950 KW
25	2500-2850 KW
30	3000-3500 KW
40	4000-4410 KW

ALCO ----- 1750-1950 KM -----

PLANT	CONTROL NO.	FAIL DATE	MEASUREMENT	FAILURE MODE	FAILURE MECHANISM
1P3	013733	083076	AL18 G	EDG 31 BEGAN CYCLING BETWEEN 56 AND 63 CPS	GOV OIL DRAIN VLV NOT SHUT TIGHTLY
1P3	016635	092476	AL18 G	EDG 31 OUTPUT FREQ INC TO 62 HZ, COULD NOT CONT ELE	GOV AIR IN GOV OIL LINES FROM PREVIOUS REPAIR
1P3	016286	102176	AL18 L	EDG 31 UNABLE TO CONTROL SPEED OF NO 31 DG	UNIT/PARA RELAY UPER INTRMIT-DEFELTY CONN
RC1	022450	081679	AL18 J	EDG 31 B EDG OUTPUT BREAKER WOULD NOT CLOSE	BAD CONN AT CONT PWR FUSE BLOCK STUBS

Y N T	P L A N T	CONTROL NO.	FAIL DATE	M K G M	FAIL DATE	FAILURE MODE	FAILURE MECHANISM	
G	BPI	014417	032476	CA02	D	BOY	TRIP ON HI COOLING WATER TEMP	WATER PUMP SUCT SCREEN PLUGGED
G	BPI	044894	051676	CA02	D	BOY	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	INLET SCREEN PARTIALLY PLUGGED
G	BPI	045448	080576	CA02	M	A03	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	OPERATOR NOT AWARE OF SIGNIF OF START TIM
G	BPI	015449	080576	CA02	D	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	POSSIBLE WATER JACKET HEATER FAILURE
G	BPI	05444	081276	CA02	C	ALV	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	STARTING BATTERY CABLE FAILD LOOSE CONNEX
G	BPI	016072	090276	CA02	A	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	POSSIBLE FUEL SYSTEM FAILURE
G	BPI	016504	102876	CA02	G	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	POSSIBLE FUEL GOVERNOR CONTROL PROBLEM
G	BPI	016460	110476	CA02	G	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	POSSIBLE FUEL GOVERNOR PROBLEM
G	BPI	016567	112876	CA02	C	ALV	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	BROKEN SPRING IN BENDIX MECHANISM
G	BPI	016597	120276	CA02	G	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	FUEL GOVERNOR REPLACED ON 12/19/76
G	BPI	016913	122076	CA02	G	A04	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	GOVERNOR LUBE (FUEL SYS UNDER INVESTIGM
G	BPI	016912	122776	CA02	A	A04	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	FUEL GOV. LUBE OIL SUPPLY MODIFID 1/10/77
G	BPI	016911	122876	CA02	C	ALV	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	BROKEN SPRING DELCO PART #1945467
G	BPI	016910	010377	CA02	G	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	CAUSE UNKNOWN LUBE OIL RETENTION IN GOV.7
G	BPI	020298	032477	CA02	G	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	GOVERNOR LUBE SYS MODIFIED ON 1/10/77
G	BPI	018102	051877	CA02	D	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	FUEL CRITERIA EXCEEDED BY 12 SECONDS
G	BPI	018103	052677	CA02	A	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	FUEL CONTROL VALVE MODIFIED
G	BPI	018742	080577	CA02	J	A04	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	AND MAN TRANSFR FAILD TO CLOSE OUTPUT BKR
G	BPI	019541	102077	CA02	C	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	CHECKD VCLTAGE DRUP ON START CABLES
G	BPI	019993	112477	CA02	A	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	FUEL CHECKED OK PREM GRADE OF FUEL USED
G	BPI	020575	022278	CA02	M	A00	TRIP ON HI COOLN WATER TEMP PUMP SHAFT SCORED	CAUSE UNKNOWN
G	BPI	020560	020978	CA02	D	B12	TRIP ON HI WATER TEMP AFTR 25 MIN OF OPS	AIR LEAKAGE ON PUMP COOLING WATER SHAFT

PLANT	CONTROL NO.	FAIL DATE	M K G M	FAILURE MODE	FAILURE MECHANISM
G	C01 015872	082376	CB40 A 800	FUEL LINE TO AN INJECTOR OF #1 DG BURST	CAUSE UNDETERMINED
G	C01 016260	110776	CB40 K 808	DI DG-2 LOST ELECT GOVERNOR CONTROL AND VOLTAGE	POT. TRANSFORMER FUSE CONTACTS OXIDIZED
G	C01 016712	111076	CB40 J A03	DI DG-1 OUTPUT 8KR FAILED TO CLOSE--BLOWN FUSE 59RELAY	DISCONNECTED ONLY ONE WIRE ON 11/8/76
G	C01 023044	091278	CB40 F A09	DI DG-2 TRIPPED APPROX 1 MIN AFTER REACH RATED SPEED	MAIN BEARING FAILED DUE TO LOW LUBE OIL
M	Z11 015188	062176	CB40 A 813	DI DG-14 DG HAD FO LEAKAGE AT THE 8L FUEL INJ PUMP	VIB CAUSED CRACKED FING ON LINE TO INJ
M	Z11 016179	092476	CB40 M A00	DI DG-14 DIESEL GENERATOR FAILED TO START	NO CAUSE COULD BE DETERMINED
M	Z11 020255	010378	CB40 K 810	DI DG-18 DG OUTPUT VOLTAGE PEGGED HIGH-COULD NOT LOWER	PC BOARD FAILURE IN THE VOLTAGE REGULATOR
M	Z11 0203488	011678	CB40 G 810	DI DG-18 DG "DM" STARTED & LOADED BUT DECLARED INOPERABLE	LD CONTACT AIR PRESS-TRIP VLV "DM" RING LK
M	Z11 022110	080178	CB40 C A10	DI DG-18 DIESEL GENERATOR FAILED TO START	AIR LEAK IN STARTING AIR PILOT VALVE
M	Z11 022515	090278	CB40 C A10	DI DG-18 DIESEL GENERATOR FAILED TO START	STARTING AIR DIST BUSHING ROTATED IMPROV
M	Z11 022846	091478	CB40 B A02	DI DG-14 DG CAME UP TO SPEED AND THEN TRIPPED - 5 TIMES	RAG IN OIL STRAINER CAUSED LO OIL PRESS I
M	Z11 023508	122078	CB40 M A00	DI DG-18 DG FAILED TO START DURN AN INADVERTNT SAFETY INJEC	EXTENSIVE TESTING REVEALED NO CAUSE
M	Z12 017808	042777	CB40 G 810	DI DG-18 DG GOVERNOR SPEED CONTROL FAILED UN 28 DIESEL GEN	GOV SPD CONT GEAR JAMMED AGAINST HI SPD STO
M	Z12 017809	050677	CB40 I 813	DI DG-18 DG DIESEL GENERATOR 2A TRIPPED FROM FULL LOAD	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
M	Z12 017714	111077	CB40 B 812	DI DG-18 DG DIESEL GEN TRIPPED ON LOW LUBE OIL PRESSURE	CAVITATION OF LO PUMP - WATER IN LUBE OIL
M	Z12 017806	111777	CB40 I 813	DI DG-18 DG DIESEL GENERATOR TRIPPED OFF-LINE	LEAK IN AIR LINE TO MASTER SHUTDOWN VALVE
M	Z12 020258	010678	CB40 K 810	DI DG-24 DG OUTPUT VOLTAGE INCREASED AND COULD NOT LOWER	BURNED CONTACT IN THE VOLTAGE REGULATOR
M	Z12 020460	010978	CB40 G 810	DI DG-28 DG POWER OUTPUT UNLD - COULD NOT LOWER MANUALLY	GOV SYNCH IND GR JAMMED ON HI SPD STOP
M	Z12 021544	051778	CB40 K 814	DI DG-24 DG OUTPUT VOLTAGE CYCLED - COULD NOT CONTROL	DRIFT OF VLTGE REGULATOR STABILITY CIRCUIT

DE LAVAL 500-1000 KW

P L A CONTROL FAIL
 M N T NL
 * SUI 021310 032878 0110 A 406
 * SUI 022100 071978 0110 A 406

FAILURE MODE
 DIESEL GENERATOR FAILED TO START
 DIESEL GENERATOR FAILED TO START

FAILURE MECHANISM
 FUEL LNKG BINDING - BEARINGS IN LNKG DRY
 FUEL RACK BINDING-INCCRP PROC TO EXERCISE

FALPBANKS MORSE 2500-2890 KW

VEN	LA	CONTROL NO.	DATE	FAIL	M	E	K	G	M	FAILURE MODE	FAILURE MECHANISM
C	CC1	015587	072976	FM25	D	A02	J	A02	S	D 4 N #12 DG FAIL TO START AUTO FAIL ALSO FROM CONT RM JACKET COOLING H2O SYS AIRBOUND NOT VENTED	
C	CC1	015584	080776	FM25	J	A02	S	U	G	I 11 DG FAIL TO SENSE "AT VOLTAGE" COND. - OUTPUT BKR. WILL NOT CLOSE - COLD SOLDER CONN TO ERA	
C	CC1	016405	162576	FM25	M	800	R	U	I	T #12 DG S/D DUE TO DG VENT FAN STOPPED - BLOWN FUSE	CAUSE FOR BLOWN FUSE NOT DETERMINED
C	CC1	017213	111876	FM25	M	A00	R	U	I	T #12 DG S/D DUE TO ITS VENT FAN NOT STARTING	BLOWN FUSE - REPLACED CONTROLLER COIL ??
C	CC1	017822	051577	FM25	M	A09	R	T	8	T #12 DG FAN FAIL TO START WHEN GEN RECEIVED SIGNAL	DIRT ON FAN MAIN BKR CONTACTS
C	CC1	018366	091777	FM25	F	802	D	I	T	#11 DG START/LATER DISCOVERED #6 CYLINDER RELIEF	VALVE VIBRATED LOOSE AND FELL OFF DG
C	CC1	018488	071177	FM25	B	802	L	D	4	M #11 DG ON FIRE DUE TO L.O. HITTING HGT EXHAUST	O-RING SEAL ON STRNIP NOT GLOED PROPERLY
C	CC1	018487	071377	FM25	D	802	S	D	I	T #11 DG TRIPPO ON LCM JACKET COOLNT PRESS WHEN SIAS	SIGNAL REMOVED; OP SWITCH ISOLATED
C	CC1	019292	101677	FM25	K	A13	T	8	T	#12 DG FAIL TO REACH VOLTAGE WITHIN 10 SEC.	2 LOOSE FUSE HELDS IN EXCITATION CIRCUIT
C	CC1	021060	041078	FM25	L	A00	U	I	T	#12 DG OVERSPED & TRIPPED RESTARTED SUCCESSFULLY	CAUSE NOT DETERMINED TESTED SAT NEXT TIM
C	CC1	021025	041378	FM25	M	A00	U	I	N	#11 DG FAIL TO START ON LOSS OF OFFSITE POWER	START/FAILURE ALARM DISPLAY NO ABNORMALS
C	CC1	023300	121876	FM25	M	800	R	D	I	T #11 DG SHUTDOWN DUE TO ROOM VENT, FAN FAIL TO STRT	FAN FAILURE - RESEY OVERLOADS
C	CC2	016722	121576	FM25	C	A09	T	4	T	#21 DG FAIL TO START FROM CONTROL ROOM & LOCALLY	CLOGGED AIR STRT DISTRIBUTOR PILOT VALVES
C	CC2	018422	022277	FM25	C	A00	U	8	T	#21 FAIL TO START & ASSUME RAIED SPEED IN 10 SEC	AIR START SYS DISASSMOLD & INSPECTED
C	CC2	017457	031777	FM25	M	A00	R	U	I	T #12 DG VENT FAN FAIL TO START ON SIAS SIGNAL	OVERLOADS TRIPPO ON FAN; RESET OVERLOADS
C	CC2	017986	060177	FM25	D	A12	T	0	T	#21 DG FAIL TO MEET START TIME CRITERIA	SERVICE WATER INLET VALVE LEAKING EXCEED
C	CC2	026426	011678	FM25	J	816	T	1	T	#21 DG TRIPPED AFTER 29 MIN. DUE TO GEN FAULT	LOSS OF FIELD & REVERSE POWER RELAYS
C	CC2	021491	080178	FM25	D	B10	S	0	4	I #21 DG TRIPPO ON HI JACKET COOLNT TEMP	SEV H2O SUPPLY VALV FAIL TO OPEN
C	M12	014260A	021776	FM25	A	A09	B	T	1	N DG 12U FAILED TO START - SIMILAR OCCUR, LER (75-23)	DIRTY FUEL OIL FLTR; CARBON IN CRK; SE VENT
C	M12	014260B	021876	FM25	A	B09	B	T	1	N DG 12U TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR; CARBON IN CRK; SE VENT

FAIRBANKS MORSE 2500-2850 KW

V E N	P L A N I	CENTROL NU.	FAIL DATE	M F G	K W	S U B S Y S	F A I L M O D E	F A I L M E C H	T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
C	M12	0142600	022076	FM25	A	809	B	I	1	N	DG	12U	TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	DIRTY FUEL OIL FLTR, CARBON IN CRKCS VENT
C	M12	0142600	022376	FM25	F	804	B	T	G	N	DG	12U	TRIPPED OFF-LINE - SIMILAR OCCUR, (75-23)	UPPER RCD BEARING FAILURE - LACK OF LUBRI
C	M12	015106	060276	FM25	F	809	B	T	1	T	DG	13U	TRIPPED ON HI CRANKCASE PRESS - 11 MIN RUN	CRKCS AIR EDUCTOR FOUND DIRTY
C	M12	015283A	081676	FM25	G	A10	B	T	4	T	DG	12U	FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C	M12	015583B	081776	FM25	G	A10	B	T	4	T	DG	12U	FAILED TO START	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C	M12	015583C	082376	FM25	G	B10	B	T	4	T	DG	12U	TRIPPED OFF-LINE	DRIED LEATHER WASHER IN BOOSTR SERVOMOTOR
C	M12	015906	090176	FM25	B	B12	C	T	1	N	DG	13U	SHUTDOWN - FIRE ON EXHAUST MANIFOLD	LUBE & FUEL OIL ACCUM UNDER MANIF INSULAT
C	M12	016036	091976	FM25	B	B12	B	D	4	N	12U	DG	HAD TO BE SECURED AND DECLARED IMOPERABLE	EXCSV LEAKAGE OF LUBE OIL FILTER GASKET
C	M12	016031	092276	FM25	D	809	B	T	6	T	12U	DG	RECVD LOW CW FLO ALA-UNIT UNLOADED, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12	016626	120176	FM25	D	A09	B	T	6	T	13U	DG	STARTED, NO CW FLOW, SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12	016755	121876	FM25	F	806	D	G	T	DG	13U	#3	UPPER PISTON CON ROD BRNG CAP SHEARED	CAPSCREWS FAILED - PROB DUE TO DRY STARTS
C	M12	017020	011077	FM25	F	B13	S	D	G	T	DG	13U	SHUTDOWN DUE TO HIGH VIBRATION	SKID MOUNT IN RESONANCE WITH ENG FREQUEN
C	M12	018923	081077	FM25	G	A01	S	D	1	N	DG	12U	FAILED TO RESTART ON DEMAND	GOVERNOR STILL IN "NO FUEL" FROM PREV S/D
C	M12	018972	081777	FM25	D	809	B	T	G	T	12U	DG	LOW CW FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12	018976B	092677	FM25	D	809	B	T	G	N	COOLING WTR	LOW FLOW ALARM - 12U DIESEL GEN	INSLF CL INJECTION FOR ADD MUSSEL CONTROL	
C	M12	019255	092477	FM25	I	B14	S	T	B	T	12U	DG	APPEARED TO TRIP ON GEN OVERCURRENT	MICRO SW OUT OF ADJ ON DG DVSPD TRIP MECH
C	M12	019929	110977	FM25	K	A01	S	D	1	T	DG	13U	TRIPPED WHILE PARALLELING WITH 4160V BUS	IMPROPER VOLTAGE SETTING PRIOR TO PARALL
C	M12	021386	050878	FM25	D	809	B	T	G	T	12U	DG	LOW CW FLOW ALARM, DG UNLOADED AND SECURED	EXCSV MUSSEL FOULING OF DG HT EXCHANGERS
C	M12	022131	080378	FM25	A	807	T	B	T	DG	13U	SHUTDOWN DUE TO LEAKING INJECTOR	CRACK IN INJ PUMP DISCH VALVE CAGE	
C	M12	023213	120578	FM25	D	809	B	T	G	T	12U	DG	S/D DUE TO LOW COOLING WATER FLOW	MUSSEL SHELLS IN THE HEAT EXCHANGER

FAIRBANKS MORSE 2500-2850 KW

V E N T	P L A N T	CONTROL NO.	FAIL DATE	M F G W	F A I L S U B S Y S	M O D E	T Y P E	C L A S S	R E P A I R	D I F F I C U L T Y	FAILURE MODE	FAILURE MECHANISM
G DA1	014334	022776	FM25	B	B12	R	T	D	T		SMALL FIRE ON EXHAUST MANIFOLD OF DG 1G21	OIL LEAK FROM FRONT COVER PLATE
G DA1	014337	031776	FM25	H	B12	R	T	D	T		SMALL FIRE NEAR EXHAUST MAN-TURBOCHRG R FLANGE	1G21 LEAKY FLANGE GASKET
G DA1	014953	062276	FM25	D	809	C	T	B	T		1G-31 DG TRIPPD ON HI JACKET TEMP-DECLARED INOPRBL	ESW LOW FLOW DUE TO MUD IN STRAINER
G DA1	015993	100776	FM25	F	A05	D	D	T			1G21 BROKEN LOWER VERT DRIVE COUPLING HUB	HUB MADE OF WRONG MATERIAL
G DA1	016452	110476	FM25	A	B04	D	D	T			DG 1G-21 S/D DUE TO FIRE -FUEL LINE FRACTURE	INADEQUATE DESIGN
G DA1	017756	051077	FM25	J	A10	S	D	B	T		1G-21 DG OUTPUT BKR FAILED TO CLOSE	AUX CONTACTS OF STNDBY TRANSFORMER OPEN
G DA1	017963	051277	FM25	G	B06	S	D	I	T		1G-31 DG WOULD NOT REACH FULL LOADING ONLY 250G KW	SPEED SETTING ADJUSTMNT NOT RESET
G DA1	021171	040576	FM25	F	A06	D	G	M			BEARING WIPED ON 4/13/77 NOT DUE TO MISALIGNMENT	LUBE OIL FILTER DRAIN VALVE WAS OPEN
G EN1	014778	031576	FM25	C	A10	D	D	T			1A DG FAILED TO START DURING SURVEILLANCE	SDL OPER AIR VLV IN START SYS STUCK SHUT
G EN1	014745	050176	FM25	M	B13	S	T	B	T		NORMAL SURV. TEST DG 1C TRIPPD; LOOSE WIRE	NUT VIBRATED OFF WIRE-PANEL R43-PC01C
G EN1	014796	051576	FM25	M	A00	U	U	I			1B DG FAILED TO START ON FIRST ATTEMPT	UNKNOWN WILL DO WEEKLY START TO DETERMINE
G EN1	015557	062676	FM25	B	B02	S	D	B	T		DG 1C TRIPPD DUE TO LUBE OIL SWITCH NOT CALIBRATED	PERSONNEL DID NOT CALIBRATE SWITCH
G EN1	015568	080576	FM25	K	A06	S	D	I	T		DG 1A TRIPPED DUE TO LOSS OF EXCITATION DRNG SYNCH	DEFECTIVE PROCEDURE - PARALLELED OUT OF SYN
G EN1	015947	081476	FM25	M	A00	R	D	U	T		1C DG FAILED TO START DURING SURV TEST - RECURRING	EXACT CAUSE OF START FAILURE NOT KNOWN
G EN1	016065	091176	FM25	G	A10	R	D	I	T		1A DG FAILED TO START - SURV TEST - OCCURRED PREV	LOW OIL LEVEL IN GOVERNOR
G EN1	016842	122776	FM25	M	B00	R	U	U	T		DG 1C TRIPPD APPROX 45 MIN. OF RUN TIME; REPETITIVE	CHECKNG OUT LOGIC ON 1C DG
G EN1	016843	123176	FM25	M	A00	R	U	I	T		MAN START OF 1A DG FAILED THIS HAS HAPPND BEFORE	INSPECTED & RETESTED SATISFACTORILY
G EN1	018141	052877	FM25	M	A00	U	U	T			1A DG FAILED TO COME UP TO RATED VOLT IN REQD. TIME	TOOK 16 SEC VS 12 SEC RETESTED SATISFAC
G EN1	018644	061377	FM25	D	B14	I	D	4	T		1C DG TRIPPD RESTARTED SATISFACT LO JACKET CLNT	LOW COOLNT PRESS SWITCH TO BE CALIBRATED
G EN1	018646	061877	FM25	D	B14	I	D	4	T		1C DG TRIPPD ON LO COOLNT JACKET PRESSURE	POSSIBLE INCORRECT PRESSURE SETPOINTS

FAIRBANKS MORSE ----- 2500-2800 KM -----

PLANT	CONTROL NO.	FAIL DATE	PK G M	FAILURE MODE	FAILURE MECHANISM
G ENI	018047	022577	FM25	UN LD COUNT JACKET PRESS	OPERT PRESSURE WAS ABOVE TRIP SETPOINT
G ENI	018039	061277	FM25	LOST MANUAL VOLTAGE CONTROL	MAN REG MTR OPER AFMR PWR SUP DIODES FAIL
G ENI	020031	081677	FM25	DURING SURV TESTING, DG 18 GEN INBOARD BRNG FAILED	BEARING OVERHEATED - EXACT CAUSE UNKNOWN
G ENI	020013	111977	FM25	DG 18 DG OUTPUT VOLTAGE TOO HIGH - 18 DG SHUTDOWN	IMPROPER ADJUSTMENT OF AUTO REG SETPOINT
G ENI	020284	112577	FM25	DG 18 DG FAILED TO START, STUCK GOVNR BOOSTER SERVO MOTOR	AIR PISTON WAS CORRODED
G EN2	022751A	102878	FM25	DG 18 DIESEL FAILED TO REACH 250RPM IN 7 SEC.	STICKING GOVNR BOOSTER SERVO
G EN2	022751B	103178	FM25	DG 18 DIESEL FAILED TO REACH 250RPM IN 7 SEC.	FAULTY ELECTRONIC SPEED SWITCH SIGNAL
W JF1	020990	030678	FM25	DG 18 GEN 1C FAILED TO START DURING TEST	CORROSION PRODUCTS CLOGGED AIR START WLVs
W JF1	02237A	062778	FM25	DG 18 GEN 2C DG WOULD NOT RESPOND TO AUTO OR MAN SPEED CHG	BLCM FUSES FOR MCP AND MOF
W JF1	022987	100378	FM25	DG 18 GEN 1C FAILED TO CLOSE ON START	JUMPER FOR UNIT 1/UNIT 2 SEPAR, INCRECTLY PUT
W K02	014823	030176	FM25	DG 18 ENR DIESEL DID NOT REACH RATED CAPACITY	# 12 CYL INJ PLUNGER & BARREL CALLED
W K02	019354	021377	FM25	DG 18 ENR DIESEL GEN FAILED TO ASSUME FULL LOAD	SEVERAL FUEL INJ RODS WERE STICKING
W K02	021313	041078	FM25	DG 18 EDG LOAD FAILED TO INCREASE ABOVE 900KW	COMM BRUSH VIBRATED OUT OF GOV SPD CHGR

FAIRBANKS HORSE 3000-3500 KW

V	P	LA	CONTROL	FAIL	M	DATE	MODE	FAILURE MECHANISM
N	N	N	NO.	DATE	K			
T					G			
B	CR3	018231	FM30	060277	A	113	T	WAM DG FAILED TO START ON MONTHLY TEST
B	CR3	018565	FM30	072677	I	A06	S	D 1 T W38M DG FAILED TO START DIESEL TRIPS WERE NOT RESET REVISED PROCEDURES TO RESET TRIPS
B	CR3	019362	FM30	092877	B	A10	S	0 8 T 38 DG FAILED TO START DUE TO START PERMISSIVE LOST
B	CR3	020221	FM30	122777	G	A09	K	0 8 T 38 DG FAILED TO START --3RD OCCURRENCE
B	CP3	020278	FM30	010378	G	A09	R	0 6 T 38 DG FAILED TO START --4TH OCCURRENCE
B	CR3	023166	FM30	111378	M	A00	R	U 1 T EDG-B FAILED TO FAST START ON TWO CONS. ATTEMPTS
B	TI1	014298	FM30	022176	J	A06	S	0 1 T W18M DG OUTPUT BREAKER FAILED TO CLOSE
B	TI1	020295	FM30	011278	B	A14	S	4 T EDG 1B FAILED TO START ON SIMULATED AUTO ES TEST
B	TI1	020597	FM30	031078	B	A10	T	0 1 T EDG FAILED TO START
B	TI2	021609	FM30	042578	F	800	R	U 1 T W8M DG TRIPPED ON HI CRANKSE PRESS AFTER 32 MIN RUN
B	TI2	021607	FM30	052078	F	A05	C	0 6 T DG B FAILED TO START
B	TI2	021605	FM30	052378	F	809	R	1 0 M DG 8 TRIPPED ON HIGH CRANKCASE PRESS - 32 MIN RUN
B	TI2	023430	FM30	122078	A	A09	T	0 1 T DF-A-18 DID NOT START
G	P82	018886	FM30	082677	D	A01	S	0 1 T E1 DG FAILED TO START DUE TO HI JMT CLG WTR TEMP
G	P82	018887	FM30	082677	I	A06	S	0 4 T E4 DG TRIPPED ON OVERSPED
G	P82	019414	FM30	101877	D	A02	S	0 1 N E3 DG TRIPPED FOLLOWING MANUAL START
G	P82	020090	FM30	121977	L	A00	U	0 1 T E1 DG TRIPPED ON "M" PHASE DIFF AFTER PARALLELING
G	P82	020065	FM30	022878	B	B12	C	0 6 T E-2 DIESEL TRIPPED ON HIGH CRANKCASE PRESSURE
G	P82	022462	FM30	081078	G	A10	T	1 T E-3 DG START TIME DID NOT MEET TS REQUIREMENT
G	P82	023349A	FM30	122178	G	A10	D	1 T E3 DG START TIME 13 SEC. VS. REQUIRED 16 SEC.

FAIRBANKS MORSE 3000-3500 MW

PL	CONTROL NO.	FAIL DATE	M K G M	FAILURE MODE	FAILURE MECHANISM
G	PR2 0233498	122178	FM30 G 400	E2 DG START TIME 11 SEC. VS. 10 SEC	POSSIBLE GOVERNOR PROBLEMS
G	VY1 014740	050676	FM30 F 409 R T 4 N	"B" DIESEL GENERATOR TRIPPED ON HI CRANKSE PRESS	CLOGGED CRANKSE EJ SUP ORIFICE OR EJ BODY
G	VY1 015739	082576	FM30 A 813	"I" "B" DG GOS TO TIGHTEN FUEL HEADER FITTINGS	ENGINE VIBRATION LOOSEMED MECHANICAL CONN
G	VY1 016323	062377	FM30 F 813 R T 4 T	"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE	VIBRTN CAUSED HOSE CLMP ON AIR EJECT FAIL
G	VY1 019828	072677	FM30 C 409	"T" "T" "A" DIESEL GENERATOR FAILED TO START	AIR START SOL VALVES BOUND CLSD BY DEBRIS
G	VY1 020194	121977	FM30 F 813 R T 4 T	"B" DG TRIPPED ON HIGH CRANKCASE PRESSURE	ENG VIB CAUSED AIR EJECT HOSE TO LOOSEN
G	VY1 020464	012478	FM30 D 809	"T" "T" DIESEL GENERATOR "A" TRIPPED ON HI JAKET CLMG TEMP	3-WAY VLV BLOCKED TO BYPASS CLNT ARND HX
M	PR1 018342	061777	FM30 G 810	"T" "B" "D" "G" FAILED TO RESPOND TO LOAD CHANGE SIGNALS	LINK LEVER KEY MISSING CAPSCREWS LOOSE
M	PR2 015735	091076	FM30 F 802	"D" "T" "D" "L" "G" TRIPPED ON HIGH CRANKCASE PRESSURE	HOSE CLAMPS ON PIPE NOT CONN AFTER MAINT

FAIRBANKS MORSE ----- 4000-4418 KW -----

P L A N I N T	CONTROL NUM.	FAIL DATE	M F K G M	SUB SYS	FAILURE MODE	FAILURE MECHANISM
W	JF1 C19655	081777	FM40 C	A10 B D U T	DG 18 TRIPPED DURING ATTEMPT TO VERIFY OPERABILITY	MAIN AIR VALVE FAILED TO SHUT, CAUSED OVRSP
W	JF1 019062	082677	FM40 C	A10 B D U T	DG 18 TRIPPED ON OVSPO DURING MANUAL START	MAIN AIR START VLV FAILED TO FULLY SHUT
W	JF1 019559	091377	FM40 C	B10 B D N	DSL GEN 18 EVENTUALLY TRPP ON OVSPO AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
W	JF1 019566	091677	FM40 C	B10 B D N	DSL GEN 1-2A EVENTUALLY TRPP ON OVSPO AFTER START	MAIN AIR START VALVE FAILED TO FULLY SHUT
W	JF1 019568	100277	FM40 G	A10 B D T	DSL GEN 1-2A FAILED TO START DURING TEST	SPEED SWITCH FAILED - 120V VS 1.0V RATING
W	JF1 020092	030278	FM40 C	A09 C T D T	DSL GEN 18 FAILED TO ATTAIN RATED SPEED	CORROSION PRODUCTS CLOGGED AIR START VLVs
W	JF1 C21185	032378	FM40 C	A02 D D N	DSL GEN 18 FAILED TO COME UP TO SPEED PER TECH SP	MAT- AIR START VLV PUSHER ASSY MISSING
W	JF1 022235	081278	FM40 J	A10 S 9 8 N	OUTPUT BRK FOR DG 18 FAILED TO CLOSE AUTOMATICALLY	OPER MECH FOR AUX SWITCHS OUT OF ALIGNMT
W	JF1 022373	090578	FM40 G	A10 R 0 8 M	1-2A DG WOULD NOT RESPOND TO AUTO VLTG CR SPD CHGS	BLOWN FUSES FOR MDP, CAUSED BY FAIL DIODES
W	JF1 C22630	091778	FM40 G	A10 0 4 T	18 DG FREQ COULD NOT BE INCR ABOVE 58.5 HZ	CPING BET DC MTR AND 60V POS PUT WAS LOSS

GENERAL MOTORS 200-400 KW

PLANT	CONTROL NO.	FAIL DATE	KW	MODE	REASON	FAILURE MODE	FAILURE MECHANISM
WY1	017316	030177	GM02	C	A10	#1 DG FAILED TO START DUE TO	ARMATURE SHAFT BROKEN--REPLACED W SPARE
WY1	018653	080277	GM02	D	809	#1 DG OVERHEATED--RUNNING FOR APPROX 25 MINUTES	SLUDGE AND SCALE IN 67% OF RADIATOR TUBES
WY1	018654	080277	GM02	D	809	#3 DG OVERHEATED AFTER 30 MIN. OF OPERATION	72% OF RADIATOR TUBES BLOCKED SLUDGE SCALE

GENERAL MOTORS 500-1000 KW

PLANT	CONTROL NO.	DATE	REMARKS	FAILURE MODE	FAILURE MECHANISM
G 001	020400A	012978	GM10 M	U-1 B/U DG FAILED TO START 1ST 5 TIMES-LW TEMPERAT	WINTER WEATHER
G 001	620652	030478	GM10 C	U-1 FAILED TO START DUE TO COLD WEATHR	6 HEATRS INSTALLED & ROOM WINTERIZED
G 001	921517	050778	GM10 B	U-1 B/U FAILED TO START R/X IN HOT SPD MODE	SYNCHRO START SWITCH FAILD
G 001	021516	051178	GM10 A	TEMPORARY DG FAILED TO START DUE TO LOW LUBE OIL PRS	L.O. PUMP COUPLING DAMAGED
				U-1 B/U DG FAILED TO START-BLOW FUSES IN CONT LOGIC	SHORTED DIODE ACROSS FUEL PRIMING PUMP

GENERAL MOTORS ----- 250-2850 KM -----

PL	CONTROL NO.	FAIL DATE	F K G M	SYSTEM	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM
B	AK1 014838	051176	GM25 C A10	START	OG #1 FAILED TO START ON SIMULATED E-3 ACTUATION	FAILURE DIODE IN AUTO START CIRCUIT	
B	AK1 019578	102377	GM25 C A14	START	OG #1 FAILED TO START DUE TO LURE OIL GETTING INTO EXHAUST TURBOCHARGER BEING FAILED CAUSING SEAL FAILURE	ALSO DIODE CR-1 FOUND SHORTED	
B	AK1 021063	032078	GM25 E 800	START	OG #2 ON FIRE DUE TO LURE OIL GETTING INTO EXHAUST TURBOCHARGER BEING FAILED CAUSING SEAL FAILURE	IMPROPER SETTINGS OF HI SPEED AND OVERSPD	
B	AK1 019816	122977	GM25 G A14	START	OG #1 STARTED AND TRIPPED ON OVERSPD	DIRTY CRANKCASE VENT CIL COLLECTOR	
B	AK1 020273	011978	GM25 F A09	START	OG #1 TRIPPO ON HI CRANKCASE PRESSURE	DESIGN/FABRICIN OR COMPRT FAILURE/REPLACD	
B	AK1 020708	020878	GM25 E 805	START	OG #1 FAILED TO START DUE TO NOISY TURBOCHARGER	CAUSE UNKNOWN EXTENSIVE MAINT PERFORMED	
B	AK1 021560	050978	GM25 E 800	START	OG #1 FAILED TO START DUE TO NOISY TURBOCHARGER	CAUSE UNKNOWN EXTENSIVE MAINT PERFORMED	
B	AK1 021692	060478	GM25 K A10	START	OG #1 FAILED TO OPERATE WITH PROPER FREQ/VOLT	FAILD PRIMARY POTENTIAL FUSE FOR OG 1-1	
B	AK1 023007	103178	GM25 M B11	START	OG #1 FAILED TO OPERATE WITH PROPER FREQ/VOLT	OUTSIDE AIR DAMPER WOULD NOT OPEN	
B	AK1 015359	071578	GM25 M A00	START	SEVERAL ATTEMPTS TO START "M" DG WERE UNSUCCESSFUL	NO DEFINITE CAUSE COULD BE FOUND	
B	AK1 015622	080678	GM25 C A10	START	"M" DG FAILED TO START DURING SPECIAL TEST	IMPROPER GEAR ENGAGEMENT-AIR STRT MTR ODC	
B	AK1 016656	120678	GM25 G B10	START	"M" DG TRIPPED OFF-LINE 25 MIN INTO TEST	SPEED CONT SW FLD CLOSED/SPD DECR TO TRIP	
B	AK1 018653	082477	GM25 M A00	START	DIESEL GENERATOR "M" FAILED TO START	NO SPECIFIC CAUSE COULD BE DETERMINED	
B	AK1 022613	100478	GM25 A B01	START	OG #1 FAILED TO START DUE TO SPRAY OF FUEL OIL "M" DG 003	FUEL LEAK-EXCESSIVELY LOOSEENED STRR PKG GLND	
C	AK1 014559	040778	GM25 M A06	START	OG #1 START ON SECONDARY AIR REVD 10.6 SECS-VS. 10SECS.	PROCEDURE WAS INADEQUATE	
C	AK1 014596	042778	GM25 C A02	START	OG #2 PRIMARY AIR START MTR FAILED TO DISENGAGE	IMPRPR SEING FOR MAG PKUP ON SWICMG TACH	
C	AK1 015614	081578	GM25 G B10	START	OG #2 SMOKE COMING FROM DG-2 GOVERNOR MTR ENCLCSURE	ARMATURE HAD OPEN WINDING	
C	AK1 015722	081578	GM25 C A14	START	OG #2 PRIMARY AIR START MTR FAILED TO DISENGAGE	SEING FOR MAG PKUP ON SWICMG TACH DRIFTED	
C	AK1 017662B	040677	GM25 C A09	START	OG #1 FAILED TO START WITHN 10 SEC/STRID OK ON PRL AIR	DEPOSITS FOUND ON SECONDARY AIR MOTORS	
C	AK1 017662A	041477	GM25 C A09	START	OG #2 FAILED TO START IN 10 SEC STRID OK ON PRIMARY	DEPOSITS IN SECONDARY AIR MOTORS	

GENERAL MOTORS ----- 2500-2850 KW -----

PLANT	CONTROL NO	FAIL DATE	EX	REASON	FAILURE MODE	FAILURE MECHANISM
C	FC1 021642	061078	GM25	K A10 R D I T	DG-1 FAILED TO REACH RATED TERM VLTG ON STARTUP	BLOWN FUSE IN GEN FIELD CIRCUIT
C	FC1 041799	071278	GM25	K B10 R D B T	DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUT DOWN	3 EXCITER SUBCOMPONENT FAILURES(COINCIDENT)
C	FC1 022249	080978	GM25	K B10 R D B T	DG-1 FIELD WENT TO MAX EXCITATION - UNIT SHUT DOWN	REFER VOLTAGE ZENER DIODE OUTPUT DRIFTED
C	MY1 020733	021978	GM25	G A09 T B T	DG-1A FAILED TO RESPOND DURING TEST RUN FOR TRAINING	DIRTY CONTACT ON SPEED CONTROL PC BOARD
C	MY1 022715	092578	GM25	A A06 S D I T	DG-1B COULD NOT BE LOADED DURING TEST AFTER MAINT	AIR WAS NOT PURGED FROM FUEL LINES
G	DR2 014913	052376	GM25	C A00 U I T	UNIT 2/3 DG FAILED TO START	CAUSE UNKNOWN BUT POSSIBLE AIR START SYST
G	DR2 016168	093076	GM25	K B09 F D T	2/3 DG OUTPUT ERRATIC AFR CONTROL PLACED IN "STOP"	SHOPIED SELENIUM RECTIFIER DUE TO DIRT
G	DR2 016443	102976	GM25	I A14 J Y D T	UNIT 2 DG FAILED TO START TWICE MALFUNCTION S/D SOLENOID PLUNGER OUT OF ADJUSTMENT	SOLENOID PLUNGER OUT OF ADJUSTMENT
G	DR2 016054	121876	GM25	A B02 S U T	UNIT 2 DG FAILED TO CARRY REGD LOAD 120600KW MAX	H2O IN FUEL SUPPLY FROM FLUSHING OPERATION
G	DR2 017397	032277	GM25	C A10 R D I T	UNIT 2/3 FAILED TO START	AIR START MOTOR PINION GEAR JAMMED
G	DR2 018203	063077	GM25	G A00 K D I T	2/3 DG TRIPPED ON OVERSPEED DURING 2 ATTEMPTS	POSSIBLE CUT-OFF-ADJUST GOVERNOR COMPENSATION
G	DR2 018484	071277	GM25	G A00 R D I T	U 2/3 D/G TRIPPED ON OVERSPEED--OCCURED ALSO 6/30/77	PREDABLE CUT-OFF ADJUST GOVERNOR COMPENSATION
G	DR2 019651	103077	GM25	E B06 F G T	UNIT 2/3 UNLOADED TRIPPED ON LOW H2O PRESS REST-1	TURBO-CHARGE CLUTCH(SHAFT BEARING
G	DR2 017732	111677	GM25	I A09 S D I T	ALTO-START SIGNAL SENT TO UNIT 2/3 DUBIN COPE SPRY	RESET START FAILURE RELAY & DIESEL START
G	DR2 019728	112977	GM25	D B12 C O T	2/3 DG S/D DUE TO COOL H2O PUMP TRIP 10MIN. LOADED	WATER LEAKO GROUNDED PUMP STATOR
G	DR2 017723	120277	GM25	C A13 R T I T	UNIT 2 DG AIR RECEIVER LOW PRESS TERMINATED START	LOOSE WIPE AT TERMINAL 25A5
G	DR2 019614	120377	GM25	C A12 D N T	2/3 DG FAILED TO ROLL OVER--LOW START AIR PRESSURE	RUPTURED REGULATOR DIAPHRAM
G	DR2 019405	120477	GM25	J A00 U I T	U2 DG OUTPUT BKR FAILED TO CLOSE--NO APPARENT CAUSE	3 SUBSEQUENT TESTS WERE SUCCESSFUL
G	DR2 020442	010378	GM25	C A13 R T B T	UNIT 2 DG FAILED TO START WEEKLY SURV TEST	LOOSE WIRE AT TERMINAL 25A5
G	DR2 021048	030778	GM25	C A00 J D B T	OPERATOR SHOOK AIR START SOLENOID UNIT 2/3 STARTED	POSSIBLE WIRE DAMAGED DUE TO FREQ INSPEC

GENERAL MOTORS 2500-2850 KW

UNIT	CONTROL NO.	FAIL DATE	M K	FAILURE MODE	FAILURE MECHANISM
G DR2	020855	030878	GM25 G	ENGINE OVERSHOT AT 1010 RPM WHILE DS SET AT 1020	HI OVERSHOOT BY OUT-OF-ADJUST GOVNR COMP
G DR2	021538	052278	GM25 G	U-2 DG TRIPPED 4 TIMES ON OVERSPEED; R/A IN S/D MODE	GOVNR SETTING FOUND SET TOO HIGH
G DR2	021862	063078	GM25 D	U-4 T 2/3 DG COOLING H2O PUMP TRIP ON HI AMPS; REPLACED	OVERLOAD TRIP SET CLOSE TO RUNNING AMPS
G DR2	022262	082478	GM25 C	A10 R U 4 T 2/3 UNIT 005 UNIT 2 FAILED TO START ON 1ST ATTEMP	PISTON GEAR NOT ENGAGED ON AIR START MTR
G DR2	022589	092278	GM25 C	A00 R U 8 T UNIT 2/3 FAILED TO START; AIR STRY MTRS ENGAGED	AIR-START SYS WILL BE MODIFIED
G DR2	023337	121678	GM25 C	A00 R D 4 T 2/3 DG AIR START MOTORS DISENGAGED AFTER FEW SECS.	T02 RELAY CLEARED; T02 AND AIR VALVE ?
G DR3	01	030376	GM25 G	A13 R T 4 T DG COULD NOT BE LOADED FROM CONTROL ROOM	GOVNR CONTROL WIRE VIBRATED FREE FROM LUG
G DR3	016435	092176	GM25 B	809 T 4 T DIESEL 3 RECEIVED HI TEMP ALARM	PARTIALLY CLOGGED STRAINER IN L.O. CIRC PMP
G DR3	016187	100976	GM25 G	A13 R I 4 T LOSS OF CONTROL ROOM SPEED CONTROL	LUGSE WIRE ON GOVNR CONTROL CIRCUIT
G DR3	016455	110576	GM25 G	810 R 1 B T LOST SPEED CONTROL FROM CONTROL ROOM	FAILED OVERTPAVL LIMIT SWITCH ON GOVNR
G DR3	017569	032277	GM25 K	A16 G G M GEN FIELD FAILED TO FLASH	INTERMITT CAPACITOR SHORT IN FLASH CIRC
G DR3	014722	112277	GM25 G	A10 R D 8 T 3 DG STARTED/OVERLOAD ALARM-DG TRIPPED	HAD CAPACITOR IN SPEED SENSING CRT. ?
G DR3	014727	112977	GM25 G	810 R D 8 M 3 DG TRIPPED 30 MIN AFTER START AND LOADING	SHORTED CAPICITER ON SPEED SENSING BOARD
G FPI	040496	111776	GM25 I	A16 R D 6 I "BM" EDG FAILED TO START DURING SURVEILLANCE TEST	GEN TACH RELAY DID NOT OPERATE, DEF CHVR
G FPI	016600	121576	GM25 B	A10 R D 1 I DURING TESTING "A" EDG FAILED TO START	LOW LUBE OIL PRESS - RELIEF VLV LEAKAGE
G FPI	016971	011977	GM25 B	A10 R D 1 I DURING SURV, EDG TRIPPED ON EMERGENCY START	LOW LUBE OIL PRESS, SECOND ATTEMPT SUCCESSFL
G FPI	017725	042677	GM25 I	A10 R D 8 I DURING ROUTINE SURV TEST, EDG FAILED TO START	TACHMELP RELAY FAILED
G FPI	020518	021578	GM25 J	810 I 1 I "AM" EDG TRIPPED DURING SURVEILLANCE TEST	BLOWN FUSE IN SYNCH CRT FOR OUTPUT BRKR
G FPI	023101	120578	GM25 G	A02 J D 4 T "MADG" TRIPPED WHEN BEING PARALLELED	MISADJUSTMENT OF GOVERNOR
G MD1	016166	101676	GM25 C	A09 I D T #11 DG FAILED TO START ON #2 STARTING SYSTEM	#2 START SYS AIR LUNT COMP FULLED W RUSH

GENERAL MOTORS 2500-2650 KW

V E N	P L A N I	C O N T R O L N U .	F A I L D A T E	M F K G W	S U B / S Y S	F A I L M O D E	T Y P E	C L A S S	R E P A I R	D I S C O V E R Y	FAILURE MODE	FAILURE MECHANISM
G DC1	014447	030376	GM25	K A10	D B T	DG 2 STARTED BUT DID NOT DEV SUFF VLTG TO LOAD					WESTHSE FFCO RELAY FLD TO ENRGZ FLD FLASH	
G DC1	015642	030970	GM25	C A00	U 1 T	DG #2 FAILED TO START DURING OPERABILITY TEST					CONTROL SEQ FAULT - HOWEVER, SEQ CORRECT	
G DC1	023119	113078	GM25	K A10	D B T	#106 STARTED BUT DLM FAILED TO EXCITE--AUTO ACT.TES					UNUSED TARGET MECH LINKAGE IN RELAY BINDN	
G DC1	014120	011276	GM25	C A10	D B T	UNIT 1 DG FAILED TO START WHEN MODE SW IN START MD					AIR START SOL VLV DIRTY--NOT OPEN FULLY	
G DC1	018112	042577	GM25	K A10	D G T	WHILE TESTING THE DG, THE FIELD FAILED TO FLASH					CAPACITOR ACROSS VLTG SUP RELAY DEFECTIVE	
G DC1	019100	082477	GM25	L A13	T 4 T	UNIT 1 DG STARTED AND RAN, BUT NO VLTG, SYNCH, FREQ					FREQ GEN TACH SET SCREWS VIBRATED LOOSE	
G DC1	019994	112877	GM25	K A10	D 4 M	1/2 DG WOULD NOT START SUCCESSFULLY, FIELD BKR DEFECT					FAILED DIODE IN FLD BKR INTLK CIRCUIT	
W BV1	014903	052076	GM25	C A04 R	T 4 N	DG #1 FAILED TO START 3 TIMES DG #2 STARTED OK					WATER ACCUMULATION IN AIR START SYSTEMS	
W BV1	015913	090376	GM25	J A00	U 1 T	#1 DG OUTPUT BREAKER FAILED TO CLOSE					NO APPARENT CAUSE	
W BV1	017683	022477	GM25	L B05	D 4 T	DG OUTPUT BREAKER TRIPPED; INTERNAL LOSS OF FIELD					TRIP NOT DISCONNECTED DURING ACCEPT. TEST	
W BV1	017348	031477	GM25	J A04 B	D 4 T	#2 DG OUTPUT BREAKER FAILED TO CLOSE					DIRTY CONTACTS ON BKR CONT SWITCH	
W BV1	017621	041177	GM25	J A04 S	D 4 T	#1 DG OUTPUT BREAKER FAILED TO CLOSE--DIRTY CONTACT					DESIGN CHANGE REQUEST FOR SEALED RELAYS	
W BV1	017693	042677	GM25	J A04 B	D 4 T	#1 DG OUTPUT BKR. FAILED TO CLOSE--DESIGN REQUESTED					DIRTY CONTACTS ON NFLD(ND FIELD) RELAY	
W BV1	017696	042977	GM25	C A09 R	T 4 N	DG #1 FAILED TO START REPETITIVE					MOISTURE IN STARTING AIR	
W BV1	017627	050977	GM25	J A04 R	D 4 T	#2 DG OUTPUT BKR. FAILED TO CLOSE--REPETITIVE					STICKING RELAY(MSR2) IN MANUAL START CKT.	
W BV1	018068	060377	GM25	J A04 R	D 1 T	#2 DG OUTPUT BKR. FAILED TO CLOSE ON FIRST ATTEMPT					CLOSED ON NEXT ATTEMPT; STICKY NFLD(A RELAY)	
W BV1	018028	071777	GM25	K A10 R	T 8 T	#2 DG STARTED AND CLOSED ONTO BUS; OUTPUT VOLTS =0.					LOOSE CONNECTIONS IN AUTO FIELD FLASH CKT	
W BV1	020437	011178	GM25	J A04 R	D 4 T	#2 DG OUTPUT BKR. FAILED TO CLOSE IN EXERCISE MODE					NO CAUSE COULD BE DETERMINED	
W BV1	021355	041878	GM25	A B12	T 0 M	#1 DG WAS S/D AND DECLARED INOPERABLE--OIL LEAKS					FLAW IN FUEL OIL PUMP DISCHARGE PIPE NIPL	
W BV1	021647	060178	GM25	B B02	D 1 T	#2 DG LUBE OIL LEAK AT ENGINE CONTROL PANEL GAUGE					GAUGE WAS CALIBRATED ON 5/21; LOOSE CONN.	

GENERAL MOTORS 2500-2650 KW

UNIT	CONTROL NO.	FAIL DATE	EX C W	FAILURE MODE	FAILURE MECHANISM	
MUN	8V1 022197	072878	GR25	K	#2 DG FAIL TO FLASH DURING SI AND LOSP EVENT	STICKY FIELD FLASH CUTOFF RELAY: AUTO CMT.
MUN	8V1 023098	090578	GR25	J	#1 DG OUTPUT BRK. FAIL TO CLOSE; #2 DG DCS	BRK CLOSED MANUALLY; 1 HOUR RUN AT FULL LD
MUN	8V1 023948	091278	GR25	J	#1 DG OUTPUT BRK. FAIL TO CLOSE USING CONT. SWITCH	CLOSED LATER NEGATING TROUBLESHOOTING
MUN	8V1 014162	020376	GR25	A	#1 DG-28 TRIPPED ON OVERSPEED WHILE STARTING	CALIB TOOL LEFT IN FUEL RACK-PACK HLD OPN
MUN	8V1 019174	092077	GR25	E	#1 DSG GEN 1A S/D WHEN SMOKE & FIRE OBSVD IN TURBOCHG	CARBON BUILDUP DUE TO SHORT DURATION OPER
MUN	8V1 019519	102577	GR25	M	UNIT D/G 1A STARTED & WAS AT 70 RPM WHEN IT STOPPED	COULD NOT DETERMINE CAUSE OF FAILURE
MUN	8V1 020095	122177	GR25	G	#1 D/G 1B WOULD NOT PICK UP MORE THAN 1500 KW LOAD	SYNCHRO MOTOR LIMIT SWCHS ADJUSTED IMPROV
MUN	8V1 017146	020977	GR25	J	#1 DG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	DIRT IN LWR BRNG OF OVRCRKT RELAY TNG D1-C
MUN	8V1 018417	062977	GR25	I	#1 DG DIESEL GENERATOR FAILED TO START - LOGIC FAILURE	SPEED SENSING ASSY SETPOINT DRIFTED
MUN	8V1 021445	051778	GR25	F	#1 DG OUTPUT BREAKER WOULD NOT CLOSE DURING TEST	WST 602A143M01 LATCH-CHANG 2M DEFECTIVE
MUN	8V1 014869	041676	GR25	F	#1 DIESEL GENERATOR DAMAGED ON START	#17 CYL FLOODED - CAUSED BROKEN INTERNALS
MUN	8V1 017591	020377	GR25	A	#1 DG #8M FAILED TO START	PROBABLE-AIR IN FUEL SUPPLY LINES
MUN	8V1 018147	033177	GR25	A	#1 DG #8M DID NOT REACH SPEED & VLTG WITHIN SPEC TIME	AIR IN FUEL LINE-CRACKS IN SUCTION TUBING
MUN	8V1 021919	060178	GR25	A	#1 DG HI LEVEL IN FUEL TANK (ENG.MULATD) DG S/D	LEVEL SWITCH MALFUNCTION--REPLACED SW1C

GENERAL MOTORS 3600-3500 KW

PLANT	CONTROL	FAIL DATE	WPK	GM	FAILURE MODE	FAILURE MECHANISM	
C 511	016881	110276	GM30	M A01	S D 4 T 1A	DG FAILED TO START	PERSONNEL ERROR - INCORRECT VALVE LINEUP
C 511	017134	011877	GM30	E B04	R T G Y 1B	DG RAN FOR 95 MIN THEN TRIPPED ON LOCKOUT	TURBOCHARGER SHAFT AND OIL SEAL DAMAGED
C 511	017135A	011977	GM30	A A09	R T I Y THE 1A	DIESEL GENERATOR FAILED TO START	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C 511	017135B	011977	GM30	A A09	R T I Y THE 1A	DG FAILED TO START AGAIN - LATER SAME DAY	DIRTY FUEL RACK LINKAGE-RACK STUCK OPEN
C 511	017494	030177	GM30	I A01	S D I Y 1A	DIESEL GENERATOR FAILED TO START	OPER FAILED TO RESET OVERSPEED TRIP
C 511	019111	092677	GM30	E B04	R Y G T 1A	DG SHUTDOWN WHEN SMOKE ISSUED FROM TURBOCHARGER	FAILED TURBO CHARGER UNIT
C 511	022532	090578	GM30	J A10	T B Y MAT	DG OUTPUT BREAKER WOULD NOT CLOSE REMOTELY	DIRTY CONTACTS ON ITS OPERATION RELAY
G B F1	014102	011476	GM30	G A12	T I Y	FAILED TO RESPOND TO ELEC. GOVNR SIGNALS DG #0	OIL DRAINING FROM HYDRAULIC ACTUATOR
G B F1	016261	110276	GM30	G B09	C T 4 Y D	DG ERRATIC SPEED BEHAVIOR UNDER LOAD	DIRTY OIL IN GOVERNOR
G B F3	019133	091977	GM30	K A10	D I T 3D	DG TRIPPED ON OVERSPEED ;GOVERNOR INOPERABLE	TD FUSE OPEN DISENABLING FIELD CIRCUIT

NORDBERG MANUFACTURING 3000-3500 MW

PLANT	CONTR NO.	FAIL DATE	W F K G M	SYMBOL	DESCRIPTION	FAILURE MODE	FAILURE MECHANISM	
6 BR1	016854A	010477	MM30 B	A04	C 0 4 T #3 DG	TRIPPED R/X AT POWER	LOW LUBE OIL TEMP	LOW SETPOINT FOR PRE-FILTER HEATER / JACK
6 BR1	016854B	010477	MM30 B	A04	C 0 4 T #4 DG	TRIPPED R/X AT POWER	TO SWITCH NOT RESET	L.G. PRESS SWITCH TIME DELAY INCORRECT
6 BR1	019391	101177	MM30 G	B02	0 8 T #2 DG	UNABLE TO MAINTAIN LOAD	CYCLING 500MW	SHORTED LEADS TO GOVERNOR; INCORRECT ASMB
6 BR1	020908	120977	MM30 C	A09	T 0 T #3 DG	START TIME 10.2 SEC	VS 10	CARBON BUILDUP ON AIR VALVE STUCK SHUT
6 BR1	019448	121677	MM30 J	BUC	0 0 T	SMOKE COMING FROM 326 RELAY AND 8608 RELAY	FLAMING	REPLACED AND CALIBRATED RELAYS
6 BR1	022454	091178	MM30 A	B07	I 4 T #1 DG	CYLINDER #1 NOT FIRING	HEAVY LEADING ???	FAULTY FUEL PUMP REPLACED
6 BR2	014136	010976	MM30 J	A1C	0 4 N #1 DG	STARTED BUT OUTPUT BRK	FAILED TO CLOSE TO E-1	BROKEN LUG WIRE DUE TO STRESS
6 BR2	014614	031476	MM30 A	B12	I 0 T AT 96:	POWER #2 DG STARTED TO CYCLE	IN LOCAL-MANUAL FUELOIL	SHIFT VALVE LEARN GASKET WERKED
6 BR2	015461	061176	MM30 A	A02	C 0 0 T #1 DG	STALLED & FAILED TO TIE INTO E-BUS	R/X AT PR 40 GAL H2O	IN SADDLE & 4 DAY TANK
6 BR2	015399	111176	MM30 C	A08	T 0 T DG	FAILED OPER TEST-12.2 ON #2	AIR RECEIVER	CHECK VALVE RUSTED SHUT
6 BR2	016023	122976	MM30 G	B10	T 0 T #2 DG	FAILED OPERABILITY TEST	--LOSS OF SPEED CONT.	CLUTCH ADJUSTED AND STATOR VOLTAGE REPLAC
6 BR2	020612	021378	MM30 K	A01	S 0 1 N	FOLLOWING SCRAM ON UNIT 1	#01 DG LC RELAY WOULD NOT RESET	LOSS OF EXCITATION RELAY NOT RESET

APPENDIX O

RESULTS OF THE DIESEL-GENERATOR, DOES NOT START,
FAILURE RATE ESTIMATIONS



DOES NOT START - (WEEKLY TESTING) - 1976

BABCOCK & WILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
RS1	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
T11	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
TOTALS				4	52560.0	312		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

311

DOES NOT START - (WEEKLY TESTING) - 1976

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
CC1	8760.0	2	52	3	17520.0	104	1.7E-04	2.9E-02
CC2	744.0	2	4	1	1488.0	8	6.7E-04	1.3E-01
FC1	8760.0	2	52	3	17520.0	104	1.7E-04	2.9E-02
MI2	8760.0	2	52	4	17520.0	104	2.3E-04	3.8E-02
MY1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PA1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
SL1	6072.0	2	36	1	12144.0	72	8.2E-05	1.4E-02
TOTALS				12	101232.0	600		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1976

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	8760.0	4	52	1	35040.0	208	2.9E-05	4.8E-03
BP1	8760.0	1	52	11	8760.0	52	1.3E-03	2.1E-01
BR2	8760.0	4	52	3	35040.0	208	6.6E-05	1.4E-02
CO1	8760.0	2	52	1	17520.0	104	5.7E-05	9.8E-03
DA1	8760.0	2	52	1	17520.0	104	5.7E-05	9.8E-03
DR1	8760.0	1	12	0	8760.0	12	3.4E-04*	2.5E-01*
DR2	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
DR3	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
EN1	8760.0	3	52	6	26280.0	156	2.3E-04	3.8E-02
FP1	8760.0	4	52	2	35040.0	208	5.7E-05	9.6E-03
M11	8760.0	1	52	0	8760.0	52	3.4E-04*	5.8E-02*
MD1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
NM1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
OC1	8760.0	2	52	0	17520.0	104	1.1E-04	1.9E-02
PB2	8760.0	4	52	0	35040.0	208	8.5E-05*	1.4E-02*
PI1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
QC1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
QC2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
VY1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
TOTALS				34	385440.0	2248		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1976

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BV1	5616.0	2	33	2	11232.0	66	1.8E-04	3.0E-02
DC1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
HN1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
IP2	8760.0	3	52	0	26280.0	156	1.1E-04*	1.9E-02*
IP3	6432.0	3	38	0	19296.0	114	1.6E-04*	2.6E-02*
KE1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PR1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PR2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PT1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PT2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
RG1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
RD2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
SA1	456.0	3	3	0	1368.0	9	2.2E-03*	3.3E-01*
SO1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
SU1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
SU2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
TR1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
TL3	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
TU4	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
YR1	8760.0	3	52	0	26280.0	156	1.1E-04*	1.9E-02*
Z11	8760.0	3	52	1	26280.0	156	3.8E-05	6.4E-03
Z12	8760.0	3	52	0	26280.0	156	1.1E-04*	1.9E-02*
TOTALS				6	399816.0	2373		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1976

FINAL STATISTICS

	STANDBY HOUR RATE	DEMAND RATE
	2.3	2.3
BAB.CMIL.	7.5E-05	1.3E-02
	2.9	2.9
	1.6	1.6
COMB.ENG.	1.2E-04	2.0E-02
	1.7	1.7
	1.3	1.3
GEN.ELEC.	8.8E-05	1.5E-02
	1.4	1.4
	2.0	2.0
WESTINGH.	1.5E-05	2.5E-03
	2.3	2.3
	1.4	1.4
PYR'S	4.0E-05	6.7E-03
	1.5	1.5
	1.2	1.2
OVERALL	6.0E-05	1.0E-02
	1.3	1.3

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1977

BABCOCK & WILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
CR3	8424.0	2	50	4	16848.0	100	2.4E-04	4.0E-02
DB1	2664.0	2	16	1	5328.0	32	1.9E-04	3.1E-02
RS1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
T11	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
TOTALS				7	74736.0	444		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1977

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
CC1	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
CC2	8760.0	2	52	3	17520.0	104	1.7E-04	2.9E-02
FC1	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
M12	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
MY1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PA1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
SL1	8760.0	2	52	3	17520.0	104	1.7E-04	2.9E-02
TOTALS				12	122640.0	728		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1977

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	8760.0	4	52	1	35040.0	208	2.9E-05	4.8E-03
BP1	8760.0	1	52	7	8760.0	52	6.0E-04	1.3E-01
BR2	8760.0	4	52	3	35040.0	208	8.6E-05	1.4E-02
CC1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
DA1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
DR1	8760.0	1	52	0	8760.0	52	3.4E-04*	5.8E-02*
DR2	8760.0	2	52	7	17520.0	104	4.0E-04	6.7E-02
DR3	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
EN1	8760.0	3	52	2	26280.0	156	7.6E-05	1.3E-02
FP1	8760.0	4	52	2	35040.0	208	5.7E-05	9.6E-03
MI1	8760.0	1	52	0	8760.0	52	3.4E-04*	5.8E-02*
MO1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
NM1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
OC1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PB2	8760.0	4	52	4	35040.0	208	1.1E-04	1.9E-02
PI1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
QC1	8760.0	2	52	3	17520.0	104	1.7E-04	2.9E-02
QC2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
WY1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
TOTALS				33	385440.0	2288		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1977

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BV1	8760.0	2	52	7	17520.0	104	4.0E-04	6.7E-02
DC1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
HN1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
IP2	8760.0	3	52	0	26280.0	156	1.1E-04*	1.9E-02*
IP3	8760.0	3	52	0	26280.0	156	1.1E-04*	1.9E-02*
JF1	3432.0	5	20	3	17160.0	100	1.7E-04	3.0E-02
KE1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
PR1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PR2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
PT1	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
PT2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
RG1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
RD2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
SA1	8760.0	3	52	2	26280.0	156	7.6E-05	1.3E-02
SO1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
SU1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
SU2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
TR1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
TL3	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
TU4	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
YR1	8760.0	3	52	1	26280.0	156	3.8E-05	6.4E-03
Z11	8760.0	3	52	0	26280.0	156	1.1E-04*	1.9E-02*
Z12	8760.0	3	52	0	26280.0	156	1.1E-04*	1.9E-02*
TOTALS				19	455160.0	2766		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1977

FINAL STATISTICS

	STANDBY HOUR RATE	DEMAND RATE
	1.9	1.9
BAB.EWIL.	9.4E-05	1.6E-02
	2.1	2.1
	1.6	1.6
COMB.ENG.	9.8E-05	1.6E-02
	1.7	1.7
	1.3	1.3
GEN.ELEC.	8.6E-05	1.4E-02
	1.4	1.4
	1.5	1.5
WESTINGH.	4.2E-05	7.0E-03
	1.5	1.5
	1.3	1.3
PWR'S	5.8E-05	9.8E-03
	1.3	1.3
	1.2	1.2
OVERALL	6.8E-05	1.2E-02
	1.2	1.2

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1978

BABCOCK&WILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
CR3	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
DB1	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
RS1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
T11	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
T12	6648.0	2	40	2	13296.0	80	1.5E-04	2.5E-02
TOTALS				8	100896.0	600		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

319

DOES NOT START - (WEEKLY TESTING) - 1978

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AP2	600.0	2	4	0	1200.0	8	2.5E-03*	3.7E-01*
CC1	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
CC2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
FC1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
M12	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
MY1	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
PA1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
SL1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
TOTALS				6	123840.0	736		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DCES NOT START - (WEEKLY TESTING) - 1978

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	PLP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	8760.0	4	52	0	35040.0	208	8.5E-05*	1.4E-02*
BP1	8760.0	1	52	1	8760.0	52	1.1E-04	1.9E-02
BR2	8760.0	4	52	1	35040.0	208	2.9E-05	4.8E-03
CD1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
DA1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
DR1	8760.0	1	52	5	8760.0	52	5.7E-04	9.6E-02
DR2	8760.0	2	52	7	17520.0	104	4.0E-04	6.7E-02
DR3	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
EN1	8760.0	3	52	0	26280.0	156	1.1E-04*	1.9E-02*
EN2	4296.0	3	26	2	12888.0	78	1.6E-04	2.6E-02
FP1	8760.0	4	52	1	35040.0	208	2.9E-05	4.8E-03
MI1	8760.0	1	52	0	8760.0	52	3.4E-04*	5.6E-02*
MD1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
NM1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
OC1	8760.0	2	52	1	17520.0	104	5.7E-05	9.6E-03
PB2	8760.0	4	52	3	35040.0	208	8.6E-05	1.4E-02
PI1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
QC1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
QC2	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
VY1	8760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-02*
TOTALS				23	398328.0	2366		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1978

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HCLR RATE	DEMAND RATE
BV1	8760.0	2	52	4	17520.0	104	2.3E-04	3.8E-02
DC1	8760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
DC2	7080.0	2	42	2	14160.0	84	1.4E-04	2.4E-02
HN1	8760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
IP2	8760.0	3	52	0	26280.0	156	1.1E-C4*	1.9E-C2*
IP3	8760.0	3	52	0	26280.0	156	1.1E-C4*	1.9E-C2*
JF1	6760.0	5	52	8	43800.0	260	1.8E-C4	3.1E-02
KE1	8760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
NA1	6456.0	2	38	0	12912.0	76	2.3E-C4*	3.9E-C2*
PR1	8760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
PR2	8760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
PT1	8760.0	2	52	1	17520.0	104	5.7E-C5	9.6E-C3
PT2	6760.0	2	52	0	17520.0	104	1.7E-04*	2.9E-C2*
RG1	8760.0	2	52	1	17520.0	104	5.7E-C5	9.6E-C3
RD2	8760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
SA1	8760.0	3	52	0	26280.0	156	1.1E-C4*	1.9E-C2*
SD1	8760.0	2	52	2	17520.0	104	1.1E-04	1.9E-02
SL1	8760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
SU2	8760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
TR1	6760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
TU3	6760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
TU4	6760.0	2	52	0	17520.0	104	1.7E-C4*	2.9E-C2*
YR1	8760.0	3	52	0	26280.0	156	1.1E-C4*	1.9E-C2*
Z11	8760.0	3	52	4	26280.0	156	1.5E-04	2.6E-02
Z12	8760.0	3	52	0	26280.0	156	1.1E-C4*	1.9E-C2*
TOTALS				22	508872.0	3026		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1978

FINAL STATISTICS

	STANDBY HOUR RATE	DEMAND RATE
	1.8	1.8
BAB.EMIL.	7.9E-05	1.3E-02
	2.0	2.0
	2.0	2.0
COMB.ENG.	4.8E-05	8.2E-03
	2.3	2.3
	1.4	1.4
GEN.ELEC.	5.8E-05	9.7E-03
	1.5	1.5
	1.4	1.4
WESTINGH.	4.3E-05	7.3E-03
	1.5	1.5
	1.3	1.3
PWR'S	4.9E-05	8.3E-03
	1.3	1.3
	1.2	1.2
OVERALL	5.2E-05	8.8E-03
	1.3	1.3

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1976 THRU 1978

BABCOCK&WILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
ARI	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
CR3	17184.0	2	102	6	34368.0	204	1.7E-04	2.9E-02
DB1	11424.0	2	68	3	22848.0	136	1.3E-04	2.2E-02
RS1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
T11	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
T12	6648.0	2	40	2	13296.0	80	1.5E-04	2.5E-02
TOTALS				19	228192.0	1356		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

323

DOES NOT START - (WEEKLY TESTING) - 1976 THRU 1978

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR2	600.0	2	4	0	1200.0	8	2.5E-03*	3.7E-01*
CC1	26280.0	2	156	7	52560.0	312	1.3E-04	2.2E-02
CC2	18264.0	2	108	4	36528.0	216	1.1E-04	1.9E-02
FC1	26280.0	2	156	6	52560.0	312	1.1E-04	1.9E-02
M12	26280.0	2	156	6	52560.0	312	1.1E-04	1.9E-02
MY1	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
PA1	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
SL1	23592.0	2	140	5	47184.0	280	1.1E-04	1.8E-02
TOTALS				36	347712.0	2064		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1976 THRU 1978

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	26280.0	4	156	2	105120.0	624	1.9E-05	3.2E-03
BP1	26280.0	1	156	19	26280.0	156	7.2E-04	1.4E-01
BR2	26280.0	4	156	7	105120.0	624	6.7E-05	1.1E-02
CO1	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
DA1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
DR1	26280.0	1	156	5	26280.0	156	1.9E-04	3.2E-02
DR2	26280.0	2	156	16	52560.0	312	3.0E-04	5.1E-02
DR3	26280.0	2	156	4	52560.0	312	7.6E-05	1.3E-02
EN1	26280.0	3	156	6	78840.0	468	1.0E-04	1.7E-02
EN2	4296.0	3	26	2	12888.0	78	1.6E-04	2.6E-02
FP1	26280.0	4	156	5	105120.0	624	4.8E-05	8.0E-03
MI1	26280.0	1	156	0	26280.0	156	1.1E-04*	1.9E-02*
MO1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
NMI	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
OC1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
PB2	26280.0	4	156	7	105120.0	624	6.7E-05	1.1E-02
PI1	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
QC1	26280.0	2	156	4	52560.0	312	7.6E-05	1.3E-02
QC2	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
VY1	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
TOTALS				90	116928.0	6942		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1976 THRU 1978

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOOR RATE	DEMAND RATE
BV1	23136.0	2	137	13	46272.0	274	2.8E-05	4.7E-02
DC1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
DC2	7080.0	2	42	2	14160.0	84	1.4E-04	2.4E-02
HN1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
IP2	26280.0	3	156	0	78840.0	468	3.8E-05*	6.4E-03*
IP3	23952.0	3	142	0	71856.0	426	4.2E-05*	7.0E-03*
JF1	12192.0	5	72	11	60960.0	360	1.8E-04	3.1E-02
KE1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
NA1	6456.0	2	38	0	12912.0	76	2.3E-04*	3.9E-02*
PR1	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
PR2	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
PT1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
PT2	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
RG1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
RD2	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
SA1	17976.0	3	107	2	53928.0	321	3.7E-05	6.2E-03
SD1	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
SH1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
SU2	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
TR1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
TU3	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
TU4	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
YR1	26280.0	3	156	1	78840.0	468	1.3E-05	2.1E-03
Z11	26280.0	3	156	5	78840.0	468	6.3E-05	1.1E-02
Z12	26280.0	3	156	0	78840.0	468	3.8E-05*	6.4E-03*
TOTALS				47	1363848.0	8093		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (WEEKLY TESTING) - 1976 THRU 1978

FINAL STATISTICS

	STANDBY HOUR RATE	DEMAND RATE
	1.5	1.5
BAB. & WIL.	8.3E-05	1.4E-02
	1.5	1.5
	1.4	1.4
COMB. ENG.	8.6E-05	1.5E-02
	1.4	1.4
	1.2	1.2
GEN. ELEC.	7.7E-05	1.3E-02
	1.2	1.2
	1.3	1.3
WESTINGH.	3.4E-05	5.8E-03
	1.3	1.3
	1.2	1.2
PWR'S	4.9E-05	8.3E-03
	1.2	1.2
	1.1	1.1
OVERALL	6.0E-05	1.0E-02
	1.1	1.1

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1976

BABCOCK & WILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
RS1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
T11	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
TOTALS				4	52560.0	72		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

327

DOES NOT START - (MONTHLY TESTING) - 1976

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
CC1	8760.0	2	12	3	17520.0	24	1.7E-04	1.3E-01
CC2	744.0	2	1	1	1488.0	2	6.7E-04	5.0E-01
FC1	8760.0	2	12	3	17520.0	24	1.7E-04	1.3E-01
M12	8760.0	2	12	4	17520.0	24	2.3E-04	1.7E-01
MY1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PA1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SL1	6072.0	2	8	1	12144.0	16	8.2E-05	6.3E-02
TOTALS				12	101232.0	138		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1976

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	8760.0	4	12	1	35040.0	48	2.9E-05	2.1E-02
BP1	8760.0	1	12	11	8760.0	12	1.3E-03	9.2E-01
BR2	8760.0	4	12	3	35040.0	48	8.6E-05	6.3E-02
CO1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
DA1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
DP1	8760.0	1	12	0	8760.0	12	3.4E-04*	2.5E-01*
DP2	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
DR3	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
EN1	8760.0	3	12	6	26280.0	36	2.3E-04	1.7E-01
FP1	8760.0	4	12	2	35040.0	48	5.7E-05	4.2E-02
M11	8760.0	1	12	0	8760.0	12	3.4E-04*	2.5E-01*
MO1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
NM1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
OC1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
PB2	8760.0	4	12	0	35040.0	48	8.5E-05*	6.2E-02*
PI1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
QC1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
QC2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
VY1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
TOTALS				34	345440.0	528		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1976

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BV1	5616.0	2	8	2	11232.0	16	1.8E-04	1.3E-01
DC1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
HM1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
IP2	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
IP3	6432.0	3	9	0	19296.0	27	1.6E-04*	1.1E-01*
KE1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PF1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PF2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PT1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PT2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
RG1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
RC2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SA1	456.0	3	1	0	1368.0	3	2.2E-03*	1.6E+00*
SO1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SU1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
SL2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TR1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TU3	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TL4	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
VR1	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
Z11	8760.0	3	12	1	26280.0	36	3.8E-05	2.8E-02
Z12	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
TOTALS				6	399816.0	550		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1976

FINAL STATISTICS

	STANDBY HOURLY RATE	DEMAND RATE
BAB.EMIL.	2.3 7.6E-05 2.9	2.3 5.6E-02 2.9
COMB.ENG.	1.6 1.2E-04 1.7	1.6 8.7E-02 1.7
GEN. EC.	1.3 8.8E-05 1.4	1.3 6.4E-02 1.4
WESTINGH.	2.0 1.5E-05 2.3	2.0 1.1E-02 2.3
PWR'S	1.4 4.0E-05 1.5	1.4 2.9E-02 1.5
OVERALL	1.2 6.0E-05 1.3	1.2 4.3E-02 1.3

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1977

BABCOCKWILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
CR3	8424.0	2	12	4	16848.0	24	2.4E-04	1.7E-01
DB1	2664.0	2	4	1	5328.0	8	1.9E-04	1.3E-01
RS1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
TI1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TOTALS				7	74736.0	104		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1977

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
CC1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
CC2	8760.0	2	12	3	17520.0	24	1.7E-04	1.3E-01
FC1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
MI2	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
MY1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PA1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SL1	8760.0	2	12	3	17520.0	24	1.7E-04	1.3E-01
TOTALS				12	122640.0	168		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1977

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	LANDBY HOUR RATE	DEMAND RATE
BF1	8760.0	4	12	1	35040.0	48	2.9E-05	2.1E-02
BP1	8760.0	1	12	7	8760.0	12	8.0E-04	5.8E-01
BK2	8760.0	4	12	3	35040.0	48	8.6E-05	6.3E-02
CO1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
DA1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
DR1	8760.0	1	12	0	8760.0	12	3.4E-04*	2.5E-01*
DR2	8760.0	2	12	7	17520.0	24	4.0E-04	2.9E-01
DW3	8760.0	2	12	2	17520.0	24	2.1E-04	8.3E-02
EN1	8760.0	3	12	2	26280.0	36	7.6E-05	5.6E-02
FP1	8760.0	4	12	2	35040.0	48	5.7E-05	4.2E-02
MI1	8760.0	1	12	0	8760.0	12	3.4E-04*	2.5E-01*
MO1	8760.0	2	12	6	17520.0	24	1.7E-04*	1.2E-01*
NM1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
OC1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PB2	8760.0	4	12	4	35040.0	48	1.1E-04	8.3E-02
PI1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
QC1	8760.0	2	12	3	17520.0	24	1.7E-04	1.3E-01
QC2	8760.0	2	12	6	17520.0	24	1.7E-04*	1.2E-01*
VY1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
TOTALS				33	385440.0	528		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

332

DOES NOT START - (MONTHLY TESTING) - 1977

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BV1	8760.0	2	12	7	17520.0	24	4.0E-04	2.9E-01
DC1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
HN1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
IP2	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
IP3	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
JF1	3432.0	5	5	3	17160.0	25	1.7E-04	1.2E-01
KE1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
PR1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PR2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PI1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
PT2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
RG1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
RO2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SA1	8760.0	3	12	2	26280.0	36	7.6E-05	5.6E-02
SO1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SU1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SU2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TR1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
TU3	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
TU4	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
YR1	8760.0	3	12	1	26280.0	36	3.8E-05	2.8E-02
Z11	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
Z12	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
TOTALS				19	455160.0	625		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1977

FINAL STATISTICS

	STANDBY HOUR RATE	DEMAND RATE
	1.9	1.9
BAR. & MIL.	9.4E-05	6.7E-02
	2.1	2.1
	1.6	1.6
COMB. ENG.	9.8E-05	7.1E-02
	1.7	1.7
	1.3	1.3
GEN. ELEC.	8.6E-05	6.3E-02
	1.4	1.4
	1.5	1.5
WESTINGH.	4.2E-05	3.0E-02
	1.5	1.5
	1.3	1.3
PHR'S	5.8E-05	4.2E-02
	1.3	1.3
	1.2	1.2
OVERALL	6.8E-05	5.0E-02
	1.2	1.2

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1978

BABCOCKWILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
CR3	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
DB1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
PS1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TI1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
TI2	6648.0	2	9	2	13296.0	18	1.5E-04	1.1E-01
TOTALS				8	100896.0	138		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

335

DOES NOT START - (MONTHLY TESTING) - 1978

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR2	600.0	2	1	0	1200.0	2	2.5E-03*	1.5E+00*
CC1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
CC2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
FC1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
MI2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
MY1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
PA1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SL1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
TOTALS				6	123840.0	170		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1978

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	8760.0	4	12	0	35040.0	48	8.5E-05*	6.2E-02*
BP1	8760.0	1	12	1	8760.0	12	1.1E-04	8.3E-02
BR2	8760.0	4	12	1	35040.0	48	2.9E-05	2.1E-02
CO1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
DA1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
DR1	8760.0	1	12	5	8760.0	12	5.7E-04	4.2E-01
DR2	8760.0	2	12	7	17520.0	24	4.0E-04	2.9E-01
DR3	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
EN1	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
EN2	4296.0	3	6	2	12888.0	18	1.6E-04	1.1E-01
FP1	8760.0	4	12	1	35040.0	48	2.9E-05	2.1E-02
MI1	8760.0	1	12	0	8760.0	12	3.4E-04*	2.5E-01*
MO1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
NM1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
OC1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
PB2	8760.0	4	12	3	35040.0	48	8.6E-05	6.3E-02
PI1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
QC1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
QC2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
YY1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TOTALS				23	398328.0	546		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

336

DOES NOT START - (MONTHLY TESTING) - 1978

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BV1	8760.0	2	12	4	17520.0	24	2.3E-04	1.7E-01
DC1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
DC2	7080.0	2	10	2	14160.0	20	1.4E-04	1.0E-01
HN1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
IP2	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
IP3	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
JF1	8760.0	5	12	8	43800.0	60	1.8E-04	1.3E-01
KE1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
NA1	6456.0	2	9	0	12912.0	18	2.3E-04*	1.7E-01*
PR1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PR2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
PT1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
PT2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
RG1	8760.0	2	12	1	17520.0	24	5.7E-05	4.2E-02
RC2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SA1	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
SC1	8760.0	2	12	2	17520.0	24	1.1E-04	8.3E-02
SL1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
SU2	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TR1	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TU3	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
TU4	8760.0	2	12	0	17520.0	24	1.7E-04*	1.2E-01*
YR1	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
Z11	8760.0	3	12	4	26280.0	36	1.5E-04	1.1E-01
Z12	8760.0	3	12	0	26280.0	36	1.1E-04*	8.3E-02*
TOTALS				22	508872.0	698		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1978

FINAL STATISTICS

	STANDBY HOUR RATE	DEMAND RATE
	1.8	1.8
BAB. & WIL.	7.9E-05	5.8E-02
	2.0	2.0
	2.0	2.0
COMB. ENG.	4.8E-05	3.5E-02
	2.3	2.3
	1.4	1.4
GEN. ELEC.	5.8E-05	4.2E-02
	1.5	1.5
	1.4	1.4
WESTINGH.	4.3E-05	3.2E-02
	1.5	1.5
	1.3	1.3
PWR'S	4.9E-05	3.6E-02
	1.3	1.3
	1.2	1.2
OVERALL	5.2E-05	3.6E-02
	1.3	1.3

* INDICATES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1976 THRU 1978

BABCOCK&WILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR1	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
CR3	17184.0	2	24	A	34368.0	48	1.7E-04	1.3E-01
DB1	11424.0	2	16	3	22848.0	32	1.3E-04	9.4E-02
RS1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
T11	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
T12	6648.0	2	9	2	13296.0	18	1.5E-04	1.1E-01
TOTALS				19	228192.0	314		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

339

DOES NOT START - (MONTHLY TESTING) - 1976 THRU 1978

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR2	600.0	2	1	0	1200.0	2	2.5E-03*	1.5E+00*
CC1	26280.0	2	36	7	52560.0	72	1.3E-04	9.7E-02
CC2	18264.0	2	25	4	36528.0	50	1.1E-04	8.0E-02
FC1	26280.0	2	36	6	52560.0	72	1.1E-04	8.3E-02
M12	26280.0	2	36	6	52560.0	72	1.1E-04	8.3E-02
MY1	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
PA1	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
SL1	23592.0	2	32	5	47184.0	64	1.1E-04	7.8E-02
TOTALS				30	347712.0	476		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1976 THRU 1978

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	26280.0	4	36	2	105120.0	144	1.9E-05	1.4E-02
BP1	26280.0	1	36	19	26280.0	36	7.2E-04	5.3E-01
BP2	26280.0	4	36	7	105120.0	144	6.7E-05	4.9E-02
CD1	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
DA1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
DR1	26280.0	1	36	5	26280.0	36	1.9E-04	1.4E-01
DR2	26280.0	2	36	16	52560.0	72	3.0E-04	2.2E-01
DR3	26280.0	2	36	4	52560.0	72	7.6E-05	5.6E-02
EN1	26280.0	3	36	8	78840.0	108	1.0E-04	7.4E-02
EN2	4296.0	3	6	2	12888.0	18	1.6E-04	1.1E-01
FP1	26280.0	4	36	5	105120.0	144	4.8E-05	3.5E-02
MI1	26280.0	1	36	0	26280.0	36	1.1E-04*	8.3E-02*
HG1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
NM1	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
OC1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
PB2	26280.0	4	36	7	105120.0	144	6.7E-05	4.9E-02
PI1	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
QC1	26280.0	2	36	4	52560.0	72	7.6E-05	5.6E-02
QC2	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
VY1	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
TOTALS				90	1169208.0	1602		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT START - (MONTHLY TESTING) - 1976 THRU 1978

WESTINGHOUSE

PLANT	CRIF-HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BV1	23136.0	2	32	13	46272.0	64	2.8E-04	2.0E-01
DC1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
DC2	7680.0	2	10	2	14160.0	20	1.4E-04	1.0E-01
HN1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
IP2	26280.0	3	36	0	78840.0	108	3.8E-05*	2.8E-02*
IP3	23952.0	3	33	0	71856.0	99	4.2E-05*	3.0E-02*
JF1	12192.0	5	17	11	60960.0	85	1.8E-04	1.3E-01
KE1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
NA1	6456.0	2	9	0	12912.0	18	2.3E-04*	1.7E-01*
PR1	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
PR2	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
PT1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
PT2	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
RG1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
RC2	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
SA1	17976.0	3	25	2	53928.0	75	3.7E-05	2.7E-02
SU1	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
SL1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
SU2	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
TR1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
TU3	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
TU4	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
YF1	26280.0	3	36	1	78840.0	108	1.3E-05	9.3E-03
Z11	26280.0	3	36	5	78840.0	108	6.3E-05	4.6E-02
Z12	26280.0	3	36	0	78840.0	108	3.8E-05*	2.8E-02*
TOTALS				47	1363848.0	1673		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

APPENDIX P

RESULTS OF THE DIESEL-GENERATOR, DOES NOT CONTINUE
TO RUN, FAILURE RATE ESTIMATIONS



DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976

BABCOCK&WILCOX

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AK1	52.0	2	0	104.0	2.9E-02*
RS1	52.0	2	1	104.0	9.6E-03
TII	52.0	2	0	104.0	2.9E-02*
TOTALS			1	312.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

345

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976

COMBUSTION ENGINEERING

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
CC1	52.0	2	1	104.0	9.6E-03
CC2	4.0	2	0	8.0	3.7E-01*
FC1	52.0	2	1	104.0	9.6E-03
MI2	52.0	2	9	104.0	8.7E-02
MY1	52.0	2	0	104.0	2.9E-02*
PA1	52.0	2	0	104.0	2.9E-02*
SL1	36.0	2	0	72.0	4.2E-02*
TOTALS			11	600.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976

GENERAL ELECTRIC

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BF1	52.0	4	1	208.0	4.6E-03
BP1	52.0	1	2	52.0	3.8E-02
BR2	52.0	4	2	208.0	9.6E-03
CO1	52.0	2	2	104.0	1.9E-02
DA1	52.0	2	4	104.0	3.8E-02
DR1	52.0	1	0	52.0	5.8E-02*
DR2	52.0	2	2	104.0	1.9E-02
DR3	52.0	2	2	104.0	1.9E-02
EN1	52.0	3	3	156.0	1.9E-02
FP1	52.0	4	0	208.0	1.4E-02*
MI1	52.0	1	0	52.0	5.8E-02*
MO1	52.0	2	0	104.0	2.9E-02*
NM1	52.0	2	0	104.0	2.9E-02*
OC1	52.0	2	0	104.0	2.9E-02*
PB2	52.0	4	0	208.0	1.4E-02*
PI1	52.0	2	2	104.0	1.9E-02
QC1	52.0	2	0	104.0	2.9E-02*
QC2	52.0	2	0	104.0	2.9E-02*
VY1	52.0	2	1	104.0	9.6E-03
			TOTALS	21	2288.0

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976

WESTINGHOUSE

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RAY.
BV1	33.0	2	0	66.0	4.5E-02*
DC1	52.0	2	0	104.0	2.9E-02*
HN1	52.0	2	0	104.0	2.9E-02*
IP2	52.0	3	0	156.0	1.9E-02*
IP3	38.0	3	3	114.0	2.6E-02
KE1	52.0	2	0	104.0	2.9E-02*
PR1	52.0	2	0	104.0	2.9E-02*
PR2	52.0	2	1	104.0	9.6E-03
PF1	52.0	2	0	104.0	2.9E-02*
PT2	52.0	2	0	104.0	2.9E-02*
RG1	52.0	2	0	104.0	2.9E-02*
RG2	52.0	2	1	104.0	9.6E-03
SA1	3.0	3	0	9.0	3.3E-01*
SO1	52.0	2	0	104.0	2.9E-02*
SU1	52.0	2	0	104.0	2.9E-02*
SU2	52.0	2	0	104.0	2.9E-02*
TK1	52.0	2	0	104.0	2.9E-02*
TU3	52.0	2	0	104.0	2.9E-02*
TU4	52.0	2	0	104.0	2.9E-02*
YR1	52.0	3	0	156.0	1.9E-02*
ZI1	52.0	3	1	156.0	6.4E-03
ZI2	52.0	3	0	156.0	1.9E-02*
TOTALS			6	2373.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976

FINAL STATISTICS

	OPERATING HOUR RATE
	4.7
BAB.EMIL.	3.2E-03
	19.5
	1.7
COMB.ENG.	1.8E-02
	1.8
	1.4
GEN.ELEC.	9.2E-03
	1.5
	2.0
WESTINGH.	2.5E-03
	2.3
	1.5
PWR'S	5.5E-03
	1.5
	1.3
OVERALL	7.0E-03
	1.3

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1977

BABCOCK&WILCOX

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR1	52.0	2	0	104.0	2.9E-02*
CR3	50.0	2	0	100.0	3.0E-02*
DB1	16.0	2	0	32.0	9.4E-02*
RS1	52.0	2	0	104.0	2.9E-02*
T11	52.0	2	0	104.0	2.9E-02*
TOTALS			0	444.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

349

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1977

COMBUSTION ENGINEERING

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
CC1	52.0	2	3	104.0	2.9E-02
CC2	52.0	2	0	104.0	2.9E-02*
FC1	52.0	2	0	104.0	2.9E-02*
M12	52.0	2	4	104.0	3.8E-02
MY1	52.0	2	0	104.0	2.9E-02*
PA1	52.0	2	0	104.0	2.9E-02*
SL1	52.0	2	2	104.0	1.9E-02
TOTALS			9	728.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1977

GENERAL ELECTRIC

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BF1	52.0	4	0	208.0	1.4E-02*
BP1	52.0	1	0	52.0	5.8E-02*
BR2	52.0	4	2	208.0	4.8E-03
CO1	52.0	2	0	104.0	2.9E-02*
DA1	52.0	2	1	104.0	9.6E-03
DR1	52.0	1	0	52.0	5.8E-02*
DR2	52.0	2	2	104.0	1.9E-02
DR3	52.0	2	1	104.0	9.6E-03
EN1	52.0	3	6	156.0	3.8E-02
FP1	52.0	4	0	208.0	1.4E-02*
MI1	52.0	1	0	52.0	5.8E-02*
MO1	52.0	2	0	104.0	2.9E-02*
NM1	52.0	2	0	104.0	2.9E-02*
OC1	52.0	2	0	104.0	2.9E-02*
PB2	52.0	4	0	208.0	1.4E-02*
PI1	52.0	2	0	104.0	2.9E-02*
QC1	52.0	2	0	104.0	2.9E-02*
QC2	52.0	2	0	104.0	2.9E-02*
VY1	52.0	2	2	104.0	1.9E-02
		TOTALS	14	2288.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1977

WESTINGHOUSE

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BV1	52.0	2	1	104.0	9.6E-03
DC1	52.0	2	0	104.0	2.9E-02*
HN1	52.0	2	0	104.0	2.9E-02*
IP2	52.0	3	0	156.0	1.9E-02*
IP3	52.0	3	0	156.0	1.9E-02*
JF1	20.0	5	2	100.0	2.0E-02
KE1	52.0	2	2	104.0	1.9E-02
PR1	52.0	2	1	104.0	9.6E-03
PR2	52.0	2	0	104.0	2.9E-02*
PT1	52.0	2	0	104.0	2.9E-02*
PT2	52.0	2	0	104.0	2.9E-02*
RG1	52.0	2	0	104.0	2.9E-02*
RO2	52.0	2	1	104.0	9.6E-03
SA1	52.0	3	2	156.0	1.3E-02
SU1	52.0	2	0	104.0	2.9E-02*
SU1	52.0	2	0	104.0	2.9E-02*
SU2	52.0	2	0	104.0	2.9E-02*
TR4	52.0	2	1	104.0	9.6E-03
TU3	52.0	2	0	104.0	2.9E-02*
TU4	52.0	2	0	104.0	2.9E-02*
YR1	52.0	3	2	156.0	1.3E-02
ZI1	52.0	3	0	156.0	1.9E-02*
ZI2	52.0	3	4	156.0	2.6E-02
TOTALS		16	4	2700.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1977

FINAL STATISTICS

	OPERATING HOUR RATE
BAB.GWIL.	6.7E-03*
	1.7
COMB.ENG.	1.2E-02
	1.9
	1.6
GEN.ELEC.	6.1E-03
	1.7
	1.5
WESTINGH.	5.9E-03
	1.6
	1.4
PWR'S	6.5E-03
	1.4
	1.3
OVERALL	6.3E-03
	1.3

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1978

BABCOCK&WILCOX

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR1	52.0	2	1	104.0	9.6E-03
CR3	52.0	2	0	104.0	2.9E-02*
DB1	52.0	2	3	104.0	2.9E-02
RS1	52.0	2	1	104.0	9.6E-03
T11	52.0	2	0	104.0	2.9E-02*
T12	40.0	2	2	80.0	2.5E-02
TOTALS			7	600.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

353

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1978

COMBUSTION ENGINEERING

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR2	4.0	2	0	8.0	3.7E-01*
CC1	52.0	2	1	104.0	9.6E-03
CC2	52.0	2	2	104.0	1.9E-02
FC1	52.0	2	2	104.0	1.9E-02
M12	52.0	2	3	104.0	2.9E-02
MY1	52.0	2	0	104.0	2.9E-02*
PA1	52.0	2	0	104.0	2.9E-02*
SL1	52.0	2	0	104.0	2.9E-02*
TOTALS			8	736.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RLN - (WEEKLY TESTING) - 1978

GENERAL ELECTRIC

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BF1	52.0	4	0	208.0	1.4E-02*
BP1	52.0	1	1	52.0	1.9E-02
BR2	52.0	4	1	208.0	4.8E-03
CD1	52.0	2	0	104.0	2.9E-02*
DA1	52.0	2	0	104.0	2.9E-02*
DR1	52.0	1	0	52.0	5.8E-02*
DR2	52.0	2	1	104.0	9.6E-03
DR3	52.0	2	0	104.0	2.9E-02*
EN1	52.0	3	0	156.0	1.9E-02*
EN2	26.0	3	0	78.0	3.8E-02*
FP1	52.0	4	1	208.0	4.8E-03
MI1	52.0	1	0	52.0	5.8E-02*
MO1	52.0	2	0	104.0	2.9E-02*
NM1	52.0	2	0	104.0	2.9E-02*
OC1	52.0	2	0	104.0	2.9E-02*
PB2	52.0	4	1	208.0	4.8E-03
PI1	52.0	2	1	104.0	9.6E-03
QC1	52.0	2	0	104.0	2.9E-02*
QC2	52.0	2	0	104.0	2.9E-02*
VY1	52.0	2	1	104.0	9.6E-03
TOTALS			7	2366.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1978

WESTINGHOUSE

PLANT	CUMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BV1	52.0	2	2	104.0	1.9E-02
DC1	52.0	2	0	104.0	2.9E-02*
DC2	42.0	2	3	84.0	3.6E-02
HN1	52.0	2	0	104.0	2.9E-02*
IP2	52.0	3	0	156.0	1.9E-02*
IP3	52.0	3	0	156.0	1.9E-02*
JF1	52.0	5	0	260.0	1.2E-02*
KE1	52.0	2	0	104.0	2.9E-02*
NA1	38.0	2	0	76.0	3.9E-02*
PR1	52.0	2	0	104.0	2.9E-02*
PR2	52.0	2	0	104.0	2.9E-02*
PT1	52.0	2	0	104.0	2.9E-02*
PT2	52.0	2	0	104.0	2.9E-02*
RG1	52.0	2	0	104.0	2.9E-02*
RD2	52.0	2	1	104.0	9.6E-03
SA1	52.0	3	0	156.0	1.9E-02*
SU1	52.0	2	0	104.0	2.9E-02*
SU1	52.0	2	0	104.0	2.9E-02*
SU2	52.0	2	0	104.0	2.9E-02*
TR1	52.0	2	0	104.0	2.9E-02*
TU3	52.0	2	1	104.0	9.6E-03
TU4	52.0	2	0	104.0	2.9E-02*
YR1	52.0	3	0	156.0	1.9E-02*
Z11	52.0	3	2	156.0	1.3E-02
Z12	52.0	3	3	156.0	1.9E-02
TOTALS		12		3020.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1978

FINAL STATISTICS

	OPERATING HOUR RATE
	1.9
BAB.GWIL.	1.22-02
	2.1
	1.8
COMB.ENG.	1.1E-02
	2.0
	1.9
GEN.ELEC.	3.0E-03
	2.1
	1.6
WESTINGH.	4.0E-03
	1.7
	1.4
PWR'S	6.2E-03
	1.4
	1.3
OVERALL	5.1E-03
	1.4

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976 THRU 1976

BABCOCK&WILCOX

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR1	156.0	2	1	312.0	3.2E-03
CR3	162.0	2	0	204.0	1.5E-02*
DR1	68.0	2	3	136.0	2.2E-02
RS1	156.0	2	2	312.0	6.4E-03
T11	156.0	2	0	312.0	9.6E-03*
T12	40.0	2	2	80.0	2.5E-02
TOTALS			8	1356.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED



357

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976 THRU 1976



COMBUSTION ENGINEERING

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR2	4.0	2	0	8.0	3.7E-01*
CC1	156.0	2	5	312.0	1.6E-02
CC2	108.0	2	2	216.0	9.3E-03
FC1	156.0	2	3	312.0	9.6E-03
M12	156.0	2	16	312.0	5.1E-02
MY1	156.0	2	0	312.0	9.6E-03*
PA1	156.0	2	0	312.0	9.6E-03*
SL1	140.0	2	2	280.0	7.1E-03
TOTALS			28	2064.0	



* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED





**IMAGE EVALUATION
TEST TARGET (MT-3)**




MICROCOPY RESOLUTION TEST CHART









**IMAGE EVALUATION
TEST TARGET (MT-3)**





MICROCOPY RESOLUTION TEST CHART







**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976 THRU 1978

GENERAL ELECTRIC

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BF1	156.0	4	1	624.0	1.6E-03
BP1	156.0	1	3	156.0	1.9E-02
BR2	156.0	4	5	624.0	8.0E-03
CO1	156.0	2	2	312.0	6.4E-03
DA1	156.0	2	5	312.0	1.6E-02
DR1	156.0	1	0	156.0	1.9E-02*
DR2	156.0	2	5	312.0	1.6E-02
DR3	156.0	2	3	312.0	9.6E-03
EN1	156.0	3	9	468.0	1.9E-02
EN2	26.0	3	0	78.0	3.8E-02*
FP1	156.0	4	1	624.0	1.6E-03
MI1	156.0	1	0	156.0	1.9E-02*
MO1	156.0	2	0	312.0	9.6E-03*
NM1	156.0	2	0	312.0	9.6E-03*
QC1	156.0	2	0	312.0	9.6E-03*
PB2	156.0	4	1	624.0	1.6E-03
PI1	156.0	2	3	312.0	9.6E-03
QC1	156.0	2	0	312.0	9.6E-03*
QC2	156.0	2	0	312.0	9.6E-03*
YY1	156.0	2	4	312.0	1.3E-02
TOTALS			42	6942.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (WEEKLY TESTING) - 1976 THRU 1978

WESTINGHOUSE

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BV1	137.0	2	3	274.0	1.1E-02
DC1	156.0	2	0	312.0	9.6E-03*
DC2	42.0	2	3	84.0	3.6E-02
HN1	156.0	2	0	312.0	9.6E-03*
IP2	156.0	3	0	468.0	6.4E-03*
IP3	142.0	3	3	426.0	7.6E-03
JF1	72.0	5	2	360.0	5.6E-03
KE1	156.0	2	2	312.0	6.4E-03
NA1	38.0	2	0	76.0	3.9E-02*
PR1	156.0	2	1	312.0	3.2E-03
PR2	156.0	2	1	312.0	3.2E-03
PI1	156.0	2	0	312.0	9.6E-03*
PI2	156.0	2	0	312.0	9.6E-03*
RG1	156.0	2	0	312.0	9.6E-03*
RO2	156.0	2	3	312.0	9.6E-03
SA1	107.0	3	2	321.0	6.2E-03
SU1	156.0	2	0	312.0	9.6E-03*
SU1	156.0	2	0	312.0	9.6E-03*
SU2	156.0	2	0	312.0	9.6E-03*
TR1	156.0	2	1	312.0	3.2E-03
TU3	156.0	2	1	312.0	3.2E-03
TU4	156.0	2	0	312.0	9.6E-03*
YR1	156.0	3	2	468.0	4.3E-03
Z11	156.0	3	3	468.0	6.4E-03
Z12	156.0	3	7	468.0	1.5E-02
TOTALS			34	8093.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DUES NOT CONTINUE YD RUN - (WEEKLY TESTING) - 1976 THRU 1978

FINAL STATISTICS

	OPERATING HOUR RATE
	1.8
BAB. CWIL.	5.9E-03
	2.0
	1.4
COMB. ENG.	1.4E-02
	1.4
	1.3
GEN. ELEC.	6.1E-03
	1.3
	1.3
WESTINGH.	4.2E-03
	1.4
	1.2
PWR'S	6.1E-03
	1.2
	1.2
OVERALL	6.1E-03
	1.2

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976

BABCOCK&WILCOX

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR1	12.0	2	0	24.0	1.2E-01*
RS1	12.0	2	1	24.0	4.2E-02
T11	12.0	2	0	24.0	1.2E-01*
TOTALS			1	72.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

361

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976

COMBUSTION ENGINEERING

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
CC1	12.0	2	1	24.0	4.2E-02
CC2	1.0	2	0	2.0	1.5E+00*
FC1	12.0	2	1	24.0	4.2E-02
M12	12.0	2	9	24.0	3.8E-01
MY1	12.0	2	0	24.0	1.2E-01*
PA1	12.0	2	0	24.0	1.2E-01*
SL1	8.0	2	0	16.0	1.9E-01*
TOTALS			11	138.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976

GENERAL ELECTRIC

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BF1	12.0	4	1	48.0	2.1E-02
BP1	12.0	1	2	12.0	1.7E-01
BR?	12.0	4	2	48.0	4.2E-02
CU1	12.0	2	2	24.0	8.3E-02
DA1	12.0	2	4	24.0	1.7E-01
DR1	12.0	1	0	12.0	2.5E-01*
DR2	12.0	2	2	24.0	8.3E-02
DR3	12.0	2	2	24.0	8.3E-02
EN1	12.0	3	3	36.0	8.3E-02
FP1	12.0	4	0	48.0	6.2E-02*
MI1	12.0	1	0	12.0	2.5E-01*
MO1	12.0	2	0	24.0	1.2E-01*
NM1	12.0	2	0	24.0	1.2E-01*
OC1	12.0	2	0	24.0	1.2E-01*
PB2	12.0	4	0	48.0	6.2E-02*
PI1	12.0	2	2	24.0	8.3E-02
QC1	12.0	2	0	24.0	1.2E-01*
QC2	12.0	2	0	24.0	1.2E-01*
VT1	12.0	2	1	24.0	4.2E-02
TOTALS			21	528.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976

WESTINGHOUSE

PLANE	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BV1	8.0	2	0	16.0	1.9E-01*
DC1	12.0	2	0	24.0	1.2E-01*
HN1	12.0	2	0	24.0	1.2E-01*
IP2	12.0	3	0	36.0	8.3E-02*
IP3	9.0	3	3	27.0	1.1E-01
KE1	12.0	2	0	24.0	1.2E-01*
PR1	12.0	2	0	24.0	1.2E-01*
PR2	12.0	2	1	24.0	4.2E-02
PF1	12.0	2	0	24.0	1.2E-01*
PT2	12.0	2	0	24.0	1.2E-01*
RG1	12.0	2	0	24.0	1.2E-01*
RU2	12.0	2	1	24.0	4.2E-02
SA1	1.0	3	0	3.0	1.0E+00*
SO1	12.0	2	0	24.0	1.2E-01*
SU1	12.0	2	0	24.0	1.2E-01*
SU2	12.0	2	0	24.0	1.2E-01*
TR1	12.0	2	0	24.0	1.2E-01*
TU3	12.0	2	0	24.0	1.2E-01*
TU4	12.0	2	0	24.0	1.2E-01*
YR1	12.0	3	0	36.0	8.3E-02*
Z11	12.0	3	1	36.0	2.8E-02
Z12	12.0	3	0	36.0	8.3E-02*
TOTALS			6	550.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976

FINAL STATISTICS

	OPERATING HOUR RATE
	4.7
BAB. & WIL.	1.4E-02
	19.5
	1.7
COMB. ENG.	8.0E-02
	1.8
	1.4
GEN. ELEC.	4.0E-02
	1.5
	2.0
WFSTINGH.	1.1E-02
	2.3
	1.5
P&R'S	2.4E-02
	1.5
	1.3
OVERALL	3.0E-02
	1.3

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1977

BABCOCKE WILCOX

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR1	12.0	2	0	24.0	1.2E-01*
CR3	12.0	2	0	24.0	1.2E-01*
DB1	4.0	2	0	8.0	3.7E-01*
RS1	12.0	2	0	24.0	1.2E-01*
T11	12.0	2	0	24.0	1.2E-01*
TOTALS			0	104.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

365

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1977

COMBUSTION ENGINEERING

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
CC1	12.0	2	3	24.0	1.3E-01
CC2	12.0	2	0	24.0	1.2E-01*
FC1	12.0	2	0	24.0	1.2E-01*
M12	12.0	2	4	24.0	1.7E-01
MY1	12.0	2	0	24.0	1.2E-01*
PA1	12.0	2	0	24.0	1.2E-01*
SL1	12.0	2	2	24.0	8.3E-02
TOTALS			9	168.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1977

GENERAL ELECTRIC

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BF1	12.0	4	0	48.0	6.2E-02*
BP1	12.0	1	0	12.0	2.5E-01*
BR4	12.0	4	2	48.0	4.2E-02
CU1	12.0	2	0	24.0	1.2E-01*
DA1	12.0	2	1	24.0	4.2E-02
DR1	12.0	1	0	12.0	2.5E-01*
DR2	12.0	2	2	24.0	8.3E-02
DR3	12.0	2	1	24.0	4.2E-02
EN1	12.0	3	6	36.0	1.7E-01
FP1	12.0	4	0	48.0	6.2E-02*
MI1	12.0	1	0	12.0	2.5E-01*
MU1	12.0	2	0	24.0	1.2E-01*
NM1	12.0	2	0	24.0	1.2E-01*
QC1	12.0	2	0	24.0	1.2E-01*
PB2	12.0	4	0	48.0	6.2E-02*
PI1	12.0	2	0	24.0	1.2E-01*
QC1	12.0	2	0	24.0	1.2E-01*
QC2	12.0	2	0	24.0	1.2E-01*
VY1	12.0	2	2	24.0	8.3E-02
TOTALS			14	528.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1977

WESTINGHOUSE

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BV1	12.0	2	1	24.0	4.2E-02
DC1	12.0	2	0	24.0	1.2E-01*
HN1	12.0	2	0	24.0	1.2E-01*
IP2	12.0	3	0	36.0	8.3E-02*
IP3	12.0	3	0	36.0	8.3E-02*
JF1	5.0	5	2	25.0	8.0E-02
KE1	12.0	2	2	24.0	8.3E-02
PR1	12.0	2	1	24.0	4.2E-02
PR2	12.0	2	0	24.0	1.2E-01*
PF1	12.0	2	0	24.0	1.2E-01*
PF2	12.0	2	0	24.0	1.2E-01*
KG1	12.0	2	0	24.0	1.2E-01*
RO2	12.0	2	1	24.0	4.2E-02
SA1	12.0	3	2	36.0	5.6E-02
SO1	12.0	2	0	24.0	1.2E-01*
SU1	12.0	2	0	24.0	1.2E-01*
SU2	12.0	2	0	24.0	1.2E-01*
TR1	12.0	2	1	24.0	4.2E-02
TU3	12.0	2	0	24.0	1.2E-01*
TU4	12.0	2	0	24.0	1.2E-01*
YR1	12.0	3	2	36.0	5.6E-02
Z11	12.0	3	0	36.0	8.3E-02*
Z12	12.0	3	4	36.0	1.1E-01
TOTALS			16	625.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1977

FINAL STATISTICS

	OPERATING HOUR RATE
BAB.&WIL.	2.9E-02*
	1.7
COMB.ENG.	5.4E-02
	1.9
	1.6
GEN.ELEC.	2.7E-02
	1.7
	1.5
WESTINGH.	2.6E-02
	1.6
	1.4
PWR'S	2.8E-02
	1.4
	1.3
OVERALL	2.7E-02
	1.3

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1978

BABCOCK&WILCOX

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AK1	12.0	2	1	24.0	4.2E-02
CR3	12.0	2	0	24.0	1.2E-01*
DB1	12.0	2	3	24.0	1.3E-01
RS1	12.0	2	1	24.0	4.2E-02
T11	12.0	2	0	24.0	1.2E-01*
T12	9.0	2	2	18.0	1.1E-01
TOTALS			7	138.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

369

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1978

COMBUSTION ENGINEERING

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR2	1.0	2	0	2.0	1.5E+00*
CC1	12.0	2	1	24.0	4.2E-02
CC2	12.0	2	2	24.0	8.3E-02
FC1	12.0	2	2	24.0	8.3E-02
M12	12.0	2	3	24.0	1.3E-01
MY1	12.0	2	0	24.0	1.2E-01*
PA1	12.0	2	0	24.0	1.2E-01*
UL1	12.0	2	1	24.0	1.2E-01*
TOTALS			8	170.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1978

GENERAL ELECTRIC

PLANT	COMP. HRS.	POPULATION	FAILURES	POP. HOURS	OPERATING RISK RATE
BF 1	12.0	4	0	48.0	0.2E-02*
BF 2	12.0	1	1	12.0	8.3E-02
BR 2	12.0	4	1	48.0	2.1E-02
CU 1	12.0	2	0	24.0	1.2E-01*
DA 1	12.0	2	0	24.0	1.2E-01*
DR 1	12.0	1	0	12.0	2.5E-01*
DR 2	12.0	2	1	24.0	4.2E-02
DR 3	12.0	2	0	24.0	1.2E-01*
EN 1	12.0	3	0	36.0	8.3E-02*
EN 2	6.0	3	0	18.0	1.7E-01*
FP 1	12.0	4	1	48.0	2.1E-02
MI 1	12.0	1	0	12.0	2.5E-01*
MO 1	12.0	2	0	24.0	1.2E-01*
NM 1	12.0	2	0	24.0	1.2E-01*
OC 1	12.0	2	0	24.0	1.2E-01*
PB 2	12.0	4	1	48.0	2.1E-02
PI 1	12.0	2	1	24.0	4.2E-02
QC 1	12.0	2	0	24.0	1.2E-01*
QC 2	12.0	2	0	24.0	1.2E-01*
WY 1	12.0	2	1	24.0	4.2E-02
TOTALS			7	546.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1978

WESTINGHOUSE

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BV1	12.0	2	2	24.0	8.3E-C2
DC1	12.0	2	0	24.0	1.2E-C1*
DC2	10.0	2	3	20.0	1.5E-C1
HN1	12.0	2	0	24.0	1.2E-C1*
IP2	12.0	3	0	36.0	8.3E-C2*
IP3	12.0	3	0	36.0	8.3E-C2*
JF1	12.0	5	0	60.0	5.0E-C2*
KE1	12.0	2	0	24.0	1.2E-C1*
NA'	9.0	2	0	18.0	1.7E-C1*
PR1	12.0	2	0	24.0	1.2E-C1*
PR2	12.0	2	0	24.0	1.2E-C1*
PT1	12.0	2	0	24.0	1.2E-C1*
PT2	12.0	2	0	24.0	1.2E-C1*
RG1	12.0	2	0	24.0	1.2E-C1*
RU2	12.0	2	1	24.0	4.2E-C2
SA1	12.0	3	0	36.0	8.3E-C2*
SO1	12.0	2	0	24.0	1.2E-C1*
SU1	12.0	2	0	24.0	1.2E-C1*
SU2	12.0	2	0	24.0	1.2E-C1*
TR1	12.0	2	0	24.0	1.2E-C1*
TU3	12.0	2	1	24.0	4.2E-C2
TU4	12.0	2	0	24.0	1.2E-C1*
YR1	12.0	3	0	36.0	8.3E-C2*
Z11	12.0	3	2	36.0	5.0E-C2
Z12	12.0	3	3	36.0	8.3E-C2
TOTALS		12	12	698.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TEST 9) - 1978

FINAL STATISTICS

	OPERATING HOUR RATE
	1.9
BAB.EWIL.	5.1E-02
?	2.1
	1.8
COMB.ENG.	4.7E-02
	2.6
	1.9
GEN.ELEC.	1.3E-02
	2.1
	1.6
WESTINGH.	1.7E-02
	1.7
	1.4
PWR'S	2.7E-02
	1.4
	1.3
OVERALL	2.2E-02
	1.4

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976 THRU 1978

BABCOCK & WILCOX

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR1	36.0	2	1	72.0	1.4E-02
CR3	24.0	2	0	48.0	6.2E-02*
DB1	16.0	2	3	32.0	9.4E-02
RS1	36.0	2	2	72.0	2.8E-02
T.4	36.0	2	0	72.0	4.2E-02*
112	9.0	2	2	18.0	1.1E-01
TOTALS			8	314.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976 THRU 1978

COMBUSTION ENGINEERING

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
AR2	1.0	2	0	2.0	1.5E+00*
CC1	36.0	2	5	72.0	6.9E-02
CC2	25.0	2	2	50.0	4.0E-02
FC1	36.0	2	3	72.0	4.2E-02
MI2	36.0	2	16	72.0	2.2E-01
MY1	36.0	2	0	72.0	4.2E-02*
PA1	36.0	2	0	72.0	4.2E-02*
SL1	32.0	2	2	64.0	3.1E-02
TOTALS			28	476.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976 THRU 1978

GENERAL ELECTRIC

PLANT	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BF1	36.0	4	1	144.0	6.9E-03
BP1	36.0	1	3	36.0	8.3E-02
BR2	36.0	4	5	144.0	3.5E-02
CO1	36.0	2	2	72.0	2.8E-02
DA1	36.0	2	5	72.0	6.9E-02
DR1	36.0	1	0	36.0	8.3E-02*
DR2	36.0	2	5	72.0	6.9E-02
DR3	36.0	2	3	72.0	4.2E-02
EN1	36.0	3	9	108.0	8.3E-02
EN2	6.0	3	0	18.0	1.7E-01*
FP1	36.0	4	1	144.0	6.9E-03
MI1	36.0	1	0	36.0	8.3E-02*
MO1	36.0	2	0	72.0	4.2E-02*
NM1	36.0	2	0	72.0	4.2E-02*
OC1	36.0	2	0	72.0	4.2E-02*
PB2	36.0	4	1	144.0	6.9E-03
PI1	36.0	2	3	72.0	4.2E-02
QC1	36.0	2	0	72.0	4.2E-02*
QC2	36.0	2	0	72.0	4.2E-02*
VY1	36.0	2	4	72.0	5.6E-02
TOTALS			42	1602.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976 THRU 1976

WESTINGHOUSE

PLANE	COMP.HRS.	POPULATION	FAILURES	POP.HOURS.	OPERATING HOUR RATE
BV1	32.0	2	3	64.0	4.7E-02
DC1	36.0	2	0	72.0	4.2E-02*
DC2	10.0	2	3	20.0	1.5E-01
HN1	36.0	2	0	72.0	4.2E-02*
IP2	36.0	3	0	108.0	2.8E-02*
IP3	33.0	3	3	99.0	3.0E-02
JF1	17.0	5	2	85.0	2.4E-02
KE1	36.0	2	2	72.0	2.8E-02
NA1	9.0	2	0	18.0	1.7E-01*
PR1	36.0	2	1	72.0	1.4E-02
PR2	36.0	2	1	72.0	1.4E-02
PI1	36.0	2	0	72.0	4.2E-02*
PI2	36.0	2	0	72.0	4.2E-02*
RG1	36.0	2	0	72.0	4.2E-02*
RO2	36.0	2	3	72.0	4.2E-02
SA1	25.0	3	2	75.0	2.7E-02
SU1	36.0	2	0	72.0	4.2E-02*
SU1	36.0	2	0	72.0	4.2E-02*
SU2	36.0	2	0	72.0	4.2E-02*
TR1	36.0	2	1	72.0	1.4E-02
TU3	36.0	2	1	72.0	1.4E-02
TU4	36.0	2	0	72.0	4.2E-02*
YR1	36.0	3	2	108.0	1.9E-02
Z11	36.0	3	3	108.0	2.8E-02
Z12	36.0	3	7	108.0	6.5E-02
TOTALS		34		1873.0	

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

DOES NOT CONTINUE TO RUN - (MONTHLY TESTING) - 1976 THRU 1978

FINAL STATISTICS

	OPERATING HOUR RATE
	1.8
BAB.EWIL.	2.5E-02
	2.0
	1.4
COMB.ENG.	5.9E-02
	1.4
	1.3
GEN.ELEC.	2.6E-02
	1.3
	1.3
WESTINGH.	1.8E-02
	1.4
	1.2
PWR'S	2.6E-02
	1.2
	1.2
OVERALL	2.6E-02
	1.2

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

APPENDIX Q

RESULTS OF THE DIESEL-GENERATOR, DOES NOT OPERATE,
FAILURE RATE ESTIMATIONS

AGGREGATE STANDBY RATES - (WEEKLY TESTING) - 1976 THRU 1978

BABCOCKWILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AK1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
CR3	17184.0	2	102	6	34368.0	204	1.7E-04	2.9E-02
DB1	11424.0	2	68	6	22848.0	136	2.6E-04	4.4E-02
RS1	26280.0	2	156	5	52560.0	312	9.5E-05	1.6E-02
T11	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
T12	6648.0	2	40	4	13296.0	80	3.0E-04	5.0E-02
TOTALS				27	228192.0	1356		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

379

AGGREGATE STANDBY RATES - (WEEKLY TESTING) - 1976 THRU 1978

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR2	600.0	2	4	0	1200.0	8	2.5E-03*	3.7E-01*
CC1	26280.0	2	156	12	52560.0	312	2.3E-04	3.8E-02
CC2	16264.0	2	108	6	36528.0	216	1.6E-04	2.8E-02
FC1	26280.0	2	156	9	52560.0	312	1.7E-04	2.9E-02
M12	26280.0	2	156	22	52560.0	312	4.2E-04	7.1E-02
MY1	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
PA1	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
SL1	23592.0	2	140	7	47184.0	280	1.5E-04	2.5E-02
TOTALS				58	347712.0	2064		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

AGGREGATE STANDBY RATES - (WEEKLY TESTING) - 1976 THRU 1978

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	26280.0	4	156	3	105120.0	624	2.9E-05	4.8E-03
BP1	26280.0	1	156	22	26280.0	156	8.4E-04	1.4E-01
BR2	26280.0	4	156	12	105120.0	624	1.1E-04	1.9E-02
CD1	26280.0	2	156	4	52560.0	312	7.6E-05	1.3E-02
DA1	26280.0	2	156	8	52560.0	312	1.5E-04	2.6E-02
DR1	26280.0	1	156	5	26280.0	156	1.9E-04	3.2E-02
DR2	26280.0	2	156	21	52560.0	312	4.0E-04	6.7E-02
DR3	26280.0	2	156	7	52560.0	312	1.3E-04	2.2E-02
EN1	26280.0	3	156	17	78840.0	468	2.2E-04	3.6E-02
EN2	4296.0	3	26	2	12888.0	76	1.6E-04	1.6E-02
FP1	26280.0	4	156	6	105120.0	624	5.7E-05	9.6E-03
MI1	26280.0	1	156	0	26280.0	156	1.1E-04*	1.9E-02*
MO1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
NM1	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
OC1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
PB2	26280.0	4	156	8	105120.0	624	7.6E-05	1.3E-02
PI1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
QC1	26280.0	2	156	4	52560.0	312	7.6E-05	1.3E-02
QC2	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
VY1	26280.0	2	156	6	52560.0	312	1.1E-04	1.9E-02
TOTALS				132	1169208.0	6942		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

AGGREGATE STANDBY RATES - (WEEKLY TESTING) - 1976 THRU 1978

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BV1	23136.0	2	137	16	46272.0	274	3.5E-04	5.8E-02
DC1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
DC2	7080.0	2	42	5	14160.0	84	3.5E-04	6.0E-02
HN1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
IP2	26280.0	3	156	0	78840.0	468	3.8E-05*	6.4E-03*
IP3	23952.0	3	142	3	71856.0	426	4.2E-05	7.0E-03
JF1	12192.0	5	72	11	60960.0	360	2.1E-04	3.6E-02
KE1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
NA1	6456.0	2	36	0	12912.0	76	2.3E-04*	3.9E-02*
PR1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
PR2	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
PI1	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
PT2	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
RG1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
RO2	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
SA1	17976.0	3	107	4	53928.0	321	7.4E-05	1.2E-02
SO1	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
SU1	26280.0	2	156	1	52560.0	312	1.9E-05	3.2E-03
SU2	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
TR1	26280.0	2	156	2	52560.0	312	3.8E-05	6.4E-03
TU3	26280.0	2	156	3	52560.0	312	5.7E-05	9.6E-03
TU4	26280.0	2	156	0	52560.0	312	5.7E-05*	9.6E-03*
YR1	26280.0	3	156	3	78840.0	468	3.8E-05	6.4E-03
ZI1	26280.0	3	156	8	78840.0	468	1.0E-04	1.7E-02
ZI2	26280.0	3	156	7	78840.0	468	8.9E-05	1.5E-02
TOTALS				81	1363848.0	8093		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

AGGREGATE STANDBY RATES - (WEEKLY TESTING) - 1976 THRU 1978

FINAL STATISTICS

	STANDBY HOUR RATE	DEMAND RATE
	1.4	1.4
BAB.&WIL.	1.2E-04	2.0E-02
	1.4	1.4
	1.2	1.2
COMB.ENG.	1.7E-04	2.8E-02
	1.3	1.3
	1.2	1.2
GEN.ELEC.	1.1E-04	1.9E-02
	1.2	1.2
	1.2	1.2
WESTINGH.	5.9E-05	1.0E-02
	1.2	1.2
	1.1	1.1
PWR'S	8.6E-05	1.4E-02
	1.1	1.1
	1.1	1.1
OVERALL	9.6E-05	1.6E-02
	1.1	1.1

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

AGGREGATE STANDBY RATES - (MONTHLY TESTING) - 1976 THRU 1978

BABCOCK&WILCOX

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
CR3	17184.0	2	24	6	34368.0	48	1.7E-04	1.3E-01
EB1	11424.0	2	16	6	22848.0	32	2.6E-04	1.9E-01
RS1	26280.0	2	36	5	52560.0	72	9.5E-05	6.9E-02
T11	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
T12	6648.0	2	9	4	13296.0	18	3.0E-04	2.2E-01
TOTALS				27	228192.0	314		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

AGGREGATE STANDBY RATES - (MONTHLY TESTING) - 1976 THRU 1978

COMBUSTION ENGINEERING

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
AR2	600.0	2	1	0	1200.0	2	2.5E-03*	1.5E+00*
CC1	26280.0	2	36	12	52560.0	72	2.3E-04	1.7E-01
CC2	18264.0	2	29	6	36528.0	50	1.6E-04	1.2E-01
FC1	26280.0	2	36	9	52560.0	72	1.7E-04	1.3E-01*
M12	26280.0	2	36	22	52560.0	72	4.2E-04	3.1E-01
MY1	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
PA1	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
SL1	23592.0	2	32	7	47184.0	64	1.5E-04	1.1E-01
TOTALS				58	347712.0	476		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

AGGREGATE STANDBY RATES - (MONTHLY TESTING) - 1976 THRU 1978

GENERAL ELECTRIC

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HOUR RATE	DEMAND RATE
BF1	26280.0	4	36	3	105120.0	144	2.9E-05	2.1E-02
BPI	26280.0	1	36	22	26280.0	36	8.4E-04	6.1E-01
BR2	26280.0	4	36	12	105120.0	144	1.1E-04	8.3E-02
CD1	26280.0	2	36	4	52560.0	72	7.6E-05	5.6E-02
DA1	26280.0	2	36	8	52560.0	72	1.5E-04	1.1E-01
DR1	26280.0	1	36	5	26280.0	36	1.9E-04	1.4E-01
DR2	26280.0	2	36	21	52560.0	72	4.0E-04	2.9E-01
DR3	26280.0	2	36	7	52560.0	72	1.3E-04	9.7E-02
EN1	26280.0	3	36	17	76840.0	108	2.2E-04	1.6E-01
EN2	4296.0	3	6	2	12888.0	18	1.6E-04	1.1E-01
FP1	26280.0	4	36	6	105120.0	144	5.7E-05	4.2E-02
MI1	26280.0	1	36	0	26280.0	36	1.1E-04*	8.3E-02*
MO1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
NM1	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
OC1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
PB2	26280.0	4	36	8	105120.0	144	7.6E-05	5.6E-02
PI1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
QC1	26280.0	2	36	4	52560.0	72	7.6E-05	5.6E-02
QC2	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
XY1	26280.0	2	36	6	52560.0	72	1.1E-04	8.3E-02
TOTALS				132	1169208.0	1602		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

AGGREGATE STANDBY RATES - (MONTHLY TESTING) - 1976 THRU 1976

WESTINGHOUSE

PLANT	CRIT.HRS.	POPULATION	DEMANDS	FAILURES	POP.HOURS	POP.DEMANDS	STANDBY HLUR RATE	DEMAND RATE
BV1	23136.0	2	32	16	46272.0	64	3.5E-04	2.5E-01
DC1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
DC2	7080.0	2	10	5	14160.0	20	3.5E-04	2.5E-01
HN1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
IP2	26280.0	3	36	0	78840.0	108	3.7E-05*	2.8E-02*
IP3	23952.0	3	33	3	71856.0	99	4.2E-05	3.0E-02
JF1	12192.0	5	17	13	60960.0	85	2.1E-04	1.5E-01
KE1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
NA1	6456.0	2	9	0	12912.0	18	2.3E-04*	1.7E-01*
PR1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
PR2	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
PT1	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
PT2	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
RG1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
RO2	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
SA1	17976.0	3	25	4	53928.0	75	7.4E-05	5.3E-02
SO1	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
SU1	26280.0	2	36	1	52560.0	72	1.9E-05	1.4E-02
SU2	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
TK1	26280.0	2	36	2	52560.0	72	3.8E-05	2.8E-02
TU3	26280.0	2	36	3	52560.0	72	5.7E-05	4.2E-02
TU4	26280.0	2	36	0	52560.0	72	5.7E-05*	4.2E-02*
YR1	26280.0	3	36	3	78840.0	108	3.8E-05	2.8E-02
Z11	26280.0	3	36	8	78840.0	108	1.0E-04	7.4E-02
Z12	26280.0	3	36	7	78840.0	108	8.9E-05	6.5E-02
TOTALS				81	1363848.0	1873		

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED

AGGREGATE STANDBY RATES - (MONTHLY TESTING) - 1976 THRU 1978

FINAL STATISTICS

	STANDBY HOUR RATE	DEMAND RATE
	1.4	1.4
BAB. & WIL.	1.2E-04	8.6E-02
	1.4	1.4
	1.2	1.2
COMB. ENG.	1.7E-04	1.2E-01
	1.3	1.3
	1.2	1.2
GEN. ELEC.	1.1E-04	8.2E-02
	1.2	1.2
	1.2	1.2
WESTINGH.	5.9E-05	4.3E-02
	1.2	1.2
	1.1	1.1
PWR'S	8.6E-05	6.2E-02
	1.1	1.1
	1.1	1.1
OVERALL	9.6E-05	7.0E-02
	1.1	1.1

* DENOTES UPPER 95 PERCENT CONFIDENCE BOUND WHEN NO FAILURES RECORDED