CONTROLLED
PITTSBURGH TESTING LABORATORY
ESTABLISHED 1881
850 POPLAR STREET, PITTSBURGH, PA. 15220
PLEASE REPLY TO:
P. O. BOX 1646
PITTSBURGH, PA. 15230
AREA CODE 412 TELEPHONE 922-4000

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

LABORATORY No. 800986

CLIENT'S No. P.O.12210.50
04994

ORDER No. PG-12606

REPORT

January 23, 1980

REPORT OF POTENTIAL ALKALI
REACTIVITY ASTM C227
FOR
GULF STATES UTILITIES COMPANY
STONE AND WEBSTER ENGINEERING CORP., AGENT
P. O. BOX 217
ST. FRANCISVILLE, LA. 70775

PROJECT	:	RIVERBEND
Material	:	No. 57 Coarse Aggregate
Cement	:	Northampton Type I H.A.
		Na_2O : 0.38
		K_2O : 0.77
		Total Alkalies @ Na_2O : 0.89

	Average Length Change Percent
14 Day	+0.01
1 Month	+0.01
2 MOnth	+0.02
3 Month	+0.02
4 Month	Due 2/20/80
6 Month	

Mixing water as percent Cement : 24.0

RECEIVED
JAN 2 [illegible] 1980
STONE & WEBSTER
ENGINEERING CORPORATION
12210/[illegible]

8004040367