

Appendix A

Sacramento Municipal Utility District
P. O. Box 15830
Sacramento, California 95813

Docket No. 50-312
License No. DPR-54

Notice of Violation

Based on the results of the NRC inspection conducted on January 21-25, 1980, it appears that one of your activities was not conducted in full compliance with conditions of your NRC Facility License No. DPR-54 as indicated below.

- A. Technical Specification 2.2, Appendix B, requires that the total residual chlorine in effluent water not exceed a maximum rate of 0.2 mg/liter.

Contrary to this requirement the total chlorine concentration in plant effluent exceeded the limit on October 24, November 20, December 3, December 5 and December 14, 1979.

This item is a deficiency.

8004210243