

3. Effluent Treatment Systems

We have determined that the effluent treatment system, if constructed as described in the CECO submittals, is capable of handling the types and quantities of effluents expected to be generated by the decontamination program. Our review was limited to the use of the system for chemical decontamination only, and use of the system for any other purpose subsequent to that program must be reviewed prior to such use.

4. Radiological Safety

We have further concluded that the radiological safety program described in the submittals is adequate to assure that the health and safety of the public and the onsite personnel will not be endangered by the Dresden 1 decontamination project.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) because the chemical cleaning does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the cleaning project does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: December 9, 1975

8004210256