

8005020116

BASES FOR ESTABLISHING TMI-2 INTERIM RELEASE CRITERIA

- REQUIRES NRC REVIEW AND APPROVAL OF OPERATIONS HAVING RELEASE POTENTIAL
- REQUIRES CONFORMANCE TO TECH SPECS AND ALARA
- ALLOWS CONTINUATION OF ONGOING DECONTAMINATION ACTIVITIES
- ALLOWS MAINTENANCE AND DATA GATHERING, INCLUDING POSSIBLE REACTOR BUILDING ENTRY

EXCLUSIONS TO PROPOSED INTERIM CRITERIA

- PURGING OF REACTOR BUILDING EXCEPT AIR LOCK.
- DISPOSAL OF WATER PROCESSED BY EPICOR - II.
- TREATMENT OR DISPOSAL OF PRIMARY SYSTEM COOLANT OR WATER IN REACTOR BUILDING BASEMENT.

INTERIM* CRITERIA FOR TMI-2 RADIOLOGICAL EFFLUENTS

- ONSITE DEPUTY PROGRAM DIRECTOR AUTHORIZED TO PERMIT UP TO 5% OF 10 CFR PART 50 APPENDIX I DESIGN OBJECTIVES -- NORMALIZED TO WEEKLY RATE.
- DIRECTOR OF NRR AUTHORIZED TO PERMIT UP TO 50% OF 10 CFR PART 50 APPENDIX I DESIGN OBJECTIVES -- NORMALIZED TO WEEKLY RATE.
- COMMISSION APPROVAL REQUIRED FOR RELEASES IN EXCESS OF ABOVE.

* PENDING COMPLETION OF PEIS

CURIE DISCHARGES ALLOWED BY 5% CRITERIA

GASEOUS: 150 CURIES PER WEEK KR-85

(INCLUDES ABOUT 20 CURIES PER WEEK BACKGROUND)

LIQUID: 0.04 CURIES PER WEEK

(EXCLUDING TRITIUM)