



Public Service Company of Colorado

8005060 064
see to DAC:ADM:
CENTRAL FILES
PDR:HQ
LPDR
TIC
~~NSIC~~
STATE

March 18, 1980
Fort St. Vrain
Unit No. 1
P-80051

Mr. Karl V. Seyfrit, Director
Nuclear Regulatory Commission
Region IV
Office of Inspection and Enforcement
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76012

Subject: Environmental Qualification
of Class IE Equipment

References: IE Bulletin 79-01B
P-80037, March 4, 1980
Swart to Seyfrit

Dear Mr. Seyfrit:

As indicated in our letter of March 4, 1980 (P-80037), PSC is hereby submitting a partial response to IE-79-01B. Along with the submittal, we are summarizing the actions that are being taken as a result of IE Bulletin 79-01B. Justification is provided for not responding in areas that we feel do not apply to an HTGR. Also provided is the current status of our response and the schedule for its completion.

General

As previously submitted to the NRC (Attachment D to P-77137, Millen to Denise, June 15, 1977, enclosed as Attachment D), the double-ended rupture of a cold reheat pipe in the Reactor Building produces the most severe environmental conditions in that building. Similarly, the double-ended rupture of a hot reheat pipe produces the most severe environmental conditions in the Turbine Building. For the conditions resulting from a double-ended rupture of a hot or cold reheat pipe, components were qualified to the distance nearest the opposite loop steamline or to the nearest steamline if the component must function even if its own loop fails. If the distance was equal to or greater than 20 feet, the conditions of the 20 foot curve for the reactor or turbine buildings was used to qualify the components.

Mr. Karl V. Seyfrit, Director
March 18, 1980
Page 2

Partial Submittal (Attachment A)

Our submittal consists of a listing of Class IE electric equipment within the "accident zone" that is required to electrically function under accident conditions to provide safe shutdown cooling.

The submittal is formatted similarly to enclosures #1 and #2 of IE-79-01B.

Equipment locations are given in the column entitled "SRB LOCATION", which is defined in Attachment E.

The submittal that is similar to enclosure #2 is a tabulation of "tagged items." The term "tagged items" refers to equipment, instruments or components that are identified by a specific number. The numbers are alpha numeric in nature and provide the following information:

1. The alpha portion identifies the type of component, ie; as, P=Pump, HS=Hand Switch, etc. See Attachment B for a complete list of the Alpha prefixes.
2. The numeric portion identifies the system involved. Specifically, the first two digits identify the system involved. See Attachment B for a complete list of system numbers and names.

The submittal that is similar to enclosure #1 consists of "untagged" or "subtier" components. These subtier components are the many items such as relays, switches and other control components that are required as a part of the control loop or circuitry to make the tagged (equipment) item function. These types of items do not carry any specific identification other than the manufacturer's model or part number and are generally not shown on the plant P&I drawings.

Summary of Actions

The following areas are being investigated in relation to our response to IE-79-01B:

1. The environmental test records for the possible inclusion of additional subtier items.
2. The computer programming required to format our final response similar to enclosure #3 of IE-79-01B.
3. Equipment suppliers are being contacted regarding aging.
4. The Emergency Procedures are being reviewed.

Areas Not Applicable to an HTGR

Pressure:

The FSV HTGR does not have a containment building, therefore, there is no storage of blowdown steam and thus no ambient pressure buildup.

The reactor and turbine buildings are both vented. Therefore, pressure transients resulting from a high energy line break will be very localized and short-term in nature.

Further details about steamline rupture analysis at FSV may be found in Attachment D to P-77137, dated June 15, 1977.

Relative Humidity:

For the same reasons as discussed above under the pressure heading, Relative Humidity is not a problem at FSV after a high energy line break.

Chemical Spray:

No chemical sprays are utilized at FSV for cooling.

Radiation:

There are no radiological concerns directly associated with a high energy line break at FSV. That is, the process fluid (steam or feedwater) is not contaminated.

To postulate a radiological incident DBA #1 "Permanent Loss of Forced Circulation" and DBA #2 "Rapid Depressurization/Blowdown" were considered. DBA #1 provides the worst case radiological conditions, but the overall radiological concerns are minimal.

Complete details of this accident may be found in Section 2.1.6.b of P-79312 (Swart to Varga) dated December 28, 1979, enclosed as Attachment C.

In summary, the peak doses in the Reactor Building following DBA #1 are as follows:

<u>Location</u>	<u>Peak Gamma Dose Rate</u>	<u>Time of Peak</u>	<u>180 Day Accumulated Dose (Rem)</u>
Reactor Building (above Refueling Floor)	1.4 R/hr	24 hours	400

Mr. Karl V. Seyfrit, Director
March 18, 1980
Page 4

In conclusion, the reactor building will be accessible for short-term operations following such an accident. The accumulated doses indicated above would have no operational effect on the Reactor Building equipment.

Submergence

The nuclear reactor at Fort St. Vrain is cooled by gas and not water. Shutdown of the reactor is accomplished by control rod insertion. Emergency shutdown is accomplished by pressurized shutdown hoppers that drop boron balls into the reactor. Water is not used for shutdown or emergency core spray of the reactor in an HTGR. Venting of the reactor cooling quench water and/or primary coolant water into the containment sump is not applicable for Fort St. Vrain. Therefore, submergence is not deemed to be a problem at Fort St. Vrain.

Schedule


Component evaluation worksheets similar to IE-79-01B Enclosure 3 will be submitted in a preliminary form within approximately 2 weeks, along with any revisions to the master list.

After the above is completed, revised versions of the master list and component worksheets will be supplied on a weekly basis if revisions are required.

The response to this bulletin and the schedule for its completion is based upon the use of the firewater system as the source of motive power for the helium circulators and water to cool a steam generator as described in the FSV FSAR Section 14.4. This mode of reactor cooling utilizes only seismically and environmentally qualified equipment components and systems. With this in mind, there should be no problem in meeting the 90 day response deadline for IE-79-01B.

If the review of the FSV Emergency Procedures or any other item has a major impact on the schedule the staff will be so advised.

Very truly yours,



Frederic E. Swart, Manager
Nuclear Project Department

FES/MEN:pa

Attachments

POOR ORIGINAL

COMPONENT	SCI	SUPPLIER	SCI	MODEL	PRODUCT	SRB	LOC
1		23		24	4		35
SUBT-	009	ALLEN BRADLEY		700N400	RELAY		RX2
SUBT-	010	ALLEN BRADLEY		700N800	RELAY		RX2
SUBT-	011	ASCO		HB8302C25F	VALVE		RX2
SUBT-	012	ASCO		HB8302C29U	VALVE		RX2
SUBT-	013	ASCO		HB8302C29F	VALVE		RX2
SUBT-	015	ASCO		LB8320A108	VALVE		TB2
SUBT-	016	ASCO		H88302C25G	VALVE		RX2
SUBT-	017	ASCO		8302C26U	VALVE		TB2
SUBT-	018	ASCO		HB8302C25U	VALVE		RX2
SUBT-	019	ASCO		8320A89	VALVE		RX2
SUBT-	023	BARKSDALE		12453	VALVE		RX2
SUBT-	024	COLLINS		SS409	TRANSMITTER		RX2
SUBT-	071	GENERAL ELECTRI		CR120A04222AA	RELAY		RX2
SUBT-	072	GENERAL ELECTRI		CR2940UM200AC	CONTROL SW		RX2
SUBT-	073	ITT GEN CONT'L		AH91	MOTOR		RX2
SUBT-	074	KAHN COMPANIES		3784-508	THERMOSTAT		TB2
SUBT-	078	KAHN COMPANIES		3784-512	VALVE		TB2
SUBT-	079	KAHN COMPANIES		3784-514	VALVE		TB2
SUBT-	080	KAHN COMPANIES		3784-515	CONTACTOR		TB2
SUBT-	081	KAHN COMPANIES		3784-520	SWITCH		TB2
SUBT-	082	KAHN COMPANIES		3784-521	SWITCH		TB2
SUBT-	083	KAHN COMPANIES		3784-522	VALVE		TB2
SUBT-	093	KIELEY MUELLER		467	AIR SET		RX2
SUBT-	101	HAGONE HAN		8003	CONTRACTOR		RX2

SUBT-	123	MOOG	72-101D	VALVE	TB2
SUBT-	129	PARKER HANNIFIN	D1W20HVY-10	VALVE	TB2
SURT-	131	PARKER HANNIFIN	3MD20UBHP-3B	VALVE	TB2
SUBT-	205	ASCO	8300C9U	VALVE	TB2
SUBT-	209	ASCO	8302C25F	VALVE	RX2
SUBT-	248	WESTINGHOUSE	AR440A	RELAY	TB2
SUBT-	261	AGASTAT	2412AE	RELAY	TB2
SUBT-	287	ROTORK	70A	VALVE ACTUATOR	RX2
SUBT-	305	GENERAL ELECTRI	HEA61A29J	RELAY	TB2
SUBT-	320	ROTORK	30A	VALVE ACTUATOR	TB2
SUBT-	390	VICKERS	DG5S4-042AT-21	VALVE	TB2
SUBT-	391	VICKERS	DG5S4-042AE-21	VALVE	TB2
SUBT-	400	ASCO	8316B16	VALVE	RX2
SUBT-	466	ASCO	830081U	VALVE	TB2
SUBT-	487	ITE	EF3-B015	STARTER	TB2
SUBT-	495	MOOG	72-102	VALVE	TB2
SUBT-	509	ITE	HE3A-100	CIRCUIT BREAKER	TB2
SUBT-	511	VICKERS	DG5S4-C42AWB-40	VALVE	RX2
SUBT-	512	LIMITORQUE	SMB-4T	VALVE ACTUATOR	TB2
SUBT-	513	VICKERS	DG5S4-042AT-30	VALVE	RX2
SUBT-	514	VICKERS	DG5S4-042AT-31	VALVE	RX2
SUBT-	515	HI TEMP	71M1002	THERMAL HOOD	RX2
SUBT-	516	HI TEMP	71M1001	THERMAL HOOD	RX2

00TEAM

POOR ORIGINAL

REV 213 15MAR80 PAGE 1
359/2, R/9, 1/6 10MAR80

SAFETY RELATED TAGGED COMPONENTS
(RESPONSE TO BULLETIN IF 79-016)

GENERAL ATOMIC COMPANY
REP80 BY SYSTEM

COMPONENT	SRH LUC	SRH LUC
.....	35	35
.....
HV- 2190-4	XX2	XX2
HV- 2190-5	XX2	XX2
HV- 2190-6	XX2	XX2
HV- 2190-7	XX2	XX2
HV- 2190-8	XX2	XX2
HV- 2190-9	XX2	XX2
HV- 2193	XX2	XX2
HV- 2194	XX2	XX2
LSL- 21113	XX2	XX2
PV- 21120	XX2	XX2
LI- 21121	XX2	XX2
LI- 21122	XX2	XX2
LI- 21123	XX2	XX2
LI- 21124	XX2	XX2
LI- 21129	XX2	XX2
LS- 21130	XX2	XX2
LV- 21130	XX2	XX2
LSH- 21132	XX2	XX2
FIS- 21137	XX2	XX2
FIS- 21138	XX2	XX2
FIS- 21139	XX2	XX2
FIS- 21140	XX2	XX2
POIS- 21149	XX2	XX2
POIS- 21150	XX2	XX2
POIS- 21151	XX2	XX2
POIS- 21152	XX2	XX2
POIS- 21153	XX2	XX2
POIS- 21154	XX2	XX2
POIS- 21155	XX2	XX2
POIS- 21156	XX2	XX2
POIS- 21157	XX2	XX2
POIS- 21158	XX2	XX2
POIS- 21159	XX2	XX2
POIS- 21160	XX2	XX2
POIS- 21173	XX2	XX2
POIS- 21174	XX2	XX2
POIS- 21175	XX2	XX2
POIS- 21176	XX2	XX2
POIS- 21177	XX2	XX2
POIS- 21178	XX2	XX2
POIS- 21179	XX2	XX2
POIS- 21180	XX2	XX2
POIS- 21181	XX2	XX2
POIS- 21182	XX2	XX2
POIS- 21183	XX2	XX2
POIS- 21184	XX2	XX2
XFP- 21185	XX2	XX2
HV- 21185	XX2	XX2
HV- 21186	XX2	XX2

COMPONENT	SRH LUC	SRH LUC
.....	35	35
.....
HSV- 2135-2	XX2	XX2
LSV- 2136	XX2	XX2
HSV- 2136-1	XX2	XX2
LSV- 2136-1	XX2	XX2
HSV- 2136-2	XX2	XX2
LV- 2137	XX2	XX2
LSL- 2137	XX2	XX2
LV- 2138	XX2	XX2
LSL- 2138	XX2	XX2
POIS- 2155	XX2	XX2
POIS- 2156	XX2	XX2
XEP- 2175	XX2	XX2
XEP- 2176	XX2	XX2
XEP- 2177	XX2	XX2
XEP- 2178	XX2	XX2
FIS- 2183	XX2	XX2
FIS- 2184	XX2	XX2
FIS- 2185	XX2	XX2
FIS- 2186	XX2	XX2
HV- 2187-1	XX2	XX2
HV- 2187-2	XX2	XX2
HV- 2187-3	XX2	XX2
HV- 2187-4	XX2	XX2
HV- 2187-5	XX2	XX2
HV- 2187-6	XX2	XX2
HV- 2187-7	XX2	XX2
HV- 2187-8	XX2	XX2
HV- 2187-9	XX2	XX2
HV- 2188-1	XX2	XX2
HV- 2188-2	XX2	XX2
HV- 2188-3	XX2	XX2
HV- 2188-4	XX2	XX2
HV- 2188-5	XX2	XX2
HV- 2188-6	XX2	XX2
HV- 2188-7	XX2	XX2
HV- 2188-8	XX2	XX2
HV- 2188-9	XX2	XX2
HV- 2189-1	XX2	XX2
HV- 2189-2	XX2	XX2
HV- 2189-3	XX2	XX2
HV- 2189-4	XX2	XX2
HV- 2189-5	XX2	XX2
HV- 2189-6	XX2	XX2
HV- 2189-7	XX2	XX2
HV- 2189-8	XX2	XX2
HV- 2189-9	XX2	XX2
HV- 2190-1	XX2	XX2
HV- 2190-2	XX2	XX2
HV- 2190-3	XX2	XX2

COMPONENT	SRH LUC	SRH LUC
.....	35	35
.....
PSH- 11177	XX2	XX2
PSH- 11178	XX2	XX2
PSH- 11179	XX2	XX2
PSH- 11180	XX2	XX2
PSH- 11181	XX2	XX2
PSH- 11182	XX2	XX2
PSH- 11183	XX2	XX2
PSH- 11184	XX2	XX2
PSH- 11185	XX2	XX2
PSH- 11186	XX2	XX2
PSH- 11187	XX2	XX2
PSH- 11188	XX2	XX2
P- 2101-S	XX2	XX2
P- 2102	XX2	XX2
P- 2102-S	XX2	XX2
P- 2103	XX2	XX2
P- 2103-S	XX2	XX2
SV- 2105	XX2	XX2
ZS- 2105	XX2	XX2
P- 2106	XX2	XX2
SV- 2106	XX2	XX2
ZS- 2106	XX2	XX2
P- 2107	XX2	XX2
P- 2108	XX2	XX2
SV- 2109	XX2	XX2
HV- 2109-1	XX2	XX2
HV- 2109-2	XX2	XX2
ZS- 2109-2	XX2	XX2
P- 2110	XX2	XX2
SV- 2110	XX2	XX2
HV- 2110-1	XX2	XX2
HV- 2110-2	XX2	XX2
ZS- 2110-2	XX2	XX2
SV- 2111	XX2	XX2
ZS- 2111	XX2	XX2
SV- 2112	XX2	XX2
ZS- 2112	XX2	XX2
SV- 2115	XX2	XX2
HV- 2115-1	XX2	XX2
HV- 2115-2	XX2	XX2
ZS- 2115-2	XX2	XX2
SV- 2116	XX2	XX2
HV- 2116-1	XX2	XX2
HV- 2116-2	XX2	XX2
ZS- 2116-2	XX2	XX2
SV- 2135	XX2	XX2
LSV- 2135-1	XX2	XX2
LSV- 2135-1	XX2	XX2

COMPONENT 1	SRR LIC 35	COMPONENT 1	SRR LIC 35	COMPONENT 1	SRR LIC 35
xEP- 21186	RX2	HV- 21416-1	RX2	PSL- 2231	1B2
HV- 21187	RX2	ZS- 21416-1	RX2	PSL- 2233	1B2
xEP- 21187	RX2	HV- 21416-2	RX2	PSL- 2235	1B2
HV- 21188	RX2	FT- 21425	RX2	HV- 2237	1B2
xEP- 21188	RX2	FT- 21426	RX2	HV- 2238	1B2
HV- 21213	RX2	FT- 21427	RX2	FT- 2239	RX2
HV- 21214	RX2	FT- 21428	RX2	FV- 2239	RX2
HV- 21257	RX2	HV- 2201	1B2	xEP- 2239	RX2
HV- 21258	RX2	ZS- 2201	1B2	FT- 2240	RX2
HV- 21259	RX2	HV- 2202	1B2	FV- 2240	RX2
HV- 21260	RX2	ZS- 2202	1B2	xEP- 2240	RX2
PT- 21285	RX2	HV- 2203	1B2	HV- 2241	RX2
PDT- 21285-1	RX2	ZS- 2203	1B2	HV- 2242	RX2
xEP- 21285-1	RX2	HV- 2204	1B2	PV- 2243	RX2
PDT- 21285-2	RX2	ZS- 2204	1B2	PV- 2244	RX2
xEP- 21285-2	RX2	FT- 2205	1B2	HV- 2249	RX2
PT- 21286	RX2	FV- 2205	1B2	ZS- 2249	RX2
PDT- 21286-1	RX2	FT- 2206	1B2	HV- 2250	RX2
xEP- 21286-1	RX2	FV- 2206	1B2	ZS- 2250	RX2
PDT- 21286-2	RX2	FT- 2209	1B2	HV- 2251	RX2
xEP- 21286-2	RX2	FT- 2210	1B2	ZS- 2251	RX2
FV- 21297	RX2	FT- 2211	1B2	HV- 2252	RX2
FSL- 21297	RX2	FT- 2212	1B2	ZS- 2252	RX2
FV- 21298	RX2	FT- 2213	1B2	HV- 2253	1B2
FSL- 21298	RX2	FT- 2214	1B2	HV- 2254	1B2
PDIS- 21319	RX2	HV- 2215	RX2	HV- 2265	1B2
PDIS- 21320	RX2	ZS- 2215	RX2	HV- 2266	1B2
PDIS- 21321	RX2	HV- 2216	RX2	PT- 2267	1B2
PDIS- 21322	RX2	ZS- 2216	RX2	xEP- 2267	1B2
PDIS- 21323	RX2	HV- 2217	RX2	PT- 2268	1B2
PDIS- 21324	RX2	ZS- 2217	RX2	PV- 2268	1B2
PDIS- 21325	RX2	HV- 2218	RX2	PSL- 2269	1B2
PDIS- 21326	RX2	ZS- 2218	RX2	PSL- 2271	1B2
PDIS- 21327	RX2	HV- 2223	1B2	PSL- 2273	1B2
PDIS- 21328	RX2	HV- 2224	1B2	HV- 2290	RX2
PDIS- 21329	RX2	TE- 2225-1	RX2	ZS- 2290	RX2
PDIS- 21330	RX2	TE- 2225-2	RX2	HV- 2291	RX2
PDIS- 21393	RX2	TE- 2225-3	RX2	ZS- 2291	RX2
PDIS- 21395	RX2	TE- 2225-4	RX2	HV- 2292	1B2
PDIS- 21396	RX2	TE- 2225-5	RX2	HV- 2293	1B2
PDIS- 21397	RX2	TE- 2225-6	RX2	ZS- 22115	RX2
PDIS- 21398	RX2	TE- 2226-1	RX2	ZS- 22116	RX2
PDT- 21411	RX2	TE- 2226-2	RX2	ZS- 22117	RX2
PDT- 21412	1B2	TE- 2226-3	RX2	ZS- 22118	RX2
PDT- 21413	RX2	TE- 2226-4	RX2	PV- 22129	1B2
PDT- 21414	1B2	TE- 2226-5	RX2	xEP- 22129	1B2
HV- 21415-1	RX2	TE- 2226-6	RX2	PT- 22129-1	1B2
ZS- 21415-1	RX2	PV- 2229	1B2	xEP- 22129-1	1B2
HV- 21415-2	RX2	PV- 2230	1B2	PV- 22130	1B2

REV213 1VMARBU PAGE 3
359/2,R/9,1/6 19MARBU

SAFETY RELATED TAGGED COMPONENTS
(RESPONSE TO BULLETIN IE 79-01H)

GENERAL ATOMIC COMPANY
REPSO BY SYSTEM

COMPONENT	SRB	LUC
1	35	35
N- 9219	TR2	
N- 9220	TR2	
N- 9231	TR2	
I- 9321-A	TR2	
I- 9321-B	TR2	
I- 9321-C	TR2	
I- 9321-D	TR2	
I- 9354	TR2	
I- 9355	TR2	
I- 9371	TR2	
I- 93123	TR2	
I- 93124	TR2	
I- 93125	TR2	
I- 93126	TR2	
I- 93127	TR2	
I- 93128	TR2	
I- 93129	TR2	
PDSH- 93129	TR2	
I- 93130	TR2	
PDSH- 93130	TR2	
I- 93131	TR2	
PDSH- 93131	TR2	
I- 93132	TR2	
PDSH- 93132	TR2	
I- 93133	TR2	
PDSH- 93133	TR2	
I- 93134	TR2	
PDSH- 93134	TR2	
I- 93135	TR2	
I- 93136	TR2	
I- 93137	TR2	
I- 93138	TR2	
I- 93139	TR2	
I- 93140	TR2	
I- 93141	TR2	
I- 93142	TR2	
I- 93143	TR2	
TSH- 93444	TR2	
TSH- 93449	TR2	
TSH- 93450	TR2	
TSH- 93451	TR2	
TSH- 93452	TR2	
TSH- 93453	TR2	
XE- 93454-A	TR2	
XE- 93454-B	TR2	
XE- 93454-C	TR2	
XE- 93455-A	TR2	
XE- 93455-B	TR2	
XE- 93455-C	TR2	

COMPONENT	SRB	LUC
1	35	35
PSL- 3123	TR2	
PSL- 3124	TR2	
PSL- 3125	TR2	
HV- 4225	TR2	
HV- 4257	TR2	
PS- 4266	TR2	
HSV- 4266	TR2	
TE- 4637-3	TR2	
TE- 4638-3	TR2	
C- 8201	TR2	
S- 8201	TR2	
C- 8201-S	TR2	
S- 8202	TR2	
C- 8203	TR2	
PS- 8207	TR2	
PS- 8208	TR2	
TS- 8208	TR2	
PS- 8214	TR2	
TS- 8214	TR2	
TS- 8218	TR2	
TS- 8219	TR2	
PS- 8221	TR2	
PS- 8222	TR2	
TS- 8236	TR2	
TS- 8237	TR2	
PS- 8244	TR2	
TS- 8245	TR2	
TS- 8246	TR2	
PS- 8247	TR2	
PS- 8248	TR2	
TS- 8249	TR2	
PS- 8258-1	TR2	
PS- 8258-2	TR2	
HS- 9101-2	TR2	
P- 9101-SX	TR2	
P- 9101-X	TR2	
HS- 9102-2	TR2	
P- 9102-SX	TR2	
P- 9102-X	TR2	
HS- 9103-2	TR2	
HS- 9104-2	TR2	
P- 9105-X	TR2	
P- 9106-X	TR2	
LSL- 91147	TR2	
LSL- 91148	TR2	
N- 9208	TR2	

COMPONENT	SRB	LUC
1	35	35
XEP- 22130	TR2	
PT- 22130-1	TR2	
XEP- 22130-1	TR2	
HV- 22131	TR2	
HV- 22132	TR2	
HV- 22133	TR2	
HV- 22134	TR2	
TE- 22135	TR2	
TE- 22136	TR2	
TE- 22137	TR2	
TE- 22138	TR2	
TE- 22139	TR2	
TE- 22140	TR2	
TE- 22142	TR2	
TE- 22143	TR2	
TE- 22146	TR2	
PV- 22153	TR2	
XEP- 22153-1	TR2	
XEP- 22154	TR2	
PV- 22154	TR2	
XEP- 22154-1	TR2	
PSH- 22197	TR2	
PSH- 22198	TR2	
HV- 22200	TR2	
HV- 22201	TR2	
HV- 22202	TR2	
HV- 22203	TR2	
HV- 22204	TR2	
HV- 22205	TR2	
HV- 22206	TR2	
HV- 22207	TR2	
HV- 22208	TR2	
HV- 22209	TR2	
HV- 22210	TR2	
HV- 22211	TR2	
HV- 22212	TR2	
HV- 22213	TR2	
HV- 22221	TR2	
HV- 22222	TR2	
HV- 22223	TR2	
HV- 22224	TR2	
HV- 22225	TR2	
HV- 22226	TR2	
HV- 22227	TR2	
HV- 22228	TR2	
HV- 2366-1	TR2	
HV- 2366-2	TR2	

COMPONENT	SRH
1	35
.....
XE- 93456-A	RX2
XE- 93456-H	RX2
XE- 93456-C	RX2
XE- 93457-A	RX2
XE- 93457-H	RX2
XE- 93457-C	RX2
XE- 93470-A	RX2
XE- 93470-H	RX2
XE- 93470-C	RX2
XE- 93471-A	RX2
XE- 93471-B	RX2
XE- 93471-C	RX2
TE- 93472	RX2
TE- 93473	RX2
TE- 93474	RX2
XE- 93479-A	RX2
XE- 93479-H	RX2
XE- 93479-C	RX2
XE- 93480-A	RX2
XE- 93480-H	RX2
XE- 93480-C	RX2

COMPONENT	SRH
1	35
.....

COMPONENT	SRH
1	35
.....

ALPHA PREFIXES

<u>Designation</u>	<u>Description</u>
A	Absorbers, Traps and Demineralizers
C	Compressors, Blowers, Vacuum Pumps, Fans Including Drives
E	Exchangers, Cooling Towers
F	Filters, Strainers, and Dryers
I	Instrument and/or Control Racks and Panels
N	Electrical Power/Control Cabinets
P	Pumps and Drives
S	Special Packaged Items
T	Tanks and Vessels
FV	Flow Valve
FT	Flow Transmitter
HS	Hand Switch
HV	Hand Valve
LS	Level Switch
LT	Level Transmitter
LV	Level Valve
PS	Pressure Switch
PT	Pressure Transmitter
PV	Pressure Valve
SV	Speed Valve
TS	Temperature Switch
XE	Special Element (Steamline Rupture Sensor)
ZS	Position Switch
FIS	Flow Indicating Switch
FSL	Flow Switch Low
HS	Hand Solenoid Valve
LSH	Level Switch High
LSL	Level Switch Low
LSV	Level Solenoid Valve
PDT	Pressure Differential Transmitter
PSH	Pressure Switch High
PSL	Pressure Switch Low
TSH	Temperature Switch High
XEP	Special Electrical Pneumatic Transducer
PDIS	Pressure Differential Indicating Switch
PDSH	Pressure Differential Switch High

SYSTEM NUMBERS

<u>System</u>	<u>Description</u>
11	Reactor Vessel and Internal Components
21	Primary Coolant System
22	Secondary Coolant System
23	Helium Purification System
31	Feedwater and Condensate
42	Service Water System
46	Reactor Plant Cooling Water System
82	Instrument and Service Air
91	Piping-Hydraulic Oil System
92	Electrical-Including Switchgear and Standby Diesel Generator
93	Control and Instrumentation

Section 2.1.6.b -- Design Review of Plant Shielding and Environmental Qualification of Equipment for Spaces/Systems Which May Be Used In Post-Accident Operations

PSC December 12, 1979 (P-79299) REPLY:

"PSC will perform the radiation protection design reviews required by Section 2.1.6.b, utilizing the source terms recommended in Regulatory Guides 1.3, 1.4, and 1.7, and will submit the results of the review to the NRC by January 1, 1980. Where doses received are in excess of GDC 19 guidelines, PSC will take those steps necessary to permit post-accident operations in vital areas. Any required modifications will be completed by January 1, 1981."

PSC December 27, 1979 (P-79312) SUBMITTAL:

The assessment of post-accident operator actions in vital areas at Fort St. Vrain (FSV) indicates that doses received from a hypothetical FSV accident scenario will not be in excess of the GDC 19 guidelines for the duration of the accident, provided the FSV reactor plant exhaust filters are adequately shielded.

PSC hereby commits to providing necessary shielding modifications to the FSV reactor plant exhaust filters by January 1, 1981 to permit operator access to vital areas under accident conditions.

The hypothetical Fort St. Vrain (FSV) accident scenario consists of the FSV Design Basis Accident (DBA) #1 combined with successive PCRV primary coolant leakage after depressurization. For clarification, the DBA #1 and PCRV leakage scenarios are explained below.

DISCUSSION:

To obtain a post-accident release of radioactivity equivalent to that described in Regulatory Guides 1.3, 1.4 and 1.7 requires a permanent loss of all forced circulation for the FSV HTGR. This specific accident was identified as DBA #1 in FSAR Section 14.10 and Appendix D. These analyses performed by General Atomic Company at the time of licensing did not consider Regulatory Guides 1.3 and 1.4 source terms (i.e., the equivalent of the 50% of the core radioiodine and 100% of the core noble gas inventory for release to the primary coolant) appropriate for the HTGR. However, because of past precedence by the then Atomic Energy Commission (AEC) of using the above source terms, offsite doses resulting from the postulated accident were calculated and presented in the previously mentioned FSAR sections using both the General Atomic Company release assumptions and AEC TID-14844 release assumptions. In both cases the offsite doses are within 10CFR100 limits.

DBA #1 Description:

A non-mechanistic loss of forced circulation is postulated from full power operation, where the reactor is scrammed by the plant protection system and all attempts to restore forced circulation using the multiple heat sinks, circulators and motive power for the circulators fail. Because of the large heat sink provided by the graphite core, considerable time is available to initiate primary coolant depressurization and to restore forced circulation. The FSV FSAR specifies the time available to initiate depressurization to be 5 hours, which was later amended by PSC letter P-77250 dated December 22, 1977 to be 2 hours. The reduction in time was due to the capability of the helium purification system to process primary coolant during the planned blowdown of the clean primary coolant to the reactor building ventilation stack. Thus, the depressurization of the PCRV is initiated after 2 hours and completed 7 hours later (or 9 hours from the onset of the accident), at which time the PCRV has been depressurized to 5 psig.

The fuel is slow to heat up due to the large heat sink provided by the core graphite. A peak average active core temperature of 5400°F is reached about 80 hours after the onset of the accident. At this temperature, the core structural integrity and geometry are not compromised since the vaporization temperature of graphite is 6900°F. Peak activity released to the primary coolant, considering decay, is reached about 24 hours into the accident.

Heat removal is provided by the liner cooling system in the redistribute mode which maximizes cooling in the top head of the PCRV.

Leakage of primary coolant from the PCRV is assumed to occur at a conservatively high leakage rate of 0.2% of the primary coolant inventory per day.

Offsite doses were calculated for a 6 month duration of the accident, but most of the offsite dose occurs in the first 200 hours of the accident, due to fission product decay.

The reactor building ventilation system maintains continuous venting of the reactor building environment at 1.5 volumes/hr during the entire period of the accident.

Primary Coolant Leakage Rate During DBA #1:

The FSV FSAR DBA #1 (Appendix D, page D.1-56) assumed an arbitrarily conservative and non-mechanistic estimate of PCRV leakage after the intentional depressurization by assuming that the liner has failed completely (or does not exist) and only concrete permeability controls the leakage. An internal 5 psi pressure differential was assumed which purportedly gave a PCRV leak rate of 8.33×10^{-5} fraction per hr (0.2%/day). Reference was made to Question IX.7 of Amendment No. 9 of the FSV FSAR for the calculation of the permeation rate for the FSV PCRV concrete under these conditions.

Examination of Question D.2 revealed simply the conclusion that a 5 psi positive differential pressure led to 0.2%/day and 2 psi positive differential pressure led to 0.08%/day. Question IX.7 also did not provide details of the calculation of the 0.2%/day rate. However, considerable

detail and a derivation was provided for the analysis of leakage rate tests at high pressures. The following equation was provided (eqn.14 on page IX.7-8):

$$W \text{ (lb/day)} = 1.13 \times 10^{-5} \frac{\Delta P}{\Delta P_c} \frac{A}{X} \ln\left(\frac{P_1}{P_2}\right) + 2.2 \times 10^{-6} \frac{\Delta P}{\Delta P_c} \frac{A}{X} (P_1^2 - P_2^2) \quad (\text{eqn. 14})$$

- Where ΔP = PCRV inside pressure in psig
 ΔP_c = PCRV inside pressure in psig for which the net compressive stress in concrete = 0
 A = Face area of concrete, ft²
 X = Concrete thickness, ft
 P_1 = Permeation or high side pressure, psia
 P_2 = Ambient or low side pressure, psia

Numerical values were inserted for $P_1 = 845$ psig with the assumption that ΔP_c was approximately equal to P_1 in the following equation (eqn.15 on same page):

$$W = 1.13 \times 10^{-5} \times \frac{9000}{10} \ln \frac{857.5}{12.5} + 9.1 \times 10^{-7} \frac{9000}{10} (857.5^2 - 12.5^2) = 0.043 + 602 = 600 \text{ lb/day} \quad (\text{eqn. 15})$$

The first item to note is that the coefficient for the second (laminar flow) term is in error which is most likely a single error in transcribing from equation 14 to 15 since equation 13 has the 9.1×10^{-7} coefficient. Equation 15 should read:

$$W = 1.13 \times 10^{-5} \times \frac{9000}{10} \ln \frac{857.5}{12.5} + 2.2 \times 10^{-6} \frac{9000}{10} (857.5^2 - 12.5^2) = 0.043 + 1445 = 1450 \text{ lb/day} \quad (\text{eqn. 15 revised})$$

The second item is that the $\Delta P/\Delta P_c$ term has been dropped in going from eqn.14 to eqn.15, which is significant if it is assumed that these equations are appropriate for evaluating the leak rate at $P_1 = 5$ psig.

LEAK RATE

Pressure P ₁ (psig)	lb/day			% / day			Given
	Eqn 14	15	15 Revised	14	15	15 revised	
5	.0019	.13	.30	.001	.07	.17	.20
2	.0003	.046	.107	.0001	.025	.059	.08

App D;
Amend 9
Question
0.2

Amend 9
Question
0.2

Since equation 14 is the appropriate equation, the 0.2%/day leak rate is conservative by a factor of 200. Furthermore, the only equation that comes close to the values given in the SAR is 15 Revised, that is, $\Delta P/\Delta P_0$ has been neglected which accounts for the factor of 200.

For purposes of plant shielding and equipment environmental evaluations, the historic 0.2%/day is assumed to exist as an upper limit of all potential contaminated primary coolant leakage including permeability through the PCRV concrete. This is judged to be conservative since the primary coolant with any significant activity is contained within the PCRV or helium purification components contained in wells within the PCRV.

Radionuclide Source Terms for DBA-1:

As previously stated, the fuel within the graphite core is slow to heatup during DBA#1. Once it has reached the FSAR fuel particle coating failure temperature of 1725°C (3137°F), the fission products are assumed, for purposes of this shielding evaluation, to be released per the TIC-14844 assumptions. For release to the primary coolant within the PCRV, this is 100% of noble gases, 50% of the iodines and 1% others. The total activity in curies contained in the primary coolant, assuming no leakage from the PCRV, as a function of lapsed time, is given in Table 2.1.6.b-1.

Consistent with TIC-14844 release assumptions, 50% of the iodines plateout within the primary coolant system resulting in a depletion of the iodine to 25% of core inventory in the reactor building air. Thus, the total activity in curies in the reactor building, assuming the upper limit of 0.2%/day leakage (which is being purged by the reactor building ventilation system at the rate 1.5 volumes/hr), is given in Table 2.1.6.b-2.

TABLE 2.1.6.L-1

HUREG-0578 STUDY TOTAL ACTIVITY (C1) PRESENT IN THE PCRV PRIMARY COOLANT AT GIVEN ELAPSED TIME (hours). PCRV PRESSURE BOUNDARY REMAINS INTACT. TID-14844 NORMALIZATION FRACTIONS USED, 100% NOBLE GASES, 50% IODINE 1% OTHERS

ISOTOPE	ELAPSED TIME (Hours)													
	2	8	24	34	40	48	52	58	72	120	240	475	720	4320
-88	1.05104	2.89105	2.80105	2.39104	5.89103	1.37103	5.50102	1.76102	7.04101	0	0	0	0	0
-88	8.57103	2.79105	2.80105	2.66104	6.51103	1.46103	6.07102	1.89102	7.08101	0	0	0	0	0
-95	3.15101	6.66103	1.84105	2.57105	3.01105	3.59105	3.69105	3.84105	4.18105	4.12105	3.88105	3.43105	3.02105	4.6010
-95	3.18101	6.74103	1.87105	2.63105	3.09105	3.69105	3.80105	3.97105	4.35105	4.37105	4.31105	4.12105	3.88105	8.9010
-131	1.33103	3.50105	6.18106	6.91106	7.33106	7.88106	7.90106	7.93106	7.98106	7.57106	4.89106	2.07106	8.45105	0
-132	1.44103	2.34105	1.79106	6.09105	5.64105	5.61105	3.68105	2.96105	2.72105	1.76105	4.02104	4.99103	5.46102	0
-133	2.48103	5.30105	6.44106	5.25106	4.70106	4.12106	3.65106	3.05106	2.04106	4.84105	8.81103	0	0	0
-133	5.25103	1.40106	2.50107	2.78107	2.94107	3.14107	3.14107	3.12107	3.09107	2.73107	1.41107	3.86106	9.90105	0
-135	1.98103	2.46105	1.40106	5.49105	3.31105	1.88105	1.25105	6.83104	1.78104	2.94102	0	0	0	0
-135M	7.28102	8.34104	4.59105	1.72105	1.04105	5.97104	3.91104	2.14104	5.58103	0	0	0	0	0
-135	1.75103	5.43105	6.24106	3.86106	2.93106	2.11106	1.62106	1.08106	4.39105	1.81104	0	0	0	0
-140	5.44101	1.44104	2.58105	2.92105	3.13105	3.39105	3.42105	3.45105	3.54105	3.57105	2.70105	1.56105	8.80104	0
-140	3.34101	7.37103	2.01105	2.60105	2.93105	3.36105	3.43105	3.54105	3.75105	3.96105	3.10105	1.80105	1.01105	0

TABLE 2.1.6.b-2

NUREG-0578 STUDY TOTAL ACTIVITY (C1) PRESENT IN THE REACTOR BUILDING ATMOSPHERE AT GIVEN ELAPSED TIME (hours). PCRV LEAK RATE TO BUILDING 0.2%/DAY. REACTOR BUILDING VENTED AT 1.5 VOLUMES/HR. TID-14844 NORMALIZED FRACTIONS USED, 100% NOBLE GASES, 25% IODINE, 1% OTHERS

SLIDE	ELAPSED TIME (Hours)													
	2	8	24	34	40	48	52	58	72	120	240	475	720	4320
88	3.77-01	1.31+01	1.33+01	1.32+00	3.22-01	7.10-02	3.00-02	9.23-03	3.38-03	0	0	0	0	0
88	3.55-01	1.37+01	1.42+01	1.48+00	3.58-01	7.77-02	3.34-02	1.02-02	3.61-03	0	0	0	0	0
95	1.20-03	3.29-01	9.81+00	1.40+01	1.64+01	1.97+01	2.04+01	2.12+01	2.31+01	2.29+01	2.16+01	1.91+01	1.68+01	2.56+00
95	1.21-03	3.33-01	9.98+00	1.43+01	1.69+01	2.02+01	2.10+01	2.19+01	2.41+01	2.43+01	2.39+01	2.29+01	2.16+01	4.94+00
31	2.52-02	8.64+00	1.65+02	1.90+02	2.02+02	2.17+02	2.19+02	2.20+02	2.21+02	2.10+02	1.36+02	5.76+01	2.35+01	0
32	2.57-02	5.24+00	4.24+01	1.58+01	1.46+01	1.46+01	1.05+01	8.46+00	7.75+00	5.14+00	1.30+00	1.61-01	1.77-02	0
33	4.68-02	1.30+01	1.70+02	1.44+02	1.29+02	1.13+02	1.01+02	8.45+01	5.65+01	1.34+01	2.45-01	0	0	0
133	1.99-01	6.94+01	1.34+03	1.54+03	1.63+03	1.75+03	1.75+03	1.75+03	1.75+03	1.52+03	7.85+02	2.14+02	5.50+01	0
35	3.68-02	5.89+00	3.60+01	1.51+01	9.05+00	5.09+00	3.47+00	1.89+00	4.89-01	0	0	0	0	0
135M	3.14-02	7.71+00	8.59+01	7.38+01	5.53+01	3.53+01	2.75+01	1.81+01	6.20+00	1.07-01	0	0	0	0
135	6.75-02	2.73+01	3.40+02	2.26+02	1.72+02	1.22+02	9.56+01	6.40+01	2.56+01	1.01+00	0	0	0	0
140	2.06-03	7.12-01	1.38+01	1.61+01	1.72+01	1.87+01	1.89+01	1.91+01	1.96+01	1.98+01	1.50+01	8.67+00	4.89+00	0
140	1.27-03	3.66-01	1.08+01	1.43+01	1.61+01	1.85+01	1.90+01	1.96+01	2.08+01	2.20+01	1.72+01	9.98+00	5.62+00	0

Radiation Levels During DBA-1:

Based upon TID-14844 source term release assumptions, the radiation levels were calculated in the reactor building and the control room to determine the operator accessibility. Details are described herein.

Assumptions

In addition to the assumptions used in deriving the source terms, the following assumptions were made for evaluating shielding adequacy:

1. Credit was taken for a 50% depletion of the iodines due to plateout in the primary coolant system prior to release to the reactor building atmosphere.
2. All fission products were assumed to remain gasborne. In other words, no plateout of fission products was contemplated.
3. All the activities were uniformly distributed throughout the free space of the reactor building or the PCRV.
4. The iodines and particulates removed by the reactor-building ventilation filters were deposited in any two of the three filters available.
5. Only major shielding such as concrete walls was considered.

Reactor Building

To determine the accessibility of the reactor building during the course of DBA-1, the gamma dose rate in the reactor building was calculated as a function of elapsed time. The contributing sources consist of the gasborne activity in the reactor building as a result of PCRV leakage, the primary coolant activity contained in the PCRV, and the buildup of iodines and particulates on the reactor building ventilation HEPA and charcoal adsorbers. The contribution from the ventilation filters was not considered, as the filters will be properly shielded.

Two dose points were selected for the dose-rate calculation. The first point is located at the center of the space above the refueling floor (= 40 ft from the floor), and the second point is on the refueling floor directly above the refueling penetration. The PATH code described in FSAR Section 11.2.2.4 was utilized to perform the calculation.

Figure 1 shows the dose rate at the first dose point. Essentially all the contributions come from the gasborne activity in the reactor building. The activity in the PCRV is relatively insignificant to the first dose point, because of a large separation distance between the source and dose point. Short-term access to the reactor building is possible.

The dose rate at the second dose point (i.e., on the refueling floor) is given in Figure 2. The contributions from the reactor building and from the PCRV are individually represented, along with the total dose rate. The contribution from the PCRV is due to the primary coolant activity present in the interspace below the primary closure for the control rod drive. The maximum dose rate on the floor is 1.0 rem/hr, which is less than the peak dose rate of 1.4 rem/hr at the first dose point. Therefore, the refueling floor is accessible on a short-term basis.

Control Room

The dose rates in the control room include the contributions from the airborne activity in the reactor building atmosphere, and from the iodine and particulate activity accumulated in the plant ventilation filters. The PATH code was used to determine the contribution from each source as a function of time into accident. The dose point was located in the reactor engineer's office, as shown in Figure 3.

The results of the PATH calculations are shown in Figure 3 as a function of elapsed time. It is apparent that the contribution from the airborne activity in the reactor building is relatively small or negligible as compared with that from the reactor building ventilation filters. The dose rate reaches a peak of 700 mrem/hr about one month into accident. The important nuclides are Zr95, Nb95 and La140 accumulated in the filters.

The dose rate in the control room appears to be excessive for continuous manned access. Adequate shielding will be provided for the ventilation filters so that the dose rate from the filters can be reduced to an acceptable level.

Summary Results

The peak dose rates in the reactor building and control room are summarized below. Also indicated are the time at which the peak dose rate occurs following an accident, and the total dose accumulated over a period of 180 days from the initiation of the accident.

<u>Location & Condition</u>	<u>Peak Gamma Dose Rate</u>	<u>Time of Peak</u>	<u>180 Day Accumulated Dose (rem)</u>
Reactor Building (above refueling floor)	1.4 R/hr	24 hrs.	400
Control Room			
From Vent Filters (Unshielded)	700 mR/hr	≈ 720 hrs.	2400
From Reactor Building	3 mR/hr	24 hrs.	0.9

Conclusion

The following conclusions are reached from the review of shielding design adequacy for DBA-1 conditions and TID-14844 source term release assumptions:

1. The reactor building ventilation filters will be adequately shielded to reduce the dosage contribution from the filters.
2. Areas immediately outside the reactor building should be accessible only on a restricted basis, because of direct radiation from the activity in the reactor building.

POOR ORIGINAL

FIG. 1 - RADIATION LEVELS IN REACTOR BUILDING
- DURING DBA-1





FIG. 2 - RADIATION LEVELS ON REFUELING FLOOR DURING DBA-1



POOR ORIGINAL

ELAPSED TIME (HR)

POOR ORIGINAL

FIG. 3 RADIATION LEVELS IN CONTROL ROOM DURING DBA-1

