

CONTROL BLOCK:

--	--	--	--	--	--	--

1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	LICENSE NUMBER										25	LICENSE TYPE					30	57 CAT 58				

CON'T

REPORT SOURCE 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

0 1 5 0 5 0 - 0 3 2 5 7 0 4 0 7 8 0 8 0 5 0 2 8 0 9

PACKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | While performing PT 1.1.4PC, "Reactor Low Water Level #1 Channel Calibration,"

03 | switch 1 of 1-B21-LIS-N017B&C was out of tolerance. The N017B&C reportable value

04 | is >59.1" applied water. The N017B as-found value was 61" applied water, while

05 | N017C as-found value was 65.2" applied water. The health and safety of the general

06 | public was not endangered by this event.

07

08 | Technical Specifications 2.2.1, 6.9.1.9a

7 8 9

0 9

SYSTEM CODE I A 11

CAUSE CODE X 12

CAUSE SUBCODE Z 13

COMPONENT CODE I N S T R U 14

COMP SUBCODE E 15

VALVE SUBCODE Z 16

(17) LER/RO REPORT NUMBER 8 0 —

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

[E] (18) [X] (19) [Z] (20) [Z] (21) [0] [0] [0] [0] [N] (23) [Y] (24) [N] (25) [B] [0] [8] [0]

33 34 35 36 37 40 41 42 43 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The cause was determined to be instrument drift. Both instruments were calibrated

and returned to service. A plant modification has been written to replace these

			instruments with more reliable instrumentation during or before the 1981 refueling
--	--	--	--

1 2 | outage.

1	3
---	---

8 9 FACILITY STATUS 1 5 E 28 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 OTHER STATUS N/A 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Periodic Test 32

ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1	6	2	(33)	2	(34)
				N/A	N/A

PERSONNEL EXPOSURES									
NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	(37) 2	(38) N/A			(39)

7	8	9	11	12	13	90
PERSONNEL INJURIES						
NUMBER		DESCRIPTION				(41)

7 8 9 10 11 12 N/A

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE		DESCRIPTION
1	9	Z (42) N/A

PUBLICITY		ISSUED		DESCRIPTION		NRC USE ONLY	
2	0	N	44	N/A			
7	8	9	10			68	69

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521