



8005140210

"Double-Seal"
BALL VALVES

WAFER-SPHERE
BUTTERFLY VALVES

PNEUMATIC and ELECTRIC
ACTUATORS

April 18, 1980

Mr. B. H. Grier, Director Region I
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406

ZM031111E

Subject: 10 CFR 21 - Reporting of Defects and
Noncompliance

Dear Mr. Grier:

Jamesbury Corp. was informed on April 16, 1980 by Mr. E. B. Poser of Bechtel Corp. that the ASME Code Class 2, 3" 8226 EX Model A Wafer-sphere valve, Serial number NC 40000-01-C returned by them to Jamesbury as a result of leakage thru one of the flange bolt holes is considered to be a defect as defined by 10 CFR-21. Jamesbury will review this situation with Bechtel Corp., and in addition will review all other orders that have been shipped that may have contained 3" 8226 EX Wafer-sphere valves.

Our notification via this letter, we believe, comply with the letter and intent of 10 CFR 21.

Very truly yours,

JAMESBURY CORP.

F. W. Kreuzinger
Quality Assurance Manager

FWK:hp

cc: Mr. E. Volgenau, Director
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. E. B. Poser and Mr. Shortt
Bechtel Corp.
P.O. Box 3965

San Francisco, Ca. 94119

ATTACHED IS A PART 21 REPORT FROM IE MAIL UNIT - ROOM 359E/W

TIC

PART 21 IDENTIFICATION NO. 80-212-000 COMPANY NAME Jamebury Corp

DATE OF LETTER 4/25/80 DOCKET NO. _____

DATE DISTRIBUTED 5/1/80 ORIGINAL REPORT SUPPLEMENTARY

DISTRIBUTION:

REACTOR(R)

FUEL CYCLE &

SAFEGUARDS(S)

MATERIALS(M)

NRR/DOR, DIRECTOR

AD/FFMSI

AD/SG-IE

NRR/DPM DIRECTOR

NMSS/FCMS

AD/ROI

AD/ROI (2)

REGIONS

REGIONS

AD/RCI

IE FILES

NRR/DOR, DIRECTOR

REGIONS

PDR

NMSS/SG SS-881

IE FILES (2)

LPDR

PDR

CENTRAL FILES ✓

CENTRAL FILES-SS-396

LPDR

CENTRAL FILES (CHRON)

CENTRAL FILES(CHRON)
(016)

TERA

PDR

TERA

IE FILES (2)

LPDR

LOEB/MPA MNB 5715

CENTRAL FILES 016

TERA

CENTRAL FILES (CHRON)

LOEB/MPA MNB 5715

CENTRAL FILES - SS-396

LOEB/MPA MNB 5715

ACTION:

PRELIMINARY EVALUATION OF THE ATTACHED REPORT INDICATES LEAD RESPONSIBILITY FOR FOLLOW-UP AS SHOWN BELOW:

IE

NRR

NMSS

OTHER

RCI

ROI

SG

FFMSI