

8005140376

P466/D3

CRITERIA FOR THE DESIGN OF SAFETY RELATED SURVEILLANCE
INSTRUMENTATION IN NUCLEAR POWER GENERATING STATIONS

This document is a draft which represents work being done by IEEE/NPEC SC3.2. The user is cautioned that this is not an approved document and cannot be presumed to reflect an IEEE position.

Draft 3 Oct. 22, 1976

Criteria for the Design of Safety Related Surveillance Instrumentation in Nuclear Power Generating Stations.

1. SCOPE

This standard establishes minimum design criteria for permanently installed surveillance instrumentation that serves a safety related function during normal plant operation or during those time intervals when the station is shut down. Plant protective and post accident monitoring functions are not included. Instrumentation addressed in this document is that which is necessary to enable the operator to:

- a. Determine that plant operating conditions are within the limits assumed for the safety analysis of the plant (for example, control rod position indicators).
- b. Determine that safety system status is maintained within the limits required to ensure minimum system performance if needed. (For example, emergency core cooling accumulator pressure and level).
- c. Verify that the performance of safety system equipment is acceptable during functional testing.
- d. Determine safety system bypass status. ^{operations?}
- e. Verify that routine release rates and total releases of radioactive plant effluents are within the limits established for plant operation.

279 →
or
RG-1.47

2. DEFINITIONS

- 2.1 Safety Related Surveillance Instrumentation-Information display channels, including alarms, which provide to the station operating personnel information related to safety system status and those plant operating conditions which are subject to safety limitations, as defined in the scope of this standard. These display channels will be referred to as "surveillance" throughout this document.
- 2.2 Information Display Channel - An arrangement of electrical and mechanical components and/or modules from measured process variable to display device as required to sense and display conditions within the generating station.
- 2.3 Modules - Any assembly of interconnected components which constitutes an identifiable device, instrument, or piece of equipment. A module can be disconnected, removed as a unit, and replaced with a spare. It has definable performance characteristic which permit it to be tested as a unit. A module could be a card or other sub-assembly of a larger device, provided it meets the requirements of this definition.

- 2.4 Safety Systems - The collection of systems required to mitigate the consequences of design basis events.

NOTE: The safety system is the aggregate of a protection system and a protective action system. It includes the engineered safety features, the reactor trip system and the auxiliary supporting features.

- 2.5 Margin - The difference between the most severe service conditions and the conditions used in design to account for uncertainties in defining performance requirements during normal plant operation.

3. DESIGN BASIS

A specific surveillance system design basis shall be provided for each nuclear power generating station. The information thus provided shall be available, as needed, for making judgments on safety related system functional adequacy. The design basis shall document, as a minimum, the following:

- a. The generating station process variables (for example, pressure, flow, gamma, etc.) that are required to be monitored.
- b. The generating station equipment (for example, valves, switchgear) for which status is required to be monitored.
- c. The minimum number and location of information display channels required to monitor adequately those items covered in 3 a. and b.
- d. Operational limits and margins for those items listed in 3 a. and b.
- e. The range of transient and steady state conditions of energy supply and environment (e.g. voltage, humidity, etc.) throughout which the surveillance instrumentation must perform.
- f. Minimum performance requirements including the following:
 1. response time.
 2. accuracy
 3. range
- g. The type of display required for each information display channel (e.g. indicator, recorder, status light, alarm).

4. DESIGN REQUIREMENTS

- 4.1 General Functional Requirement - The nuclear power generating station surveillance instrumentation shall perform its function with precision and reliability. This requirement applies for the range of conditions specified in sections 3 d. and 3 e.

- 4.2 Failure Criterion - The surveillance instrumentation need not be designed to withstand postulated single failures which could result in the loss of the surveillance instrumentation function if such failures are detectable.

A failure can be detected by using redundant or functionally equivalent (diverse) information channels, including alarms, that are electrically independent, as explained in requirement 4.6 below. In this case a failure can be detected by comparing one channel output against the other channel output (in addition to periodic testing of these channels). Alternatively, a failure can be detected by using a single information channel whose display can be verified by supplementary means (e.g. by visual inspection of levels or valve positions or by laboratory sample analysis) or by a testing program which can be shown to provide acceptable reliability of the display information.

The choice of using either a single channel or redundant or diverse channels must be made with due consideration of the complexity and frequency of testing of a single channel and the convenience obtainable by using redundant or diverse channels.

A single failure includes such events as the shorting or open-circuiting of interconnecting signal or power cables. It also includes single credible malfunctions or events that cause a number of consequential component, module, or channel failures. For example, the overheating of an amplifier module is a single failure even though several transistor failures result. Mechanical damage to a mode switch would be a single failure although several channels might become involved.

- 4.3 Quality of Components and Modules - Components and modules shall be of a quality that is consistent with minimum maintenance requirements and low failure rates for its intended service. This shall be achieved through the specification of requirements known to promote these characteristics such as requirements for design, manufacturing, quality control, inspection, calibration, and test, the derating of components, or the use of existing components with favorable operating history.
- 4.4 Equipment Qualifications - Type test data, manufacturers data, or reasonable engineering extrapolation from test data or operating history shall be available to verify that the surveillance instrumentation shall meet on a continuing basis, its performance requirements.
- 4.5 Channel Integrity - All surveillance instrumentation shall be designed to maintain functional capability throughout the range of conditions relating to environment and energy supply specified in Section 3e. Surveillance instrumentation need not be designed to maintain functional capability following a seismic event or other

potentially damaging event, provided that the plant can be put into a condition where the instrumentation is not required or maintenance can be performed within a time frame consistent with the need for the displayed information.

- 4.6 Separation Criterion - Where the requirements of Section 4.2 are met by the use of redundant or diverse information display channels, those channels that provide the same function shall be electrically independent to accomplish decoupling of the effects of electrical transients and to reduce the likelihood of interaction between channels during maintenance operations or in the event of equipment malfunction. An exception to electrical independence may be made for diverse channels if it can be shown that no single electrical fault can cause the channels to give consistent but erroneous information.

Redundant or diverse channels need not be physically separated provided that, should damage to the channels occur, the plant can be put into a condition where they are not required or that maintenance can be performed in a time frame consistent with the need for the displayed information.

- 4.7 Instrumentation Channels with Multiple Functions - If the surveillance instrumentation is also used for functions outside the scope of this standard, it should meet the requirements consistent with the function most important to safety.
- 4.8 Derivation of System Inputs - To the extent feasible and practical, inputs to surveillance instrumentation channels shall be derived from signals that are direct measurements of the desired variables.
- 4.9 Power Source - Surveillance instrumentation need not be capable of operating independent of off-site power availability if the plant can be put in a condition where the instrumentation is not required following a loss of off-site power.
- 4.10 Capability of Sensor Checks - For those sensors which must function during a normal mode of operation, means shall be provided for checking, with a high degree of confidence, their operational availability. This may be accomplished in various ways, for example:
- a. by varying and observing the response of the monitored variable; or
 - b. by introducing and varying, as appropriate, a substitute input to the sensor of the same nature as the measured variable; or
 - c. by cross-checking between redundant or diverse information channels.

IEEE-384

4.11 Capability for Test and Calibration - Capability shall be provided for testing and calibrating the surveillance instrumentation channels. Where the required time interval between testing is less than the normal time interval between generating station shutdowns, there shall, to the maximum extent possible, be capability for testing during power operation.

4.12 Channel Bypass or Removal from Operation - The surveillance instrumentation need not be provided with redundancy to allow bypass and maintenance of one channel during power operation provided that, should maintenance be required:

3
6

- a. the plant can be brought to a condition where the channel is not needed.
- b. The maintenance can be performed in a time frame consistent with the need for the displayed information, or
- c. other means exist for obtaining the displayed information.

why

4.13 Access to Means for Bypassing - The design shall permit the administrative control of the means for manually bypassing the surveillance instrumentation.

4.14 Access to Set-Point Adjustments, Calibration and Test Points - The design shall permit the administrative control of access to all set-point adjustments, equipment calibration adjustments, and test points.

4.15 Identification of Redundant Channels - If the design basis required physical separation of redundant or diverse surveillance instrumentation channels, identification shall exist to distinguish between the redundant or diverse channels. Components or modules mounted in installed assemblies that are clearly identified as being part of a surveillance instrumentation channel do not themselves require identification.

1. The intended purpose and application of this standard is not clear.

The question arises from the use of safety-related. Section 7.5 of the Standard Format and Content for Safety Analysis Reports states that safety-related display instrumentation (SRDI) "provides information to enable the operator to perform required safety function." Section 7.5 of the Standard Review Plan identifies the criteria for SRDI. These include IEEE Std 279-1971 and the other requirements for Class 1E equipment. For post-accident monitoring (a subset of SRDI) certain requirements for Class 1E (e.g., seismic qualification) have been modified. Otherwise, all SRDI must conform to 1E criteria, these include system bypass status information, permanently installed safety system functional testing instrumentation and instrumentation for monitoring safety system operability. Furthermore, in reading Section 4, it seems that the titles from IEEE Std 279-1971 have been restated and the criteria changed from positive to negative. That is the functional requirements which are not required are identified. Thus, it would appear that this standard is an indistinct attempt to establish diluted criteria for safety-related instrumentation and is directed solely at the licensing process. Little consideration is given to improving nuclear power plant reliability and/or safety. Two major changes in direction should be made. First the term safety-related should be deleted and the scope should be in line with Comment 2. Second, the standard should take an approach similar to P-603. That is it should address surveillance instrumentation systems.

1. The intended purpose and application of this standard is not clear.

The question arises from the use of safety-related. Section 7.5 of the Standard Format and Content for Safety Analysis Reports states that safety-related display instrumentation (SRDI) "provides information to enable the operator to perform required safety function." Section 7.5 of the Standard Review Plan identifies the criteria for SRDI. These include IEEE Std 279-1971 and the other requirements for Class 1E equipment. For post-accident monitoring (a subset of SRDI) certain requirements for Class 1E (e.g., seismic qualification) have been modified. Otherwise, all SRDI must conform to 1E criteria, these include system bypass status information, permanently installed safety system functional testing instrumentation and instrumentation for monitoring safety system operability. Furthermore, in reading Section 4, it seems that the titles from IEEE Std 279-1971 have been restated and the criteria changed from positive to negative. That is the functional requirements which are not required are identified. Thus, it would appear that this standard is an indistinct attempt to establish diluted criteria for safety-related instrumentation and is directed solely at the licensing process. Little consideration is given to improving nuclear power plant reliability and/or safety. Two major changes in direction should be made. First the term safety-related should be deleted and the scope should be in line with Comment 2. Second, the standard should take an approach similar to P-603. That is it should address surveillance instrumentation systems.

2. Section 1 - Scope

The scope should be directed towards improving plant reliability by providing better information to the operator and thus enhancing safety. A copy of the scope for the classification Beta digital computer systems standard currently being developed by ANS 4.3.3 is attached. The underlined portions regarding reliability, maintaining the plant within normal limits and enhancement of safety are particularly applicable to surveillance instrumentation. Furthermore, one application for the Beta standard is the computer based CRT display systems. Such systems could also be included in safety-related surveillance instrumentation (SRSI) systems. Therefore, some effort should be made to ensure compatibility between the standards.

3. Section 3 - Design Basis

The design basis do not include the operator/system interface requirements. This interaction is a key element in surveillance systems. The scope (and Comment 1 above) imply this. However, after the scope, this aspect is not clearly incorporated into the standard. The operator/system interface should be considered throughout. For example, the design basis should include the requirements for the operator requirements such as short term, long term, or immediate response. (Reference 1, 2, 3, 4, and 5 provide some additional information). Including the operator's actions would also be in keeping with on-going work by IEEE and ANS regarding operator actions and control room design.

4. Section 4.3 - Quality of Components and Modules

This section should incorporate reliability design goals such as MTTR, MTBF, and availability. There is extensive work going on to collect and catalogue data by IEEE, EPRI, and EEI. Also most instrument manufacturers have reliability data which they use in determining manufacturing, marketing and servicing approaches. Reliability and availability goals are being incorporated into the BETA standard (Comment 2).

5. Section 4 - Design Requirements

In conjunction with Comments 1 and 2, this section should include positive statements of the design requirements. Also, the design requirements to satisfy the operator/system interface design basis should be incorporated. For example, depending on the operator actions required, immediate response, short term response, etc., the design requirements for a given surveillance instrumentation system signal might require an annunciator, indicator, recorder, or combination of several types of display. The design requirements and bases should also require identification and justification of diverse signals.

¹E. W. Hagan, "Human Reliability Analysis, "Nuclear Safety, Volume 17, No. 3, May-June, 1976.

²William G. Milam, George J. Peterman and Michael D. Sulouff, "Advanced Concepts in Control Room Planning", 16th ISA Power Instrumentation Symposium, 1973, Chicago, Illinois.

³Gadi Jupan, "Power Plant Controls: Display, Computers and Man", IEEE Spectrum, November, 1974.

⁴R. Dallimonti, "Human Factors in Control Center Design", Instrumentation Technology, May, 1976.

⁵Jose A. Calvo and R. T. Jones, "A More Efficient Control Room Operator Process Interface", IEEE/ASME Joint Power Generation Conference, St. Louis, Missouri, September, 1971.

ATTACHMENT 1

SCOPE

This standard establishes minimum criteria for the design, development, and implementation of classification Beta digital computer systems for nuclear power generating stations. For the purposes of this standard, classification Beta comprises digital computer systems that are not used for, or as part of, the nuclear reactor plant safety systems but whose failure or misoperation would reduce plant availability or capacity factor. These Beta systems are used for critical applications within the nuclear power plant such that, in case of failure of the computer system, insufficient time would exist for an operator to independently perform its functions and/or evaluate its results. Proper functioning of the Beta system will provide increased assurance that the nuclear plant operation will remain within the range of normal limits, with a corresponding enhancement of safety.* The minimum requirements established by this standard are for the digital computer system hardware and programs, and include the specifications and functional requirements, design and integration, testing and certification, modification, and documentation of the systems.

*Examples of such applications are: direct digital control of the reactor, operating setpoint control, operator guidance, annunciator control and alarm analysis.

DEPARTMENT OF ENVIRONMENTAL RESOURCES
POST OFFICE BOX 2063
HARRISBURG, PENNSYLVANIA 17120

June 18, 1979

7.2.2
8001170792

DJP

Mr. Bruce T. Lunden
Staff Director
President's Commission on the
Accident at Three Mile Island
2100 M Street, N.W.
Washington, D.C. 20037

Dear Mr. Lunden:

This is written in response to your May 22, 1979 letter requesting information from this office concerning our activities during the Three Mile Island accident.

1. Enclosed is a copy of the Bureau's response plan for Three Mile Island. The General Plan was rewritten in 1977. The Three Mile Island Annex was written in 1974. All Annexes to the Plan are written in "Draft" form since they are routinely changed to update personnel and telephone numbers. The original "Pennsylvania Plan for the Implementation of Protective Action Guides" (PAPIPAG) was written in 1973. It was completely revised in 1977. This plan is intended to address Bureau operations only.
2. This organization was contacted by the Pennsylvania Emergency Management Agency (PEMA) duty officer (Clarence Deller) at 7:03 a.m. on March 28. The Bureau's duty officer for the month was William Dornsife, Nuclear Engineer, who was at home at the time. Mr. Dornsife was informed that TMI had contacted the PEMA duty officer at 7:01 a.m. and that a site emergency had been declared. TMI had requested that the Bureau call Unit 2 control room as per standard procedures. Mr. Dornsife first contacted Ms. Margaret Reilly, Chief, Division of Environmental Radiation, to inform her of the incident and request that she and other staff members proceed to the office immediately. At approximately 7:05 a.m. Mr. Dornsife called the TMI switchboard and was unable to be connected to the Unit 2 control room. He was contacted at home by Unit 2 control room at 7:06 a.m.

In general, they stated that a site emergency had been declared, high radiation levels were present in the plant and that they may have had a small loss of coolant accident. The leakage was stopped and the plant was stable and being cooled normally. In addition, on-site surveys found no detectable radiation levels above background. Other information relating to plant status was obtained to assure that conditions were stable. No recommendation was made for protective actions for off-site populations. While on the phone, Mr. Dornsife remembers hearing a public address announcement to evacuate the fuel handling and auxiliary building. He was then transferred to a plant health physicist who verified out-of-plant radiation levels. The individual then said he had to go--"I'll call you back"--and hung up. Mr. Dornsife proceeded into the office as per the plan.

June 18, 1979

By that time, Ms. Reilly had contacted Thomas Gerusky, Director of the Bureau, to inform him and to request that he leave for the office. She also called Kevin Malloy, Dauphin County Emergency Management Director, to inform him of the accident and suggest that he head for his office.

Mr. Thomas Gerusky was the first to reach the office, contacted TMI at 7:25 a.m. by telephone and established an open line with Unit 2 control room. Ms. Reilly arrived momentarily and Mr. Dornife followed within 10 minutes. A summary of the information obtained from the control room (taken from notes and recall) is as follows:

There was a site emergency at Unit 2--steam generator failure, primary to secondary leak and loop isolated. At approximately 7:30 a.m. a general emergency was declared because of a high reading of 800 R/hr in the reactor containment building. The unit had been shut down, there was some failed fuel, the high pressure injection system was initiated, some primary coolant was lost and high radiation areas in the auxiliary building.

With the dome monitor reading 800 R/hr, the procedure is to estimate off-site doses in the event of a leak in the containment building. Assuming a 0.2% leak rate and the wind out of 30°, the estimated exposure on the west side of the river was 10R/hr from a reference containment atmosphere mix. A State Police helicopter was at the site and the Bureau requested that TMI survey teams be flown across the river to establish the exposure rate.

Meanwhile, other Bureau of Radiation Protection staff were in contact with the Pennsylvania Emergency Management Agency to notify them of the reactor condition, that an evacuation of an area southwest of the plant in York County (between Goldsboro and York Haven) was a possibility and that York County should be alerted. A few minutes later it was verified that no radiation levels above background were detectable. PEMA was so notified.

Following this information, we notified other staff members and the Department administration of the accident and present conditions.

We alerted the Pennsylvania Department of Agriculture, Division of Milk Sanitation, of the event.

We had learned during the Chinese fallout episode of 1976 that telephones would be tied up, that the press would be contacting us and that communications would be a problem. We maintained the open line with the site and contacted the Department's Public Information Officer to handle press inquiries. Our regular clerical staff was experienced in responding to public inquiries and had all press calls referred to the Public Information Officer.

June 18, 1979

At approximately 9:00 a.m., Mr. Charles Meinhold, Director of Health and Safety at DOE's Brookhaven National Laboratory and head of the Federal Interagency Radiation Assistance Program Team at BNL, contacted us by telephone to state that their team was ready to assist us at our request. At that point, no off-site problems were occurring so we told them to hold until we had more information. At about 11:00 a.m. we requested assistance.

At 9:00 a.m., Mr. Dornsife was requested by the Deputy Secretary to go to Lieutenant Governor Scranton's office to brief him on the situation and to participate in a press conference at 10:00 a.m.

He contacted Gary Miller, TMI station superintendent, to be updated on what had occurred. Mr. Miller's briefing of Mr. Dornsife is reconstructed (based partly on notes and partly on memory) as follows:

At about 0400 a turbine trip occurred at 98% power. As designed, the reactor tripped and all safeguard systems, including high pressure injection, actuated automatically when required. There was a violation of technical specifications, specifically, that the auxiliary feed system block valves were initially closed. The electromatic relief valve on the pressurizer lifted and did not reset; however, the indication in the control room (electrical signal to valve) let the operator to believe it had reclosed. The block valve downstream of the relief valve is now closed. The pressurizer may have gone solid and low pressure in the reactor coolant system probably caused flashing and steam bubbles in the system. This may have led to a temporary loss of main coolant circulation. There was a possible primary to secondary leak in the "B" steam generator which has been isolated. The boron concentration in the primary has been diluted to about 100 ppm. This may have been caused by secondary to primary feedback through the leaking steam generator when the system was pressurized. There has been a slight amount of failed fuel. The exact magnitude is not certain at this time--it may have been only some gap activity. The reactor building dome monitor was reading 600R/hr and the reactor building pressure was about 1 psig. The fence post dose was less than 1 mrem/hr. The wind is currently blowing to the west at about 1 to 2 mph and they are sending monitoring teams to Goldsboro.

At approximately 10:45 a.m. the utility notified us that radiation was being detected off-site and that exposure rates were 3 mr/hr or less. A Bureau radiation monitoring team was sent out to verify the TMI readings. Similar levels were observed.

We were concerned about the probable presence of radiiodines in the plume of radiogases from the plant. The DFR Bureau of Radiation Protection (BRP) was not equipped to do mobile in-the-field airborne iodine estimates. (We did have a fixed monitor at the Observation Building which we chose to leave in place for a historical sample.) TMI field teams were out, though, making these measurements according to plan. Several of their field estimate samples were suggesting I-131 concentrations of up to tens of thousands of picocuries per cubic meter. Unconfirmed, this concentration range would suggest an eventual (days) need for protective actions against inhalation with plant deterioration and a significant impact on fresh fluid milk production and use.

Since the backgrounds at the facility had understandably increased, Mr. Dubiel, TMI health physicist, asked if we could recount the samples in our labs at Harrisburg. We agreed. The samples were transported by helicopter to the helipad at Holy Spirit Hospital and thence to the lab by BRP staff. Spectrum analysis, using GeLi detector, indicated no I-131 (sensitivity at about 10 pCi/m³). We began to suspect the current direct exposure mode to be noble gases with little, if any, I-131. This was consistent with knowledge that the dominant source was the water on the aux building floor and the existent charcoal filters on the aux building vent.

We advised the Agriculture Department that milk sampling should begin with farm sampling of milkings of Wednesday evening (3/28) and Thursday morning (3/29). The results of the analyses of those samples showed milkborne I-131 to be in the range of tens of picocuries per liter--hardly an acute contaminating episode. The sampling of fresh milk continues.

For the remainder of the first day--ground surveys performed by teams from this Bureau, DOE, NRC and utility confirmed that the off-site levels of radioactivity were in the range of about 1-10 mrem/hr (β-γ). Occasional higher levels were observed on site, in the plume and in relatively stagnant pockets due to the meteorological condition. The meteorological conditions during the first few days were such that the wind speed was very low and the direction was variable. Therefore, very little dispersion was occurring and pockets of noble gases with higher than average radiation levels were not uncommon near the site.

Reports from the site and from the NRC I&E teams which had arrived first after 10:00 a.m. confirmed that the primary source of radioactive releases were noble gases which were being offgassed from reactor coolant water which had been pumped from the reactor building sump to the auxiliary building sump tank and that the sumps had overflowed onto the floor. Prior to this it had been suspected that the main source of release had been the venting of steam from the "A" steam generator directly to the atmosphere which had occurred most of the morning.

During that morning, the Peach Bottom Atomic Power Plant staff called offering assistance, as did the State of New Jersey and Pennsylvania State University.

Levels of radioactivity in the environment remained at or below 3 mr/hr throughout the next day with some occasional high reading found on site and in the plume. Helicopter surveys were being performed by the ARMS aircraft which came with the DOE teams. Levels detected in the plume right over the release stack ranged up to 3000 mr/hr (β - γ).

On Friday morning, March 30, releases from the plant increased due to venting of gases from the make-up tank. Levels as high as 20-25 mr/hr (β - γ) were observed for a short period of time just off-site. One helicopter reading of 1200 mr/hr (β - γ) was found at 600 feet, 300 feet above the reactor building and in the plume. DOE teams and Bureau teams were measuring ground level radiation levels off-site as was the NRC and the utility.

The Bureau received a call from PEMA stating that "Doc" Collins of NRC-Bethesda had called them recommending evacuation out to ten miles downwind because of the 1200 mr/hr reading. We advised PEMA that off-site readings did not indicate a need for evacuation and that the plant had stated that the venting should be over shortly.

Ms. Reilly and Mr. Dornsife contacted Mr. Collins at NRC-Bethesda to ask why the recommendation was made. He stated that the "top brass" had recommended it and he was only following orders. By that time telephone lines were tied up, and Mr. Dornsife went to PEMA headquarters while Mr. Gerusky went to the Governor's office. Ms. Reilly stayed in contact with TMI and the survey teams. Both Mr. Dornsife and Mr. Gerusky recommended against evacuation due to current conditions.

Radiation levels off-site steadily decreased to 1 mr/hr or less during the day. Some intermittent readings were higher in the immediate vicinity of the site and on-site. Levels remained at that point until they declined to background much later in the episode.

Effective March 28, 1979, the Bureau of Radiation Protection office went on a 24-hour schedule. The Bureau has a full-time Harrisburg staff of 19 including four laboratory personnel. Good working relationships had been long established with the NRC Region I office, with the DOE emergency teams and with the utility's radiation protection organization.

Following the March 30 episode, additional EPA, HEW, DOE and NRC health physics personnel were involved in environmental radiation surveillance activity. The operation of the Bureau became one of collecting and analyzing data and making recommendations based upon the data. Assistance in operations was gained from other program personnel in the Department and the Laboratory.

June 18, 1979

The Bureau stayed on a 24-hour schedule for approximately two weeks, a 12-hour schedule for the third week, and back to normal for the remaining time. On Friday, May 30, 1979, the Bureau Nuclear Engineer was assigned to the Three Mile Island Site on a 12-hour-a-day basis to keep the Governor's Office and this Bureau informed of any activity which could cause off-site problems. Dedicated telephone lines were installed in our office with the NRC Region I trailer, NRC headquarters, DOE operations at the Harrisburg-York State Airport, and the FDA Bureau of Radiological Health. On about April 1, 1979, representatives from NRC, DOE and FDA were located in our Harrisburg office as liaison personnel to collect and relay information with their respective organizations.

Water releases were also a problem and additional monitoring was required. The Department's Bureau of Water Quality Management, the Bureau of Radiation Protection and USEPA combined resources to provide a water sampling and analysis program. A copy of that program is attached.

Activities wound down slowly until the reactor was placed in a natural circulation cooling mode. With the "crisis" over, the Bureau continues a long-term operation to monitor the environment during the recovery stage.

3. Comments

There is no doubt that there was a lack of understanding of the scope of the problem during the first days of the accident. It was known that some fuel cladding failure had occurred but the extent of core damage was not known until later. Off-site consequences were initially caused because of contaminated water being pumped from the containment to the auxiliary building and the sumps overflowing. Other releases resulted when venting of radioactive gases occurred prior to hooking up a line to return the gases to the containment building.

Based on the monitoring information that we had received throughout the accident, we felt assured that the maximum accumulated off-site dose to any individual would not have exceeded 100 mrem. This was a factor of ten below the EPA protective action guidelines upon which our plan was based and where we were prepared to take protective actions to limit further off-site cumulative dose.

After the decision was made to move the NRC headquarters staff to Middletown and to set up an adequate communications system, the problems became more solvable and calmness returned to the area. There was a serious problem in communications from the facility, to Commonwealth and Federal officials and to the general public. This was partially resolved when the decision was made to issue press statements from either the Governor's Office or NRC-Middletown.

TMG/MAR/WPD/dmm

cc: Bill Dornisfe
Bruce Segal, DOE
Historian's Office
Rm. C478-GT
DOE, 20545

Sincerely yours,

Thomas M. Gerusky
Thomas M. Gerusky, Director
Bureau of Radiation Protection

Att.

DJPE
8001170751

SHAW, PITTMAN, POTTS & TROWBRIDGE
1800 M STREET, N. W.
WASHINGTON, D. C. 20036

RAMSAY D. POTTS
STEWART L. PITTMAN
GEO. GEORGE F. TROWBRIDGE
STEPHEN D. POTTS
GERALD CHARNOFF
PHILLIP D. BOSTWICK
R. TIMOTHY HANLON
GEORGE M. ROGERS, JR.
JOHN B. RHINELANDER
BRUCE W. CHURCHILL
LESLIE A. NICHOLSON, JR.
MARTIN D. KRALL
RICHARD J. FENDALL
JAY E. SILBERG
BARBARA M. ROSSOTTI
GEORGE V. ALLEN, JR.
WM. BRADFORD REYNOLDS
FRED A. LITTLE
FRED DRASNER
NATHANIEL P. BREED, JR.
MARK AUGENBLICK
ERNEST L. BLAKE, JR.
CARLETON S. JONES
THOMAS A. BAXTER
JAMES M. BURGER
SHELDON J. WEISEL
JOHN A. McCULLOUGH
J. PATRICK HICKEY
JAMES THOMAS LENHART

STEVEN L. MELTZER
DEAN D. AULICK
JOHN ENGEL
STEPHEN B. HUTTNER
WINTHROP N. BROWN
JAMES B. HAMLIN
ROBERT E. ZAHLER
RICHARD E. GALEN
ROBERT B. ROBBINS
LAURA K. FARRAND
MATIAS F. TRAVIESO-DIAZ
VICTORIA J. PERKINS
JOHN H. O'NEILL, JR.
JAY A. EPSTIEN
GEORGE D. CROWLEY, JR.
MICHAEL D. HAYS
THOMAS H. McCORMICK
SUSAN D. FALKSON
STEVEN M. LUCAS
RAND L. ALLEN
ALAN J. WEISBARD
WILLIAM P. BARR
ALAN R. YUSPEH
JOHN L. CARR, JR.
PHILIP J. HARVEY
KAY L. RICHMAN
TIMOTHY B. McBRIDE
CHARLES W. SURASKY*

(202) 331-4100
TELECOPIER
(202) 296-7394 & 296-1760
TELEX
89-2693 (SHAWLAW WSH)
CABLE "SHAWLAW"
JOHN H. SHARON
EDWARD B. CROSLAND
COUNSEL

*NOT ADMITTED IN D. C.

December 4, 1979

George Frampton, Esquire
NRC/TMI Special Inquiry Group
Nuclear Regulatory Commission
Washington, D.C. 20555

Dear George:

In response to the November 26, 1979, written request of R. C. Haynes, enclosed are copies of the following documents:

Three Mile Island Unit II Work Request Nos. 0027, 0028, 0037, 0039, 0172, 0173, 0249, 0282, 0335, 0204, 0436, 0468, 0478, 0489, 490, 495, 496, 500, 602, 730, 890, 956, 957, 2151 and 1296.

In addition, we are still attempting to locate Work Request Nos. 0036, 1053 and 1076.

Sincerely,

Mat

Matias F. Travieso-Diaz

JFW:rt
Enclosures
cc: Mr. Jacque Durr (w/encl.)

Most of 123 pg 547

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

RECOMMENDED PRIORITY

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					REQUEST DATE							
5	7	8	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38							
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38

1A

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CAUSE OF MALFUNCTION (IF KNOWN)

MAIN STEAM VALVE 1/2" GLOBE UNDER HP
TURBINE BLOWING BY AND HANDWHEEL MISSING
LOCATED NEAR GS STRAINER THAT BLEW
GASKET AT TURB TRIP PUT CAP ON ULV NIPPL
VALVE LEAKING BY

ORIGINATOR'S EMP. NO. 06301	ORIGINATOR'S SIGNATURE CADO	DATE 12-5-78	SUPERVISOR'S EMP. NO. 06301	SUPERVISOR'S SIGNATURE CADO	DATE 12-5-78
--------------------------------	--------------------------------	-----------------	--------------------------------	--------------------------------	-----------------

4200

WORK ORDER NUMBER 036000187JN	GC CODE 3995134	ACCOUNT NUMBER 00111010	PLANT CONDITION SU OP HD CD RF HS LR	NPRD FAILURE YR MO DAY HR MIN
CHANGE MOD REG D 0000	R WP 0000	NUC SAFETY 0000	REG AGENCY CODE 0000	CHG/MOD NUMBER 0000
TAGGING APPLICATION NO.	ENV CODE X	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS

S/M APPROVAL COMMENCE WORK MO DAY YR	S/F APPROVAL COMMENCE WORK MO DAY YR	PROCEDURE NUMBER 120678121878	PRIORITY	RESP. LOCATION OR CONTRACTOR 1C086902000300	EST. CREW SIZE	EST. MANHOURS
---	---	----------------------------------	----------	--	----------------	---------------

ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR EST. CREW EST. MANHOURS	ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR EST. CREW EST. MANHOURS	ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR EST. CREW EST. MANHOURS
--	--	--

TXN CD 807A	ACT 1	JOB COMPLETION DATE MO DAY YR 010379	FIELD WORK COMPLETION DATE MO DAY YR 121878	SIGN OFF REASON CODE 50 51 52 53 1	TOTAL ACTUAL MANHOURS 58 59 000320	PURCHASE REQUISITION NUMBER 66 67	PURCHASE ORDER NUMBER 73 74	MATERIAL ORDER NUMBER 80
----------------	----------	--	---	--	--	--------------------------------------	--------------------------------	-----------------------------

TXN CD 801A	ACT 4	RESOLUTION DESCRIPTION 07 REMOVED INSTRUMENT CONNECTION AND INSTAL 08 LED CAP AND BACK (SEAL) WELDED CAP 09 10
----------------	----------	--

TXN CD 808A	ACT 4	NPRD FAILURE END YR MO DAY HR MIN 48 49 50	FAILURE NO.	FAILURE STATUS	ORIGINATOR -- SUPERVISOR -- SUPERVISOR OF MAINTENANCE -- MAINTENANCE FOREMAN -- JOB PERFORMER -- MAINTENANCE FOREMAN -- SUPERVISOR OF MAINTENANCE -- CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
----------------	----------	--	-------------	----------------	--

TXN CD 808A	ACT 4	NPRD FAIL TYPE 39 40	NPRD FAIL MODE 41 42 43	CAUSE OF FAILURE CODES A B	EFFECT OF FAILURE CODES A B	FAILURE DETECTION CODE 55 56 57 58	ACTION TAKEN CODES A B	LICENSE EVENT REPORTED DATE YR MO DAY 65 66 71
----------------	----------	-------------------------	----------------------------	-------------------------------	--------------------------------	---------------------------------------	---------------------------	--

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

PF

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	LOG				MO	DAY	YR
MS	*	*		036002	CM	C00271	12	04	78

RECOMMENDED PRIORITY

1A

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

MAIN STEAM VALVE 1/2" GLOBE UNDER H.P. TURBINE BLOWING BY AND HANDWHEEL MISSING LOCATED NEAR GS STRAINER THAT BLEW GASKET AT TURB TRIP PUT CAP ON ULU NIPPL

CAUSE OF MALFUNCTION (IF KNOWN)

VALUE LEAKING BY

ORIGINATOR'S EMP. NO. 06301	<i>CAdo</i>	ORIGINATOR'S SIGNATURE	12-5-78	DATE	SUPERVISOR'S EMP. NO. 06301	<i>CAdo</i>	SUPERVISOR'S SIGNATURE	12-5-78	DATE
--------------------------------	-------------	------------------------	---------	------	--------------------------------	-------------	------------------------	---------	------

WORK ORDER NUMBER 4200		GC CODE JN	ACCOUNT NUMBER 3998134	PLANT CONDITION SU OP HD CD RF HS LR				NPRD FAILURE YR MO DAY		START HR MIN	
036000	187			00	11	10	10				
CHARGE NO. 0000	P W P	NUC SAFETY	REG AGENCY CODE	CHG/MOD NUMBER	ENV CODE X	OUTAGE CAUSE CODE	STATUS HOLD CODE				

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
12	06	78

PRI LOC P	RESP. LOCATION OR CONTRACTOR 1C0869
-----------------	--

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

GPU TEST
SUPT. APPROVAL
J. J. [Signature] 12/6

Post Maintenance Testing required and Acceptance Criteria.

Cap installed at valve nipple at turbine trip test - No leakage from caps

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0027

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes,
PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because
it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date

7. Plant status or prerequisite conditions required for work. *Lester Skutumpah*
8. QC Dept. review, if required in item No. 3

QC Supervisor N/A Date _____

9. Supervisor of Maintenance approval to commence work: *W. Pictor* Date 12/6/78

10. Maintenance Foreman Assigned: _____

11. Shift Foreman's approval to commence work C. Alan Date 12/18/78

STE APPROVAL

Initial if Shift
Foreman
signature is not required

Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0027

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature

12/18/78
Date

Fulton

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

C. Guthrie

Shift Foreman's Signature

12-18-78

Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

C. Guthrie

Shift Foreman's Signature

12-18-78

Date

STE APPROVAL N/A

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

W. Metzger

Supervisor of Maintenance Signature

1/3/78
Date

WORK AUTHORIZATION TO CATALYTIC, INC.

In accordance with the terms, conditions, and provisions of General Maintenance Contract, Met-Ed P.O. #38735, Catalytic, Inc. is hereby authorized to perform the work described on Work Request No. C0027 attached hereto and forming a part hereof.

Acceptance:

Date: 12/8/78

Nitzman M/E Wm
MET-ED By: (Print Name, Title & Initial)

Date: 12/8/78

JUGLER, Planner RM
CATALYTIC, INC. By: (Print Name, Title & Initial)

cc: M. R. Dendler

WORK COMPLETED BY CATALYTIC, INC.

The attached Work Request # C-0027

JO # 01048

has been completed and hereby returned as noted below.

Remarks:

R.A. Jugler 12/22/78
Planning Department

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

✓

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	LOOP				MO	DAY	YR	
WT	P	0008B	036002	CM		C00281	12	05	78	2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

REPLACE OR ADJUST PACKING ON WT-P-8B,
TRIED TO ADJUST WITH NO REAL SUCCESS.

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.
05106

[Signature]
ORIGINATOR'S SIGNATURE
12-5-78
DATE

SUPERVISOR'S EMP. NO.
05873

[Signature]
SUPERVISOR'S SIGNATURE
12-5-78
DATE

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRO FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	187HE		3998134	1	1	1	1	1	1					

CHANGE MOD REQ D	R W P	NUC SAFETY	VP RD	REG AGENCY CODE	CHG/MOD NUMBER
0000					

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK
MO DAY YR
12 06 78

PLANT LOCATION OR CONTRACTOR
2036m

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

No specific packing leakage

GPU TEST
SUPT. APPROVAL
[Signature] 12/4

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

M 042636

Material Order Generation

ITEMS 8 9	DATE MO DAY YR	USED FOR / RETURNED FROM:	WT-P-88	ITEMS 8 9	DATE MO DAY YR
--------------	-------------------	------------------------------	---------	--------------	-------------------

ISSUED FROM / RETURNED TO:	STOREROOM NAME Tm1	STRM NO 10 12	ISSUED TO (INTERCHANGE)	STOREROOM NAME	STRM NO 16
-------------------------------	--------------------------	---------------------	----------------------------	-------------------	------------------

TXN		TXN	
13 15		13 15	
710	Issue	740	Scrap Sale
720	Cash Sale	510	Return/Retire
730	Charge Sale	620	Interchange

WORK REQUEST NO.
C 0028

A C C O U N T N U M B E R	ORDER		ACCOUNT			
	ID 20	WORK ORDER	JOB NUMBER	ACCOUNT	VOLT	PP

RE S U B	STOCK SYMBOL NUMBER			Q A	QUANTITY ISSUE/RETURN	U/I	QUANTITY REQUIRED	DESCRIPTION
	MA 46	SUB	ITEM 55					
1						1 SET	1 SET	Packing, GRINDS/SET
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								

SIGNED: _____ APPROVED: *John Lane*

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0028

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date

7. Plant status or prerequisite conditions required for work. Operating or shutdown

8. QC Dept. review, if required in item No. 3
QC Supervisor Date _____

9. Supervisor of Maintenance approval to commence work: Date 12/6/78

10. Maintenance Foreman Assigned:

11. Shift Foreman's approval to commence work _____ Date _____

SIE APPROVAL

Initial if Shift Foreman signature is not required

Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0038

12. Retest met acceptance criteria

Yes No

13. Work Performed by date/time

Work Reviewed - Maintenance Foreman's Signature

Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

Shift Foreman's Signature

Date

15. Testing completed and component released for normal use.

STE APPROVAL

Initial if S. F. signature is not required.

Shift Foreman's Signature

Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

Supervisor of Maintenance Signature

Date

Close WT-V309D

WT-V309F

WT-P98

Gen. + Ext. Control Switch

Carver Pump Co.

Model HFL

S/N 83421

1/08/79

Need Op to Clean
the -pump AREA

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE				JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY	
SYS	7	R	COMP TYPE	11	12	COMP ID	15	16	17	22	23	24	25	26	27	28	29	30	31	32	33	MO	DAY	YR	32							
Hy	*									0	3	6	0	0	2	CM						C	0	0	3	7	1	2	0	7		7

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CAUSE OF MALFUNCTION (IF KNOWN)

REPAIR LEAK AT HYDROGEN MANWAY ON GENERATOR

ORIGINATOR'S EMP. NO. 06386	ORIGINATOR'S SIGNATURE <i>metz</i>	DATE 12/7/78	SUPERVISOR'S EMP. NO. 06386	SUPERVISOR'S SIGNATURE <i>metz</i>	DATE 12/7/78
--------------------------------	---------------------------------------	-----------------	--------------------------------	---------------------------------------	-----------------

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
036000187LN			3994134	1	1	1	1	1	1	1					

CHANGE MOD REQ D	A W P	NUC SAFETY	KP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0000							X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR			1C0869	02	00160
1	2	0778	0	1	0879					

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A	C	T	4	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
807A					MO DAY YR	MO DAY YR					
					39 05 12 79	44 45 01 03 79	50 51 1	000160			

TXN CD	A	C	T	4	RESOLUTION DESCRIPTION
801A					07 Bolts holding manway removed and coated
801A					08 with silcone
801A					09
801A					10

TXN CD	A	C	T	4	NPRO FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY
808A					YR MO DAY HR MIN			
					39 48 49 50			

TXN CD	A	C	T	4	NPRO FAILURE TYPE	NPRO FAILURE MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
808A					39 40	41 42 43	50 51	55 56 57 58	65 66	71	YR MO DAY

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

323.1120

MW

RECOMMENDED PRIORITY

COMPUTER DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	MO				DAY	YR	
H	Y	*	*	036002	CM	C00371	12	07	78

1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

REPAIR LEAK AT HYDROGEN MANWAY ON GENERATOR

CAUSE OF MALFUNCTION (IF KNOWN)

--

ORIGINATOR'S EMP. NO.
06386

metz
ORIGINATOR'S SIGNATURE

12/7/78
DATE

SUPERVISOR'S EMP. NO.
06386

metz
SUPERVISOR'S SIGNATURE

12/7/78
DATE

4200

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000187	LN	LN	3998134	1	1	1	1	1	1	1				

CHANGE MOD REG'D	R W P	NUC SAFETY	RD	REG AGENCY CODE	CHG/MOD NUMBER
0	0	0	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK
MO DAY YR
1 2 07 78

RESP LOCATION OR CONTRACTOR
1C0869

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

No H₂ leakage at manway

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—
JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

GPU TEST
SUPT. APPROVAL
K Toole

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0037

- 1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
- 4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date


- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
- 6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date

- 7. Plant status or prerequisite conditions required for work. *Operating or shutdown*
- 8. QC Dept. review, if required in item No. 3
QC Supervisor N/A Date _____
- 9. Supervisor of Maintenance approval to commence work: W. Metzger Date 12/7/78
- 10. Maintenance Foreman Assigned: _____

- 11. Shift Foreman's approval to commence work Amick Date 1-8-79

STF APPROVAL



Initial if Shift Foreman signature is not required

NA
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0037

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature
1/3/78 JV Blanton
Date

14. Work completed and component alligned for testing.

Initial if S. F. signature is not required.

A. Miller 1-8-79
Shift Foreman's Signature Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

A. Miller 1-8-79
Shift Foreman's Signature Date

STE APPROVAL

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

NA
QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

D. M. Shorler 5-12-79
Supervisor of Maintenance Signature Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT				JOB TYPE			JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE		COMP ID		ID		LOC		UNIT		JOB TYPE			JOB TICKET NUMBER				MO	DAY	YR									
5	7	8	11	12	13	14	15	16	17	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38			

RECOMMENDED PRIORITY

CONDENSATE PUMP IC BREAKER ON BUS 2-3
-TRIPPED, MOTOR IS OKAY, APPEARS TO BE A
RELAY PROBLEM

RELAY DEPT. PROBLEM REPORT COPY ATTACHED

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 06301	ORIGINATOR'S SIGNATURE <i>C Adas</i>	DATE 12-6-78	SUPERVISOR'S EMP. NO. 06301	SUPERVISOR'S SIGNATURE <i>C Adas</i>	DATE 12-6-78
--------------------------------	---	-----------------	--------------------------------	---	-----------------

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION				NPRD FAILURE		START					
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN

CHARGE MOD	R	NUC	NP	REG	CHG/MOD	TAGGING	ENV	OUTAGE	STATUS	ESTIMATED
REQ D	W	SAFETY	RD	AGENCY CODE	NUMBER	APPLICATION NO.	CODE	CAUSE CODE	HOLD CODE	DOLLARS

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	ACT	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4	39	44	45	50	51	52	53

TXN CD	ACT	RESOLUTION DESCRIPTION
1	4	39

TXN CD	ACT	NPRD FAILURE END	FAILURE NO.	FAILURE STATUS	ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN — JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE — CM COORDINATOR · DATA ENTRY · SUPERVISOR OF MAINTENANCE CM COORDINATOR · DATA ENTRY
1	4	39	48	49	50

TXN CD	ACT	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
1	4	39	40	41	42	43	50	51

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	ID				MO	DAY	YR	
00	P	0001C	00	03600	02CM	00039	12	06	78	1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CONDENSATE PUMP IC BREAKER ON BUS 2-3										
TRIPPED, MOTOR IS OKAY, APPEARS TO BE A										
RELAY PROBLEM										

CAUSE OF MALFUNCTION (IF KNOWN)

RELAY DEPT. PROBLEM REPORT COPY ATTACHED										
--	--	--	--	--	--	--	--	--	--	--

ORIGINATOR'S EMP. NO.
06201

C Ada
ORIGINATOR'S SIGNATURE

12-6-78
DATE

SUPERVISOR'S EMP. NO.
06301

C Ada
SUPERVISOR'S SIGNATURE

12-6-78
DATE

4200

WORK ORDER NUMBER				GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL					SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
0360	00187	JF			3998134	1	1	1	1	0	1					

HAZARDOUS MOD REQ'D	R W F	NUC SAFETY	SP PD	REG AGENCY CODE	CHG/MOD NUMBER	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
0	0	0	0			X		

S/M APPROVAL COMMENCE WORK
MO DAY YR
12 07 78

RESP LOCATION OR CONTRACTOR
120R1

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

Pump will operate from proper bus

GPU TEST
SUPT. APPROVAL

R. Stole

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

RELAY DEPARTMENT
RELAY OPERATION/PROBLEM REPORT

Forward Completed form to Shift Supervisor for his review.

Time	Date	Bus	Component	MOTOR Currents from Installed AMMETER (If Running)	WHITE CARD DATA TARGET (Which On (In Relay Window))
1546	12-6-78	2-3	CO-P-1C	n/a	EX. 50-51-83 No. 2H 50G 86

REMARKS:

1. Did Breaker Trip? Yes No
2. Was Work Request Submitted Yes No
3. Is problem a relay problem or is it a system or component problem. Relay Other
4. Other info. that may aid the Relay Dept:

CCC Dept. Investigating, Megger motor OK.
 Racked in the breaker on Bus 2-3, after about 2 minutes we received a cond. pers. overload alarm and on 86 lockout on CO-P-1C tripped on Bus 2-3 with the breaker still open. We did not try to start CO-P-1C on 2-3. When that happened, we started CO-P-1C on buses 2-4, everything appears OK after several hours of operation.

4H
 Ground O/C:
 3-CO-P-1C-2

NOTE:

1. If corrective action is required, submit a work request in addition to this form.
2. ON OVERLOAD RELAYS, the "L" & "T" Toger trip the breaker. "I" alone will trip the breaker.
3. If the breaker has tripped and the 50G or 50-51-83 "I" target is present, the motor/cable should be checked by Electrical Dept. prior to attempting re-start. Megger OK.
4. START CO-P-1C ON 2-4 BUS every thing OK.

Performed By:
 Aux Operator - C Adas
 Date 12-6-78 Shift C
 OTHERS
 Date 12-6-78 Time 1600
 Date 12-6-78
 SHIFT FOREMAN/SUPERVISOR
 C Adas

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0172

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes No _____
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes No _____
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes No _____
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent: _____ Date _____

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes No _____
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes No _____
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations _____ Date _____

7. Plant status or prerequisite conditions required for work. Operating or shutdown
8. QC Dept. review, if required in item No. 3
QC Supervisor E. Daniels 12-13-78 Date 12-13-78
9. Supervisor of Maintenance approval to commence work: P. Seiglitz 12-17-78 Date 12-17-78
10. Maintenance Foreman Assigned: GAMES

11. Shift Foreman's approval to commence work [Signature] Date 12-14-78

STE APPROVAL
[Signature] 12-14-78

Initial if Shift Foreman signature is not required

14015
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0172

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature

12-15-78 110641
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

C. Guthrie
Shift Foreman's Signature

12-14-78
Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

C. Guthrie
Shift Foreman's Signature

12-14-78
Date

16. Quality Control Department review of work and testing completed (QC work only).

NA
Surveillance Report No.

W. Smith
QC Department

12/19/78
Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

STE APPROVAL

W. Smith
Supervisor of Maintenance Signature

12/21/78
Date

C30 12-15-78

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE			JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY
SYS	7	8	COMP TYPE	11	12	COMP ID	15	16	17	22	23	24	25	28	32	33	MO	DAY	YR	38										
U	D	L	F			00	04	0	3	6	0	0	2	CM			C	0	1	7	2	1	3	7	8					

RECOMMENDED PRIORITY

2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

07C-F-4A has high DP Filter needs changed
Root tank filter 230' elev fuel handling
old

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 04455	ORIGINATOR'S SIGNATURE <i>Dave [unclear]</i>	DATE 12/13/78	SUPERVISOR'S EMP. NO. 06301	SUPERVISOR'S SIGNATURE <i>C Adams</i>	DATE 6301
--------------------------------	---	------------------	--------------------------------	--	--------------

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRO FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
036000187EG		399	8134	1	1	1	1	0	1	1					

CHANGE MOD. REQ. D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	1	1	0			03627	B			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIOR	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
12	13	78	12	14	78	410	FI	Rev.0	2036m	02000080

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
MO DAY YR	MO DAY YR					
12 21 78	12 14 78	1	000120		0057929	

RESOLUTION DESCRIPTION														
07	REMOVED USED FILTER & REPLACED NEW FILTER													
08	R													
09														
10														

NPRO FAILURE END					FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY										
YR	MO	DAY	HR	MIN	48	49	50										

NPRO FAIL TYPE	NPRO FAIL MODE	CAUSE OF FAILURE CODES		EFFECT OF FAILURE CODES		FAILURE DETECTION CODE		ACTION TAKEN CODES		LICENSEE REPORTED D.					
39	40	A	B	A	B	55	56	57	58	A	B	YR	MO	DAY	71

TXN CD	ACT
807A	
801A	
801A	
801A	
801A	
808A	
808A	

DESIGNATED END USE DATA

N I II III
S I II III

SYSTEM APPLICATION

(TAG NOS.) WDL-F-3A

B/M OR SPEC. NO. _____

COMMENTS

FILTER

THIS TAG IS NOT TO BE REMOVED
UNTIL MATERIAL IS INSTALLED
IN A DESIGNATED END USE.

MET-ED

Quality Control

1 F01N050

ACCEPT

P.O. NO. 57929 ITEM NO. 1

Q.C. INSP. TACCONOR DATE 7-6-78

GPF 4008.003

TMI-65A REV. 11-76

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	REQ NO				MO	DAY	YR	
WDL	F	004A	036002	CM		C0172	12	13	78	2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

WDL-F-4A has high AP Filter needs changed
Mount tank filters 280' elec fuel handling bldg

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.
04455

David Wilson
ORIGINATOR'S SIGNATURE

12/15/78
DATE

SUPERVISOR'S EMP. NO.
06301

C Adams
SUPERVISOR'S SIGNATURE

6301
DATE

4200

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	187EB		3998134	1	1	1	1	0	1					

CHANGE MOD REQ'D	P W P	NUC SAFETY	NPRD	REG AGENCY CODE	CHG/MOD NUMBER
0	1	1	0		

ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
6		

S/M APPROVAL COMMENCE WORK
MO DAY YR
12 13 78

RESP LOCATION OR CONTRACTOR
2036M

Comply with the Provisions set forth in AP1002, AP1003 and Met Ed Safety Manual.

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

No leakage at system after new filter is installed

GPU TEST
SUPT. APPROVAL

J. Kautzman
12/15/78

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

COPY 1

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET-FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TICKET NUMBER					REQUEST DATE			RECOMMENDED PRIORITY
SYS		COMP TYPE		COMP ID		JOB NO		LOCATION / UNIT			JOB TYPE		JOB TICKET NUMBER			MO	DAY	YR										
5	8	11	12	13	14	15	16	17	22	23	24	25	26	27	28	32	33	38										
F	W	P		0	0	0	1	0	3	6	0	0	2	C	M			C	0	1	7	3	1	2	1	7	8	1A

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

FW-P-1B SPEED INDICATOR NEEDS CALIBRATION
G, IT DOES NOT GO TO ZERO WITH THE FEED
PUMP COMPLETELY STOPPED
ODS STICKER 389

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 06301	ORIGINATOR'S SIGNATURE C Adams	DATE 12-13-78	SUPERVISOR'S EMP. NO. 06301	SUPERVISOR'S SIGNATURE C Adams	DATE 12-13-78
--------------------------------	-----------------------------------	------------------	--------------------------------	-----------------------------------	------------------

4200

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
036000	187HA		3998134	1	1	1	1	1	0	1					

CHANGE MOD REQ D	H W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
1	2	1	3	7	8	121478		1036N	03	00004:0

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A C T	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4	MO DAY YR	MO DAY YR	50 51 52 53	58 59	66 67	73 74	80
8	0	7	A	12/15/78	12/14/78	1	000040	

TXN CD	A C T	RESOLUTION DESCRIPTION		
1	4			
8	0	1	A	07 CAL CONTROL ROOM INDICATOR AND LOOP CHECK
8	0	1	A	08 KED SPEED CIRCUIT
8	0	1	A	09
8	0	1	A	10

TXN CD	A C T	NPRD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY
1	4	YR MO DAY HR MIN	48 49	50	
8	0	8	A		

TXN CD	A C T	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
1	4	39 40	41 42 43	A B	A B	55 56 57 58	A B	YR MO DAY
8	0	8	A					

12-2-35

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	LOG NO				MO	DAY	YR	
FW	P			036002CM		C0173	12	13	78	1A

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

FW-P-18	SPEED INDICATOR NEEDS CALIBRATION
G, IT DOES NOT GO TO ZERO WITH THE FEED	
PUMP COMPLETELY STOPPED	
OOS STICKER 389	

CAUSE OF MALFUNCTION (IF KNOWN)

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

ORIGINATOR'S EMP. NO. 06301	ORIGINATOR'S SIGNATURE <i>C Adams</i>	DATE 12-13-78	SUPERVISOR'S EMP. NO. 06301	SUPERVISOR'S SIGNATURE <i>C Adams</i>	DATE 12-13-78
---------------------------------------	--	-------------------------	---------------------------------------	--	-------------------------

4200

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION							NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
036000	0187HA		3998134	1	1	1	1	0	1						

U-1/2/3/4 MOD REQ D	R W P	NUC SAFETY	NP RO	REG AGENCY CODE	CHG/MOD NUMBER
0	0	0	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
12	13	78

PRIORITY	RESP LOCATION OR CONTRACTOR
	1036W

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

Speed indicator goes to zero when pump is stopped

**GPU TEST
SUPT. APPROVAL
J Faulkner 12/13/78**

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0173

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date


7. Plant status or prerequisite conditions required for work. Operating or shutdown
8. QC Dept. review, if required in item No. 3

QC Supervisor _____ Date _____

9. Supervisor of Maintenance approval to commence work: W. Metzger Date 12/13/78

10. Maintenance Foreman Assigned: Albert

11. Shift Foreman's approval to commence work C. Guthrie Date 12-14-78



Initial if Shift Foreman signature is not required

N/A
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 173

12. Retest me* acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature

Final Report 1330 12/14/78 J.P. Albert
Date

14. Work completed and component aligned for testing.
 Initial if S. F. signature is not required. C Guthrie 12-14-78
Shift Foreman's Signature Date

15. Testing completed and component released for normal use.
 Initial if S. F. signature is not required. C Guthrie 12-14-78
Shift Foreman's Signature Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No. N/A QC Department Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.
W. Metzger 12/15/78
Supervisor of Maintenance Signature Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION																	LOCATION / UNIT		JOB TYPE		JOB TICKET NUMBER		REQUEST DATE			RECOMMENDED PRIORITY
SYS	7	8	COMP TYPE		11	12	COMP ID		15	16	17			22	23	24	25			MO	DAY	YR				
EA			302	0001								036002	CM							C0249121578		2				

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

RADWASTE GAS ALARM AND ALARM FOR HAVS & GAS ANALYZER LOW FLOW IS IN, FLOW IS OK																						
REPAIR																						

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 05455	GUTHRIE	12-15-78	SUPERVISOR'S EMP. NO. 05455	GUTHRIE	12-15-78
ORIGINATOR'S SIGNATURE		DATE	SUPERVISOR'S SIGNATURE		DATE

4200

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER		PLANT CONDITION					NPRD FAILURE			START				
LOCATION	SERIAL				SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN	
036000187EA			3999134		11	11	11	11	11								

CHANGE MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0000							A			0000860

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER					PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR									

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	ACT	JOB COMPLETION DATE		FIELD WORK COMPLETION DATE			SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4	MO	DAY	YR	MO	DAY	YR				
807A		01	29	79	01	02	79	1	000040		

TXN CD	ACT	RESOLUTION DESCRIPTION																			
1	4																				
801A		07 FOUND REMOTE FLASHER WIRED WRONGE WIRED																			
801A		08 CORRECTLY																			
801A		09																			
801A		10																			

TXN CD	ACT	NPRD FAILURE END					FAILURE NO	FAILURE STATUS	ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN — JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE — CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY														
1	4	YR	MO	DAY	HR	MIN																	
808A																							

TXN CD	ACT	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES		EFFECT OF FAILURE CODES		FAILURE DETECTION CODE	ACTION TAKEN CODES		LICENSE EVENT REPORTED DATE				
1	4	39	40	41	42	43	50	51	55	56	57	58	65	66	71
808A															

124-22

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	UNIT				MO	DAY	YR
EA	30200D1			036002	CM	C0249	12	15	78

RECOMMENDED PRIORITY

2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

RADWASTE GAS ALARM AND ALARM FOR HAZAR
GAS ANALYZER LOW FLOW IS IN, FLOW IS OK
REPAIR

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.
 05455

GUTHRIE
 ORIGINATOR'S SIGNATURE

12-15-78
 DATE

SUPERVISOR'S EMP. NO.
 05455

[Signature]
 SUPERVISOR'S SIGNATURE

12-15-78
 DATE

4200

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION				NPRD FAILURE			START				
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
036000	187EA		3948134	1	1	1	1	0	1	1					

NUC REG'D	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER
0	0	0		

ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
A		

S/M APPROVAL COMMENCE WORK
 MO DAY YR
 12 29 78

RESP LOCATION OR CONTRACTOR
 203GN

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
 JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM


JOB TICKET NUMBER C0249

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes,
PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because
it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

_____ Unit Superintendent

_____ Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes No _____
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).


_____ Unit Superintendent/Supervisor of Operations

_____ Date

7. Plant status or prerequisite conditions required for work. Operating or shut down
8. QC Dept. review, if required in item No. 3

QC Supervisor _____

Date _____


9. Supervisor of Maintenance approval to commence work: DE Wzary/ga

Date 12/29/78

10. Maintenance Foreman Assigned: D. Weiner


11. Shift Foreman's approval to commence work C. Tullhue

Date 12-29-78



Initial if Shift
Foreman
signature is not required

14276



_____ Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER C0249

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature
Ellen Norman 12/30/78 0605 12/12/79 D. Wheeler
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

F. Schumann
Shift Foreman's Signature

1/12/79
Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

F. Schumann
Shift Foreman's Signature

1/11/79
Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No. N/A QC Department _____ Date _____

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

M. Metzger
Supervisor of Maintenance Signature

1/22/79
Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
 JOB-TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION										LOCATION / UNIT					JOB TYPE	JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY			
SYS	7	8	COMP TYPE		11	12	COMP ID		15	16	17	22	23	24	25	28		32	33	DAY	YR	38				
5	FE	7										0	3	6	0	0	2	CM					12	18	78	2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CONNECT ELECTRICAL SERVICES TO THE NEWLY RELOCATED UNIT 2 MAINT TRAILERS. LOCATED ON THE EAST SIDE OF UNIT 1 AND 2 CORRIDOR

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 06386	ORIGINATOR'S SIGNATURE <i>Metzger</i>	DATE <i>12/18/78</i>	SUPERVISOR'S EMP. NO. 06386	SUPERVISOR'S SIGNATURE <i>Metzger</i>	DATE <i>12/18/78</i>
---------------------------------------	--	-------------------------	---------------------------------------	--	-------------------------

WORK ORDER NUMBER 036000187AR	GC CODE	ACCOUNT NUMBER 3998134	PLANT CONDITION SU OP HD CD RF HS LR	NPRD FAILURE YR MO DAY	START HR MIN
---	---------	----------------------------------	---	---------------------------	-----------------

CHANGE MOD REQ'D	P W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			

S/M APPROVAL COMMENCE WORK MO DAY YR	S/F APPROVAL COMMENCE WORK MO DAY YR	PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
12 18 78	01 08 79			2C0769	02	000060

ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR EST CREW EST MANHOURS	ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR EST CREW EST MANHOURS	ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR EST CREW EST MANHOURS

TXN CD	ACT	JOB COMPLETION DATE MO DAY YR	FIELD WORK COMPLETION DATE MO DAY YR	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
807A		042779	326791	000060				

TXN CD	ACT	RESOLUTION DESCRIPTION
801A		07 INSTALLED CONDUIT & CABLE, CONNECTED AS
801A		08 REQUIRED
801A		09
801A		10

TXN CD	ACT	NPRD FAILURE END YR MO DAY HR MIN	FAILURE NO.	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
808A					

TXN CD	ACT	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES A B	EFFECT OF FAILURE CODES A B	FAILURE DETECTION CODE	ACTION TAKEN CODES A B	LICENSE EVENT REPORTED DATE YR MO DAY
808A								

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	MO				DAY	YR	
FE	*	*		036002	CM	02821	12	18	78

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CONNECT ELECTRICAL SERVICES TO THE NEWLY RELOCATED UNIT 2 MAINT TRAILERS LOCATED ON THE EAST SIDE OF UNIT 1 AND 2 CORRIDOR

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.
06386

Metzger 12/18/78
ORIGINATOR'S SIGNATURE DATE

SUPERVISOR'S EMP. NO.
06386

Metzger 12/18/78
SUPERVISOR'S SIGNATURE DATE

4200A 6721/529.9

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	187AR		3998134	1	1	1	1	1	0	1				

ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
X		

S/M APPROVAL COMMENCE WORK
MO DAY YR
12 18 78

RESP LOCATION OR CONTRACTOR
2C6869

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria

Work completed as per description section

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—
JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0282

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date


7. Plant status or prerequisite conditions required for work: Operating or shutdown
8. QC Dept. review, if required in item No. 3

QC Supervisor N/A Date _____

9. Supervisor of Maintenance approval to commence work: W. Metzger Date 12/18/78

10. Maintenance Foreman Assigned: W.M. DEAN

11. Shift Foreman's approval to commence work Amell Date 1-8-79



Initial if Shift Foreman signature is not required

NA
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0282

*

12. Retest met acceptance criteria

Yes No

13. Work Performed by date/time

3-26-79
J SCALES

Work Reviewed - Maintenance Foreman's Signature

3-26-79 J. J. Dean
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

[Signature] 3/26/79
Shift Foreman's Signature Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

[Signature] 3/26/79
Shift Foreman's Signature Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

NA
QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.


[Signature] 4-27-79
Supervisor of Maintenance Signature Date

*

INSTALLED 300' of 4" CONDUIT, 3-350' 250 MCM
CABLE, CONNECTED TO NEW LOAD CENTER.
CONNECTED FEEDERS TO TRAILERS.

INSTALLED 400' 1" CONDUIT FOR GAITRONICS
AND CONNECTED TO TRAILERS, UNITS ALSO.

INSTALLED 150' 1" CONDUIT FOR TELEPHONES.



REVNO.	12-1978	FIRST ISSUE	CFS	
DATE		DESCRIPTION	ENGR.	SUP. ENGR.
ENGINEER	CFS			
STATE REG.	NO.			

UNIT 2 MAINTENANCE TRAILER

THREE MILE ISLAND NUCLEAR STATION
UNIT NO. 2

JERSEY CENTRAL POWER & LIGHT COMPANY

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					REQUEST DATE		
SYS	COMP. TYPE		COMP. ID		NO.		LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					MO	DAY	YR								
6	7	9	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38		
SA	IT				00	01	03	06	00	02	CM																					

RECOMMENDED PRIORITY

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

EXCESSIVE PACKING LEAK

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 05712	ORIGINATOR'S SIGNATURE <i>E. Stuenkel</i>	DATE 12/27	SUPERVISOR'S EMP. NO. 05873	SUPERVISOR'S SIGNATURE <i>Amiller</i>	DATE 12-22-78
--------------------------------	--	---------------	--------------------------------	--	------------------

4200A 6721/530.7

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRO FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
036000	1874M		3998134	1	1	1	1	1	1	1					

CHANGE MOD. REQ. D.	RWP	NUC SAFETY	NP-RO	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
12	22	78						1036M	02000	040

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	ACT	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
807	A	021579		2B				

TXN CD	ACT	RESOLUTION DESCRIPTION
801	A	07
801	A	08
801	A	09
801	A	10

TXN CD	ACT	NPRO FAILURE END	FAILURE NO.	FAILURE STATUS	ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN — JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE — CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
808	A				

TXN CD	ACT	NPRO FAILURE TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
808	A							

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	MO				DAY	YR		
SR	P	0001B	036002	CM	C0335	12	22	78	1	

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

EXCESSIVE PACKING LEAK									

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 052412	<i>E. St. Martin</i> ORIGINATOR'S SIGNATURE	<i>12/24/78</i> DATE	SUPERVISOR'S EMP. NO. 05873	<i>A. Miller</i> SUPERVISOR'S SIGNATURE	<i>12-22-78</i> DATE
--	--	-------------------------	---------------------------------------	--	-------------------------

4200A 6721/530.7

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
0360	001874M		3998134	1	1	1	1	1	1					
CHANGE MOD REQ D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE						
0	0	0	0			X								

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
12	22	78

RESP LOCATION OR CONTRACTOR
1036M

Cancel

Limits and Precautions:

- a) Personnel **Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual;**
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria. *Leakage reduced to normal*

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					REQUEST DATE			RECOMMENDED PRIORITY
SYS					COMP TYPE					COMP. ID.																							
5	7	8	11	12	15	16	17	22	23	24	25	28	32	33	38	MO	DAY	YR															
0	3	6	0	0	0	2	3	0	3	6	0	0	2	0	4	1	2	1	2														

RECOMMENDED PRIORITY

2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

The VALVE IS ONLY PARTIALLY OPEN BUT THE LIMIT SWITCH THINKS IT IS FULL OPEN THIS IS A LARGE BUTTERFLY VALVE UP ON B COOLING TOWER

CAUSE OF MALFUNCTION (IF KNOWN)

MISPOSITIONED LIMIT SWITCH

ORIGINATOR'S EMP. NO.	<i>James R. Floyd</i>	DATE	12/13/78	SUPERVISOR'S EMP. NO.	<i>James R. Floyd</i>	DATE	12/13/78
03842	ORIGINATOR'S SIGNATURE			03842	SUPERVISOR'S SIGNATURE		

4200 - A6724-531.3

WORK ORDER NUMBER		GC CODE	ACCJUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
0360	00187NB			1	1	1	1	0	1	1					

CHANGE MOD REQ'D	R WP	NUC SAFETY	NP RD	REG. AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0			4206	X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRI	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
12	14	78	02	28	79			20364	02000	160

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A	C	T	JOB COMPLETION DATE			FIELD WORK COMPLETION DATE			SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER						
8	0	7	A	MO	DAY	YR	MO	DAY	YR	50	51	52	53	53	59	66	67	73	74	80
				03	23	79	02	28	79	1	00016									

TXN CD	A	C	T	RESOLUTION DESCRIPTION															
8	0	1	A	07 CHECK LIMITS & OPENING OF VALVE															
8	0	1	A	08 ADJUST PERCENT EXPILATUR TO READ PROPERLY															
8	0	1	A	09															
8	0	1	A	10															

TXN CD	A	C	T	NPRD FAILURE END					FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY											
8	0	8	A	YR	MO	DAY	HR	MIN	48	49	50											

TXN CD	A	C	T	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES		EFFECT OF FAILURE CODES		FAILURE DETECTION CODE	ACTION TAKEN CODES		LICENSE EVENT REPORTED DATE				
8	0	8	A	39	40	41	42	43	50	51	55	56	57	58	65	66	71

GENERATION CORRECTIVE MAINTENANCE SYSTEM—
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION/UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	MO				DAY	YR		
CW	V	00643B		036002	CM	0204	12	13	78	2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

The VALVE is only partially open but the LIMIT SWITCH THINKS IT IS FULL OPEN. This is a large butterfly valve up on B COOLING TOWER.

CAUSE OF MALFUNCTION (IF KNOWN)

MISPOSITIONED LIMIT SWITCH

ORIGINATOR'S EMP. NO. 03842	<i>James R Floyd</i> ORIGINATOR'S SIGNATURE	12/13/78 DATE	SUPERVISOR'S EMP. NO. 03842	<i>James R Floyd</i> SUPERVISOR'S SIGNATURE	12/13/78 DATE
--------------------------------	--	------------------	--------------------------------	--	------------------

4100 A6724-531.3

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	187NB		3778134	1	1	1	1	0	1					

ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
X		

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
12	14	78

PRIORITY	RESP LOCATION OR CONTRACTOR
	20364

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

Limit switch is adjusted to allow valve to fully open & close

GPU TEST
SUPT. APPROVAL
7 Jan 12/14

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—
JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0204

- 1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1003. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
- 4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
- 6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date

- 7. Plant status or prerequisite conditions required for work: Operating or shutdown
- 8. QC Dept. review, if required in item No. 3
QC Supervisor N/A Date N/A
- 9. Supervisor of Maintenance approval to commence work: W. Metz Date 12/14/78
- 10. Maintenance Foreman Assigned: C. Ruppion Jr 60

11. Shift Foreman's approval to commence work C. G. Guthrie Date 2/28/79

Initial if Shift Foreman signature is not required

N/A

Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0201

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature
John Watts 2-28-79 [Signature]
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required. C. Guthrie 2-28-79
Shift Foreman's Signature Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required. C. Guthrie 2-28-79
Shift Foreman's Signature Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No. N/A QC Department Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.
[Signature] 3/23/79
Supervisor of Maintenance Signature Date

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0436

- 1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes No _____
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes No _____
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes No _____
- 4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
- 6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date


- 7. Plant status or prerequisite conditions required for work. Shutdown
- 8. QC Dept. review, if required in item No. 3

QC Supervisor W. Shoemaker by telecon Date 12-29-78

- 9. Supervisor of Maintenance approval to commence work: B. White for W. Shoemaker Date 12-29-78

- 10. Maintenance Foreman Assigned: B. White page 62

- 11. Shift Foreman's approval to commence work C. Adas Date 12-29-78



Initial if Shift Foreman signature is not required

NA
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER C-0436

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature
WAGNER 12-29-78
HUNTER 1100 12-29-78 [Signature]
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

C Ada

Shift Foreman's Signature

12-29-78

Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

C Ada

Shift Foreman's Signature

12-29-78

Date

16. Quality Control Department review of work and testing completed (QC work only).

MA 628
Surveillance Report No.

[Signature]
QC Department

1/3/79
Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

[Signature]
Supervisor of Maintenance Signature

1/5/79
Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION										LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					REQUEST DATE			RECOMMENDED PRIORITY
SYS	7	8	COMP. TYPE	11	12	COMP. ID	15	16	17	22	23	24	25	28	32	33	MO	DAY	YR	38								
5			V			0001				036002	CM						12	28	78		1							

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

LIMIT SWITCH CONTACT 6 ON RC-VI SHOULD BE CLOSED WHEN VALVE IS CLOSED. WHEN THE VALVE IS CLOSED, THIS CONTACT DOES NOT CLOSE.

CAUSE OF MALFUNCTION (IF KNOWN)

ROTOR FOR CONTACT 6 IS OUT OF ADJUSTMENT

ORIGINATOR'S EMP. NO.
06850

J. DeLuca
ORIGINATOR'S SIGNATURE

12-28-78
DATE

SUPERVISOR'S EMP. NO.
06550

J. DeLuca
SUPERVISOR'S SIGNATURE

12-28-78
DATE

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION				NPRD FAILURE			START					
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN	
0360001870A			3994134	00	11	10	00									

CHANGE MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
					0110		X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER				P R I O R I T Y	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR								
12	29	78	12	29	78	1420-410	REV-0	10364	02000160				

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A C T	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
		MO DAY YR	MO DAY YR					
807A		010579	122978	1	000040			

TXN CD	A C T	RESOLUTION DESCRIPTION
801A		07 VALVE CYCLED PROPERLY THE PROBLEM WAS FOUND TO BE AN OPEN LINK AT THE PATCH PANEL
801A		08 FOUND TO BE AN OPEN LINK AT THE PATCH PANEL
801A		09 L. CLOSED LINK, CIRCUIT NOW FUNCTIONS AS
801A		10 PER DESIGN

TXN CD	A C T	NPRO FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
		YR MO DAY HR MIN			
808A			48	49	

TXN CD	A C T	NPRO FAIL TYPE	NPRO FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
		39	40	41 42 43	50 51	55 56 57 58	A B	YR MO DAY
808A								

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP. ID.	TO DO				MO	DAY	YR	
RC	V	0001		03600	2CM	C0436	12	28	78	1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

LIMIT SWITCH CONTACT 6 ON RC-VI SHOULD BE CLOSED WHEN VALVE IS CLOSED. WHEN THE VALVE IS CLOSED, THIS CONTACT DOES NOT CLOSE.

CAUSE OF MALFUNCTION (IF KNOWN)

ROTOR FOR CONTACT 6 IS OUT OF ADJUSTMENT

ORIGINATOR'S EMP. NO. 06850	<i>J. D. Lawton</i> ORIGINATOR'S SIGNATURE	12-28-78 DATE	SUPERVISOR'S EMP. NO. 06850	<i>J. D. Lawton</i> SUPERVISOR'S SIGNATURE	12-28-78 DATE
--------------------------------	---	------------------	--------------------------------	---	------------------

4200

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
03600	00187CA		3998134	001	1	0	0							

REG. AGENCY CODE	CHG/MOD NUMBER	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
0110		X		

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
12	29	78

P R I O R	RESP. LOCATION OR CONTRACTOR
	1036L

Comply with the Provisions set forth in AP1002, AP1003 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

As per sect. 7.0 in procedure 1420-Y-10

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					REQUEST DATE			RECOMMENDED PRIORITY
SYS	7	9	COMP. TYPE	11	12	COMP. ID	15	16	17	22	23	24	25	26	27	28	29	30	31	32	33	MO	DAY	YR									
5	7	9																															

RECOMMENDED PRIORITY
1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

RB NORMAL COOLING UNIT 'A' HAS CONTINUOUS LOW PAN TEMP ALARM. VERIFIED HTR EKR CLOSED + SPRAY PUMPS ON. LOCAL TEMP MEASURE WAS 59°F REPAIR

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 05455	ORIGINATOR'S SIGNATURE <i>GUTHRIE</i>	DATE 12/31/78	SUPERVISOR'S EMP. NO. 05455	SUPERVISOR'S SIGNATURE <i>GUTHRIE</i>	DATE 12/31/78
--------------------------------	--	------------------	--------------------------------	--	------------------

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
0360	00187	FA	5305	1	1	1	1	1	0	1					

CHANGE MOD REG D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
0	1	0	0	1	0			1036A	02	000120

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A	C	T	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4			MO DAY YR	MO DAY YR	50 51	52 53	58 59	66 67	73 74
807A				010579	010478	1	000120			

TXN CD	A	C	T	RESOLUTION DESCRIPTION
1	4			
801A				07 RESET AND CAL. PAN TEMP SWITCHES
801A				08
801A				09
801A				10

TXN CD	A	C	T	NPRD FAILURE END	FAILURE NO.	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY
1	4			YR MO DAY HR MIN	48 49	50	
808A							

TXN CD	A	C	T	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
1	4			39 40	41 42	43	50 51	55 56 57	58	65 66
808A										

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	MO				DAY	YR	
RB	≡	0001A	036002	CM	C0468	12	31	78	

RECOMMENDED PRIORITY

1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

RB NORMAL COOLING UNIT 'A' HAS CONTINUOUS LOW PAN TEMP. ALARM. VERIFIED HTR BKR CLOSED & SPRAY PUMPS ON. LOCAL TEMP. MEASURE WAS 59°F. REPAIR

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.
05455

GUTHRIE
ORIGINATOR'S SIGNATURE

12/31/78
DATE

SUPERVISOR'S EMP. NO.
05455

GUTHRIE
SUPERVISOR'S SIGNATURE

12/31/78
DATE

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	187	FA	5305	1	1	1	1	0	1					

CHANGE MOD REG D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER
0	0	0	0		

ENV CODE	DUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK

MO	DAY	YR
01	02	79

RESP. LOCATION OR CONTRACTOR

1	0	3	6	A
---	---	---	---	---

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Post Maintenance Testing required and Acceptance Criteria. UNIT WORKS PROPERLY

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

COPY 1

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0468

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date


7. Plant status or prerequisite conditions required for work. Open S/D
8. QC Dept. review, if required in item No. 3

QC Supervisor _____ Date _____

9. Supervisor of Maintenance approval to commence work: E. Showalter Date 1/2/79

10. Maintenance Foreman Assigned: G. L. Best

11. Shift Foreman's approval to commence work A Miller Date 1-4-79



Initial if Shift Foreman signature is not required

116
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0468

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature

Riggowbac L/SCLAIR 1430 1-4-79 JF [Signature]
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

[Signature] 1-4-79
Shift Foreman's Signature Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

[Signature] 1-4-79
Shift Foreman's Signature Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No. N/A QC Department Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

[Signature] 1/5/79
Supervisor of Maintenance Signature Date

JOB TICKET (WORK REQUEST)
 REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0478

1. Does work represent a change or modification to an existing system or component?
 If yes, an approved change modification is required per AP 1021.
 C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes No _____
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No

4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

*

[Signature] 1/31/79
 Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

 Unit Superintendent/Supervisor of Operations Date


7. Plant status or prerequisite conditions required for work. operating or shutdown

8. QC Dept. review, if required in item No. 3 688
 QC Supervisor [Signature] Date 1/9/79

9. Supervisor of Maintenance approval to commence work: E. Showalter Date 1/10/79

10. Maintenance Foreman Assigned: _____

11. Shift Foreman's approval to commence work [Signature] Date 1/15/79



Initial if Shift Foreman signature is not required

 Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER _____

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature
1/26/79
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

J. Scheumann
Shift Foreman's Signature

1/26/79
Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

J. Scheumann
Shift Foreman's Signature

1/26/79
Date

16. Quality Control Department review of work and testing completed (QC work only).

AVA
Surveillance Report No.

Edonis
QC Department

4/18/79
Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

R. Fontana
Supervisor of Maintenance Signature

4/20/79
Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION																	LOCATION / UNIT			JOB TYPE			JOB TICKET NUMBER			REQUEST DATE			RECOMMENDED PRIORITY					
SYS	7	8	COMP. TYPE		11	12	COMP. ID.		15	16	17	22	23	24	25	JOB TICKET NUMBER		28	32	33	34	35												
3	A		1	9	0	0	F	1				0	3	6	0	0	2	C	M				C	0	4	7	8	1	2	3	1	7	8	2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CONTROL ROOM PANEL 19 ALARM E-1 SHOULD NOT BE IN. INVESTIGATE

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 0 3 4 1 6	ORIGINATOR'S SIGNATURE <i>M. B. Polino</i>	DATE 12/31/78	SUPERVISOR'S EMP. NO. 0 6 7 0 1	SUPERVISOR'S SIGNATURE <i>C. Ado</i>	DATE 12/31/78
------------------------------------	---	------------------	------------------------------------	---	------------------

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
0360	0018762		5306	1	1	1	1	1	0	1					

CHANGE MOD REC'D	H W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			100

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	P R I O R I T Y	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
01	10	79	01	15	79	1430-421 Rev-1	2	2051	01000	060

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A C T	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER					
1	4	MO	DAY	YR	MO	DAY	YR	MO	DAY	YR			
807	A	042079	033179	6	000060								

TXN CD	A C T	RESOLUTION DESCRIPTION
1	4	
801	A	07 Repaired by Leb. ECM Department.
801	A	08
801	A	09
801	A	10

TXN CD	A C T	NPRD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR	SUPERVISOR	SUPERVISOR OF MAINTENANCE	MAINTENANCE FOREMAN	JOB PERFORMER	MAINTENANCE FOREMAN	SUPERVISOR OF MAINTENANCE	CM COORDINATOR	DATA ENTRY	SUPERVISOR OF MAINTENANCE	CM COORDINATOR	DATA ENTRY
1	4	YR	MO	DAY	HR	MIN	48	49	50							
808	A															

TXN CD	A C T	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE										
1	4	39	40	41	42	43	50	51	55	56	57	58	A	B	YR	MO	DAY	71
808	A																	

130-6

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	MO				DAY	YR	
Z A		1900 F1		036.002 CM		0478	12	31	78

RECOMMENDED PRIORITY

2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CONTROL ROOM PANEL 19 ALARM E-1 SHOULD NOT T B E I N . I N V E S T I G A T E

CAUSE OF MALFUNCTION (IF KNOWN)

--

ORIGINATOR'S EMP. NO.
02416

M. L. Polino 12/31/78
ORIGINATOR'S SIGNATURE DATE

SUPERVISOR'S EMP. NO.
06701

C. R. De 12-31-78
SUPERVISOR'S SIGNATURE DATE

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
0360	0018762		5306	1	1	1	1	0	1					

W	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER
0	0	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK
MO DAY YR
011079

RESP LOCATION OR CONTRACTOR
220J1

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria. *Mounting as per sect. 6.11 in procedure 1430-Y-21*

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY								
SYS	COMP TYPE		COMP ID												MO	DAY	YR																
5	7	8	11	12	13	14	15	16	17	22	23	24	25	28	32	33	38																
T	F									0	3	6	0	0	2	C	M																2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CAUSE OF MALFUNCTION (IF KNOWN)

WTP-19-4 AND 3 DO NOT START AUTOMATICALLY AND WHEN STARTED MANUALLY THEY ARE VERY NOISY THEY SOUND LIKE THEY ARE NOT PUMPING

SUMP HAD ERSIN IN IT LAST WEEK AND WAS CLEANED OUT BUT PUMPS PROBABLY HAVE SOME

ORIGINATOR'S EMP. NO. 05749	ORIGINATOR'S SIGNATURE <i>Donald A. Berry</i>	DATE 1-2-79	SUPERVISOR'S EMP. NO. 05749	SUPERVISOR'S SIGNATURE <i>Donald A. Berry</i>	DATE 1-2-79
--------------------------------	--	----------------	--------------------------------	--	----------------

A1721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION					NPRD FAILURE			START				
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN	
036000187H5			5307	1	1	1	1	0	1							
CHANGE MOD REQ'D	R W P	N/A SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS						
0	0	0	0				X									

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
01	03	79						2036N		

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A	C	T	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
807A				MO DAY YR	MO DAY YR					
				012579		2A				

TXN CD	A	C	T	RESOLUTION DESCRIPTION
801A				07
801A				08
801A				09
801A				10

TXN CD	A	C	T	NPRD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
808A				YR MO DAY HR MIN	48	49	50

TXN CD	A	C	T	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE							
808A				39	40	41	42	43	50	51	55	56	57	58	65	66	71

128-10

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID.	MO				DAY	YR		
WT	P	0014		036002	CM	C0488	01	02	79	2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

WTP-14-A AND B DO NOT START AUTOMATICALLY, AND WHEN STARTED MANUALLY THEY ARE VERY NOISY THEY SOUND LIKE THEY ARE NOT PUMPING

CAUSE OF MALFUNCTION (IF KNOWN)

SUMP HAD RESIN IN IT LAST WEEK AND WAS CLEANED OUT BUT PUMPS PROBABLY HAVE SOME

ORIGINATOR'S EMP. NO.
05749

Donald G. Berry
ORIGINATOR'S SIGNATURE DATE 1-2-79

SUPERVISOR'S EMP. NO.
05749

Donald G. Berry
SUPERVISOR'S SIGNATURE DATE 1-2-79

AG721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	M	D	RF	HS	LR	YR	MO	DAY	HR
036000	187HE		5307	1	1	1	1	0	1					

CHANGE MOD REQ'D	R W P	NUC SAFETY	NP PD	REG AGENCY CODE	CHG/MOD NUMBER
0	0	0	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK
MO DAY YR
01 03 79

RESP. LOCATION OR CONTRACTOR
2036N

Cancel

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

Pumps operate as designed

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE				JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY
SYS		COMP TYPE			COMP ID		LOCATION / UNIT					JOB TYPE				JOB TICKET NUMBER				MO	DAY	YR									
5	7	8	11	12	15	16	17	22	23	24	25	28	32	33	38	32	33	38													
0	0	4						0	3	6	0	0	2	C	M	C	0	4	9	0	0	1	0	2	7	9	1				

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CAUSE OF MALFUNCTION (IF KNOWN)

ACID CONCENTRATION INDICATION FOR DMLIST
ER REGENERATION IS NOT FUNCTION PROPERLY
EITHER THE RECORDER IS OUT OF CALIB OR
THE PROBE IS BAD

ORIGINATOR'S EMP. NO.	ORIGINATOR'S SIGNATURE	DATE	SUPERVISOR'S EMP. NO.	SUPERVISOR'S SIGNATURE	DATE
05749	Donald A. Berry	11/27/79	05749	Donald A. Berry	11/27/79

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION				NPRD FAILURE			START					
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN	
0360001874E	5307			1	1	1	0	1								

CHANGE MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			000050

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER				P R I O R I T Y	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR								
01	03	79	01	03	79					1036N	01	000040	

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A C T	JOB COMPLETION DATE		FIELD WORK COMPLETION DATE		SIGN OFF REASON CODE		TOTAL ACTUAL MANHOURS		PURCHASE REQUISITION NUMBER		PURCHASE ORDER NUMBER		MATERIAL ORDER NUMBER	
1	4	MO	DAY	YR	MO	DAY	YR								
807A		01	25	79	01	12	79	1	000100						

TXN CD	A C T	RESOLUTION DESCRIPTION												
1	4													
801A		07 REPLACED FRAYED CORD FOR #2 PEN AND RECA												
801A		08 LIBERATED REGORDSR. PUT BACK IN SERVICE												
801A		09												
801A		10												

TXN CD	A C T	NPRD FAILURE END					FAILURE NO.	FAILURE STATUS	ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN — JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE — CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY							
1	4	YR	MO	DAY	HR	MIN										
808A							48	49	50							

TXN CD	A C T	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES		EFFECT OF FAILURE CODES		FAILURE DEFECT CODE	ACTION TAKEN CODES		LICENSE EVENT REPORTED DATE				
1	4	39	40	41	42	43	50	51	55	56	57	58	65	66	71
808A															

128-12

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	UNIT				MO	DAY	YR	
C0	*	*		036002	CM	C0496	01	02	79	1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

ACID CONCENTRATION INDICATION FOR POLISH
ER REGENERATION IS NOT FUNCTION PROPERLY
EITHER THE RECORDER IS OUT OF CALIB OR
THE PROBE IS BAD

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 05749	<i>Donald A. Berry</i> ORIGINATOR'S SIGNATURE	1/2/79 DATE	SUPERVISOR'S EMP. NO. 05749	<i>Donald A. Berry</i> SUPERVISOR'S SIGNATURE	1/2/79 DATE
--------------------------------	--	----------------	--------------------------------	--	----------------

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
03600	01874E		5307	1	1	1	1	1	0	1				

CHNG MOD REC'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
0	0	0	0			X		

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
01	03	79

P R I O R I T Y	RESP LOCATION OR CONTRACTOR
	1036N

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

Functions as designed

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—
JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0490

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).


Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date

7. Plant status or prerequisite conditions required for work. Operating or shutdown
8. QC Dept. review, if required in item No. 3
QC Supervisor _____ Date _____
9. Supervisor of Maintenance approval to commence work: W. Metzger Date 1/3/79
10. Maintenance Foreman Assigned: Bennett

11. Shift Foreman's approval to commence work W. Bennett Date 1/3/79



Initial if Shift
Foreman
signature is not required

Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0490

12. Retest met acceptance criteria

Yes No

13. Work Performed by date/time

Work Reviewed - Maintenance Foreman's Signature

GILBERT

1/12/79
Date

[Signature]

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

[Signature]
Shift Foreman's Signature

1/15/79
Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

[Signature]
Shift Foreman's Signature

1/15/79
Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

N/A
QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

[Signature]
Supervisor of Maintenance Signature

1/25/79
Date

CR-7373
WT-FR ~~7217~~
BECKMAN INSTRAMATIC

GENERATION CORRECTIVE MAINTENANCE SYSTEM
 JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP. TYPE	COMP. ID	MO				DAY	YR	
DH	V	0008		036002	CM	C04950	10	4	79

RECOMMENDED PRIORITY

2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

PROVIDE ALARM ON PNL 8 WHEN BWST LEVEL I
 SLOW OR ES TEST SWITCH IS IN TEST POSIT
 ION PER ECM S-5970 REV 4

CAUSE OF MALFUNCTION (IF KNOWN)

TO GIVE CRO BETTER INDICATION OF STATUS
 FOR DH-Y-8A/B INTERLOCK WITH BWST LEVEL

ORIGINATOR'S EMP. NO.
 06638

James R. Pauls
 ORIGINATOR'S SIGNATURE
 1/4/79
 DATE

SUPERVISOR'S EMP. NO.
 06638

James R. Pauls
 SUPERVISOR'S SIGNATURE
 1/4/79
 DATE

46721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	187CE		5302	1	1	1	1	0	1					

CHANGE REQ'D	R W P	NUC SAFETY	NR RD	REG AGENCY CODE	CHG/MOD NUMBER
1	0	1	0		00310

OK Tony

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK
 MO DAY YR
 03 27 79

RESP LOCATION OR CONTRACTOR
 2036L

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria: *WIRING COMPLETED AND FUNCTIONS AS PER DESIGN OF ECM S-5970 REV 4*

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—
 JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

COPY 1

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0495

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. 2-0310 Yes No
- 2a. Does work require an RWP Yes No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes No
- 3a. Is work on a QC component as defined in GP 1008. Yes No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date

7. Plant status or prerequisite conditions required for work. operating or shutdown
8. QC Dept. review, if required in item No. 3

QC Supervisor [Signature] Date 3/12/79

9. Supervisor of Maintenance approval to commence work: E. Showalter Date 3/12/79

10. Maintenance Foreman Assigned: [Signature] (page 68)

11. Shift Foreman's approval to commence work [Signature] Date 3/26/79

Initial if Shift
Foreman
signature is not required

N/A
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER C-0495

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature
WAGNER 3-27-79 BYRitt
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required. C. Guthrie 3/27/79
Shift Foreman's Signature Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required. C. Guthrie 3/27/79
Shift Foreman's Signature Date

16. Quality Control Department review of work and testing completed (QC work only).
N/A OTK [Signature] 5/1/79
Surveillance Report No. QC Department Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.
[Signature] 5/4/79
Supervisor of Maintenance Signature Date

WORK REQUEST PROCEDURE
TMI Nuclear Station
Maintenance Procedure Format and Approval

WR C-0495

Unit No. 2

This form outlines the format and acts as a cover sheet for a maintenance procedure. Due to the limited size of the form, additional pages may be attached as required. Work Request procedure A.P 1016 Section 6 should be used as a guide in preparing the maintenance procedure.

1. Procedure Title & No.:
ADD ALARM ON PNL 8 FOR DH-V-8A/B
IN TEST POSITION WHEN BUST LEVEL IS LOW AS PER
ECM-5976 REV 4 FQ 2679

2. Purpose:
PROVIDE GUIDANCE FOR ABOVE

3. Description of system or component to be worked on.
DH-V-8A/B TEST SWITCH

4. References:
ATTACHED FQ 2679
ECM 5-5970 R 4

5. Special Tools, and Materials required.
NONE

6. Detailed Procedure (attach additional pages as required)
SEE ATTACHED

Supervisor of Maintenance recommends approval D. Shouler Date 2-26-79

* PORC RECOMMENDS APPROVAL

Unit No. 1 Chairman [Signature] Date Unit No. 2 Chairman R. Warner Date 3/5/79

* UNIT SUPERINTENDENT APPROVAL

Unit No. 1 [Signature] Date Unit No. 2 [Signature] Date 3/6/79

* Standing Procedure _____ Supervisor of QC _____ Date _____

*Note: These approvals required only on Nuclear Safety Related/Radiation work permit jobs.

6.0 Procedure

- 6.1 Obtain Shift Supervisor/Shift Foreman permission to begin work.
- 6.2 Tag or isolate as necessary to provide personnel and equipment safety.
- 6.3 Terminate spare wires of cable MA-259C in conpt. 9AF/MCC-2-11EA & Cont. Pul 8 (TB-C-11)
- 6.4 Terminate 2 spare wires of cable MB-279C in conpt. 11AF/MCC 2-21EA & Cont. Pul, 8 (TB-C)
- 6.5 Add jumpers between conpts 2DR & 9AF of MCC 2-11EA and between conpts. 4BR & 11AF of MCC 2-21EA.
- 6.6 In control pul 8 remove jumper between TB-CA-13 & CA-14 and add jumper between TB-CA-13 & TB-C-12.
- 6.7 Add window in Pul 8 alarm window B17 engraved "BWST LEVEL LOW OR ES TEST SW. ACTUATED"
- 6.8 Prove logic of alarm circuit and notify Shift Supervisor/Shift Foreman that the new alarm circuit has been added as per FQ 2679 and ECM S-5970 R4.
- 6.9 Remove tags if necessary.

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION										LOCATION / UNIT					JOB TYPE				JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP. TYPE		COMP. ID.			LOCATION / UNIT					JOB TYPE				JOB TICKET NUMBER				MO	DAY	YR					
5	7	8	11	12	13	14	15	16	17	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	

SR 4 0003 036002 CM C 7496010379 1

REPLACE LUBE WATER STRAINER CARTRIDGES - SUSPECTED CLOGGED

VERY DIRTY RIVER WATER

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 05973	ORIGINATOR'S SIGNATURE <i>A Miller</i>	DATE 1-3-79	SUPERVISOR'S EMP. NO. 05873	SUPERVISOR'S SIGNATURE <i>A Miller</i>	DATE 1-3-79
--------------------------------	---	----------------	--------------------------------	---	----------------

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
036000187	HM	5307		1	1	1	1	0	1	1					

CHANGE MOD REQ D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			1000180

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRI OR Y	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
01	04	79	01	08	79			1036M	020	0008:0

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	ACT	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4	MO DAY YR	MO DAY YR	50 51 52 53	58 59	66 67	73 74	80
807A		011079	010879	1	0004:0			

TXN CD	ACT	RESOLUTION DESCRIPTION
1	4	
801A		07 CHANGED FILTERS
801A		08
801A		09
801A		10

TXN CD	ACT	NPRD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR C/F MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY
1	4	YR MO DAY HR MIN	48 49	50	
808A					

TXN CD	ACT	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
1	4	39 40	41 42 43	50 51	55 56 57 58		A B	YR MO DAY
808A								

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION:				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP. ID	MOD ID				MO	DAY	YR	
SR	U	0003		036002	CM	C04960	01	03	79	1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

REPLACE LUBE WATER STRAINER CARTRIDGES - SUSPECTED CLOGGED
--

CAUSE OF MALFUNCTION (IF KNOWN)

VERY DIRTY RIVER WATER

ORIGINATOR'S EMP. NO.
05873

A Miller
ORIGINATOR'S SIGNATURE

1-3-79
DATE

SUPERVISOR'S EMP. NO.
05873

A Miller
SUPERVISOR'S SIGNATURE

1-3-79
DATE

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	187HM		5307	1	1	1	1	1	0	1				

CHG/MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER
0	0	0	0		

ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
X		

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
01	04	79

P R I O R I T Y	RESP. LOCATION OR CONTRACTOR
	1036M

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

Strainers cleaned - DP is within limits

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—
JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

COPY 1

JOB TICKET (WORK REQUEST)
 REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0496

1. Does work represent a change or modification to an existing system or component?
 If yes, an approved change modification is required per AP 1021.
 C/M No. _____ Yes _____ No
- 2a. Does work require an RW^D Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).


 Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

 Unit Superintendent/Supervisor of Operations Date

7. Plant status or prerequisite conditions required for work.
8. QC Dept. review, if required in item No. 3 Operating or shutdown
 QC Supervisor N/A Date _____
9. Supervisor of Maintenance approval to commence work: [Signature] Date 1/4/79
10. Maintenance Foreman Assigned: [Signature]

11. Shift Foreman's approval to commence work [Signature] Date 1-8-79



Initial if Shift Foreman signature is not required

N/A
 Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0490

12. Retest met acceptance criteria

Yes No

13. Work Performed by date/time

Work Reviewed - Maintenance Foreman's Signature

1-8-79
Date

[Signature]

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

[Signature]

Shift Foreman's Signature

1-8-79
Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

[Signature]

Shift Foreman's Signature

1-8-79
Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

N/A
QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

[Signature]

Supervisor of Maintenance Signature

1/10/79
Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE				JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY
SYS					COMP TYPE					COMP ID																					
5	7	8	11	12	15	16	17	22	23	24	25	28	32	33	38	MO	DAY	YR													
EF	*							036002	CM							01	04	79	2												

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

THE EF-P-1 COOLING WATER LINE DOWNSTREAM OF EF-V26 NEEDS TO BE PAINTED.

CAUSE OF MALFUNCTION (IF KNOWN)

PIPING IS RUSTING. LINE WAS NEVER PAINTED AFTER INSTALLATION.

ORIGINATOR'S EMP. NO.
06281

JEMorch
ORIGINATOR'S SIGNATURE
1/3/79
DATE

SUPERVISOR'S EMP. NO.
06281

JEMorch
SUPERVISOR'S SIGNATURE
1/3/79
DATE

A6721

WORK ORDER NUMBER				GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL					SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
0360	001974C			5307	1	1	1	1	0	1						

CHANGE MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
01	04	79						2036V		

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A	C	T	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
807	A			39 44 45	50 51 52	2	58 59	66 67	73 74	80

TXN CD	A	C	T	RESOLUTION DESCRIPTION
801	A			07
801	A			08
801	A			09
801	A			10

TXN CD	A	C	T	NPRD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN — JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE — CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
808	A			39 48 49	50		

TXN CD	A	C	T	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
808	A			39 40	41 42 43	50 51	55 56 57	58	65 66	71

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP. ID	REQ. NO.				MO	DAY	YR	
EF	*	*		036002CM		C0500	01	04	79	2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

THE EF-P-1 COOLING WATER LINE DOWNSTREAM OF EF-V26 NEEDS TO BE PAINTED.

CAUSE OF MALFUNCTION (IF KNOWN)

PIPE IS RUSTING. LINE WAS NEVER PAINTED AFTER INSTALLATION.

ORIGINATOR'S EMP. NO. 06281	<i>JEMorck</i>	DATE 1/3/79	SUPERVISOR'S EMP. NO. 06281	<i>JEMorck</i>	DATE 1/3/79
	ORIGINATOR'S SIGNATURE			SUPERVISOR'S SIGNATURE	

AG721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000187	HC		5387	1	1	1	0	1						

HASUL MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG MOD NUM	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
0	0	0	0			X		

S/M APPROVAL COMMENCE WORK

MO	DAY	YR
01	04	79

RESP LOCATION OR CONTRACTOR

2034V

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

Line painted

ORIGINATOR—SUPERVISOR—SUPERVISOR OF MAINTENANCE—MAINTENANCE FOREMAN—JOB PERFORMER—MAINTENANCE FOREMAN—SUPERVISOR OF MAINTENANCE

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 01002

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No _____
- 3a. Is work on a QC component as defined in GP 1008. ^M Yes No _____
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No

4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

J. B. Logan 1/11/79
Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No _____
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date

7. Plant status or prerequisite conditions required for work. OP or STD


8. QC Dept. review, if required in item No. 3

J. Daniels 1/16/79
QC Supervisor Date

9. Supervisor of Maintenance approval to commence work: W. Metzger Date 1/17/79

10. Maintenance Foreman Assigned: _____

11. Shift Foreman's approval to commence work C. Guthrie Date 1-20-79



Initial if Shift Foreman signature is not required

N/A
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0602

12. Retest met acceptance criteria

Yes No

13. Work Performed by date/time

WYNN

Work Reviewed - Maintenance Foreman's Signature

01/22/79
Date *M. Bennett*

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

C. Guthrie

Shift Foreman's Signature

1-22-79

Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

C. Guthrie

Shift Foreman's Signature

1-22-79

Date

16. Quality Control Department review of work and testing completed (QC work only).

NA
Surveillance Report No.

W. S. Palomib
QC Department

1/25/79
Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

W. Metzger
Supervisor of Maintenance Signature

1/26/79
Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TICKET NUMBER					REQUEST DATE			RECOMMENDED PRIORITY
SYS	7	8	COMP TYPE		11	12	COMP ID		15	16	17	JOB TYPE		JOB TICKET NUMBER			MO	DAY	YR									
CH	A			3	1	1	7		0	3	6	0	0	2	CM			C	0	6	0	2	0	1	0	8	7	9

RECOMMENDED PRIORITY
2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

COMPUTER POINT 3T17 IS IN ALARM CONDITION INDICATING A LOW VACUUM TRIP ON FW-H-1. THIS CONDITION DOES NOT EXIST.

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.

M. Loomis
 ORIGINATOR'S SIGNATURE

1-8-79
 DATE

SUPERVISOR'S EMP. NO.

C. Ades
 SUPERVISOR'S SIGNATURE

1-8-79
 DATE

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION					NPRD FAILURE		START				
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
036000	1876E		5306	1	1	1	1	1	0	1					

CHANGE MOD H/O/D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			000020

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER			RESP. LOCATION OR CONTRACTOR	EST. CREW SIZE	EST. MANHOURS
MO	DAY	YR	MO	DAY	YR						
01	17	79	01	20	79	1430-y-21	Rev.	12036N	01	00	020

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS	RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS	RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS

TXN CD	A	C	T
807A			

JOB COMPLETION DATE			FIELD WORK COMPLETION DATE			SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
MO	DAY	YR	MO	DAY	YR					
01	26	79	01	22	79	1	00040			

TXN CD	A	C	T
801A			
801A			
801A			
801A			

RESOLUTION DESCRIPTION

07 CALIBRATED FW-PS-3769-2. ALARM STATUS WA
 08 S BACKWARDS. REVERSED ALARM STATUS LOGIC
 09 POINT DISPLAYS CORRECTLY.
 10

TXN CD	A	C	T
808A			

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN — JOS PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE — CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY

TXN CD	A	C	T
808A			

NPRD FAILURE END		FAILURE NO.		FAILURE STATUS	EFFECT OF FAILURE CODES		FAILURE DETECTION CODE	ACTION TAKEN CODES		LICENSE EVENT REPORTED DATE
YR	MO	DAY	HR	MIN				A	B	YR MO DAY
				48	49	50				

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

132-20

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	MO				DAY	YR		
SH	A	3117		036002	CM	C06020	10	08	79	2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

COMPUTER POINT 3117 IS IN ALARM CONDITION INDICATING A LOW VACUUM TRIP ON FW-F-1. THIS CONDITION DOES NOT EXIST.

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.
06398

Mid Lopez
ORIGINATOR'S SIGNATURE

1-8-79
DATE

SUPERVISOR'S EMP. NO.
06301

C. Adams
SUPERVISOR'S SIGNATURE

1-8-79
DATE

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	18762		5306	1	1	1	1	0	1					

CHG/ MOD REG D	P W P	NUC SAFETY	HP RD	REG AGENCY CODE	CHG/ MOD NUMBER	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE
0000						X		

S/M APPROVAL COMMENCE WORK
MO DAY YR
011779

RESP. LOCATION OR CONTRACTOR
2036N

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Comply with the Provisions Section 6.11 of 1006 and 1006 Safety Manual

Post Maintenance Testing required and Acceptance Criteria.

points displays correctly and as per sect. 6.11 in procedure 1430-x-21

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

COPY 1

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					REQUEST DATE			RECOMMENDED PRIORITY		
SYS			COMP TYPE			COMP ID			LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					MO	DAY	YR									
5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37		38	39
A	H	C																																	

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

S	A	T	E	R	W	I	L	L	O	U	T	S	T	A	R	T	I	N	-	V	P	O	C	O											
M	A	N	V	A	L																														

CAUSE OF MALFUNCTION (IF KNOWN)

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

ORIGINATOR'S EMP. NO. 06713	ORIGINATOR'S SIGNATURE <i>Robert L. Barry</i>	DATE 11/15/79	SUPERVISOR'S EMP. NO. 05373	SUPERVISOR'S SIGNATURE <i>A. Miller</i>	DATE 1-15-79
--------------------------------	--	------------------	--------------------------------	--	-----------------

A6721

WORK ORDER NUMBER				GC CODE	ACCOUNT NUMBER				PLANT CONDITION				NPRD FAILURE			START				
LOCATION	SERIAL				NUMBER				SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
0360	001	77	F2	5305					1	1	1	1	0	1	1					

CHANGE MOD REQ'D	R WP	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			0000120

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER				P R I O R I T Y	RESP. LOCATION OR CONTRACTOR	EST. CREW SIZE	EST. MANHOURS
MO	DAY	YR	MO	DAY	YR								
01	16	79	01	27	79					2036L	01000	10:0	

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS	RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS	RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS

TXN CD	A CT	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4	MO DAY YR	MO DAY YR					
807A		0129790	0128791	000180				

TXN CD	A CT	RESOLUTION DESCRIPTION
1	4	
801A		07 REPLACED BURNT OUT SOLENOID COIL ON NR-V
801A		08 - 233J
801A		09
801A		10

TXN CD	A CT	NPRD FAILURE END	FAILURE NO.	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY
1	4	YR MO DAY HR MIN			
808A					

TXN CD	A CT	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
1	4	A B	A B	A B	YR MO DAY
808A					

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	MO				DAY	YR		
AH	C	0058	J	036002	CM	073001	15	79		

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

S	P	O	T	C	O	O	L	E	R	W	I	L	L	N	O	T	S	T	A	R	T	I	N	A	U	T	O	R					
M	A	N	N	A	L																												

CAUSE OF MALFUNCTION (IF KNOWN)

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

ORIGINATOR'S EMP. NO. 06793	<i>James R. Barry</i> ORIGINATOR'S SIGNATURE	DATE 1/15/79	SUPERVISOR'S EMP. NO. 05873	<i>A. Miller</i> SUPERVISOR'S SIGNATURE	DATE 1-15-79
--------------------------------	---	-----------------	--------------------------------	--	-----------------

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START				
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR		YR	MO	DAY	HR	MIN	
036000	187	F2	5305	1	1	1	1	0	1	1							

MCD REG D	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER
0	0	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
01	16	79

PRI	RESP. LOCATION OR CONTRACTOR
2	036L

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

Operate as designed

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0730

- 1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
- 4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
- 6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date


- 7. Plant status or prerequisite conditions required for work. operating or shutdown
- 8. QC Dept. review, if required in item No. 3

QC Supervisor _____ Date _____

- 9. Supervisor of Maintenance approval to commence work: W. Metzger Date 1/16/79

- 10. Maintenance Foreman Assigned: C. Kuppinger 62

- 11. Shift Foreman's approval to commence work J. Schumann Date 1/27/79



Initial of Shift Foreman signature is not required

NA
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0730

12. Retest met acceptance criteria Yes No

13. Work Performed by date/time Work Reviewed - Maintenance Foreman's Signature
Beyhat 1-28-79 [Signature]
Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required. [Signature] 1/28/79
Shift Foreman's Signature Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required. [Signature] 1/28/79
Shift Foreman's Signature Date

16. Quality Control Department review of work and testing completed (QC work only).
N/A
Surveillance Report No. QC Department Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.
[Signature] 1/29/79
Supervisor of Maintenance Signature Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					REQUEST DATE			RECOMMENDED PRIORITY					
SYS	COMP. TYPE	COMP. ID													22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38							
AS	PT	3500													0	3	6	0	0	2	CM						C	0	8	9	0	0	1	2	3	7	9	1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

AS - PIC - 3500 INDICATES > 60 PSI G WITH PT SENSING LINE VENTED. PT OUTPUT DROPS TO 0 WITH IA SECURED.

CAUSE OF MALFUNCTION (IF KNOWN)

PRESS. OVERRANGED ?

ORIGINATOR'S EMP. NO. 06225	ORIGINATOR'S SIGNATURE <i>E. Shwatter</i>	DATE 1/23/79	SUPERVISOR'S EMP. NO. 06225	SUPERVISOR'S SIGNATURE <i>EDS</i>	DATE 1/23/79
--------------------------------	--	-----------------	--------------------------------	--------------------------------------	-----------------

A6721

WORK ORDER NUMBER 036000187JN	GC CODE 5308	ACCOUNT NUMBER 5308	PLANT CONDITION 11111011	NPRD FAILURE YR MO DAY HR MIN	START HR MIN					
CHANGE MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	1	0	0				X			0000080

S/M APPROVAL COMMENCE WORK MO DAY YR	S/F APPROVAL COMMENCE WORK MO DAY YR	PROCEDURE NUMBER	RESP. LOCATION OR CONTRACTOR	EST. CREW SIZE	EST. MANHOURS
012379	012479		1036N	01	000080

ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS	ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS	ASSISTING DEPARTMENT RESP. LOCATION OR CONTRACTOR	EST. CREW	EST. MANHOURS

TXN CD	ACT	JOB COMPLETION DATE MO DAY YR	FIELD WORK COMPLETION DATE MO DAY YR	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
807A		012679	012479	1	000080			

TXN CD	ACT	RESOLUTION DESCRIPTION
801A		07 FOUND SPAN OF OUTPUT EXTREMELY HIGH BLEW
801A		08 OUT NOZZLE + FLAPPER ASSY, RECALIBRATED
801A		09 UNIT LOOP CHECKED TO TIC CONTROLLER, GOOD
801A		10

TXN CD	ACT	NPRD FAILURE END YR MO DAY HR MIN	FAILURE NO.	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY
808A			48	49	50

TXN CD	ACT	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES A B	EFFECT OF FAILURE CODES A B	FAILURE DETECTION CODE	ACTION TAKEN CODES A B	LICENSE EVENT REPORTED DATE YR MO DAY
808A								

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	MO				DAY	YR		
AS	PT	3500		036002	CM	C0890	01	23	79	1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

AS - PIC - 3500 INDICATES > 60 PSI G WITH PT
SENSING LINE VENTED, PT OUTPUT DROPS TO
0 WITH IA SECURED,

CAUSE OF MALFUNCTION (IF KNOWN)

PRESS. OVERRANGED ?

ORIGINATOR'S EMP. NO.
06225

E. Showalter / 1/23/79
ORIGINATOR'S SIGNATURE DATE

SUPERVISOR'S EMP. NO.
06225

EDS / 1/23/79
SUPERVISOR'S SIGNATURE DATE

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000	187JN		5308	1	1	1	1	0	1					

CHANGE MOD REQ D	R W P	NUC SAFETY	NP RO	REG AGENCY CODE	CHG/MOD NUMBER
0	1	0	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK
MO DAY YR
012379

PRI	RESP LOCATION OR CONTRACTOR
1	036N

Limits and Precautions:

a) Personnel

Comply with the Provisions set forth in AP1002, AP1003 and Hot Ed Safety Manual.

b) Equipment

c) Environment

d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

PT operates properly

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

COPY 1

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0890

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes No _____
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No _____
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No _____
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date


7. Plant status or prerequisite conditions required for work. OP or S/D
8. QC Dept. review, if required in item No. 3

QC Supervisor _____ Date _____

9. Supervisor of Maintenance approval to commence work: E. Shawalter Date 1/23/79

10. Maintenance Foreman Assigned: W. B. ...

11. Shift Foreman's approval to commence work F. J. Schumann Date 1/24/79



Initial if Shift Foreman signature is not required

N/A
Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER 0890

12. Retest met acceptance criteria

Yes No

13. Work Performed by date/time

R. SCHLEER - 1800

Work Reviewed - Maintenance Foreman's Signature

1/24/79
Date

[Signature]

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

[Signature]

Shift Foreman's Signature

1-25-79

Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

[Signature]

Shift Foreman's Signature

1-25-79

Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

N/A
QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

[Signature]

Supervisor of Maintenance Signature

1/26/79
Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION																	LOCATION / UNIT								JOB TYPE				JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY
SYS	7	8	COMP TYPE		11	12	COMP ID		15	16	17	LOCATION / UNIT				22	23	24	25	JOB TICKET NUMBER		28	32	33	MO	DAY	YR	38								
5	7	8																																		
5	7	8																																		

RECOMMENDED PRIORITY

2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

VALVE DID NOT OPEN TO SUPPLY BACK UP
LUBE WATER SOURCE

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 06800	ORIGINATOR'S SIGNATURE <i>Robert Conrad</i>	DATE 1/29/79	SUPERVISOR'S EMP. NO. 05478	SUPERVISOR'S SIGNATURE <i>KR Hart</i>	DATE 1/29/79
--------------------------------	--	-----------------	--------------------------------	--	-----------------

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START			
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR		YR	MO	DAY	HR	MIN
0360	00187149		5307	1	1	1	1	0	1	1						

CHANGE MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/ MOD NUMBER	TAGGING APPLICATION NO	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
							X			40

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
02	06	79						0360	02	20

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	ACT	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
39	4	MO DAY YR	MO DAY YR	50 51 52 53	58 59	66 67	73 74	80
807	A	021379		2A				

TXN CD	ACT	RESOLUTION DESCRIPTION
39	4	
801	A	07 SEE WR 9.36
801	A	08
801	A	09
801	A	10

TXN CD	ACT	NPRD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
39	4	YR MO DAY HR MIN	48 49	50	
808	A				

TXN CD	ACT	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
39	4	40	41 42 43	50 51	55 56 57 58		A B	65 66 YR MO DAY 71
808	A							

136-34

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	MO				DAY	YR		
SW	V	0020	036002	CM	C09570	01	29	79	2	
DESCRIBE MALFUNCTION OR MODIFICATION DESIRED VALVE DID NOT OPEN TO SUPPLY BACK UP LUBE WATER SOURCE										
CAUSE OF MALFUNCTION (IF KNOWN)										

ORIGINATOR'S EMP. NO.	<i>[Signature]</i>	ORIGINATOR'S SIGNATURE	DATE	1/29/79	SUPERVISOR'S EMP. NO.	<i>[Signature]</i>	SUPERVISOR'S SIGNATURE	DATE	1/29/79
06800					05498				

AG721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION							NPRD FAILURE			START			
LOCATION	SERIAL			SU	OP	HC	CD	RF	HS	LR		YR	MO	DAY	HR	MIN	
0360001	5749	5307		1	1	1	1	0	1								
CHG/ MOD REG. D	R W P	NUC SAFETY	RD	REG AGENCY CODE	CHG/ MOD NUMBER	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE									
0	8	0	0			X											

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR
02	06	79

PRIORITY	RESP. LOCATION OR CONTRACTOR
	2036N

Cancel

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

- Limits and Precautions:
- a) Personnel
 - b) Equipment
 - c) Environ
 - d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.
(ISI) procedure 2303-0737 applied after repair

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

136-2

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION/UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP IC	MO				DAY	YR	
ACS*		*		036002	CM	0956	01	30	79

RECOMMENDED PRIORITY

1

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

TERMINATE SPARE FIELD WIRES IN RTD HEAD FOR FOLLOWING RTD'S: RC15A-TE1; TE2; TE3; RC15B-TE1; TE2; TE3

CAUSE OF MALFUNCTION (IF KNOWN)

RTD'S ARE PRESENTLY USING 3 WIRE CONFIGURATION. CHANGE TO 4 WIRE CONFIGURATION.

ORIGINATOR'S EMP. NO
06638

James A. Pauls
ORIGINATOR'S SIGNATURE
1/30/79
DATE

SUPERVISOR'S EMP. NO
06038

James A. Pauls
SUPERVISOR'S SIGNATURE
1/30/79
DATE

A6721

WORK ORDER NUMBER		CC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR
036000187	CA		5302	1	0	1	1	0	0					

CHANGE MOD REQ'D	R W P	NUC SAFETY	SP AU	REG AGENCY CODE	CHG/MOD NUMBER
0	1	1	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK
MO DAY YR
01 30 79

RESP LOCATION OR CONTRACTOR
103GN

Comply with the Provisions set forth in AP1002, AP1003 and Met Ed Safety Manual.

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria *Mounted IAW sect. 6.11 in procedure 1430-Y-21*

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 0956

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes No _____
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes No _____
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes No _____
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).


Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date

7. Plant status or prerequisite conditions required for work. Operating or shutdown
8. QC Dept. review, if required in item No. 3
QC Supervisor P. Daniels Date 1/30/79
9. Supervisor of Maintenance approval to commence work: W. Metzger Date 1/30/79
10. Maintenance Foreman Assigned: _____

11. Shift Foreman's approval to commence work _____ Date _____



Initial if Shift
Foreman
signature is not required

Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER _____

12. Retest met acceptance criteria

Yes No

13. Work Performed by date/time

Work Reviewed - Maintenance Foreman's Signature

Date

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

Shift Foreman's Signature

Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

Shift Foreman's Signature

Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

Supervisor of Maintenance Signature

Date

WORK REQUEST PROCEDURE
TMI Nuclear Station
Maintenance Procedure Format and Approval

1430-Y-21
Revision 1
04/12/78

CONTROLLED COPY
*Supv. Maint
Unit 2*

Unit No. Station

This form outlines the format and acts as a cover sheet for a maintenance procedure. Due to the limited size of the form, additional pages may be attached as required. Work Request procedure AP 1016 Section 6 should be used as a guide in preparing the maintenance procedure.

1. Procedure Title & No.: 1430-Y-21

Quality Control Mounting Procedure for (Unit II) Instruments and Controls

2. Purpose: Insure instruments and controls that are not required to function during or after a seismic event must maintain its mechanical integrity in order to prevent discharge of radioactive material and/or jeopardize the overall performance capability of systems required to safely shutdown the reactor plant and maintain it in a shutdown condition.

3. Description of system or component to be worked on. Instruments, controls, linkages, tubing, instrument isolation valves, wires, and etc., used to sense and/or initiate a system response.

4. References:

- 4.1 Equipment Classification List.
- 4.2 AP 1003

5. Special Tools, and Materials required.

5.1 Tools as necessary depending on individual job. It could include scales, scribes, tubing wrenches, and regular hand tools.

6. Detailed Procedure (attach additional pages as required)

See Attached

Supervisor of Maintenance recommends approval *Jim Sturbin* Date 3-31-78

• PORC RECOMMENDS APPROVAL

Unit No. 1 Chairman *NA* Date

Unit No. 2 Chairman *J. J. [Signature]* Date 4/4/78

• UNIT SUPERINTENDENT APPROVAL

Unit No. 1 *NA* Date

Unit No. 2 *J. J. [Signature]* Date 4/5/78

• Standing Procedure

W. W. Cotter

Supervisor of QC

4-12-78

Date

*Note: These approvals required only on Nuclear Safety Related/Radiation work permit jobs.

6.0 PROCEDURE

NOTE: This procedure may be used in conjunction with other detailed work procedures.

6.1 Inform the Shift Foreman that you will be commencing work. Insure he is aware of what instrument, indication or system you may be affecting.


6.2 Mounting - Applicable if the equipment must be moved.

NOTE: For the purposes of this procedure an instrument is defined as a measuring device for determining the present value of a quantity under observation i.e., it must have a readout.

6.2.1 Inspect the mounting of the device. If it appears to have been improperly mounted or modified consult the applicable mounting print.

6.2.2 If the mounting is complex make a sketch to insure all parts are replaced properly.

6.2.3 When you are sure of the proper mounting and tagging is complete (if applicable), remove the device for maintenance. If the orientation of the mounting is not obvious, place alignment marks on the device and the mounting. Insure proper collection of the water if the device has a liquid boundary.



6.2.4 When the unit is repaired, remount the device and if necessary, consult the applicable mounting print or sketch. If any mounting part (i.e. nuts, bolts, washer, etc.) is lost or broken, replace it with an equivalent commercially available

part. For a question concerning the parts equivalency consult the Mechanical Engineering Department for guidance.

6.3 Electronic/Electrical control devices mounted in racks, cabinets, or mounting.

6.3.1 All wires shall be routed and supported so as not to be the support of the device. Terminal screws should be checked for tightness.

6.3.2 All conduit supports shall be tight.

6.3.3 Mounting bolts and screws shall be tight.

NOTE: This section is also applicable to devices mounted in the internals of QC instruments.

6.4 Devices with process connections.

6.4.1 Must be supported per original design.

6.4.2 The pressure connection point shall be sealed with proper thread sealant. (Note: Teflon tape is prohibited in primary system). Any gasket should be inspected for damage and reinstalled or replaced.

6.4.3 The device shall be leak tested in accordance with Step 6.7.5.

6.5 Instrument valves

NOTE: This procedure is not applicable if any welding is required.

6.5.1 The pressure connection point shall be sealed with proper thread sealant. (Note: Teflon tape is prohibited in primary systems). Any gasket should be inspected for damage and reinstalled or replaced.

6.5.2 The valve shall be leak tested in accordance with Step 6.7.5.

6.6 Valve operators and associated equipment.

REVISED
04/12/78

1430-Y-21
Revision 1
04/12/78

- 6.6.1 Before removing the operator ensure a sketch showing all the mountings and connections is on hand, if applicable.
- 6.6.2 When replacing the operator or associated equipment all brackets and mountings shall be tight.
- 6.6.3 All pneumatic or process connections shall be connected per 6.7.
- 6.6.4 Lubricate as necessary to insure all moving parts are free to move smoothly.
- 6.7 Threaded pipes and tubing.
 - 6.7.1 Before removing any pipe or tubing support, make sketches and record all dimensions necessary to ensure supports are properly replaced. (eg. length of support rod, distance between supports, etc.).
 - 6.7.2 All piping connections must be sealed with proper thread sealant. (Note: Teflon tape is prohibited in primary systems).
 - 6.7.3 All tubing connections shall be connected properly. (Note: Use vendors manual or 1410-Y-4 for reference).
 - 6.7.4 All pipe hangers and supports must be reinstalled in accordance with engineering specifications. If there is any questions regarding support design or spacing contact Mechanical Engineering.
 - 6.7.5 All piping and tubing connections shall be inspected for leaks and normal operating pressure immediately upon presumption and after about 10 minutes at pressure.
- 6.8 Mechanical linkages.
 - 6.8.1 Ensure a sketch of the linkage is available before disassembly. (Either obtain a vendor drawing or make your own). Ensure all sketches indicate which joints should be tight and which are free to move.

- 6.8.2 Reassemble the linkage in accordance with the sketch. Lubricate as necessary. Ensure all fasteners are properly secured.
- 6.9 Report clear to the Shift Foreman and clean up the work area.
- 6.10 Document the completed work on the work request.
- 6.11 Acceptance Criteria
 - 6.11.1 The device is mounted per the original or applicable mounting print.
 - 6.11.2 All screws, bolts, and fasteners are properly tightened.
 - 6.11.3 No pressure boundary leaks at normal operating pressure per 6.7.5.

**GENERATION CORRECTIVE MAINTENANCE SYSTEM
CM STATUS ACTIVITY FORM**

UNIT 2

COMPONENT DESIGNATOR					LOCATION UNIT			JOB TYPE	WORK AUTHORIZATION NUMBER		REQUEST DATE			
SYS	COMP. TYPE	COMP. ID.	POOR	17	22	23-24		28		32		MO	DAY	YR
5	8	12	16	17	22	23-24		28		32		33		38
A	C	S	A									0	1	30
		*					0	3	6	0	0	2	C	M

TXN	ACT	STATUS HOLD								% Completed		S/M APPROVAL TO COMMENCE WORK			FIELD WORK COMPLETION DATE		
		CODE	START DATE			RELEASE DATE											
			MO	DAY	YR	MO	DAY	YR	53	55	MO	DAY	YR	MO	DAY	YR	
1	4	39-40	41	46	47	52	53	55	56	61	62	67					
8	1	0	A												79		79
		0	1														
		0	2														
		0	3														
		0	4														
		0	5														
		0	6														
		0	7														
		0	8														
		5	0														
		5	1														
		5	2														
		5	3														
		5	4														
		5	5														
		5	6														

04/12/79
Unit 2

WORK REQUEST PROCEDURE
TMI Nuclear Station
Maintenance Procedure Format and Approval

WR Proc For
C 0956

Unit No. II

This form outlines the format and acts as a cover sheet for a maintenance procedure. Due to the limited size of the form, additional pages may be attached as required. Work Request procedure AP 1016 Section 6 should be used as a guide in preparing the maintenance procedure.

1. Procedure Title & No.:

TERMINATE SPARE FIELD WIRES IN RTD HEAD FOR ALL
RC 15's

2. Purpose:

Provide guidance for terminating spare field wire
in RTD head for all RC 15's

3. Description of system or component to be worked on.

RCS Temp Monitoring

4. References:

AP 1002
AP 1003
Met Ed Safety Manual.

5. Special Tools, and Materials required.

None

6. Detailed Procedure (attach additional pages as required)

Per Attached Pages.

Supervisor of Maintenance recommends approval

Wm. Metzger

per telecon

Date

1/30/79

* PORC RECOMMENDS APPROVAL

Unit No. 1 Chairman

AA

Date

Unit No. 2 Chairman

RPW

Date

1/30/79

* UNIT SUPERINTENDENT APPROVAL

Unit No. 1

AA

Date

Unit No. 2

Wm. Metzger

Date

1/30/79

* Standing Procedure

Supervisor of QC

Date

* Note: These approvals required only on Nuclear Safety Related/Radiation work permit jobs.

6.0 Procedure

6.1 Notify Shift Foreman/Supervisor prior to commencing work. A loop T_H

6.2 Locate RC15A-TE1A and remove covers from RTD head assembly.

6.3 RC15A-TE1 is a dual element RTD, with only one element being used for CL indication (YM-TR-1922) Locate spare field wire inside RTD head (Refer to Fig 1) and terminate on RTD head terminal block. Terminate to spare RTD sensing lead (Refer to Fig 1). Replace RTD Head Cover.

6.4 Repeat Steps 6.2 & 6.3 for Following RTD's

6.4.1 RC15A-TE2 A loop T_C by RC-P-1A

6.4.2 RC15A-TE3 A loop T_C by RC-P-2A

6.4.3 RC15B-TE1 B loop T_H

6.4.4 RC15B-TE2 B loop T_C by RC-P-1B

6.4.5 RC15B-TE3 B loop T_C by RC-P-2B


6.4 Notify Shift Foreman/Supervisor and ITC Engineer after work is completed

Note: Initial and date Figure 1 after each RTD has been completed.

100

RE 15A-TE1 _____
 PA 15A-TE2 _____
 PO 15A-TE3 _____
 PE 15B-TE1 _____
 PE 15B-TE2 _____
 PE 15B-TE3 _____

INSTALL DATE



8 LEADS, #22 GA. NICKEL CLAD
 COPPER, PRIMARY INORGANIC FIBER.
 SECONDARY MICA LAYER WITH
 WOVEN INORGANIC FIBER JACKET

FIG-1

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP. TYPE		COMP. ID.			LOCATION / UNIT			JOB TYPE	JOB TICKET NUMBER			MO	DAY	YR						
5	7	8	11	12	13	14	15	16	17	22	23	24	25	28	32	33	36				
SW	V		00	20					3600	2	CM			C09570	12	9	79				

RECOMMENDED PRIORITY
2

DESCRIBE MALFUNCTION OR MODIFICATION REQUIRED

VALVE DID NOT OPEN TO SUPPLY BACK UP
LURE WATER SOURCE

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 01800	ORIGINATOR'S SIGNATURE <i>Robert Conrad</i>	DATE 1/29/79	SUPERVISOR'S EMP. NO. 05478	SUPERVISOR'S SIGNATURE <i>KR Hart</i>	DATE 1/29/79
--------------------------------	--	-----------------	--------------------------------	--	-----------------

AG721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION			NPPD FAILURE		START						
LOCATION	SERIAL			SU	OP	HO	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
0360	0015749		5307	1	1	1	1	0	1						

CHANGE MOD REQ'D	RWP	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
	0	5	0	0			X			40

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER			PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR							
02	06	79							2036N	02	20	

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	ACT	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4	MO DAY YR	MO DAY YR	50	58 59	66 67	73 74	80
807	A	021379		2A				

TXN CD	ACT	RESOLUTION DESCRIPTION
1	4	
801	A	07 SEE WR 936
801	A	08
801	A	09
801	A	10

TXN CD	ACT	NPPD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER - MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
1	4	YR MO DAY HR MIN	48 49	50	
808	A				

TXN CD	ACT	NPPD FAIL TYPE	NPPD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
1	4	39 40	41 42	43	50 51	55 56 57 58	A B	YR MO DAY
808	A							

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION / UNIT		JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	LOG ID					MO	DAY	YR
SW	V	0020		0360	02	CM	C095701	1	29	79

RECOMMENDED PRIORITY

2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

VALVE DID NOT OPEN TO SUPPLY BACK UP
LUBE WATER SOURCE

CAUSE OF MALFUNCTION (IF KNOWN)

--

ORIGINATOR'S EMP. NO.
06800

Ante Conrad
ORIGINATOR'S SIGNATURE
1/29/79
DATE

SUPERVISOR'S EMP. NO.
05498

KR Hoyt
SUPERVISOR'S SIGNATURE
1/29/79
DATE

AG721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
0360	0018749		5307	1	1	1	1	0	1	1					

CHANGE MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER
0	8	0	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK

MO	DAY	YR
02	06	79

PRIORITY

RESP. LOCATION OR CONTRACTOR
2036N

Cancel

Comply with the Provisions set forth in AP 1002 and Met Ed Safety Manual

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria.

(ISI) Procedure 2303-1133 applies after repair

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE				JOB TICKET NUMBER				REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE		COMP ID		S		LOCATION / UNIT			JOB TYPE		JOB TICKET NUMBER		MO	DAY	YR															
5	7	8	11	12	15	16	17	22	23	24	25	28	32	33	38																
AH	D		4092A		036002	CM							C2151052379				2														

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

WHITE LITE ON PANEL 13 FOR AHD 4092A AND B DOES NOT LIGHT WHEN TESTING EMERGENCY VENTILATION SYSTEM IN RECIRC MODE. REQUIRE FOR TECH SPARR SURVEILLANCE 2303 MISA

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.	<i>D.C. Kress</i>	ORIGINATOR'S SIGNATURE	52379	DATE	SUPERVISOR'S EMP. NO.	<i>[Signature]</i>	SUPERVISOR'S SIGNATURE	7/23/79	DATE
06616					05755				

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION				NPRD FAILURE			START				
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
0360	00187FE		5305	1	1	1	1	0	1	1					

CHANGE MOD REQ'D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0	0	0	0				X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER	PRIORITY	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR					
05	25	79	06	14	79			20364	02000	160

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	ACT	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4	MO DAY YR	MO DAY YR	50 51 52 53	58 59	66 67	73 74	80
807A		071079	061779	1	00040			

TXN CD	ACT	RESOLUTION DESCRIPTION
1	4	
801A		07 ADJUSTED LIMIT SWITCH, NOW FUNCTIONS AS
801A		08 PER DESIGN
801A		09
801A		10

TXN CD	ACT	NPRD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR - SUPERVISOR - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN - JOB PERFORMER -- MAINTENANCE FOREMAN - SUPERVISOR OF MAINTENANCE - CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
1	4	YR MO DAY HR MIN	48 49	50	
808A					

TXN CD	ACT	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
1	4	39 40	41 42 43	50 51	55 56 57 58	A	B	YR MO DAY
808A								

GENERATION CORRECTIVE MAINTENANCE SYSTEM JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND



UNIT 2

COMPONENT DESIGNATION						LOCATION / UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE			RECOMMENDED PRIORITY
SYS	COMP TYPE	COMP ID	CD	SPD	MO				DAY	YR		
AH	D	4092A			036002	CM	C21510	5	23	79	2	

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

WHITE	LITE	ON	PANEL	13	FOR	AHD	4092A	AND														
E	DOES	NOT	LIGHT	WHEN	TESTING	EMERGENCY																
V	ENTILATION	SYSTEM	IN	RECIRC	MODE.	REQUI																
R	ED	FOR	TECH	SPEC	SURVEILLANCE	2303	MISA															

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO. 06616	 ORIGINATOR'S SIGNATURE	5-23-79 DATE	SUPERVISOR'S EMP. NO. 05955	 SUPERVISOR'S SIGNATURE	5/23/79 DATE
--------------------------------	---	-----------------	--------------------------------	---	-----------------

A 6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION								NPRD FAILURE			START		
LOCATION	SERIAL			SU	OP	HD	CD	RF	HS	LR			YR	MO	DAY	HR	MIN
03600	00187FZ		5305	1	1	1	1	0	1								

CHG REQ'D 0	RWD P 0	NUC SAFETY 0	NP RD 0	REG AGENCY CODE 0000	CHG/MOD NUMBER 0000	ENV CODE X	OUTAGE CAUSE CODE	STATUS HOLD CODE
----------------	------------	-----------------	------------	-------------------------	------------------------	---------------	-------------------	------------------

SYM APPROVAL COMMENCE WORK		
MO	DAY	YR
05	25	79

PRIOR	RESP. LOCATION OR CONTRACTOR
2	0364

Limits and Precautions:

- a) Personnel
- b) Equipment
- c) Environment
- d) Nuclear

Comply with the provisions
set forth in AP 1002 and
Nuclear Safety Manual

Post Maintenance Testing required and Acceptance Criteria. *Light should work properly.*

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET NUMBER 2151

1. Does work represent a change or modification to an existing system or component?
If yes, an approved change modification is required per AP 1021.
C/M No. _____ Yes _____ No
- 2a. Does work require an RWP Yes _____ No
- 2b. Is an approved procedure required to minimize personnel exposure. Yes _____ No
- 3a. Is work on a QC component as defined in GP 1008. Yes _____ No
- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used. Yes _____ No
4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

Unit Superintendent Date

- 5a. Is the system on the Environmental Impact list in AP 1026 Yes _____ No
- 5b. If 5a is Yes, is an approved procedure required to limit environmental impact Yes _____ No _____
6. Agreement that 5b is No. (Required only if 5a is Yes).

Unit Superintendent/Supervisor of Operations Date


7. Plant status or prerequisite conditions required for work. operating/shutdown
8. QC Dept. review, if required in item No. 3

QC Supervisor NA Date _____

9. code insp. to be notified
Supervisor of Maintenance approval to commence work: J.M. Lundy Yes _____ No
Date 5/29/79

10. Maintenance Foreman Assigned: B. J. R. [Signature] Page 74

11. Shift Foreman's approval to commence work C.D. Adams Date 6-14-79



Initial if Shift
Foreman
signature is not required

Radiation Work Permit No.

JOB TICKET (WORK REQUEST)
REVIEW - CLASSIFICATION - ROUTING CONTROL FORM

JOB TICKET (WORK REQUEST) NUMBER C-2151

12. Retest met acceptance criteria

Yes

No

13. Work Performed by date/time

Rich Jenkins

Work Reviewed - Maintenance Foreman's Signature

6/15/79
Date

C. E. Riggins

14. Work completed and component aligned for testing.

Initial if S. F. signature is not required.

C. Adams

Shift Foreman's Signature

6/15/79
Date

15. Testing completed and component released for normal use.

Initial if S. F. signature is not required.

C. Adams

Shift Foreman's Signature

6/15/79
Date

16. Quality Control Department review of work and testing completed (QC work only).

Surveillance Report No.

NA
QC Department

Date

17. Supervisor of Maintenance Job Ticket (Work Request) and procedure are complete and signed off as required. Change/modification form has been signed off as required.

R. E. Seely

Supervisor of Maintenance Signature

7/10/79
Date

GENERATION CORRECTIVE MAINTENANCE SYSTEM
JOB TICKET FORM (WORK REQUEST) - THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION															LOCATION / UNIT					JOB TYPE					JOB TICKET NUMBER					REQUEST DATE			RECOMMENDED PRIORITY
SYS		COMP TYPE		COMP ID		JOB NO		LOCATION / UNIT			JOB TYPE		JOB TICKET NUMBER			MO	DAY	YR															
5	7	8	11	12	13	14	15	16	17	22	23	24	25	28	32	33	38																
NU	P									0360	02	CM						C1296021679	2														

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

CAUSE OF MALFUNCTION (IF KNOWN)

CASING AGAIN PLUG DRIPPING																	

ORIGINATOR'S EMP. NO. 05893	ORIGINATOR'S SIGNATURE <i>Raymond Leggett 2-16-79</i>	DATE 2-16-79	SUPERVISOR'S EMP. NO. 05873	SUPERVISOR'S SIGNATURE <i>Armo</i>	DATE 2-16-79
--------------------------------	--	-----------------	--------------------------------	---------------------------------------	-----------------

A6721

WORK ORDER NUMBER				GC CODE		ACCOUNT NUMBER				PLANT CONDITION						NPRD FAILURE			START		
LOCATION		SERIAL								SU	OP	HD	CD	RF	HS	LR	YR	MO	DAY	HR	MIN
0360		001878E		5301				11111011													

CHANGE MOD REQ D	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER	TAGGING APPLICATION NO.	ENV CODE	OUTAGE CAUSE CODE	STATUS HOLD CODE	ESTIMATED DOLLARS
0110							X			

S/M APPROVAL COMMENCE WORK			S/F APPROVAL COMMENCE WORK			PROCEDURE NUMBER						P R I O R I T Y	RESP. LOCATION OR CONTRACTOR	EST CREW SIZE	EST MANHOURS
MO	DAY	YR	MO	DAY	YR	2036M									

ASSISTING DEPARTMENT			ASSISTING DEPARTMENT			ASSISTING DEPARTMENT		
RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS	RESP. LOCATION OR CONTRACTOR	EST CREW	EST MANHOURS

TXN CD	A C T	JOB COMPLETION DATE	FIELD WORK COMPLETION DATE	SIGN OFF REASON CODE	TOTAL ACTUAL MANHOURS	PURCHASE REQUISITION NUMBER	PURCHASE ORDER NUMBER	MATERIAL ORDER NUMBER
1	4	MO DAY YR	MO DAY YR	51 52 53	58 59	66 67	73 74	80
807A		030879		2A				

TXN CD	A C T	RESOLUTION DESCRIPTION
1	4	33
801A		07 SEE WR C0655
801A		08
801A		09
801A		10

TXN CD	A C T	NPRD FAILURE END	FAILURE NO	FAILURE STATUS	ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN — JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE — CM COORDINATOR - DATA ENTRY - SUPERVISOR OF MAINTENANCE CM COORDINATOR - DATA ENTRY
1	4	YR MO DAY HR MIN	48 49	50	
808A					

TXN CD	A C T	NPRD FAIL TYPE	NPRD FAIL MODE	CAUSE OF FAILURE CODES	EFFECT OF FAILURE CODES	FAILURE DETECTION CODE	ACTION TAKEN CODES	LICENSE EVENT REPORTED DATE
1	4	39 40	41 42 43	50 51	55 56 57	58	A B	YR MO DAY
808A								

GENERATOR CORRECTIVE MAINTENANCE SYSTEM
 JOB TICKET FORM (WORK REQUEST)-THREE MILE ISLAND

UNIT 2

COMPONENT DESIGNATION				LOCATION/UNIT	JOB TYPE	JOB TICKET NUMBER	REQUEST DATE		
SYS	COMP TYPE	COMP ID	MO				DAY	YR	
MU	P	00018036002	CM			C12960	21	6	79

RECOMMENDED PRIORITY

2

DESCRIBE MALFUNCTION OR MODIFICATION DESIRED

casing drain plug dripping									

CAUSE OF MALFUNCTION (IF KNOWN)

ORIGINATOR'S EMP. NO.
05893

Randy M. Lythe
 ORIGINATOR'S SIGNATURE DATE 2-16-79

SUPERVISOR'S EMP. NO.
05873

A. M. O'Connell
 SUPERVISOR'S SIGNATURE DATE 2-16-79

A6721

WORK ORDER NUMBER		GC CODE	ACCOUNT NUMBER	PLANT CONDITION						NPRD FAILURE			START	
LOCATION	SERIAL			SU	OP	HD	GD	RF	HS	LR	YR	MO	DAY	HR
0360	001878E		5301	1	1	1	1	0	1					

CHANGE MOD REG C	R W P	NUC SAFETY	NP RD	REG AGENCY CODE	CHG/MOD NUMBER
0	1	1	0		

ENV CODE	OUTAGE CAUSE CODE
X	

STATUS HOLD CODE

S/M APPROVAL COMMENCE WORK		
MO	DAY	YR

PRIORITY	RESP. LOCATION OR CONTRACTOR
	2036M

Correct

Limits and Precautions:

- a) Personnel Comply with the Provisions set forth in NP1002, NP1003 and Net Ed Safety Manual.
- b) Equipment
- c) Environment
- d) Nuclear

Post Maintenance Testing required and Acceptance Criteria. *Leak repaired*

ORIGINATOR — SUPERVISOR — SUPERVISOR OF MAINTENANCE — MAINTENANCE FOREMAN —
 JOB PERFORMER — MAINTENANCE FOREMAN — SUPERVISOR OF MAINTENANCE