


8005140541
S



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

April 23, 1980

Mr. R. H. Engelken, Director
Region V Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
1990 North California Boulevard
Walnut Creek Plaza, Suite 202
Walnut Creek, California 94596



Re: Operating License DPR-54
Docket No. 50-312
Reportable Occurrence 80-20

Dear Mr. Engelken:

Bulletin 79-018 issued January 14, 1980, item 6, required the District to make an immediate report if nonenvironmentally qualified components are utilized as safety equipment and required to function during postulated accidents.

A report was submitted to your office on April 17, 1980 stating that NAMCO switches, Model Nos. M-2-300 and D1200G, were identified on safety related valves. The subsequent investigation determined that these switches are solely utilized for light indication.

The switches do not control actuation, position nor any other interlock function. Therefore, this occurrence is not reportable and Reportable Occurrence 80-20 will be deleted from the LER file.

Respectfully submitted,

J. J. Mattimoe
Assistant General Manager
and Chief Engineer

JJM:RWC:jr

cs: Director, MIPC (2)

A002
5/10

80-135