



Carolina Power & Light Company

April 21, 1980

TIC
50-324
325

8005150207

APR 23 11:51

FILE: NG-3513 (B)

SERIAL: NO-80-601

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 & 2
LICENSE NOS. DPR-71 AND DPR-62
DOCKET NOS. 50-325 AND 50-324
RESPONSE TO IE BULLETIN 80-02

Dear Mr. O'Reilly:

In response to your letter of January 21, 1980, transmitting IE Bulletin 80-02, Carolina Power & Light Company submits the following information:

A review of plant documentation and discussions with General Electric have verified that the Marvin Engineering Company supplied feedwater spargers and thermal sleeves for Unit 2 only. The Unit 1 spargers and thermal sleeves were manufactured by General Electric C&I Manufacturing.


The Unit 2 spargers are interference fit spargers used for the normal distribution of feedwater; and there have been no failures, malfunctions, or unusual events associated with their use.

The attached table provides information on the Marvin Engineering equipment at the Brunswick Unit No. 2 site. It provides a brief description, a purchase date, and also provides references to the applicable specific vendor QA documentation which we understand you have already received copies of.

April 21, 1980

We trust that this information is suitable to resolve your concerns, and we plan no further action on this issue at this time. If you have any questions, please do not hesitate to contact me or a member of my staff.

Yours very truly,



B. J. Furr
Vice President
Nuclear Operations

CSB:eaj*

Attachment

BRUNSWICK PLANT
IE BULLETIN 80-02
MARVIN ENGINEERING COMPANY
FEEDWATER SPARGERS AND THERMAL SLEEVES

<u>UNIT</u>	<u>VENDOR</u>	<u>CE P.O. NO.</u>	<u>PURCHASE DATE</u>	<u>REMARKS</u>
Brunswick 2*	Marvin Engrg, (QA Manual #7, Rev. 0)	205-XC757 (QA Program NEDO-11209-04A)	2/23/79	Pins, Stops only
Brunswick 2	Marvin Eng. (QA Manual #7, Rev. 0)	2B2-XBE76 (QA Program NEDO-11209-03A)	8/25/77	Thermal Sleeves, Spargers

*Not installed