



8005160 073

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-237

DRESDEN STATION UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 48  
License No. DPR-19


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Commonwealth Edison Company (the licensee) dated February 7, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Provisional Operating License No. DPR-19 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 48, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas A. Ippolito, Chief  
Operating Reactors Branch #3  
Division of Operating Reactors

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 17, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 48

PROVISIONAL OPERATING LICENSE NO. DPR-19

DOCKET NO. 50-237

Replace the attached page 123 of the Appendix "A" Technical Specifications with the attached revised page.

TABLE 3.7.1  
PRIMARY CONTAINMENT ISOLATION DPR-19

Isolation Group	Valve Identification	Number of Power Operated Valves		Maximum Operating Time (sec)	Normal Position	Action on Initiating Signal
		Inboard	Outboard			
				3 < T < 5	0	CC
	1 Main Steam Line Isolation	4	4	< 35	C	SC
	1 Main Steam Line Drain	1		< 35	C	SC
	1 Main Steam Line Drain		1	< 5	0	SC
Note 1	1 Recirculation Loop Sample Line	1	1	< 5	0	CC
	1 Isolation Condenser Vent to main steam line	1		< 5	0	CC
	1 Isolation Condenser Vent to main steam line		1	< 5	0	CC
	2 Drywell floor drain		2	< 20	0	CC
	2 Drywell Equipment drain		2	< 20	0	CC
	2 Drywell Vent		2	< 10	C	SC
	2 Drywell Vent Relief		1	< 15	C	SC
	2 Drywell Inert and purge #1601-21		1	< 10	C	SC
	2 Drywell N <sub>2</sub> Makeup #1601-59	1		< 15	0	CC
	2 Drywell and Suppression Chamber N <sub>2</sub> Makeup #1601-57		1	< 15	0	CC
	2 Drywell and Suppression Chamber Inert #1601-55		1	< 15	0	CC
	2 Suppression Chamber N <sub>2</sub> Makeup #1601-58		1	< 15	C	SC
	2 Suppression Chamber Inert and purge #1601-56		1	< 10	0	CC
	2 Drywell and Suppression chamber vent from reactor building #1601-22		1	< 10	C	SC
	2 Drywell vent to standby gas treatment system		1	< 10	C	SC
	2 Suppression chamber vent		1	< 10	C	SC
	2 Suppression chamber vent relief		1	< 15	C	SC
Note 1	2 Drywell air sampling system		10	< 5	0	CC
	2 Drywell Pneumatic Supply Isolation		2	< 10	0	CC
	2 Torus to Condenser Drain		2	< 10	C	SC
	3 Cleanup demineralizer System	1		< 30	0	CC
	3 Cleanup demineralizer System		2	< 30	0	CC
	3 Shutdown cooling system	2		< 40	C	SC
	3 Shutdown cooling system		1	< 40	C	SC
	3 Shutdown cooling system		1	< 40	C	SC
	3 Reactor head cooling line		1	< 15	C	SC
	4 HPCI Turbine Steam supply	1		< 25	0	CC
	4 HPCI Turbine Steam supply		1	< 25	0	CC
	5 Isolation condenser steam supply	1		< 30	0	CC
	5 Isolation condenser steam supply		1	< 30	0	CC
	5 Isolation condenser condensate return	1		< 30	0	CC
	5 Isolation condenser condensate return		1	< 30	C	SC

Note 1: Valve can be reopened after isolation for sampling.

Amendment No. 48



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-249

DRESDEN STATION UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 43  
License No. DPR-25


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Commonwealth Edison Company (the licensee) dated February 7, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Provisional Operating License No. DPR-25 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 43, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas A. Ippolito, Chief  
Operating Reactors Branch #3  
Division of Operating Reactors

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 17, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 43

FACILITY OPERATING LICENSE NO. DPR-25

DOCKET NO. 50-249

Replace the attached page 123 of the Appendix "A" Technical Specifications with the attached revised page.

TABLE 3.7.1

## PRIMARY CONTAINMENT ISOLATION

DPR-25

Isolation Group	Valve Identification	Number of Power Operated Valves		Maximum Operating Time (sec)	Normal Position	Action on Initiating Signal	
		Inboard	Outboard				
	1 Main Steam Line Isolation	4	4	3 < T < 5	0	GC	
	1 Main Steam Line Drain	1		< 35	C	SC	
	1 Main Steam Line Drain		1	< 35	C	SC	
Note 1	1 Recirculation Loop Sample Line	1	1	< 5	0	SC	
	1 Isolation Condenser Vent to main steam line	1		< 5	0	GC	
	1 Isolation Condenser Vent to main steam line		1	< 5	0	GC	
	2 Drywell floor drain		2	< 20	0	GC	
	2 Drywell Equipment drain		2	< 20	0	GC	
	2 Drywell Vent		2	< 10	C	SC	
	2 Drywell Vent Relief		1	< 15	C	SC	
	2 Drywell Inert and purge #1601-21		1	< 10	C	SC	
	2 Drywell N <sub>2</sub> Makeup #1601-59	1		< 15	0	GC	
	2 Drywell and Suppression Chamber N <sub>2</sub> Makeup #1601-57		1	< 15	0	GC	
	2 Drywell and Suppression Chamber Inert #1601-55		1	< 15	0	GC	
	2 Suppression Chamber N <sub>2</sub> Makeup #1601-58		1	< 15	C	SC	
	2 Suppression Chamber inert and purge #1601-56		1	< 10	0	GC	
	2 Drywell and Suppression chamber vent from reactor building #1601-22		1	< 10	C	SC	
	2 Drywell vent to standby gas treatment system		1	< 10	C	SC	
	2 Suppression chamber vent		1	< 10	C	SC	
	2 Suppression chamber vent relief		1	< 15	C	SC	
	Note 1	2 Drywell air sampling system		10	5	0	GC
		2 Drywell Pneumatic Supply Isolation		2	< 10	0	GC
	Amendment No. 43	2 Torus to Condenser Drain		2	< 10	C	SC
3 Cleanup demineralizer System		1		< 30	0	GC	
3 Cleanup demineralizer System			2	< 30	0	GC	
3 Shutdown cooling system		2		< 40	C	SC	
3 Shutdown cooling system			1	< 40	C	SC	
3 Shutdown cooling system			1	< 40	C	SC	
3 Reactor head cooling line			1	< 15	C	SC	
4 HPCI Turbine Steam supply		1		< 25	0	GC	
4 HPCI Turbine Steam supply			1	< 25	0	GC	
5 Isolation condenser steam supply		1		< 30	0	GC	
5 Isolation condenser steam supply			1	< 30	0	GC	
5 Isolation condenser condensate return		1		< 30	0	GC	
5 Isolation condenser condensate return		1	< 30	C	SC		

Note 1; Valve can be reopened after isolation for sampling.