

CONSUMERS POWER COMPANYDOCKET NO. 50-155AMENDMENT TO FACILITY OPERATING LICENSEAmendment No. 6  
License No. DPR-6

1. The Atomic Energy Commission (the Commission) has found that:
  - A. The application for amendment by Consumers Power Company (the licensee) dated June 28, 1974, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. Prior public notice of this amendment is not required since the amendment does not involve a significant hazards consideration.
2. Accordingly, the license is amended by a change to the Technical Specifications as indicated in the attachment to this license amendment and all paragraphs under 3.B of Facility License No. DPR-6 are hereby amended and replaced with the following:

OFFICE ➤					
SURNAME ➤					
DATE ➤					

"B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised by issued changes thereto through Change No. 43."

3. This license amendment is effective as of the date of its issuance.

FOR THE ATOMIC ENERGY COMMISSION

151

Karl R. Goller, Assistant Director  
for Operating Reactors  
Directorate of Licensing

Attachment:  
Change No. 43 to Appendix A  
Technical Specifications

Date of Issuance: JUL 18 1974

OFFICE ➤						
SURNAME ➤						
DATE ➤						

ATTACHMENT TO LICENSE AMENDMENT NO. 6

CHANGE NO. 43 TO TECHNICAL SPECIFICATIONS (APPENDIX A)

FACILITY OPERATING LICENSE NO. DPR-6

The Technical Specifications contained in Appendix A attached to the Facility Operating License No. DPR-6 are revised as follows:

Replace paragraph 4.1.1.(g) with the following:

(g) Control Rod Guidance

The 32 cruciform-shaped control rods shall be guided and supported by the "fuel channel and support tube" assemblies. Each control rod shall contain a maximum of eight (8) rollers to a minimum of four (4) rollers of either a nominal 0.485-inch or 0.567-inch diameter. The bottom four (4) rollers, which can be eliminated, shall move in a minimum interfuel channel space of 0.628 inch.

OFFICE ➤						
SURNAME ➤						
DATE ➤						