

S.H.
22

8005200574

A

TEXAS UTILITIES SERVICES INC.
2001 BRYAN TOWER · DALLAS, TEXAS 75201

Log # TXX-3140
File 10010

May 12, 1980


Mr. S. B. Burwell
Licensing Project Manager
Light Water Reactors Branch No. 2
Division of Project Management
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
CONFIRMATORY PIPING ANALYSIS OF A MAIN
STEAM LINE INSIDE CONTAINMENT

Dear Mr. Burwell:

Please find enclosed two copies of an information package in response to NRC letter dated January 8, 1980 over the signature of Robert L. Baer. Attached to this letter is a list of the items contained in this package. One copy of this package has been transmitted to Mr. L. J. Auge of Energy Technology Engineering Center of Canoga Park, California.

Sincerely,



H. C. Schmidt

JSM:skf
Enclosure
cc: ARMS

- R. J. Gary
- J. C. Kuykendall
- A. T. Parker
- J. T. Merritt
- H. R. Rock
- C. K. Feist
- L. J. Auge

Boo/
s
///

SEND Non Repro. Enc.
to PM and TEZA (Return
to Reg files after Filing)

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

INFORMATION PACKAGE CONTENTS

1. Data package for Problem 1-3 detailing the following:
 - a. Applicable documentation utilized in analysis
 - b. Valve weights (not required for problem 1-3)
 - c. Table of equipment anchors
 - d. Table of anchor movements
 - e. Transformation of nozzle displacement values from Westinghouse global coordinates to G&H coordinates
 - f. Steam generator design loads
 - g. Spring constants (stiffnesses) of piping supports and rigid restraints
 - h. List of general references and modes of operation.
2. Piping Design Specification 2323-MS-200 (Revision 2).
3. Main Steam System Line List.
4. Memo summarizing insulation design criteria.
5. Relative displacements for reactor, safeguards, auxiliary and electrical building.
6. G&H document FRB-6R: Instructure response spectra for internal structure of reactor building.
7. G&H document FRB-5R: Instructure response spectra for containment building.
8. Westinghouse letter WPT-3422 dated May 6, 1980 summarizing Steam Generator No. 3 displacements.
9. Isometric drawings for stress analysis problem 1-3, detailing support locations, general pipe routing and node points used in analysis:
 - 2323-M1-3202-04 Rev. H
 - 2323-M1-3202-05 Rev. G.
10. Composite Piping Drawings Detailing Overall Piping Layout:
 - 2323-M1-0505 Rev. 6
 - 2323-M1-0506 Rev. 8
 - 2323-M1-0506-01 Rev. 11.