



8005210236

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TIC

APR 25 1980

State of Illinois  
Department of Public Health  
ATTN: Mr. Gary N. Wright, Chief  
Division of Nuclear Safety  
535 West Jefferson Street  
Springfield, IL 62761

Gentlemen:

The attached IE Information Notice No. 80-15 titled "Axial (Longitudinal) Oriented Cracking in Piping" was sent to the licensees listed below on April 21, 1980 for action:

American Electric Power Service Corporation  
Indiana and Michigan Power Company  
D. C. Cook 1, 2 (50-315, 50-316)

Cincinnati Gas & Electric Company  
Zimmer (50-358)

Cleveland Electric Illuminating Company  
Perry 1, 2 (50-440, 50-441)

Commonwealth Edison Company  
Braidwood 1, 2 (50-456, 50-457)  
Byron 1, 2 (50-454, 50-455)  
Dresden 1, 2, 3 (50-10, 50-237, 50-249)  
LaSalle 1, 2 (50-373, 50-374)  
Quad-Cities 1, 2 (50-254, 50-265)  
Zion 1, 2 (50-295, 50-304)

Consumers Power Company  
Big Rock Point (50-155)  
Midland 1, 2 (50-329, 50-330)  
Palisades (50-255)

Dairyland Power Cooperative  
LACBWR (50-409)

Detroit Edison Company  
Fermi 2 (50-341)

Illinois Power Company  
Clinton 1, 2 (50-461, 50-462)

APR 25 1980

Iowa Electric Light & Power Company  
Duane Arnold (50-331)

Northern Indiana Public Service Company  
Bailly (50-367)

Northern States Power Company  
Monticello (50-263)  
Prairie Island 1, 2 (50-282, 50-306)

Public Service of Indiana  
Marble Hill 1, 2 (50-546, 50-547)


Toledo Edison Company  
Davis-Besse 1 (50-346)

Union Electric Company  
Callaway 1, 2 (50-483, 50-486)

Wisconsin Electric Power Company  
Point Beach 1, 2 (50-266, 50-301)

Wisconsin Public Service Corporation  
Kewaunee (50-305)

Sincerely,

  
Dorothy E. Carroll, Acting Chief  
Administrative Branch

Enclosure: IE Information  
Notice No. 80-15

cc w/encl:  
Mr. D. W. Kane,  
Sargent & Lundy  
Central Files  
Reproduction Unit NRC 20b  
Local PDR  
NSIC  
TIC

SSINS No.: 6870  
Accession No.  
8002280660

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

April 21, 1980

IE Information Notice No. 8015

AXIAL (LONGITUDINAL) ORIENTED CRACKING IN PIPING

On March 8, 1980, the Commonwealth Edison Company reported to the NRC that slight leakage was observed from the "A" loop core spray injection piping during a reactor coolant system leakage test at their Quad-Cities Unit 2 Nuclear Power Station. The source of leakage was subsequently identified to be located adjacent to a shop weld joining a 90° elbow and a wedge section of elbow material used to extend the elbow to 105°. Subsequent ultrasonic inspections revealed additional cracking in several other elbows in "A" and "B" core spray loops. The cracks are located adjacent to welds and oriented transverse to the weld in the axial (longitudinal) piping direction. The affected elbows have been removed and currently failure analyses are in progress. Preliminary results from liquid penetrant examinations of the elbow interior surface in the counter bore/weld root area revealed axial oriented cracks on both sides of the weld in the counter bores adjacent to the weld roots. From the limited metallography performed to date, the cracking mode appears to be intergranular stress corrosion cracking. The cracking, however, only appears to be slightly branched. A determination as to whether or not the cracking extends into and across the welds cannot be made at this time.

It is significant to point out that these service sensitive lines, as defined by NUREG 313, had been examined on an augmented basis per NUREG 313 requirements. Two of the affected welds were inspected ultrasonically at the current outage prior to the leakage being observed at the pressure test with no indication of cracking reported. Further ultrasonic examinations, using standard ASME Section XI methods, performed after discovery of the leak clearly revealed the cracking (approximately 100% over the reference level).

Licensees are requested to inform NDE inspection personnel of the above stated information and to emphasize the need for care when performing circumferential UT scans of the weld and adjacent areas in piping components. Particular importance should be stressed when the examinations are performed on BWR service sensitive 304 stainless steel piping and on PWR 304 stainless steel piping in stagnant systems.

This Information Notice is provided as an early notification of a possibly significant matter that is still under review by the NRC staff. It is expected that recipients will review the information for possible applicability to their facility. No specific action or response is requested at this time. If you have any questions regarding this matter, please contact the Director of the appropriate NRC Regional Office.

IE Information Notice No. 80-15  
April 21, 1980

Enclosure

RECENTLY ISSUED  
IE INFORMATION NOTICES

Information Notice No.	Subject	Date Issued	Issued To
80-14	Safety Suggestions From Employees	4/2/80	All power reactor facilities with an OL or CP
80-13	General Electric Type SBM Control Swiches - Defective Cam Followers	4/2/80	All light water reactor facilities holding power reactor OLs or CPs
80-12	Instrument Failure Causes Opening of PORV and Block Valve	3/31/80	All holders of power reactor OLs and CPs
80-11	General Problems with ASCO Valves in Nuclear Application Including Fire Protection Systems	3/14/80	All holders of Reactor OL, CP, fuel fabrication and processing facilities
80-10	Partial Loss of Non-Nuclear Instrument System Power Supply During Operation	3/7/80	All power reactor facilities holding OLs and CPs
80-09	Possible Occupational Health Hazard Associated with Closed Cooling Systems	3/7/80	All holders of power reactor OLs and near term CPs
80-08	The States Company Sliding Link Electrical Terminal Block	3/7/80	All power reactor facilities with an OL or a CP
80-07	Pump Shaft Fatigue Cracking	2/29/80	All Light Water Reactor Facilities holder power reactor OLs and CPs
80-06	Notification of Significant Events	2/27/80	All holders of Reactor OLs and to near term OL applicants
80-05	Chloride Contamination of Safety Related Piping	2/8/80	All licensees of nuclear power reactor facilities and applicants and holders of nuclear power reactor CPs