LICENSEE EVENT REPORT (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 10 CONTROL BLOCK: 0 0 0 0 0 - 0 0 3 4 1 (4) 10 0 0 WILBR 0 LICENSE NUMBER LICENSEE CODE CON'T 0 9 7 0 4 1 7 8 0 8 0 5 1 3 8 0 REPORT 0 0 1 L 6 0 5 0 4 -SOURCE REPORT DATE DOCKET NUMBER EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) DURING TECHNICAL SPECIFICATION TESTING (TS 5.2.6) WHILE SHUTDOWN, THE 1A 0 2 REACTOR EMERGENCY FLOODING VENT VALVE DID NOT OPEN. TS 2.4.2.4 REQUI 0 3 RES THE VALVE TO BE CAPABLE OF REMOTE OPERATION. THE 1B REACTOR EMERGEN 0 4 CY FLOODING VENT VALVE DID PERFORMED SATISFACTORILY, SO THE FUNCTIONAL R 0 5 EQUIREMENT OF THE SYSTEM WOULD HAVE BEEN FULFILLED IF NEEDED. THIS WAS 0 6 THE FIRST FAILURE OF THIS TEST. 0 7 0.8 COMP SYSTEM CAUSE CAUSE SUBCODE VALVE SUBCODE COMPONENT CODE CODE X (14 P (15 IF (16) 1(12 (13) B E LL V 0 9 18 REVISION OCCURRENCE REPORT SECUENTIAL. LER RO EVENT YEAR REPORT NO. CODE TYPE NO. [8]0] 13 0 0 0 4 REPORT 0 COMPONENT PRIME COMP. NPRD-4 EFFECT ON PLANT METHOD ATTACHMENT SUBMITTED ACTION FUTURE TAKEN ACTION HOURS (22) FORM SUB. SUPPLIER Y 23 N (24) N (25 B | 4 | 8 | 2 (21) 0 0 0 B (18) Z (19 Z (20) 0 42 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) BS&B VALVE, TYPE 70-19-9, PROBABLY FAILED TO OPEN DUE TO INFREQUENT CYCL 1 0 THE VALVE WAS DISASSEMBLED, EXAMINED, ITS SEATING SURFACES WERE RE ING. LAPPED AND TESTED SATISFACTORILY. NEW PROPOSED T.S. REQUIRES CYCLING EV ERY COLD SHUTDOWN, IF NOT TESTED WITHIN LAST 3 MONTHS, WHICH SHOULD PREV 1 3 ENT REOCCURRENCE. 4 80 METHOD OF FACILITY (30)DISCOVERY DESCRIPTION (32 % POWER OTHER STATUS 01 01 B (31 T.S. TEST G (28 0 (29 NA 80 4.4 ACTIVITY CONTENT LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35 RELEASED OF RELEASE Z (34) NA Z (33) 6 NA 80 PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER NA 80 PERSONNEL INJURIES DESCRIPTION (41 NUMBER 0 0 0 0 NA 80 LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION Z (42) NA -94 80 21 PUBLICITY NEC USE ONLY DESCRIPTION (45) 800520554 N 44 NA 68 69 80 608-689-2331 L. S. GOODMAN PHONE . NAME OF PREPARER .