

TERA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20535

MAY 6 1980

Docket Nos. 50-295
and 50-304

Mr. D. Louis Peoples
Director of Nuclear Licensing
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

Dear Mr. Peoples:


RE: ZION STATION, UNIT NOS. 1 AND 2

We are currently reviewing the adequacy of the offsite power systems of nuclear power plants and in particular, the loss of offsite power events at your facilities. One aspect of this review concerns the history of experienced total and partial power outages and attendant degraded voltage or frequency conditions of the grid.

In our review of this matter we have drawn upon the information provided to us via Licensee Event Reports and followup letters which have been sent to us. Our records do not indicate that you have experienced any loss of offsite power events either completely or partially. Please review your experiences and, if any are identified, then report them in answer to this letter and furnish the related information as included in the enclosure.

Please provide your response to us within 30 days of the receipt of this letter.

Sincerely,


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
Request for Additional
Information

cc: w/enclosure
See next page

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

800528050a p

Mr. J. Louis Peoples
Commonwealth Edison Company

MAY 4 1960

cc: Robert J. Vollen, Esquire
109 North Dearborn Street
Chicago, Illinois 60602

Dr. Cecil Lue-Hing
Director of Research and Development
Metropolitan Sanitary District
of Greater Chicago
100 East Erie Street
Chicago, Illinois 60611

Zion-Benton Public Library District
2600 Emmeus Avenue
Zion, Illinois 60099

Mr. Phillip P. Steptoe
Isham, Lincoln and Beale
Counselors at Law
One First National Plaza
42nd Floor
Chicago, Illinois 60603

Susan N. Sekuler, Esquire
Assistant Attorney General
Environmental Control Division
188 West Randolph Street, Suite 2315
Chicago, Illinois 60601

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
Post Office Box 288
Dearfield, Illinois 60015

LOSS OF OFFSITE POWER SURVEY*

A. For losses of offsite power where less than all offsite power was lost:*

1. How many circuits to the offsite network are normally available and how many were lost during the event?
2. What was the cause of the event?
3. Why did the other lines not fail when some did fail?
4. Was any voltage increase or decrease experienced just prior to or during the outage? If so, please give details, voltages reached, affects, etc.
5. Was any frequency decay experienced just prior to or during the outage? If so, please give details, lowest frequency reached, decay rate, affects on equipment operation, etc.
6. How long was power unavailable from the circuit?
7. Date of event.

B. For losses of all offsite power:

1. How long was the power off? How long for partial recovery? Please give details.
2. If turbine trip occurred, how soon after did loss of offsite power occur?
3. If power was recovered promptly (10 minutes or less), was it due to automatic or manual actions?
4. Was any voltage increase or decrease experienced just prior to or during the outage? If so, please give details, voltages reached, affects, etc.
5. Was any frequency decay experienced just prior to or during the outage? If so, please give details, lowest frequency reached, decay rate, affects on equipment operation, etc.
6. Date of event.