

PDR-HQBC File



Bingham-Willamette Company

A DIVISION OF THE BINGHAM COMPANY

CABLE TELEGRAMS: BINGWILL



Main Offices and Factory

2800 N.W. FRONT AVENUE • PORTLAND, OREGON 97210
P.O. BOX 9247

January 30, 1980

U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza, Suite 1000
Arlington, Texas 76012

Attention: Uldis Potapovs, Chief
Vendor Inspection Branch

Reference: Docket No. 99900031/79-02
Your Letter Dated January 24, 1980

Gentlemen:

This is to confirm that the corrective action to Deviation E has been revised as stated in your letter:

"The procedure referenced (350.4, Rev. 9) has been revised to provide for higher temperature raising and lowering for part with thinner than 3 wall thickness.

Very truly yours,

BINGHAM-WILLAMETTE COMPANY

O.I. Rove
Quality Assurance Manager

OIR:bb
cc: W.E. Tharp

POOR ORIGINAL

8005270162