



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION IV  
611 RYAN PLAZA DRIVE, SUITE 1000  
ARLINGTON, TEXAS 76012

24 JAN 1980


Docket No. 99900031/79-02

Bingham-Willamette Company  
Attn: Mr. W. E. Tharp  
President  
2800 NW Front Avenue  
Portland, OR 97210

Gentlemen:

Thank you for your letter of January 2, 1980, in response to our letter dated November 29, 1979, with an enclosure. It is our understanding, as discussed during a telephone conversation on January 18, 1980, with Mr. O. I. Rove, that the wording in your "Corrective Action to Prevent Recurrence" response for Deviation E has been clarified. It now states, "The procedure referenced (D50.4, Rev. 9) has been revised to provide for higher temperature raising and lowering for parts with thinner than 3" wall thickness." Please confirm our understanding of the clarification by return letter within ten days.

Sincerely,

  
Uldis Potapovs, Chief  
Vendor Inspection Branch

8005270169