



Portland General Electric Company
Trojan Nuclear Plant
P.O. Box 439
Rainier, Oregon 97048
(503) 556-3713

May 19, 1980
CPY-497-60

Mr. R. H. Engelken, Director
U. S. Nuclear Regulatory Commission
Region V
1990 North California Blvd.
Walnut Creek, California 94596

Dear Sir:

Subject: Immediate Report of Reportable Occurrence

This letter is to confirm the prompt report made to Mr. M. H. Malmros, Resident Inspector by Mr. W. S. Orser, Manager, Operations and Maintenance, Trojan Nuclear Plant concerning a situation where it could not be assured that containment integrity was maintained during refueling operations. During the period of core alteration, a main steam isolation valve was opened for inspection while a steam generator secondary manway was removed.

This occurrence will be reported to the Nuclear Regulatory Commission as a Licensee Event Report in accordance with our established Technical Specifications.

Sincerely,

C. F. Yundt
General Manager

CPY/WSO:na

c: LER Distribution

*App 2
5/10*

8005280 595