

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | C | B | E | P | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 | L | 0 | 5 | 0 | - | 0 | 3 | 2 | 4 | 7 | 0 | 4 | 2 | 5 | 8 | 0 | 8 | 0 | 5 | 1 | 9 | 8 | 0 | 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing PT 3.1.7PC, Reactor Low Water No. 2 and 3 Channel Calibration and
0 3 | Functional Check, low level switch 2-B21-LITS-N031D-3 actuated at 122.1" water applied
0 4 | while the reportable limit is >117.18" water applied. This event did not affect the
0 5 | health and safety of the public.
0 6 |
0 7 |

0 8 | Technical Specifications 3.3.3, 6.9.1.9a
7 8 9 80

0 9 | I | B | E | I | N | S | T | R | U | S | Z |
7 8 9 10 11 12 13 18 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE CORR. SUBCODE VALVE SUBCODE
17 | LER/RO REPORT NUMBER | 8 | 0 | 0 | 4 | 1 | 0 | 3 | L | 0 |
21 22 23 24 26 27 28 29 30 31 32
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
E | C | Z | Z | 0 | 0 | 0 | 0 | N | Y | N | Y | 0 | 1 | 0 |
33 34 35 36 37 40 41 42 43 44 45 46 47
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Instrument drift was determined as the cause of the event. The switch was recalibrat-
1 1 | ed and returned to service satisfactorily. Due to a history of drift problems, this
1 2 | instrument will be replaced with analog-type instrumentation during a future outage.
1 3 |
1 4 |

1 5 | H | 0 | 0 | 0 | NA | B | Periodic Test
7 8 9 10 11 12 13 44 45 46 47
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | Z | NA | NA
7 8 9 10 11 12 13 44 45 46 47
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 | 0 | 0 | Z | NA
7 8 9 10 11 12 13 44 45 46 47
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 | 0 | 0 | NA
7 8 9 10 11 12 13 44 45 46 47
PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | NA
7 8 9 10 11 12 13 44 45 46 47
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N | NA
7 8 9 10 11 12 13 44 45 46 47
ISSUED PUBLICITY DESCRIPTION

NRC USE ONLY

8005280639 S

NAME OF PREPARER A. C. Tollison, Jr.

PHONE 919-457-9521