NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C A R S S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 1 1 1 (4) | 1 (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE

CON'T
01 REPORT SOURCE | X (6) | 0 5 0 0 0 3 1 2 (7) | 0 5 0 8 8 0 (8) | 0 5 1 2 1 8 0 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On 5/8/80, B&W, the NSSS vendor informed SMUD that as a result of the
03 ATOG program analysis for ANO-1, the calculation of offsite dose following
04 an OTSG tube rupture may be higher than reported in the FSAR. The FSAR
05 figures may be low by as much as a factor of 2. However, this is still
06 well below 10CFR100 and Technical Specification limits.
07
08

09 SYSTEM CODE Z Z (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER RO REPORT NUMBER | EVENT YEAR 8 0 | — | SEQUENTIAL REPORT NO. 0 2 6 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN Z (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The ATOG analysis has taken into account recent requirements for maintain-
11 ing 50° subcooling and tripping RCP's which impede rapid plant depressuri-
12 zation and therefore more steam will be released to the atmosphere. Con-
13 tinued work by B&W will result in development of operator guidelines and
14 an eventual revised FSAR analysis.

15 FACILITY STATUS H (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY D (31) | DISCOVERY DESCRIPTION (32) Notification from NSSS

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A

20 PUBLICITY ISSUED Y (44) | DESCRIPTION (45) Local newspapers and wire services.

NRC USE ONLY

8005290517

NAME OF PREPARER R. W. Colombo PHONE: 916-452-3211