

MEMO OF CONVERSATION

PERSON CALLING: C. B. Davis DATE 8/20/79
REPRESENTING: EG&G Idaho, Inc./INEL TIME 2:30 pm
PERSON CALLED: Mark Cunningham PHONE NUMBER _____
REPRESENTING: NRC

CITY: _____ A. C. Peterson
SUBJECT: Clarification of TMI Sensitivity _____ DISTRIBUTION W. C. Lyon, NRC-RSR
Study W. W. Bixby E. Throm, NRC
T. R. Charlton R. E. Tiller, DOE-ID
J. A. Dearien L. J. Ybarrondo
C. A. Dobbe P. H. Vander Hyde
P. E. Litteneker, DOE-ID File 2.6

Mark confirmed that the TMI sensitivity study designated as D-3 in Tong's letter should be run with one pump in each loop tripped at 73 minutes. The calculation should be run to at least 100 minutes to see if this change would significantly alter the accident. If the results are similar to the base case, the calculation need not be run very far past 100 minutes.

SIGNATURE

CB Davis

(CONTINUE ON REVERSE SIDE)