

ATTACHMENT 1

Zion Station Units 1 and 2

NRC Docket Nos. 50-295 and 50-304

Proposed Technical Specification Changes:

The following page has been revised and should replace page 300 in Attachment 2 of Reference (a):

300

6.0 ADMINISTRATIVE CONTROLS

6.1 Organization, Review, Investigation, and Audit

- A. The Station Superintendent shall have overall full-time responsibility for safe operations of the facility. During periods when the Station Superintendent is unavailable, he shall designate this responsibility to an established alternate who satisfies the ANSI N18.1 experience requirements for plant manager.
- B. The corporate management which relates to the operation of this station is as shown in Figure 1-6 of C.E.-1-A Topical Report. The Division Manager, Nuclear Stations has responsibility for the Fire Protection Program.
- C. The normal functional organization for operation of the station shall be as shown in Figure 1-6 and Figure A of C.E.-1-A Topical Report. The shift manning for the station shall be as shown in Figure 6.1.1. The Operating Assistant Superintendent, Operating Engineer, Shift Engineers, and Shift Foreman shall have a senior operating license. The Fuel Handling Foreman has a limited Senior Operating License. An Operating Engineer will be responsible for implementation of the Fire Protection Program. A Fire Brigade of at least 5 members shall be maintained onsite at all times. The Fire Brigade shall not include the minimum shift crew necessary for safe shutdown of the plant (4 members) or any personnel required for other essential functions during a fire emergency.
- D. Qualifications of the station management and operating staff shall meet minimum acceptable levels as described in ANSI N18.1 "Selection and Training of Nuclear Power Plant Personnel," dated March 8, 1971 with the exception of the Rad-Chem Supervisor or Lead Health Physicist, who shall meet or exceed the qualifications of Radiation Protection Manager of Regulatory Guide 1.8 September, 1975. The individual filling the position of Administrative and Support Services Assistant Superintendent shall meet the minimum acceptable level for "Technical Manager" as described in 4.2.4 of ANSI N18.1, 1971.
- E. Retraining and replacement training of Station personnel shall be in accordance with ANSI N18.1, "Selection and Training of Nuclear Power Plant Personnel," dated March 8, 1971. A training program for the Fire Brigade shall be maintained under the direction of the Station Fire Marshall and shall meet or exceed the requirements of Section 27 of the NFPA Code - 1975 except that Fire Brigade training will be conducted quarterly.
- F. Retraining shall be conducted at intervals not exceeding two years.
- G. The Review and Investigative Function and the Audit Function of activities affecting quality during facility operations shall be constituted and have the responsibilities and authorities outlined below: