

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-221VIRGINIA ELECTRIC AND POWER COMPANYNOTICE OF ISSUANCE OF AMENDMENTS TO FACILITYOPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 58 to Facility Operating License No. DPR-37 issued to Virginia Electric and Power Company, which revised Technical Specifications for operation of the Surry Power Station, Unit No. 2 (the facility) located in Surry County, Virginia. The amendment is effective as of the date of issuance.

This amendment revises the Technical Specifications to change the heat flux hot channel factor (F_Q) to 2.19 based on a LOCA-ECCS analysis with a steam generator tube plugging limit of 3%.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since it does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration


- 2 -

and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated May 31, 1979, as supplemented October 16 and 25, 1979, and January 11 and February 20, 1980, (2) Amendment No. 58 to License No. DPR-37, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1777 H Street, N.W., Washington, D. C. and the Swem Library, College of William and Mary, Williamsburg, Virginia. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 16th day of May, 1980.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors