

LICENSEE EVENT REPORT

PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION

CONTROL BLOCK: | | | | | | | | | | 1

0 1 | P | A | B | V | S | I | | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | | 3 | 4 | 1 | 1 | I | I | 4 | | | 5

LICENSEE CODE 10 13 LICENSE NUMBER 25 28 LICENSE TYPE 29 32 CAT 30

0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 4 | 7 | 0 | 5 | 1 | 9 | 8 | 0 | 3 | 0 | 6 | 0 | 2 | 8 | 0 | 9

REPORT SOURCE 20 23 DOCKET NUMBER 28 31 EVENT DATE 34 37 REPORT DATE 40 43

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (16)

0 2 | Plant operators were testing the diesel-driven fire pump when they received a high temperature alarm and the diesel overheated. The pump had been run for system tests three times that day with minimal cooldown time. The pump was taken out of service at this time. The plant motor-driven fire pump is presently out of service for lack of parts; however, a temporary fire pump is hooked up for service and it is felt that degradation to the system is minimized because of the backup pump.

SYSTEM CODE A B 11	CAUSE CODE E 12	CAUSE SUBCODE F 13	COMPONENT CODE X X X X X X 14	COMP. SUBCODE Z 15	VALUE SUBCODE Z 16
LEAD-NO REPORT NUMBER 8 0 17	EVENT YEAR 8 0 21	SEQUENTIAL REPORT NO. 0 3 0 24	OCCURRENCE CODE 0 1 26	REPORT TYPE T 28	REVISION NO. 0 32
ACTION TABLE A 18	FUTURE ACTION Z 19	EFFECT ON PLANT Z 20	SHUTDOWN METHOD Z 21	HOURS 0 0 0 0 27	ATTACHMENT SUBMITTED N 22
				IF FROM FORM 200 N 24	IF FROM COMP. SUPPLIER A 25
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)					COMPONENT MANUFACTURER Z 9 9 44

1 5 | During the investigation of the cause of the overheating, the fan belt was found to be slipping and was brittle. This was attributed as the root cause of the overheating problem, but the thermostat, radiator and cooling water pressure control valve were checked also.

ACTIVITY TRACK X 26	POWER 0 0 0 29	OTHER STATE Design 30	METHOD OF DISCOVERY A 31	DISCOVERY DESCRIPTION Operator observation 36
ACTIVITY CONTENT 2 33	RELEASED OF RELEASE Z 34	AMOUNT OF ACTIVITY N/A 35	LOCATION OF RELEASE N/A 38	
PERSONNEL EXPOSURES				
NUMBER 0 0 0 37	TYPE Z 38	DESCRIPTION N/A 39		
PERSONNEL PLANNING				
NUMBER 0 0 0 40	DESCRIPTION N/A 41			
LOSS OF OR DAMAGE TO FACILITY				
TYPE Z 42	DESCRIPTION N/A 43			
PUBLICITY				
STATUS N 44	DESCRIPTION N/A 45			