



VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION
P. O. BOX 402
MINERAL, VIRGINIA 23117

June 9, 1980

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Serial No. N-80-19
PO/RCS:cea
Docket No. 50-338
License No. NPF-4

Dear Mr. O'Reilly:

Pursuant to North Anna Power Station Technical Specifications, the Virginia Electric and Power Company hereby submits the following Licensee Event Report for North Anna Unit No. 2.

Report No.	Applicable Technical Specifications
LER 80-043/03L-0	T.S. 6.9.1.9.b

This report has been reviewed by the Station Nuclear Safety and Operating Committee and will be placed on the agenda for the next meeting of the System Nuclear Safety and Operating Committee.

Very Truly yours,

W. R. Cartwright
Station Manager

Enclosure (3 copies)

cc: Mr. Victor Stello, Director (30 copies)
Office of Inspection and Enforcement

Mr. Norman M. Haller, Director (3 copies)
Office of Management and Program Analysis

8006120331
S

Virginia Electric and Power Company
North Anna Power Station, Unit #1
Docket No. 50-338
Report No. 80-043/03L-0

Attachment: Page 1 of 1

Description of Event

On May 10, 1980, during 100% power operation, monthly surveillance test 1-PT-36.1 detected the failure of Train A permissive P-11. P-11 prevents manual SI block above 2000 psig and blocks automatic pressurizer PORV operation below 2000 psig.

Probable Consequences of Occurrence

Since Train B permissive P-11 remained operable, the action statement of T.S. 3.3.1.1 was met, and Train A permissive P-11 was restored to operable status in one hour, the public health and safety were not effected.

Cause of Occurrence

A logic card, universal card 411, failed.

Immediate Corrective Action

The logic card was replaced, the channel tested, and Train A permissive P-11 restored to operable status in one hour.

Scheduled Corrective Action

No scheduled corrective actions are required.

Actions Taken to Prevent Recurrence

No actions to prevent recurrence are required.