

Appendix A

NOTICE OF VIOLATION

Union Electric Company

Docket No. 50-483

Based on the results of an NRC inspection on March 11-14, 1980, it appears that one of your activities is in noncompliance with NRC requirements as noted below. This item is considered an infraction.

10 CFR 50, Appendix B, Criterion IX states in part, that, "Measures shall be established to assure that special processes, including welding, . . . are controlled and accomplished by qualified personnel using qualified procedures in accordance with applicable codes, standards, specifications, . . ." SNUPPS PSAR, paragraph 17.1.9 states, in part, that "The SNUPPS utilities require that special processes be controlled. Special processes will be accomplished under specified and controlled conditions by qualified personnel using qualified procedures and equipment in accordance with applicable codes, standards, specifications, criteria or other special requirements."

Contrary to the above, measures were not established to control welding in that, there was no welding procedure specification or qualification of the as welded/brazed condition for the cable tray fittings, i.e. T's, EL's, etc.