

APPENDIX A

NOTICE OF VIOLATION

Tennessee Valley Authority
Yellow Creek Nuclear Plant

License Nos. CPPR-172 and CPPR-173

Based on the NRC inspection April 1-4, 1980, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

As required by Criterion XVII of Appendix B to 10 CFR 50, and implemented by PSAR Section 17.1A.17, "Sufficient records shall be maintained to furnish evidence of activities affecting quality".

Contrary to the above, records generated by the batch plant are inaccurate on pour number A1-Pr and A1-J1. On pour Number A1-Pr, records produced by the batch plant recorder are inaccurate in that batch times are unreadable, numerous scale lines are too faint to read or are missing and several curves showing batch ingredient quantities begin several increments above the zero reference line. On pour number A1-J1 the recorded water contents for test number 1302 and 1304 are not compatible with the recorded slump tests.

This is a deficiency.