AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	50-313		
UNIT	ANO-1		
DATE	6/13/80		
COMPLETED BY	L.S.Bramlett		
TELEPHONE	501/968-2519		

AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
0	17	0
0	18	0
0	19	0
0	20	0
36	21	0
294	22	0
645	23	0
665	24	0
668	25	0
71	26	0
0	27	0
0	28	0
0	29	0
0	30	0
0	31	0
0		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)

OPERATING DATA REPORT

DOCKET NO. 50-313

DATE 6/13/80

COMPLETED BY L.S.Bramle 501/968-2519

	OPERATING STATUS			
2. 3. 4. 5. 6. 7.	Unit Name: Arkansas Nuclear One Reporting Period: May 1-31, 1980 Licensed Thermal Power (MWt): 2568 Nameplate Rating (Gross MWe): 902.74 Design Electrical Rating (Net MWe): 850 Maximum Dependable Capacity (Gross MWe): 88 Maximum Dependable Capacity (Net MWe): 83 If Changes Occur in Capacity Ratings (Items Number None	33 36	Notes Last Report, Give Rea	sons:
	Power Level To Which Restricted. If Any (Net MWe)		None	
10.	Reasons For Restrictions. If Any:	NA		
		This Month	Yrto-Date	Cumulative
		744.0	3647.0	47778.0
	Hours In Reporting Period	128.7	1710.4	31848.6
	Number Of Hours Reactor Was Critical	90.2	464.8	4712.2
	Reactor Reserve Shutdown Hours	109.3	1671.6	31142.1
	Hours Generator On-Line	0.0	20.8	817.5
	Unit Reserve Shutdown Hours	201913.0	3844695.0	75106739.0
	Gross Thermal Energy Generated (MWH)	60927.0	1198925.0	24920081.0
	Gross Electrical Energy Generated (MWH)	57078.0	1140353.0	23774389.0
	Net Electrical Energy Generated (MWH)	14.7	45.8	65.2
77.7	Unit Service Factor Lait Availability Factor	14.7	46.4	66.9
	Unit Availability Factor Unit Capacity Factor (Using MDC Net)	9.2	37.4	59.5
	Unit Capacity Factor (Using MDC Net) Unit Capacity Factor (Using DER Net)	9.0	36.8	58.5
	Unit Forced Outage Rate	82.8	28.0	16.4
	Shutdowns Scheduled Over Next 6 Months (Type, D	ate, and Duration of	Each):	
	M.S. D. D. S. LOS B. D. S. C.)	June 6, 19	980
	If Shut Down At End Of Report Period, Estimated I Units In Test Status (Prior to Commercial Operation		Forecast	Achieved
	INITIAL CRITICALITY			
	INITIAL ELECTRICITY			
	COMMERCIAL OPERATION			

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKETNO 50-313

UNIT NAME AND Unit I

DATE 6-13-80

COMPLETED BY L. S. Bramlett
TELEPHONE 501-968-2519

REPORT MONTH May

No.	Date	Type	Duration (Hours)	Reposet 2	Method of Shutting Down Reactor-3	Licensee Event Report =	System Code4	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0-03	800419	s	105.35	F	1	NONE	ZZ	ZZZZZ	The outage was administratively authorized for economic reasons.
0-04	800505	S	4.11	В		NONE	ZZ	ZZ	Turbine overspeed trip test.
0-05	800510	F	525.22	A	1	NONE	CA	Pumpxx	"C" RCP seal failure.

F Forced S Scheduled

Reason

A-Equipment Failure (Explain)

B-Maintenance or Test

C Refueling

D-Regulatory Restriction

L Operator Training & License Examination

F-Administrative

G Operational Lines (Explain)

H-Other (Explain)

Method:

1-Manual

2-Manual Scram.

3-Automatic Scram.

4-Other (Explain)

-1

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

I shibit I - Same Source

ev. 71

DATE:
it 1
1/81
3/1/81
after require a amendment?
core configuration tee to determine
ciated with the
echnical Specification
demonstration high
ing action and
th refueling, e.g.,
ewed design or s in fuel design,
te for approximately
test assemblies.
d (b) in the spent

the Secretary States of the Control	
DESCRIPT TAILS	TATEL THE A PERSON TO A ST
PCP. PUP. L. L. N.	INFORMATION

1.	Name of facility. Arkansas Nuclear One - Unit 1
2.	Scheduled date for next refueling shutdown. 1/1/81
3.	Scheduled date for restart following refueling. 3/1/81
4.	Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? If answer is yes, what, in general, will these be? If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Ref. 10 CFR Section 50.59)?
	Yes, reload report and associated proposed Technical Specification
	changes. Also, the safety analysis of four demonstration high
	burn-up assemblies will be provided.
5.	Scheduled date(s) for submitting proposed licensing action and supporting information. 10/1/80
6.	Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures. Will reload 68 fresh fuel assemblies and operate for approximately
	16 months. Four of which will be high burn-up test assemblies.
7.	The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool. a) 177 b) 176
8.	The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.
	present 590 increase size by 0
9.	The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.
	DATE: 1986

NRC MONTHLY OPERATING REPORT OPERATING SUMMARY - MAY 1980 UNIT I

The unit began the month in the cold shutdown mode to complete 80-03 outage work. The unit was tied on line May 5 and after 9 hours of operation the unit was taken off line for the turbine over speed trip test. The test was completed satisfactorily on May 5 and the unit was placed back on line the same day. The unit operated until May 10, when it was taken off line due to the failure of "C" reactor coolant pump seal. The unit was down the remainder of the month for repair and preventive maintenance work on reactor coolant pumps.

ARKANSAS NUCLEAR ONE - UNIT I

Periodic Core Power Distribution Comparison

A Radial Power Distribution comparison was performed at 156.2 EFPD. The RMS (root mean square) of the differences between measured and predicted at the 52 instrumented fuel assembly locations was 0.028 which is well within the acceptance criterion of 0.073.