

B&OTF WORK PRODUCTS

- BULLETIN EVALUATION REPORTS - EACH OPERATING PLANT
- SAFETY EVALUATIONS LIFTING ORDERS - B&W PLANTS
- LETTERS ISSUING AFW REQUIREMENTS
- LETTERS APPROVING GUIDELINES FOR SBLOCA EMERGENCY OPERATING PROCEDURES
- REPORT SUMMARIZING B&OTF REVIEW OF BULLETINS, ORDERS AND GENERIC EVALUATION OF SBLOCA AND LOFW (NUREG-0645)
- REPORT ON GENERIC EVALUATION OF DELAYED RCP TRIP DURING SBLOCA IN PWRs (NUREG-0623)
- REPORTS ON GENERIC EVALUATION OF SBLOCA AND LOFW IN OPERATING REACTORS
 - NUREG-0565 (B&W)
 - NUREG-0611 (W)
 - NUREG-0626 (GE)
 - NUREG-0635 (CE)

FIGURE D-1

Pat - Sec. 2
Circuit

B&W RECOMMENDATIONS FOR B&W-DESIGNED PLANTS

SYSTEMS RELIABILITY

- INSTALL AUTOMATIC BLOCK-VALVE CLOSURE SYSTEM
- OPERATIONAL TEST OF AUTOMATIC BLOCK-VALVE CLOSURE SYSTEM
- EVALUATION OF PORV OPENING PROBABILITY DURING OVERPRESSURE TRANSIENT
- REPORTING FAILURES AND CHALLENGES TO THE PORVs
- EVALUATION OF SAFETY VALVE RELIABILITY
- REPORTING FAILURES AND CHALLENGES TO THE SAFETY VALVES
- REVIEW AND UPGRADE RELIABILITY AND REDUNDANCY OF NON-SAFETY GRADE EQUIPMENT UPON WHICH SBLOCA MITIGATION RELIES
- CONSIDERATION OF DIVERSE DECAY HEAT REMOVAL PATH FOR DAVIS-BESSE I
- AUTOMATIC TRIP OF RCPs DURING SBLOCA - INSTALLED AND OPERATIONAL
- INSTRUMENTATION TO VERIFY NATURAL CIRCULATION - INSTALLED AND OPERATIONAL

ANALYSES

- ANALYSIS METHODS FOR SBLOCA, INCLUDING EVALUATION OF NODING
- PLANT-SPECIFIC CALCULATION TO SHOW COMPLIANCE WITH 10 CFR 50.46
- EVALUATION OF EFFECTS OF CORE FLOOD TANK INJECTION ON SBLOCAs
- ADDITIONAL STAFF AUDIT CALCULATIONS OF B&W'S SBLOCA ANALYSES
- EXPERIMENTAL VERIFICATION OF TWO-PHASE NATURAL CIRCULATION
- ANALYSIS OF PLANT RESPONSE TO A SBLOCA WHICH IS ISOLATED, CAUSING RCS REPRESSURIZATION AND SUBSEQUENT STUCK-OPEN PORV

- ANALYSIS OF PLANT RESPONSE TO A SBLOCA IN THE PRESSURIZER SPRAY LINE WITH A STUCK-OPEN SPRAY LINE ISOLATION VALVE
- EVALUATION OF EFFECTS OF WATER SLUGS IN PIPING CAUSED BY HPI AND CFT FLOWS
- EVALUATION OF RCP SEAL DAMAGE AND LEAKAGE DURING A SBLOCA
- SUBMIT PREDICTIONS FOR LOFT TEST L3-6 WITH RCPs RUNNING.
- SUBMIT REQUESTED INFORMATION ON THE EFFECTS OF NONCONDENSIBLE GASES:
(1) JUSTIFICATION FOR OMISSION OF RADIOLYTIC DECOMPOSITION AS A SOURCE OF NONCONDENSIBLE GASES, AND (2) VERIFICATION OF PREDICTED CONDENSATION HEAT TRANSFER DEGRADATION
- EVALUATION OF MECHANICAL EFFECTS OF SLUG-FLOW ON STEAM GENERATOR TUBES

EMERGENCY PROCEDURES

- THE REQUIREMENTS FOR EMERGENCY PROCEDURES HAVE BEEN IMPLEMENTED IN B&W PLANTS BY COMMISSION ORDERS.

OPERATOR TRAINING

- MINIMUM SIMULATOR TRAINING REQUIREMENTS FOR SBLOCA_s

B&OTF RECOMMENDATIONS FOR WESTINGHOUSE-DESIGNED OPERATING PLANTS

SYSTEMS RELIABILITY

- TECHNICAL SPECIFICATION (TS) TIME LIMIT ON AFW SYSTEM TRAIN OUTAGE (GS-1)
- TS ADMINISTRATIVE CONTROL ON MANUAL AFW SYSTEM VALVES-LOCK AND VERIFY POSITION (GS-2)
- AFW SYSTEM FLOW THROTTLING-WATER HAMMER (GS-3)
- AFW SYSTEM FLOW PATH VERIFICATION (GS-6)
- NON-SAFETY GRADE, NON-REDUNDANT AFW SYSTEM AUTOMATIC INITIATION SIGNALS (GS-7)
- AUTOMATIC INITIATION OF AFW SYSTEMS (GS-8)
- PRIMARY AFW SOURCE LOW LEVEL ALARM
- AFW PUMP ENDURANCE TEST
- INDICATION OF AFW FLOW TO THE STEAM GENERATORS
- AFW SYSTEM AVAILABILITY DURING PERIODIC SURVEILLANCE TESTING
- AUTOMATIC INITIATION OF AFW SYSTEMS (GL-1)
- SINGLE VALVES IN THE AFW SYSTEM FLOW PATH (GL-2)

B&OTF RECOMMENDATIONS FOR WESTINGHOUSE - DESIGNED OPERATING PLANTS (CONT'D)

- ELIMINATION OF AFW SYSTEM DEPENDENCY ON AC POWER FOLLOWING A COMPLETE LOSS OF AC POWER (GL-3)
- PREVENTION OF MULTIPLE PUMP DAMAGE DUE TO LOSS OF SUCTION RESULTING FROM NATURAL PHENOMENA (GL-4)
- NON-SAFETY GRADE, NON-REDUNDANT AFW SYSTEM AUTOMATIC INITIATION SIGNALS (GL-5)
- INTERACTION OF SAFETY AND NON-SAFETY SYSTEMS
- INSTRUMENTATION TO VERIFY NATURAL CIRCULATION
- PID CONTROLLER MODIFICATION
- PROPOSED ANTICIPATORY TRIP MODIFICATION
- CCI-SUPPLIED PORV
- INSTALLATION OF AUTO ISOLATION OF PORVs
- TESTING OF AUTO ISOLATION OF PORVs
- WESTINGHOUSE REPORT ON PORV FAILURE REDUCTION
- REPORTING PORV FAILURES AND CHALLENGES
- SAFETY VALVE FAILURE RATE BASED ON OPERATIONAL EXPERIENCE
- REPORTING SAFETY VALVE FAILURES AND CHALLENGES
- REACTOR COOLANT PUMP TRIP
- CONFIRMATION OF ANTICIPATORY TRIP

B&OTF RECOMMENDATIONS FOR WESTINGHOUSE-DESIGNED OPERATING PLANTS (CONT'D)

ANALYSIS

- SMALL BREAK LOCA ANALYSIS METHODS - APPENDIX K
- PLANT-SPECIFIC APPENDIX K CALCULATIONS
- TWO-PHASE NATURAL CIRCULATION EXPERIMENTS
- EVALUATE ELIMINATION OF PORV FUNCTION
- MODIFICATIONS TO RELAP4 HEATUP CALCULATION
- EFFECTS OF ACCUMULATOR INJECTION ON RELAP4 CALCULATIONS
- MODIFICATION OF RELAP4 TO REPRESENT STEAM GENERATOR REALISTICALLY

EMERGENCY PROCEDURES

- EMERGENCY PROCEDURES FOR INITIATING BACKUP WATER SUPPLIES (GS-4)
- EMERGENCY PROCEDURES FOR INITIATING AFW FLOW FOLLOWING LOSS OF ALL AC POWER (GS-5)
- REVIEW OF PROCEDURES (NRC)
- REVIEW OF PROCEDURES (NSSS VENDORS)
- SYMPTOM-BASED EMERGENCY PROCEDURES

B&QTE RECOMMENDATIONS FOR WESTINGHOUSE-DESIGNED OPERATING PLANTS (CONT'D)

OPERATOR TRAINING

- SIMULATOR TRAINING PROGRAM
- SIMULATION OF SMALL BREAK LOCA
- MONITORING CONTROL BOARD

B&QTF RECOMMENDATIONS FOR CE-DESIGNED OPERATING PLANTS

SYSTEMS RELIABILITY

- TECHNICAL SPECIFICATION (TS) TIME LIMIT ON AFW SYSTEM TRAIN OUTAGE (GS-1)
- TS ADMINISTRATIVE CONTROL ON MANUAL VALVES - LOCK AND VERIFY POSITION (GS-2)
- AFW SYSTEM FLOW THROTTLING - WATER HAMMER (GS-3)
- AFW SYSTEM FLOW PATH VERIFICATION (GS-6)
- AUTOMATIC INITIATION OF AFW SYSTEM (GS-8)
- PRIMARY AFW SOURCE LOW LEVEL ALARM
- AFW PUMP ENDURANCE TEST
- INDICATION OF AFW FLOW TO THE STEAM GENERATORS
- AFW SYSTEM AVAILABILITY DURING PERIODIC SURVEILLANCE TESTING
- AUTOMATIC INITIATION OF AFW SYSTEM (GL-1)
- SINGLE VALVES IN AFW SYSTEM FLOW PATH (GL-2)
- ELIMINATION OF AC POWER DEPENDENCY (GL-3)
- PREVENTION OF MULTIPLE PUMP DAMAGE DUE TO LOSS OF SUCTION RESULTING FROM NATURAL PHENOMENA (GL-4)
- REVIEW OF RELIABILITY & REDUNDANCY OF EQUIPMENT

B&OTF RECOMMENDATIONS FOR CE-DESIGNED OPERATING PLANTS (CONT'D)

- INSTRUMENTATION TO VERIFY NATURAL CIRCULATION
- INSTALLATION OF AUTOMATIC ISOLATION OF PORVs
- TESTING AUTOMATIC ISOLATION OF PORVs
- CE REPORT ON PORV FAILURE REDUCTIONS
- REPORTING FUTURE FAILURES AND CHALLENGES OF PORV AND SV
- AUTOMATIC TRIP OF RCPs

ANALYSIS

- ANALYSIS METHODS-APPENDIX K
- PLANT-SPECIFIC APPENDIX K CALCULATIONS
- TWO-PHASE NATURAL CIRCULATION EXPERIMENTS
- EVALUATE THE ELIMINATION OF PORV FUNCTION
- MODIFICATION TO RELAP AND CEFLASH-4AS DUE TO UNCERTAINTIES IN HEATUP CALCULATIONS
- EFFECTS OF ACCUMULATOR INJECTION ON RELAP4 CALCULATIONS
- MODIFICATION OF RELAP4 TO REPRESENT SG BEHAVIOR REALISTICALLY

B&OIF RECOMMENDATIONS FOR CE-DESIGNED OPERATING PLANTS (CONT'D)

EMERGENCY PROCEDURES

- EMERGENCY PROCEDURES FOR INITIATING BACKUP WATER SUPPLIES (GS-4)
- EMERGENCY PROCEDURES FOR INITIATING AFW FLOW FOLLOWING LOSS OF ALL AC POWER (GS-5)
- REVIEW OF PROCEDURES (NRC)
- REVIEW OF PROCEDURES (NSSS VENDORS)
- SYMPTOM-BASED EMERGENCY PROCEDURES

OPERATOR TRAINING

- EXPANDED USE OF SIMULATORS IN OPERATOR TRAINING
- SIMULATOR TRAINING PROGRAM
- SIMULATION OF SMALL-BREAK LOCAs

B&OTF RECOMMENDATIONS FOR OPERATING AND NEAR-TERM OL BWR PLANTS

SYSTEMS RELIABILITY

- SEPARATION OF HPCI AND RCIC SYSTEM INITIATION LEVELS (A.1)
- ISOLATION OF ISOLATION CONDENSERS ON HIGH RADIATION (A.2)
- SPURIOUS ISOLATION OF HPCI AND RCIC SYSTEMS (A.3)
- REDUCTION OF CHALLENGES AND FAILURES OF RELIEF VALVES (A.4)
- REPORT ON OUTAGE OF ECC SYSTEMS (A.6)
- MODIFICATION OF ADS LOGIC (A.7)
- INTERLOCK ON RECIRCULATION PUMP LOOPS (A.8)
- LOSS OF SERVICE WATER FOR BIG ROCK POINT (A.9)
- RESTART OF CORE SPRAY AND LPCI SYSTEMS ON LOW LEVEL (A.10)
- AUTOMATIC SWITCHOVER OF RCIC SYSTEM SUCTION (B.1)
- CENTRAL WATER LEVEL RECORDING (B.2)
- SPACE COOLING FOR HPCI AND RCIC SYSTEMS (B.3)

B&OTF RECOMMENDATIONS FOR OPERATING AND NEAR-TERM OL BWR PLANTS (CONT'D.)

- EFFECT OF LOSS OF ALTERNATING CURRENT POWER ON PUMP SEALS (B.4)
- USE OF RHR FOR FUEL POOL COOLING (B.5)
- COMMON REFERENCE FOR LEVEL INSTRUMENTS (B.6)
- QUALIFICATION OF ACCUMULATORS ON ADS VALVES (B.7)
- DIVERSE INITIATION SIGNAL FOR RCIC SYSTEM (B.10)
- PERFORMANCE OF ISOLATION CONDENSERS WITH NONCONDENSIBLES (B.13)
- REPORTING OF FAILURES AND CHALLENGES TO SRVs (B.14)

ANALYSES

- REVISE SMALL-BREAK LOCA MODEL FOR COMPLIANCE WITH APPENDIX K (A.12)
- PLANT-SPECIFIC ANALYSES WITH REVISED MODEL (A.13)
- NO FUEL FAILURE REQUIREMENT FOR ANTICIPATED TRANSIENTS WITH SINGLE FAILURE (A.14)
- DEPRESSURIZATION WITH OTHER THAN ADS (A.15)
- MICHELSON CONCERNS (A.17)

B&OTF RECOMMENDATIONS FOR OPERATING AND NEAR-TERM OL BWR PLANTS (CONT'D.)

- TEST PROGRAM FOR SMALL-BREAK LOCA MODEL VERIFICATION (B,9)
- USE OF NON-ECC SYSTEMS IN ANALYSES (B,12)
- IMPACT OF B&OTF RECOMMENDATIONS (B,15)

EMERGENCY PROCEDURES

- IDENTIFY WATER SOURCES PRIOR TO MANUAL ACTIVATION ADS (A,5)
- REVISED EMERGENCY PROCEDURES (A,11)
- TWO OPERATORS IN CONTROL ROOM (A,16)
- GUIDELINES FOR SYMPTOM-BASED EMERGENCY PROCEDURES (B,8)

OPERATOR TRAINING

- SMALL-BREAK LOCA ON SIMULATOR (B,11)

D13



HARDWARE-TYPE RECOMMENDATIONS

THE HARDWARE-TYPE RECOMMENDATIONS INCLUDE:


- (A) PLACING THE PORV'S AND BLOCK VALVES ON EMERGENCY POWER — (THIS RECOMMENDATION IS SIMILAR TO RECOMMENDATION NO. 2.1.1 OF NUREG-0578);
 - (B) DIRECT POSITION INDICATION OF PORV'S — (THIS RECOMMENDATION IS SIMILAR TO RECOMMENDATION NO. 2.1.3.a OF NUREG-0578);
 - (C) AUTOMATICALLY ISOLATING THE PORV'S ON LOW REACTOR SYSTEM PRESSURE AND
 - (D) DERIVATIVE "FIX" — (THIS RECOMMENDATION IS APPLICABLE TO W-DESIGNED PLANTS ONLY. IN BRIEF, IT INVOLVES RAISING THE TRIP PRESSURE SETPOINT ON THE PID CONTROLLER WHICH IS USED ON MOST W-DESIGNED PLANTS. SINCE THIS RECOMMENDATION TENDS TO BE PLANT-SPECIFIC, AND SINCE IT HAS BEEN IMPLEMENTED IN THE AFFECTED PLANTS PER A SIMILAR RECOMMENDATION MADE BY WESTINGHOUSE, ITS EFFECTIVENESS WAS NOT ASSESSED.)
- PLUS
- (E) CHANGING PORV SETPOINT — THE PORV SETPOINT WAS RAISED ON THE B&W PLANTS ONLY.

SOFTWARE-TYPE RECOMMENDATIONS


THE SOFTWARE-TYPE RECOMMENDATIONS INCLUDE:

- (A) QUALIFICATIONS – (THIS RECOMMENDATION IS SIMILAR TO RECOMMENDATION NO. 9 IN NUREG-0585, I.E., EVALUATING INTERACTIONS OF NON-SAFETY AND SAFETY SYSTEMS AND PROPER QUALIFICATION OF SAFETY SYSTEMS);
- (B) OPERATIONAL PROCEDURES AND TRAINING – (THIS RECOMMENDATION PERTAINS TO NEW GUIDELINES AND PROCEDURES TO MORE READILY IDENTIFY SMALL-BREAK LOCA'S AND TRAINING INVOLVING THE USE OF SEVERAL PARAMETERS, THE SATURATION METER AND DIRECT POSITION INDICATOR ON PORV'S IN DIAGNOSING SMALL-BREAK LOCA'S);
- (C) McGUIRE CONCERN – (THIS MATTER INVOLVES THE FAILURE OF A PORV SUPPLIED BY CCI ON A SPECIFIC PLANT DURING TESTING. BECAUSE OF THE SPECIFICITY OF THIS MATTER, THE EFFECTS OF THE "FIX" WERE NOT ASSESSED);
- (D) FAILURE TO CLOSE "EAL" – (THIS RECOMMENDATION INVOLVES THE PROMPT REPORTING OF PORV FAILURES IN CONFORMANCE WITH THE EMERGENCY ACTION LEVELS STATED IN NUREG-0610); AND
- (E) SHORT-TERM LESSONS LEARNED (STLL) RESEARCH – (THIS RECOMMENDATION INVOLVES THE TESTING OF RELIEF AND SAFETY VALVES IN CONFORMANCE WITH RECOMMENDATION NUMBER 2.1.1 OF NUREG-0578, INCLUDING THE TESTING OF VALVES UNDER THEIR EXPECTED DYNAMIC OPERATING CONDITIONS SUCH AS TWO-PHASE FLUID SLUG FLOW).


ASSESSMENT OF CITED RECOMMENDATION IN REDUCING THE LIKELIHOOD OF SMALL-BREAK LOCA'S DUE TO STUCK-OPEN PORV'S



(POST TMI)
INITIATING EVENTS LEADING
TO STUCK-OPEN PORVS
IN B&W PLANTS




0-17



(From Sheet 2A)

SHEET 3A


**B&W PLANTS
(POST TMI)**




(POST TMI)

SHEET 4

ASSESSMENT OF REDUCTION OF SBLOCA'S DUE TO STUCK-OPEN PORV'S IN B&W PLANTS



(POST-TMI)
**ASSESSMENT OF REDUCTION OF SBLOCA'S
 DUE TO STUCK-OPEN PORV'S
 IN B&W PLANTS**




0-21

B&W PLANTS (POST TMI)

SHEET 6A

INITIATING SEQUENCE: (FROM SHEET 2A)

PORV OPENS; REACTOR SCRAMS;
OFFSITE POWER REMAINS INTACT.



0-22


B&W PLANTS (POST TMI)

SHEET 7A

INITIATING SBLOCA SEQUENCE: (FROM SHEET 3A)

PORV OPENS; REACTOR DOES NOT SCRAM; PORV DOES NOT RECLOSE; REACTOR SCRAMS ON SBLOCA; OFFSITE POWER REMAINS INTACT.

(CASE 5)



0-23

**ESTIMATED EFFECTIVENESS OF THE B&O RECOMMENDATIONS IN
REDUCING THE LIKELIHOOD OF SMALL-BREAK LOCA'S IN OPERATING
PLANTS DUE TO STUCK-OPEN PORV'S**

A. LIKELIHOOD OF SUCH EVENTS PER REACTOR-YEAR IN B&W PLANTS:

CASE	PRIOR TO TMI	AFTER SHORT-TERM RECOMMENDATIONS	AFTER LONG-TERM RECOMMENDATIONS
1	5×10^{-3}	2×10^{-4}	10^{-5}
2	2×10^{-3}	4.4×10^{-5}	2.2×10^{-6}
3	5×10^{-4}	5×10^{-6}	2.5×10^{-7}
4	10^{-1}	4.5×10^{-3}	2.2×10^{-4}
5	2.5×10^{-2}	5×10^{-4}	2.5×10^{-5}
TOTAL	$\sim 10^{-1}$	$\sim 5 \times 10^{-3}$	$\sim 2 \times 10^{-4}$

B. LIKELIHOOD OF SUCH EVENTS PER REACTOR-YEAR IN C-E AND W PLANTS:

CASE	PRIOR TO TMI	AFTER SHORT-TERM RECOMMENDATIONS	AFTER LONG-TERM RECOMMENDATIONS
1	10^{-3}	2×10^{-4}	10^{-5}
2	6×10^{-5}	1.2×10^{-5}	6×10^{-7}
3	4×10^{-5}	8×10^{-6}	4×10^{-7}
4	2.5×10^{-3}	10^{-3}	5×10^{-5}
5	2×10^{-3}	8×10^{-4}	4×10^{-5}
TOTAL	$\sim 6 \times 10^{-3}$	$\sim 2 \times 10^{-3}$	$\sim 10^{-4}$

0-24

CR3 KEY PARAMETERS AVAILABILITY

<u>PARAMETER</u>	<u>INSTRUMENT NUMBER</u>	<u>CONTROL BOARD</u>	<u>COMPUTER</u>
RCS FLOW LOOP "A"	RC-14A-FT	NO	NO
RCS FLOW LOOP "B"	RC-14B-FT	NO	NO
T HOT LOOP "A"	RC-4A-TT1	NO	NO
T HOT LOOP "A"	RC-4A-TT4	NO*	NO
T HOT LOOP "B"	RC-4B-TT1	NO	NO
T HOT LOOP "B"	RC-4B-TT4	NO*	NO*
PRESSURIZER LEVEL	RC1-LT1	NO	NO

0-25

<u>PARAMETER</u> (CONTINUED)	<u>INSTRUMENT</u> <u>NUMBER</u>	<u>CONTROL</u> <u>BOARD</u>	<u>COMPUTER</u>
PRESSURIZER LEVEL	RC1-LT2	NO	NO
PRESSURIZER LEVEL	RC1-LT3	NO	YES
T COLD LOOP "A"	RC-5A-TT1	NO	NO
T COLD LOOP "A"	RC-5A-TT3	NO*	YES
T COLD LOOP "B"	RC-5B-TT1	No	NO
T COLD LOOP "B"	RC-5B-TT3	NO*	YES

*AVAILABILITY IF SELECTED

98-0



CR3 KEY PARAMETER AVAILABILITY

<u>PARAMETER</u>	<u>INSTRUMENT NUMBER</u>	<u>CONTROL BOARD</u>	<u>COMPUTER</u>
ENGINEERED SAFEGUARDS WIDE RANGE RCS PRESSURE	RC-3A-PT3	YES	NO
ENGINEERED SAFEGUARDS WIDE RANGE RCS PRESSURE	RC-3B-PT3	YES	NO
TC WIDE RANGE LOOP A	RC-5A-TT4	YES	NO
TC WIDE RANGE LOOP B	RC-5B-TT4	YES	YES
OTSG "B" OPERATING LEVEL	SP-1B-LT3	YES	NO
OTSG "B" STARTUP LEVEL	SP-1B-LT4	NO	YES

B-4

D-27

<u>PARAMETER</u>	<u>INSTRUMENT NUMBER</u>	<u>CONTROL BOARD</u>	<u>COMPUTER</u>
(CONTINUED)			
OTSG "A" FULL RANGE LEVEL	SP-1A-LT1	YES	NO
OTSG "B" FULL RANGE LEVEL	SP-1B-LT1	YES	NO
OTSG "A" PRESSURE	SP-6A-PT2	NO	YES
OTSG "B" PRESSURE	SP-6B-PT1	YES	YES
HIGH PRESSURE INJECTION FLOW	MU-23-DPT3	YES	NO
HIGH PRESSURE INJECTION FLOW	MU-23-DPT4	YES	NO

B-4

0-28

<u>PARAMETER</u>	<u>INSTRUMENT</u> <u>NUMBER</u>	<u>CONTROL</u> <u>BOARD</u>	<u>COMPUTER</u>
(CONTINUED)			
LOW PRESSURE INJECTION FLOW	DH-1-DPT2	YES	NO
CORE FLOOD TANK "B" LEVEL	CF-2-LT2	YES	YES

D-29

STATUS ON UNREVIEWED SAFETY QUESTIONS ASSOCIATED WITH AUTO
INITIATION OF AFW SYSTEMS

<u>PLANT</u>	<u>VENDOR</u>	<u>OWNER RESPONSE DATE</u>	<u>SUBSTANCE OF RESPONSE</u>	<u>LICENSEE CONCLUDES FROM ANALYSES THAT RETURN TO POWER AND CONTAINMENT PRESSURE ACCEPTABLE</u>	<u>AUTO INITIATION STATUS (3)</u>
MILLSTONE 2	CE	01/25/80	PROVIDED ANALYSIS (1)	YES (2)	DESIGN SUBMITTED
CALVERT CLIFFS	CE	01/25/80	PROVIDED ANALYSIS (1)	YES (2)	DESIGN SUBMITTED
HADDAM NECK	W	01/30/80	PROVIDED ANALYSIS (1)	YES	DESIGN SUBMITTED
PALISADES	CE	01/21/80	PROVIDED ANALYSIS (1)	YES (2)	DESIGN SUBMITTED
MAINE YANKEE	CE	01/09/80	PROVIDED ANALYSIS (1)	YES (2)	DESIGN SUBMITTED
ST. LUCIE 1	CE	01/24/80	PROVIDED ANALYSIS (1)	YES (2)	DESIGN SUBMITTED
FT. CALHOUN	CE	01/10/80	PROVIDED ANALYSIS (1)	YES (2)	DESIGN SUBMITTED
SAN ONOFRE	W	01/16/80	DOES NOT PLAN TO SUBMIT ANALYSIS UNTIL OCT. 1980	N/A	PARTIAL CONTROL GRADE DESIGN SUBMITTED

0-30

- (1) ANALYSES UNDER REVIEW BY CSB & RSB, PLAN COMPLETION IN APRIL 1980
 (2) 2-5 MINUTE TIME DELAY OF AFW INITIATION ASSUMED IN MSLB ANALYSIS
 (3) WILL NOT IMPLEMENT UNTIL STAFF APPROVES MSLB ANALYSIS

EXPERIENCE WITH PUMP TRIP DURING NON-LOCA
DEPRESSURIZING TRANSIENTS

NON-LOCA TRANSIENTS WHICH PRODUCED PRIMARY SYSTEM DEPRESSURI-
ZATION TO SI ACTUATION SETPOINT AND REQUIRED RCP TRIP

DATE	PLANT	TYPE	EVENT
9/26/79	NORTH ANNA UNIT NO. 1	WESTINGHOUSE 3-LOOP	FW HEATER MALFUNCTION TURBINE TRIP-REACTOR TRIP/CONDENSER DUMP VALVE STUCK OPEN
10/2/79	PRAIRIE ISLAND UNIT NO. 1	WESTINGHOUSE 2-LOOP	STEAM GENERATOR TUBE BREAK
1/29/80	ANO-2	COMBUSTION ENGINEERING	TURBINE TRIP-REACTOR TRIP/STEAM DUMP VALVE STUCK OPEN
2/26/80	CRYSTAL RIVER	B&W 177FA LOWERED LOOP	REACTOR TRIP/ICS FAILURE/SG OVERFEED