

DCD/DCB

OCT 23 1989

Public Service Indiana
ATTN: Mr. Ronald Richard
Gibson Generating Station
P.O. Box 408
Owensville, IN 47665

License No. 13-15544-01

Gentlemen:

This refers to a telephone contact conducted October 12, 1989. The contact was an examination of activities conducted under your license as they relate to radiation safety and to compliance with the Commission's rules and regulations and with the conditions of your license. The contact consisted of discussions with you and Mr. K. Lambert of my staff.

As a result of this examination of activities, regulatory concerns were noted and are specified below. They may be evaluated at an onsite inspection at your facility in the near future.

As you described on the telephone, the following apparent regulatory concern was identified:

Contrary to License Condition No. 15, you failed to conduct a physical inventory of your AM-241 source every six months.

You should examine your license and NRC regulations to determine how you can correct the apparent regulatory concerns that you discussed on the telephone. Please submit to this office within 30 days of this letter, a description of actions taken or those that will be taken to correct the above mentioned regulatory concern. In addition, we would like to highlight the following items that licensees should pay particular attention to as follows:

- a. Maintaining awareness and control of licensed material.
- b. Proper transfers and disposal of radioactive sources.
- c. Promptly reporting losses or thefts of licensed materials.

If you have any questions regarding this contact, you may contact us at (312)790-5292.

Sincerely,

8910300215 891023
REG3 LIC30
13-15544-01 PDC

D. J. Sreniawski, Chief
Nuclear Materials Safety Section 1

cc: DCD/DCB (RIDS)

bcc: Technical Assistant, DRSS

RIII
WJD for
Lambert/gd

RIII
WJD for
Sreniawski

IE07

1/0