

SACRAMENTO MUNICIPAL UTILITY DISTRICT | 6201 S Street, P.O. Box 15830, Secremento CA 95852-1830, (916) 452-3211

AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

AGM/NUC 89-201

November 10, 1989

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

Docket No. 50-312 Rancho Seco Nuclear Generating Station License No. DPR-54

NRC BULLETIN 89-02, STRESS CORROSION CRACKING OF HIGH-HARDNESS TYPE 410
STAINLESS STEEL INTERNAL PRELOADED BOLTING IN ANCHOR DARLING MODEL S350M SWING
CHECK VALVES OR VALVES OF SIMILAR DESIGN

Attention: George Knighton

The subject bulletin required us to determine whether swing check valves of the Model S350W Anchor Darling type, or similarly designed valves of any other type or manufacturer, existed in our plant, and if applicable, disassemble and inspect the valve internals. Reviews performed by our Technical Services Department determined that Rancho Seco does not have any valves of the same or similar design, and therefore no further actions are required.

Members of your staff with questions requiring additional information or clarification may contact Steve Rutter at (209) 333-2935, extension 4911.

State of California

SS

County of Sacramento

Dan R. Keuter, being first duly sworn, doposes and says: that he is Assistant General Manager, Nuclear of Sacramento Municipal Utility District (SMUD), the licensee herein; that he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute this document on behalf of said licensee.

Dan R. Keuter

Assistant General Manager

Nuclear

Subscribed and affirmed to before me on this 10th day of naumber, 1989.

8911160245 891110 PDR ADOCK 05000312

Elizabeth L. Gandy Notary Public

cc: J. B. Martin, NRC, Walnut Creek
A. D'Angelo, NRC, Rancho Seco

G. Kalman, NRC, Rockville F. J. Miraglia, NRR, Rockville 10