

NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

DOCKET NO. 50-333

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 139 License No. DPR-59

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Power Authority of the State of New York (the licensee) dated May 19, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.139, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

 This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra, Director Project Directorate I-1 Division of Reactor Projects - 1/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: October 2, 1989

FACILITY OPERATING LICENSE NO. DPR-59 DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Pages	Insert Pages
176	176
177	177

3.7 (cont'd)

4.7 (cont'd)

- The containment shall be purged through the Standby Gas
 Treatment System whenever the primary containment
 integrity is required. If this requirement cannot be met,
 then purging shall be discontinued without delay.
- Continuous Leak Rate Monitoring

When the primary containment is inerted, it shall be continuously monitored for gross leakage by review of the inerting system makeup requirements.

- Pressure Suppression Chamber-Reactor Building Vacuum Breakers
 - a. Except as specified in 3.7.A.4.b below, two Pressure Suppression Chamber-Reactor Building Vacuum Breakers shall be operable at all times when the primary containment integrity is required. The setpoint of the differential pressure instrumentation which actuates the pressure suppression chamber reactor building vacuum breakers shall be <0.5 psi below reactor building pressure.
 - b. From and after the date that one of the pressure suppression chamber-reactor building vacuum breakers is made or found to be inoperable for any reason, reactor operation is permissible only during the succeeding 7 days, unless such vacuum

When the primary containment is inerted, it shall be continuously monitored for gross leakage by review of the inerting system makeup requirements. The monitoring system may be taken out of service for maintenance, but shall be returned to service as soon as possible.

- Pressure Suppression Chamber-Reactor Building Vacuum Breakers
 - a. The pressure suppression chamber-reactor building vacuum breakers and associated instrumentations including setpoint shall be checked for proper operation every three months.