



Duquesne Light

Nuclear Group
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

October 9, 1989


Beaver Valley Power Station
Unit 1 - Docket No. 50-334, License No. DPR-66
Unit 2 - Docket No. 50-412, License No. NPF-73
Monthly Operating Report

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

In accordance with Appendix A, Technical Specifications, the Monthly Operating Report is submitted for Unit 1 and Unit 2 for the month of September, 1989.

Very truly yours,


J. D. Sieber
Vice President
Nuclear Group

MAW/lmg

Enclosures

cc: NRC Regional Office
King of Prussia, PA

8910240029 890930
PDR ADDCK 05000334
R PNU

TEZA
11

UNIT SHUTDOWNS AND POWER REDUCTIONS

Docket No. 50-334
 Unit Name BVPS Unit #1
 Date October 9, 1989
 Completed by M.A. Winger
 Telephone (412) 393-7621

REPORT MONTH SEPTEMBER 1989

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
34	890901	S	0	H	5	N/A	RC	Fuel XX	The Unit operated at approximately 80% output in a core coast down mode prior to the Unit's Seventh Refueling Outage.
35	890901	S	698	C	1	N/A	RC	Fuel XX	Unit shutdown for its Seventh Refueling Outage.

¹
 F-Forced
 S-Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont'd. from Previous Month
 5-Reduction
 9-Other

⁴
 Exhibit G-Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG0161).

⁵
 Exhibit I-Same Source.

OPERATING DATA REPORT

DOCKET NO.: 50-334
 REPORT DATE: 10/07/89
 COMPLETED BY: M.A.WINGER
 TELEPHONE: (412) 393-7621

OPERATING STATUS

1. UNIT NAME: BEAVER VALLEY POWER STATION, UNIT 1
2. REPORTING PERIOD: SEPTEMBER 1989
3. LICENSED THERMAL POWER (MWt): 2660
4. NAMEPLATE RATING (Gross MWe): 923
5. DESIGN ELECTRICAL RATING (Net MWe): 835
6. MAX. DEPENDABLE CAPACITY (Gross MWe): 860
7. MAX. DEPENDABLE CAPACITY (Net MWe): 810

Notes

8. IF CHANGES OCCUR IN CAPACITY RATINGS SINCE LAST REPORT, GIVE REASONS:

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (Net MWe): None

10. REASONS FOR RESTRICTIONS, IF ANY: N/A

	THIS MONTH	YEAR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD:	720.0	6551.0	117623.0
12. NO. OF HRS. REACTOR WAS CRITICAL:	22.1	5738.8	71989.7
13. REACTOR RESERVE SHUTDOWN HOURS:	0.0	0.0	4482.8
14. HOURS GENERATOR WAS ON LINE:	22.0	5722.3	70366.3
15. UNIT RESERVE SHUTDOWN HOURS:	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GEN. (MWH):	43522.0	12651193.0	165997551.5
17. GROSS ELECT. ENERGY GEN. (MWH):	14070.0	4053450.0	53246789.0
18. NET ELECTRICAL ENERGY GEN. (MWH):	9040.0	3787530.0	49695920.0
19. UNIT SERVICE FACTOR: (PERCENT)	3.1	87.4	62.2
20. UNIT AVAILABILITY FACTOR: (PERCENT)	3.1	87.4	62.2
21. UNIT CAPACITY FACTOR (MDC): PCT	1.6	71.4	55.3
22. UNIT CAPACITY FACTOR (DER): PCT	1.5	69.2	53.6
23. UNIT FORCED OUTAGE RATE: (PERCENT)	0.0	2.2	17.1

24. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, AND DURATION OF EACH):

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NOV. 10, 1989

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

	FORECAST	ACHIEVED
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

AVERAGE DAILY UNIT POWER LEVEL

Docket No. 50-334
 Unit EVPS Unit 1
 Date October 9, 1989
 Completed by M.A. Winger
 Telephone (412) 393-7621

MONTH September 1989

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>543</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>	31	<u>N/A</u>
16	<u>0</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

NARRATIVE SUMMARY OF
MONTHLY OPERATING EXPERIENCE

UNIT I

SEPTEMBER 1989

September 1 The Unit was operated at approximately 80% output in a core coastdown mode. At 2201 hours the Unit was removed from service to begin it's Seventh Refueling Outage.

September 2 At 1355 the Unit entered Mode 4.

September 3 The Unit remained in Mode 4 to prepare for the Unit's Seventh Refueling Outage.

September 4 At 2320 hours the Unit entered Mode 5.

September 5
through
September 12 The Unit remained in Mode 5 to prepare for entry into Mode 6.

September 13 At 1530 hours, the Unit entered Mode 6.

September 14
through
September 30 The Unit remained in Mode 6.

OPERATING DATA REPORT

DOCKET NO.: 50-412
 REPORT DATE: 10/07/89
 COMPLETED BY: M.A.WINGER
 TELEPHONE: (412) 393-7621

OPERATING STATUS

1. UNIT NAME: BEAVER VALLEY POWER STATION, UNIT 2
2. REPORTING PERIOD: SEPTEMBER 1989
3. LICENSED THERMAL POWER (MWt): 2660
4. NAMEPLATE RATING (Gross MWe): 923
5. DESIGN ELECTRICAL RATING (Net MWe): 836
6. MAX. DEPENDABLE CAPACITY (Gross MWe): 885
7. MAX. DEPENDABLE CAPACITY (Net MWe): 833

Notes

8. IF CHANGES OCCUR IN CAPACITY RATINGS SINCE LAST REPORT, GIVE REASONS:

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (Net MWe): None
10. REASONS FOR RESTRICTIONS, IF ANY: N/A
-
-

	THIS MONTH	YEAR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD:	720.0	6351.0	16406.0
12. NO. OF HRS. REACTOR WAS CRITICAL:	720.0	408.5	13347.8
13. REACTOR RESERVE SHUTDOWN HOURS:	0.0	0.0	0.0
14. HOURS GENERATOR WAS ON LINE:	720.0	4038.6	13217.9
15. UNIT RESERVE SHUTDOWN HOURS:	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GEN. (MWH):	1900600.0	9401369.0	33132309.4
17. GROSS ELECT. ENERGY GEN. (MWH):	609800.0	2990000.0	10619800.0
18. NET ELECTRICAL ENERGY GEN. (MWH):	578495.0	2789027.0	10004192.0
19. UNIT SERVICE FACTOR: (PERCENT)	100.0	61.6	80.6
20. UNIT AVAILABILITY FACTOR: (PERCENT)	100.0	61.6	80.6
21. UNIT CAPACITY FACTOR (MDC): PCT	96.5	51.1	73.2
22. UNIT CAPACITY FACTOR (DER): PCT	96.1	50.9	72.9
23. UNIT FORCED OUTAGE RATE: (PERCENT)	0.0	16.1	7.7

24. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, AND DURATION OF EACH):

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):

	FORECAST	ACHIEVED
INITIAL CRITICALITY	<u>N/A</u>	<u>N/A</u>
INITIAL ELECTRICITY	<u>N/A</u>	<u>N/A</u>
COMMERCIAL OPERATION	<u>N/A</u>	<u>N/A</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

Docket No. 50-412
 Unit Name BVPS Unit #2
 Date October 9, 1989
 Completed By M.A. Winger
 Telephone (412) 393-7621

REPORT MONTH SEPTEMBER 1989

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
NONE									

¹
 F-Forced
 S-Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont'd. from Previous Month
 5-Reduction
 9-Other

⁴
 Exhibit G-Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG0161).

⁵
 Exhibit I-Same Source.

AVERAGE DAILY UNIT POWER LEVEL

Docket No. 50-412
 Unit EVPS Unit 2
 Date October 9, 1989
 Completed by M. A. Winger
 Telephone (412)393-7621

MONTH September 1989

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>798</u>	17	<u>802</u>
2	<u>806</u>	18	<u>802</u>
3	<u>806</u>	19	<u>807</u>
4	<u>802</u>	20	<u>803</u>
5	<u>806</u>	21	<u>794</u>
6	<u>799</u>	22	<u>798</u>
7	<u>798</u>	23	<u>811</u>
8	<u>790</u>	24	<u>811</u>
9	<u>794</u>	25	<u>811</u>
10	<u>794</u>	26	<u>815</u>
11	<u>794</u>	27	<u>815</u>
12	<u>802</u>	28	<u>811</u>
13	<u>802</u>	29	<u>811</u>
14	<u>806</u>	30	<u>807</u>
15	<u>802</u>	31	<u>N/A</u>
16	<u>806</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

NARRATIVE SUMMARY OF
MONTHLY OPERATING EXPERIENCE

UNIT II

SEPTEMBER 1989

September 1
through
September 30

The Unit operated at a nominal value of 100% output.