



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

YANKEE ATOMIC ELECTRIC COMPANY  
DOCKET NO. 50-029  
YANKEE NUCLEAR POWER STATION  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 126  
License No. DPR-3

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
  - A. The application for amendment filed by Yankee Atomic Electric Company (the licensee) dated August 31, 1989 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter 1;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-3 is hereby amended to read as follows:


(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 126, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

8910270028 891023  
PDR ADOCK 05000029  
FDC

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard H. Wessman, Director  
Project Directorate I-3  
Division of Reactor Projects I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: October 23, 1989

ATTACHMENT TO LICENSE AMENDMENT NO.126

FACILITY OPERATING LICENSE NO. DPR-3

DOCKET NO. 50-029

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove

3/4 3-19

3/4 3-21

Insert

3/4 3-19

3/4 3-21

TABLE 2.2-6 (CONT'D)

RADIATION MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ALARM SETPOINT</u>	<u>MEASUREMENT RANGE</u>	<u>ACTION</u>
2. PROCESS MONITORS (CONT'D)					
(c) Steam Line Monitors	1 (3)	1, 2, 3, 4	NA	0.1 - 10 <sup>7</sup> mR/hr	15
(d) Primary Vent Stack (noble gas) Monitor	1	1, 2, 7, 4	NA	0.1 - 10 <sup>7</sup> mR/hr	15

TABLE 4.3.3

## RADIATION MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
1. AREA MONITORS				
(a) Spent Fuel Pit Area				
1. Fuel Manipulator	S	R	M	*
(b) Containment				
1. Fuel Manipulator	S	R	M	*
2. High Range (Also Accident Emergency Monitors)	S	R	R	1,2,3,4
2. PROCESS MONITORS				
(a) Containment				
1. Main Coolant System Leakage Air Particulate Monitor	S	R	M	1,2,3,4
(b) Radioactive Liquid Monitor				
1. Steam Generator Blowdown Monitor	S	R	M	1,2,3,4
(c) Steam Line Monitors	S	R	M	1,2,3,4
(d) Primary Vent Stack (noble gas) monitors	S	R	M	1,2,3,4

\* When handling irradiated fuel, control rods or sources.

YANKEE-ROWE

3/4 3-21

Amendment ~~50~~, ~~80~~, ~~95~~,  
26