

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

TABLE NOTATIONS (Continued)

- (f) Isolates with simultaneous RCIC Steam Supply Pressure-Low (Isolation Instrumentation) and Drywell Pressure-High (ECCS Actuation Instrumentation).
- (g) Isolates with simultaneous HPCI Steam Supply Pressure-Low (Isolation Actuation Instrumentation) and Drywell Pressure-High (ECLS Actuation Instrumentation).
- (h) Reserved.
- (i) Secondary Containment Isolation Push-buttons.
- (j) This pressure signal actuates Groups 2, 12, 13, 14, 15, 16, 17, 18, and ***.
- # With time delay of 45 seconds.

04/10/270142 891019
PDR ADCK 05000341
P PLIC