



CONNECTICUT YANKEE ATOMIC POWER COMPANY

HADDAM NECK PLANT

RR#1 • BOX 127E • EAST HAMPTON, CT 06424-9341

October 22, 1989
EN-89-1066

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Haddam Neck Plant, 1989 Steam Generator Tube Plugging Report.

In accordance with the reporting requirements of Haddam Neck Technical Specifications, Paragraph 6.9.2.d, the results of Steam Generator tube plugging conducted during the 1989 outage from October 6 to October 21, are provided below:

Steam Generator	Number of Tubes Plugged During the 1989 Outage	Total Tubes Plugged to Date
1	13	210
2	69	370
3	4	89
4	73	389

The detailed ninety day report will be submitted by January 21, 1990.

Very truly yours,

Donald B. Miller, Jr.
Station Superintendent

cc:

Mr. William T. Russell
Regional Administrator, Region I
475 Allendale Rd.
King of Prussia PA, 19406

J.T. Shedlosky
Sr. Resident Inspector
Haddam Neck

*A001
1/0*

B911060278 B91022
PDR ADOCK 05000213
P PMJ