

Georgia Power Company  
Post Office Box 262  
Waynesboro, Georgia 30830  
Telephone 404 554-9961  
404 724-8116

Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202  
Telephone 205 870-6011



**Vogtle Project**

Date: February 6, 1989  
Re: **GPC Letter GN-1576, Dated 2-3-89**  
From: J. A. Bailey  
To: J. B. Hopkins

The two room coolers shown in Attachment 2 which have air flows below the Design Air Flow were previously identified and justified in Operational Deficiency Reports (ODR). Engineering evaluated the air flow for room cooler 2-1555-A7-001 in ODR 88-1254 and room cooler 2-1539-A7-002 in ODR 88-898. These ODR's are available on site for review.

JAB/wk1

8911060299 890206  
PDR ADDCK 05000424  
P PNU

*Add: John Hopkins 14H-25<sup>4r</sup>*  
*DF04*  
*1/0*