

3.7 (cont'd)

4.7 (cont'd)

4. Pressure Suppression Chamber-Reactor Building Vacuum Breakers

- a. Except as specified in 3.7.1.4.5 below, two Pressure Suppression Chamber-Reactor Building Vacuum Breakers shall be operable at all times when the primary containment integrity is required. The setpoint of the differential pressure instrumentation which actuates the pressure suppression chamber reactor building vacuum breakers shall be <0.5 psi below reactor building pressure.
- b. From and after the date that one of the pressure suppression chamber-reactor building vacuum breakers is made or found to be inoperable for any reason, reactor operation is permissible only during the succeeding 7 days, unless such vacuum

4. Pressure Suppression Chamber-Reactor Building Vacuum Breakers

- a. The pressure suppressor, chamber-reactor building vacuum breakers and associated instrumentations including setpoint shall be checked for proper operation every three months.

8711060352 891023  
PDR ADDCA 05000333  
P PNU