
uprotimi.

Limitorque Corporation



5114 Woodall Road P.O. Box 11318 Lynchburg, VA 24506-1318 Telephone--604-528-4400 • Telex--82-9448 • FAX--804-845-9736



October 20, 1989

U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Re: Limitorque Corporation

Part 21 Notification

Subject: MAC Diagnostic System

Attention: Director, Nuclear Reactor Regulation

Centlemen:

Pur uant to the requirements of Title 10 of the Code of Federal Regulations Part 21 here in provided is notification of potential inconsistencies in the MAC Diagnostic System soft ware, as detailed in the attached letter. In order to expedite the notification of the facilities affected, Limitorque has made simultaneous written notice to both the coannistion and the attached list of nuclear utility customers.

Signed:

I. E. Wilkinson

Vice President of Engineering

LIMITORQUE CORPORATION

Limitora

Limitorque Corporation

5114 Woodall Road P.O. Box 11318 Lynchburg, VA 24506-1318 Telephone—804-528-4400 • Telex—82-9448 • FAX—804-845-9736



October 20, 1989

SUBJECT: 10 CFR Part 21 Notification

Be advised that Limitorque has concluded its evaluation of the reported incident at Carolina Power & Lights' Brunswick Station and determined that it does represent the potential for a failure of equipment to perform under designed conditions. Therefore, pursuant to the requirements of 10 CFR Part 21, herein is provided notification of a defect in Limitorque supplied equipment.

Identification Of Basic Component

The MAC diagnostic system software contains correlation equations which convert the spring pack force load cell measurement to an output torque value. The correlation equations were developed in a testing program where actual output torque and spring pack force where measured on various size Limitorque actuators.

Page 2 October 20, 1989 Part 21 Notification

Nature Of The Defect

As a result of testing data collected at Carolina Power & Lights' Brunswick Plant, Limitorque found certain inconsistencies in the MAC software output torque values for SMB, SB, and SBD size 3 actuators. The result is that the output torque values provided by MAC under-predict the output torque, torque switch settings selected based on this test data could potentially lead to an insufficient amount of output torque available to meet design requirements.

Equipment Effected

The equipment in question is all MAC torque test data for SMB, SB, and SBD size 3 actuators.

Licensee Corrective Action

The licensee is to review all SMB, SB, and SBD size 3 MAC torque test data using MAC software version 2.96 to insure that the torque switch settings meet the valve design requirements.

Limiterque Corrective Action

Limitorque has performed additional correlation testing on the SMB, SB, and SBD size 3 to verify the correct relationship between output torque and spring pack force. The MAC software was revised to include the correct correlation equation for the size 3 actuator, the revised software is version 2.96. We have also reviewed all of the test data for the other MAC correlation equations to verify their accuracy.

A copy of this notification has been sent to the NRC under a separate cover letter.

Page 3 October 20, 1989 Part 21 Notification

This Part 21 Notice is being sent to the licensing or quality assurance department of each of the MAC owners. A copy of this Notice with a copy of the 2.96 software and instructions are a'so being sent directly to our contact in the maintenance department.

Signed:

I. E. Wilkinson

Vice President of Engineering

LIMITORQUE CORPORATION

cc: 1

Mr. Mignogna

Mr. Kornsey

Part 21 Notification File

W. E. Steiger
Plant Manager
Long Island Lighting Company - Shoreham
P. O. Box 618
Wading River, NY 11792

J. T. Beckham, Jr.
Vice President
Georgia Power Company Edwin I. Hatch Plant #2
P. O. Box 439
Baxley, GA 31513

G. Bockhold General Manager Georgia Power Company - Vogtle Plant Old River Road Waynesboro, GA 30830

I. Otis Berkham
 Vice President Procurement & Materials
 Georgia Power Company
 P. O. Box 4545
 Atlanta, GA 30302

R. E. Lumsden
Manager Quality Assurance
Carolina Power & Light
P. O. Box 1151
Raleigh, NC 27602

Sub Dasgupta
Manager Procurement and Quality Control Surveillance
Babcock & Wilcox
3315 Old Forest Road
Lynchburg, VA 24501

Hisashi Nakamura Nippon Gear Ltd. 7 Kirihara-cho Fujisawa-shi, Kanagawa-ken Japan